



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टालीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/5459-5469

Date: 19.10.2020

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 05.10.2020-11.10.2020

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 16.10.2020.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This is issued with the approval of Member Secretary.

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)
SUPERINTENDING ENGINEER

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 05/10/20 to 11/10/20**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	1306845
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	2010
WBSETCL	POOL	1664235

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

SUPERINTENDING ENGINEER

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 05/10/20 to 11/10/20

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAhR H (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAhR (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-1209.4	181410	0	0	181410
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-3036.9	455535	0	0	455535
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1599.3	239895	0	0	239895
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-7.9	1185	-42.4	-6360	-5175
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-43.1	6465	-9.2	-1380	5085
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	-16	2400	-31.3	-4695	-2295
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-4585.4	687810	0	0	687810
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-107.5	16125	0	0	16125
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-148.7	22305	0	0	22305
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-9.5	1425	0	0	1425
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-649.9	97485	0	0	97485
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	0	0	-460.8	-69120	-69120
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	191.5	-28725	0	0	-28725
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1041.7	156255	0	0	156255
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-3242.7	486405	0	0	486405
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	1053.1	-157965	0	0	-157965
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	11	-1650	0	0	-1650
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	21.7	-3255	0	0	-3255
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	-390.9	58635	0	0	58635
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1065.7	-159855	0	0	-159855
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1046.8	-157020	0	0	-157020
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1152.7	-172905	0	0	-172905
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1113	-166950	0	0	-166950
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	0	0	367.1	55065	55065
	27	HV side of 400/220 Patna ICT-1	ER1408A	-1217.5	182625	0	0	182625
	28	HV side of 400/220 Patna ICT-2	ER1407A	-1829.8	274470	0	0	274470
	29	HV side of 400/220 Patna ICT-3	ER1231A	-1712.1	256815	0	0	256815
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	50.4	-7560	0	0	-7560
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	51	-7650	0	0	-7650
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-895.1	134265	0	0	134265
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-803	120450	0	0	120450
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1097.7	-164655	0	0	-164655
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1363	-204450	0	0	-204450
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-4285.5	642825	0	0	642825
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-4751.4	712710	0	0	712710
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	198.6	-29790	0	0	-29790
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	206.7	-31005	0	0	-31005
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-475.6	71340	-0.4	-60	71280
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	2276.4	-341460	0	0	-341460
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	2371.3	-355695	0	0	-355695
	44	220 KV NADHOKHAR(BSPHCL)- ARA(PG) LINE-1	ER1305A	-1074.7	161205	0	0	161205
	45	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	4345.9	-651885	0	0	-651885
	46	HV side of 400/220 KV Biharshariff(PG) ICT-4	ER1386A	-4652.3	697845	0	0	697845
		TOTAL		3025410		-26550	2998860	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-3133.2	469980	0	0	469980
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-2413.2	361980	0	0	361980
	3	HV side meter of 400/220 Jamshedpur ICT-3	ER1297A	-2208.6	331290	0	0	331290
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	2367.2	-355080	0	0	-355080
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	2824.1	-423615	0	0	-423615
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	2162.2	-324330	0	0	-324330
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	139.2	-20880	0	0	-20880
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	3254.6	-488190	0	0	-488190
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	3968.4	-595260	0	0	-595260
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	870.2	-130530	0	0	-130530
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	817.4	-122610	0	0	-122610
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	33.4	-5010	0	0	-5010
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	30.6	-4590	0	0	-4590
		TOTAL		-1306845		0	-1306845	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2797.2	419580	0	0	419580
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-142.6	21390	0	0	21390
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC)-BARIPADA(PG)	NP7408A	-2627.6	394140	0	0	394140
	8	400 KV TATA JAMSHEDPUR (DVC)-JAMSHEDPUR (PG)	NP7406A	2738.5	-410775	0	0	-410775
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-949.6	142440	0	0	142440
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-3627.3	544095	0	0	544095
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-3519.5	527925	0	0	527925
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	0	0	0	0	0
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	0	0	0	0	0
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	0	0	0	0	0
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	0	0	0	0	0
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-III(MAIN)	NP6524A	-3981.4	597210	0	0	597210
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-3797.4	569610	0	0	569610
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-6614	992100	0	0	992100
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	-798.8	119820	0	0	119820
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-2847.7	427155	0	0	427155
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	6183.7	-927555	0	0	-927555
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	6088.4	-913260	0	0	-913260
		TOTAL		2503875		0	2503875	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	-259.8	38970	0	0	38970
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	-275.7	41355	0	0	41355
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	-1223	183450	0	0	183450
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	-1538.2	230730	0	0	230730
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	0.2	-30	0	0	-30
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	0	0	0	0	0
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-2208.8	331320	0	0	331320
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3094.4	464160	0	0	464160
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-2541.8	381270	0	0	381270
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-2518.6	377790	0	0	377790
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0	0	0	0	0
	15	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA(PG)	NP7916A	-2790.9	418635	0	0	418635
	17	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	5696.5	-854475	0	0	-854475
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	15129.4	-2269410	0	0	-2269410
	19	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	0	0	0	0	0
	20	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-1145.5	171825	0	0	171825
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-853.8	128070	0	0	128070
	22	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-4856	728400	0	0	728400
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	-1914.7	287205	0	0	287205
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	-475.4	71310	0	0	71310
	28	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	-431.8	64770	0	0	64770
	29	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	30	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	31	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	-61.8	9270	0	0	9270
	32	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	-80.8	12120	0	0	12120
		TOTAL		816735	0	0	816735	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	0.00	0	0	0	0
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	0.00	0	0	0	0
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	13.40	-2010	0	0	-2010
		TOTAL		-2010	0	0	-2010	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	-557.5	-83625	-83625
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	-117.2	17580	-10.8	-1620	15960
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	-97.2	14580	-29.8	-4470	10110
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-987.4	148110	0	0	148110
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1055.3	158295	0	0	158295
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-76.9	11535	0	0	11535
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2113.7	317055	0	0	317055
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-105.1	15765	0	0	15765
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	0	0	0	0	0
	12	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	NP5881A	1570.6	-235590	0	0	-235590
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	14	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	6826.6	-1023990	0	0	-1023990
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	574.2	-86130	0	0	-86130
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-1708.8	256320	0	0	256320
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	-77.9	11685	0	0	11685
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	60.5	-9075	0	0	-9075
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-89.2	13380	0	0	13380
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	3212.8	-481920	0	0	-481920
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	399.2	-59880	0	0	-59880
	22	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	NP7557A	0	0	0	0	0
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-384.1	57615	0	0	57615
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-30.5	4575	0	0	4575
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	308.1	-46215	10.1	1515	-44700
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	0	0	0	0	0
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-I	NP8723A	642.5	-96375	0	0	-96375
	31	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-II	NP8724A	381.5	-57225	0	0	-57225
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	12.4	-1860	0	0	-1860
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	20.3	-3045	0	0	-3045
	34	400 KV PPSF NEW(WB)-RANCHI NEW(PG)-II	ER1040A	2450.9	-367635	0	0	-367635
	35	400 KV PPSF NEW(WB)-RANCHI NEW(PG)-I	ER1130A	2040.8	-306120	0	0	-306120
	36	400 KV GOKARNA(WB)-FARAKKA(NTPC)-I	ER1133A	-691.2	103680	0	0	103680
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-II	ER1138A	-1	150	0	0	150
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	0	0	0	0	0
	39	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	-3.4	510	0	0	510
	40	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	-475.1	71265	0	0	71265
	41	HV side of 400/220 KV RAJARHAT(PG) ICT-1	ER1526A	19.5	-2925	-1	-150	-3075
	42	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	0	0	0	0	0
	43	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	0	0	0	0	0
	44	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER1698A	0	0	0	0	0
	45	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER1699A	0	0	0	0	0
		TOTAL		-1575885	-88350	-1664235		

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH,w.e.f. 01/04/2020

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting ,the methodology for computaion of Reactive Charges has been changed in conformity with other RPCs.