



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टालीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/4948-4958

Date: 05.10.2020

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 14.09.2020-20.09.2020

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 25.09.2020.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This is issued with the approval of Member Secretary.

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)
SUPERINTENDING ENGINEER

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 14/09/20 to 20/09/20**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	716265
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	1845
WBSETCL	POOL	2200005

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

SUPERINTENDING ENGINEER

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 14/09/20 to 20/09/20

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVA/H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVA/H (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-937.4	140610	0	0	140610
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-2820.2	423030	0	0	423030
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1262.5	189375	0	0	189375
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-6.3	945	-250.1	-37515	-36570
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-33.3	4995	-130.7	-19605	-14610
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	-11.6	1740	-193.7	-29055	-27315
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-1710.5	256575	0	0	256575
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-49	7350	0	0	7350
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-62.3	9345	0	0	9345
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-45	6750	0	0	6750
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-224.9	33735	0	0	33735
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	2	-300	0.2	30	-270
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	321.9	-48285	0	0	-48285
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	159.5	-23925	0	0	-23925
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	81.1	-12165	0	0	-12165
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NPS261A	-834.7	125205	0	0	125205
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-2417.5	362625	0	0	362625
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	298.2	-44730	0	0	-44730
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	12.3	-1845	0	0	-1845
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	14	-2100	0	0	-2100
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NPS239A	-338.3	50745	0	0	50745
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1215.8	-182370	0	0	-182370
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1207.7	-181155	0	0	-181155
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1313.8	-197070	0	0	-197070
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1268.2	-190230	0	0	-190230
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-0.1	15	20.6	3090	3105
	27	HV side of 400/220 Patna ICT-1	ER1408A	-3105.7	465855	0	0	465855
	28	HV side of 400/220 Patna ICT-2	ER1407A	-3886.5	582975	0	0	582975
	29	HV side of 400/220 Patna ICT-3	ER1231A	-3593.1	538965	0	0	538965
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	33.3	-4995	0	0	-4995
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	33	-4950	0	0	-4950
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-806	120900	0	0	120900
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-804.4	120660	0	0	120660
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1129.3	-169395	0	0	-169395
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1261.7	-189255	0	0	-189255
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-3640.8	546120	0	0	546120
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-3763.4	564510	0	0	564510
	38	HV side of 400/220 Darbhanga DMTCL ICT-1	ER1274A	524.9	-78735	0	0	-78735
	39	HV side of 400/220 Darbhanga DMTCL ICT-2	ER1275A	608.4	-91260	0	0	-91260
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-488.1	73215	-0.1	-15	73200
	42	220 KV PURNEA(PG)-BEGUSARAI(BSPTCL)-I	ER1348A	2298.5	-344775	0	0	-344775
	43	220 KV PURNEA(PG)-BEGUSARAI(BSPTCL)-II	ER1376A	1813.4	-272010	0	0	-272010
	44	220 KV NADHOKHAR(BSPHCL)- ARA(PG) LINE-1	ER1305A	-328.7	49305	0	0	49305
	45	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	3056.4	-458460	0	0	-458460
	46	HV side of 400/220 KV Biharsharif(PG) ICT-4	ER1386A	-4414.6	662190	0	0	662190
		TOTAL			2839725		-83070	2756655
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-2116.4	317460	0	0	317460
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-1777.9	266685	0	0	266685
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-1611.1	241665	0	0	241665
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	708.3	-106245	0	0	-106245
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	1252.4	-187860	0	0	-187860
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NPS211A	1090.2	-163530	0	0	-163530
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NPS244A	120.6	-18090	0	0	-18090
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	2909.6	-436440	0	0	-436440
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	3050.2	-457530	0	0	-457530
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	602.6	-90390	0	0	-90390
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	536.7	-80505	0	0	-80505
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	-4.7	-705	-705
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	-5.2	-780	-780
		TOTAL			-714780		-1485	-716265
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-1030.4	154560	0	0	154560
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	222.8	-33420	0	0	-33420
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC) - BARIPADA(PG)	NP7408A	-808.8	121320	0	0	121320
	8	400 KV TATA JAMSHEDPUR (DVC) - JAMSHEDPUR (PG)	NP7406A	810.7	-121605	0	0	-121605
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-474.9	71235	0	0	71235
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-3272.5	490875	0	0	490875
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-3162.5	474375	0	0	474375
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	0	0	0	0	0
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	0	0	0	0	0
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	0	0	0	0	0
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	0	0	0	0	0
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-2495.6	374340	0	0	374340
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-2537.1	380565	0	0	380565
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-6077.4	911610	0	0	911610
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	1729.8	-259470	0	0	-259470
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-1588	238200	0	0	238200
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	7902.9	-1185435	0	0	-1185435
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	7868.7	-1180305	0	0	-1180305
		TOTAL			436845		0	436845

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	-19.4	2910	0	0	2910
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	-22.8	3420	0	0	3420
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeyapore ICT-1	ER1550A	-199.4	29910	0	0	29910
	6	HV side meter of 400/220 Jeyapore ICT-2	ER1571A	-134	20100	0	0	20100
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	0	0	0	0	0
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	0	0	0	0	0
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-6179	926850	0	0	926850
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2943.6	441540	0	0	441540
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-2549.2	382380	0	0	382380
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-2518.4	377760	0	0	377760
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0	0	0	0	0
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)- BARIPADA (PG)	NP7916A	-1683	252450	0	0	252450
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	537.5	-80625	0	0	-80625
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	2036.4	-305460	0	0	-305460
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	0	0	0	0	0
	20	400 KV MENDHASAL (GRIDCO)- PANDIABIL (PG)-I	NP5980A	-36.9	5535	0	0	5535
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL (PG)-II	NP7498A	-9.4	1410	0	0	1410
	22	400 KV DUBURI (GRIDCO)-PANDIABIL (PG)	NP7915A	-1058.2	158730	0	0	158730
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabil ICT-1	ER1583A	-4.3	645	0	0	645
	26	HV side of 400/220 Pandiabil ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-490.7	73605	0	0	73605
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-570	85500	0	0	85500
	29	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	30	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	31	400 KV SUNDERGARH (PG)-OPGC-1	ER1117A	-1477.5	221625	0	0	221625
	32	400 KV SUNDERGARH (PG)-OPGC-2	ER1119A	-1481.1	222165	0	0	222165
		TOTAL		2820450		0	2820450	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	0.00	0	0	0	0
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	0.00	0	0	0	0
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-1	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	12.30	-1845	0	0	-1845
		TOTAL		-1845		0	-1845	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	-1697.7	-254655	-254655
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	-105.5	15825	-0.2	-30	15795
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	-88.1	13215	0	0	13215
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1486A	-1419.9	212985	0	0	212985
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1511.5	226725	0	0	226725
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-43.1	6465	0	0	6465
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2389.7	358455	0	0	358455
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-46.7	7005	0	0	7005
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	0	0	0	0	0
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	2559.7	-383955	0	0	-383955
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	6090.6	-913590	0	0	-913590
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	1832.9	-274935	0	0	-274935
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-1732.8	259920	0	0	259920
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	-108.2	16230	0	0	16230
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	42.8	-6420	0	0	-6420
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	-77.5	11625	0	0	11625
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	3019.9	-452985	0	0	-452985
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	1000	-150000	0	0	-150000
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	0	0	0	0	0
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL)LINE-I	ER1071A	-683	102450	0	0	102450
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL)LINE-II	ER1072A	-143.8	21570	0	0	21570
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7399A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	-83.2	12480	0	0	12480
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	0	0	0	0	0
	30	400 KV SAGARDIGHI (WB)-BERHAMPURE (PG) LINE-I	NP8723A	661.5	-99225	0	0	-99225
	31	400 KV SAGARDIGHI (WB)-BERHAMPURE (PG) LINE-II	NP8724A	492	-73800	0	0	-73800
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	349.7	-52455	0	0	-52455
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	372.9	-55935	0	0	-55935
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1040A	3646.5	-546975	0	0	-546975
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1130A	3188.2	-478230	0	0	-478230
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	-996.9	149535	0	0	149535
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-196.1	29415	0	0	29415
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	0	0	0	0	0
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	0	0	0	0	0
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-773.6	116040	0	0	116040
	41	HV side of 400/220 KV RAJARHAT (PG) ICT-1	ER1526A	111.7	-16755	0	0	-16755
	42	220 KV GAZOLE (WB)-MALDA (PG)-1	ER1693A	0	0	0	0	0
	43	220 KV GAZOLE (WB)-MALDA (PG)-2	ER1696A	0	0	0	0	0
	44	220 KV GAZOLE (WB)-DALKHOLA (PG)-1	ER1698A	0	0	0	0	0
	45	220 KV GAZOLE (WB)-DALKHOLA (PG)-2	ER1699A	0	0	0	0	0
		TOTAL		-1945320		-254685	-2200005	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArh, w.e.f. 01/04/2020

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.