



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति

**Eastern Regional Power Committee**  
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008  
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: [www.erpc.gov.in](http://www.erpc.gov.in)

NO: ERPC/COM-II/VARH/5298-5308

Date: 12.10.2020

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

**Sub: Provisional Reactive Energy (VARH) Charges for the period 28.09.2020-04.10.2020**

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 09.10.2020.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.  
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

**This is issued with the approval of Member Secretary.**

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)  
SUPERINTENDING ENGINEER

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 28/09/20 to 04/10/20**

**REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL**

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	1311990
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	2310
WBSETCL	POOL	2466825

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

**SUPERINTENDING ENGINEER**

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

for the period 28/09/20 to 04/10/20

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVA/H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVA/H (Rs)	NET REACTIVE CHARGE (Rs)
<b>BSPHCL</b>	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-1088.2	163230	0	0	163230
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-2777.3	416595	0	0	416595
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1435.7	215355	0	0	215355
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-1.2	180	-26.1	-3915	-3735
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-31.8	4770	0	0	4770
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	-5.1	765	-3.3	-495	270
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-2862	429300	0	0	429300
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-122.3	18345	0	0	18345
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-146.8	22020	0	0	22020
	10	220 KV KHAGAULI(BSPHCL) - ARAH (PG)-I	NP8641A	-91	13650	0	0	13650
	11	220 KV KHAGAULI(BSPHCL) - ARAH (PG)-II	NP6060A	-566.2	84930	0	0	84930
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	0	0	-276	-41400	-41400
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	200.3	-30045	0	0	-30045
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1069.7	160455	0	0	160455
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-2214.3	332145	0	0	332145
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	449.2	-67380	0	0	-67380
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	31.5	-4725	0	0	-4725
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	38.5	-5775	0	0	-5775
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	-610.7	91605	0	0	91605
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	933.5	-140025	0	0	-140025
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	923.5	-138525	0	0	-138525
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1018	-152700	0	0	-152700
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	975.1	-146265	0	0	-146265
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	1.1	-165	168.9	25335	25170
	27	HV side of 400/220 Patna ICT-1	ER1408A	-1238.9	185835	0	0	185835
	28	HV side of 400/220 Patna ICT-2	ER1407A	-1839.3	275895	0	0	275895
	29	HV side of 400/220 Patna ICT-3	ER1231A	-1701.4	255210	0	0	255210
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	98.6	-14790	0	0	-14790
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	94.2	-14130	0	0	-14130
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1490.9	223635	0	0	223635
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1418.3	212745	0	0	212745
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1142.6	-171390	0	0	-171390
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1124.1	-168615	0	0	-168615
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-3131.8	469770	0	0	469770
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-3701.5	555225	0	0	555225
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	369.5	-55425	0	0	-55425
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	391.6	-58740	0	0	-58740
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-600.3	90045	-5.8	-870	89175
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	2475.1	-371265	0	0	-371265
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	2524.2	-378630	0	0	-378630
	44	220 KV NADHOKHAR(BSPHCL)-ARA(PG) LINE-1	ER1305A	-474.5	71175	0	0	71175
	45	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	2606.2	-390930	0	0	-390930
	46	HV side of 400/220 KV Biharshariff(PG) ICT-4	ER1386A	-4273.1	640965	0	0	640965
		<b>TOTAL</b>		<b>2624325</b>		<b>-21345</b>	<b>2602980</b>	
<b>JUVNL</b>	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-3378.9	506835	0	0	506835
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-2772.1	415815	0	0	415815
	3	HV side meter of 400/220 Jamshedpur ICT-3	ER1297A	-2477.7	371655	0	0	371655
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	2458.2	-368730	0	0	-368730
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	2927.9	-439185	0	0	-439185
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	1877.6	-281640	0	0	-281640
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	239.9	-35985	0	0	-35985
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	3547.2	-532080	0	0	-532080
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	3818	-572700	0	0	-572700
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	1264.8	-189720	0	0	-189720
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	1239.6	-185940	0	0	-185940
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	1.3	-195	0	0	-195
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0.8	-120	0	0	-120
		<b>TOTAL</b>		<b>-1311990</b>		<b>0</b>	<b>-1311990</b>	
<b>DVC</b>	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2401.2	360180	0	0	360180
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	93.4	-14010	0	0	-14010
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC)-BARIPADA(PG)	NP7408A	-2702.1	405315	0	0	405315
	8	400 KV TATA JAMSHEDPUR (DVC)-JAMSHEDPUR (PG)	NP7406A	2095.6	-314340	0	0	-314340
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-1587.9	238185	0	0	238185
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-3291.4	493710	0	0	493710
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-3317.4	497610	0	0	497610
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	0	0	0	0	0
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	0	0	0	0	0
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	0	0	0	0	0
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	0	0	0	0	0
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-III(MAIN)	NP6524A	-3775	566250	0	0	566250
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-3798.2	569730	0	0	569730
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-7865.8	1179870	0	0	1179870
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	1035.6	-155340	0	0	-155340
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-2865.8	429870	0	0	429870
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	8260.1	-1239015	0	0	-1239015
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	8156.7	-1223505	0	0	-1223505
		<b>TOTAL</b>		<b>1794510</b>		<b>0</b>	<b>1794510</b>	

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	-246.1	36915	0	0	36915
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	-281.4	42210	0	0	42210
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	-3448.2	517230	0	0	517230
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	-3023.7	453555	0	0	453555
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	3.4	-510	0	0	-510
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	0	0	0	0	0
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-2760.8	414120	0	0	414120
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3553.8	533070	0	0	533070
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-2876.4	431460	0	0	431460
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-2915.4	437310	0	0	437310
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0	0	0	0	0
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA(PG)	NP7916A	-3305.6	495840	0	0	495840
	17	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	4286.5	-642975	0	0	-642975
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	13229.4	-1984410	0	0	-1984410
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)	NP7932A	0	0	0	0	0
	20	400 KV MENDHASAL (GRIDCO)-PANDIABIL(PG)-I	NP5980A	-1313.1	196965	0	0	196965
	21	400 KV MENDHASAL (GRIDCO)-PANDIABIL(PG)-II	NP7498A	-959.2	143880	0	0	143880
	22	400 KV DUBURI (GRIDCO)-PANDIABIL(PG)	NP7915A	-5061.2	759180	0	0	759180
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	-2284.1	342615	0	0	342615
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH(PG)-STERLITE (GRIDCO)-I	ER1059A	-789.4	118410	0	0	118410
	28	400KV SUNDERGARH(PG)-STERLITE (GRIDCO)-II	ER1058A	-783.7	117555	0	0	117555
	29	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	30	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	31	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	-1594.6	239190	0	0	239190
	32	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	-1606.9	241035	0	0	241035
		<b>TOTAL</b>		<b>2892645</b>	<b>0</b>	<b>0</b>	<b>2892645</b>	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	0.00	0	0	0	0
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	0.00	0	0	0	0
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	15.40	-2310	0	0	-2310
		<b>TOTAL</b>		<b>-2310</b>	<b>0</b>	<b>0</b>	<b>-2310</b>	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	-2194.8	-329220	-329220
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	-61.8	9270	0	0	9270
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	-39.1	5865	0	0	5865
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1379.3	206895	-0.1	-15	206880
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1481.1	222165	0	0	222165
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-54.6	8190	0	0	8190
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-1967.3	295095	0	0	295095
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-42	6300	0	0	6300
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	0	0	0	0	0
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	1388.5	-208275	0	0	-208275
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	14	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	7255.6	-1088340	0	0	-1088340
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	1669.6	-250440	0	0	-250440
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-2069.5	310425	0	0	310425
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	112.7	-16905	0	0	-16905
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	34.4	-5160	0	0	-5160
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-56.1	8415	0	0	8415
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	4065.2	-609780	0	0	-609780
	21	400 KV KHARAGPUR(PG)-SAGARDIGHI(WBSETCL)-I	NP6548A	966.5	-144975	0	0	-144975
	22	400 KV KHARAGPUR(PG)-SAGARDIGHI(WBSETCL)-II	NP7557A	0	0	0	0	0
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-705.9	105885	0	0	105885
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-155.5	23325	0	0	23325
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	77.5	-11625	0	0	-11625
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	0	0	0	0	0
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-I	NP8723A	785.7	-117855	0	0	-117855
	31	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-II	NP8724A	517.4	-77610	0	0	-77610
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	422.9	-63435	0	0	-63435
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	436.1	-65415	0	0	-65415
	34	400 KV PPSF NEW(WB)-RANCHI NEW(PG)-II	ER1040A	3582.1	-537315	0	0	-537315
	35	400 KV PPSF NEW(WB)-RANCHI NEW(PG)-I	ER1130A	2516.4	-377460	0	0	-377460
	36	400 KV GOKARNA(WB)-FARAKKA(NTPC)-I	ER1133A	-792.7	118905	0	0	118905
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-II	ER1138A	-128.6	19290	0	0	19290
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	0	0	0	0	0
	39	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	0	0	0	0	0
	40	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	-690.5	103575	0	0	103575
	41	HV side of 400/220 KV RAJARHAT(PG) ICT-1	ER1526A	44	-6600	0	0	-6600
	42	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	0	0	0	0	0
	43	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	0	0	0	0	0
	44	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER1698A	0	0	0	0	0
	45	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER1699A	0	0	0	0	0
		<b>TOTAL</b>		<b>-2137590</b>	<b>-329235</b>	<b>-2466825</b>		

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH,w.e.f. 01/04/2020

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.