



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

Fax Msg No-104

Tel No.:033-24239651, 24239654 FAX No.:033-24221802, 24221358 Web:www.erpc.gov.in

NO. ERPC/PROTECTION/2020/6420-6465

DATE: 04.12.2020

To,

As per list enclosed,

Sub:Notice for 97th Protection Coordination sub-Committee (PCC) meeting of ERPC

Sir,

Notice is hereby given that 97thPCC meeting of ERPC will be held on 14th December 2020(Monday) from 10:30hrs through online Microsoft Teams meeting platform. The meeting link will be forwarded through e-mail or message. You are requested to enter the participant name and designation and organisation name while joining the meeting. The following coordinator may be contacted for any assistance:

Saswat Ranjan Swain, Asst. Director-II, ERPC, Mob: 9337791451, E-mail: saswatrj123@gmail.com

The tentative agenda items for discussion will be as follows:

- 1) Confirmation of the minutes of 96thProtection sub-Committee Meeting of ERPC.
- 2) Analysis of following grid disturbances of November2020:

Sr. No	Date	Time	Affected System	Summary	Load loss (MW)	Gen loss (MW)
1	07-11-2020	11:04	WBSETCL	400 kV AlipurduarJigmelling D/C tripped on R and Y phase fault resulting tripping of both running units at MangdechuHEP due to loss of evacuation path.	0	240
2	13-11-2020	14:36	JUSNL	B phase CT at Hatia end of 220 kV Ranchi-Hatia – 3 was busted which resulted in tripping of 220 kV Ranchi Hatia – 1 and 2 from Ranchi end and 220 kV Patratu – Hatia D/C from Patratu end. 220/132 kV 150 MVA ICT – 3 Hatia also tripped at the same time. 220/132 kV ICT – 1 & 2 and 220 kV Ranchi – Hatia – 1 & 2 were hand tripped at Hatia end after the event. As a result total power failure occurred at 220/132 kV Hatia S/S.	240	54
3	24-11-2020	18:28	BSPTCL	220 kV Gaya-Dehri D/C was under shutdown prior to the event. Tripping of 220 kV Sasaram – Dehri S/C resulted in total power failure at Dehri, Bikramganj, Banjari, Kudra, Kerpa, Tiro areas.	154	0

3) New Islanding Schemes of Eastern Region

You are requested to kindly furnish the detail report along with all records (SLD, SOE, DR, Relay and schematic diagram of auxiliary supply, wherever applicable) related to above trippings for meaningful analysis during the meeting. You are also requested to upload the details in on-line tripping incident reporting system implemented in Protection Database Management System www.erpc-protectiondb.in.

Your participation in the meeting is highly solicited.

Yours faithfully,


(D. K. Bauri)

Superintending Engineer(Operation)

LIST OF ADDRESSES:

Chief Engineer, Trans (O&M) Bihar State Power Transmission Limited, Vidyut Bhawan, Bailey Road, Patna-800021	Electrical Superintending Engineer (CRITL) Bihar State Power Transmission Limited, VidyutBhawan,Bailey Road, Patna-800021
Chief Engineer (SLDC) Damodar Valley Corporation, GOMD-I Premises, P.O.- DaneshSeikh Lane, Howrah- 711109	Chief Engineer (CTC) Damodar Valley Corporation, P.O. Maithon Dam, Dist. Dhanbad,Jharkhand-828207
Chief Engineer, (CRITL) Jharkhand UrjaSancharan Nigam Limited Kusai Colony, Doranda, Ranchi-834002	Electrical Superintending Engineer (CLD) Jharkhand UrjaSancharan Nigam Limited, KusaiColony,Doranda, Ranchi-834002
Chief General Manager (O&M), OPTCL, Janpath, Bhubaneswar, Odisha – 751 022. FAX: 0674-2542932 cgm.onm@optcl.co.in	Sr. General Manager (PPA), Technical Wing, OHPCL, Orissa State Police Housing & Welfare Corpn. Bldg. VaniviharChowk, Janpath, Bhubaneswar-752022
Chief Load Dispatcher, SLDC OPTCL, P.O. Mancheswar Rly. Colony Bhubaneswar-751017	Chief Engineer (Testing), WBSETCL Central Testing Laboratory, Abhikshan, Salt Lake, Kolkata-700091 (Fax no. 2367-3578/1235)
Chief Engineer (CLD) WBSETCL, P.O.Danesh Sheikh Lane, AndulRoad, Howrah-711109	Addl. Chief Engineer (ALDC) West Bengal Electricity Distribution Company Ltd VidyutBhavan, 7 th Floor, Bidhannagar, Sector-I Salt Lake City, Kolkata-700091(Fax-033-2334-5862)
Dy. Chief Engineer (Testing)/ Sr. Manager (Testing) CESC Ltd.,4, SasiSekhar Bose Road, Kolkata-700025	General Manager (O&M) KhSTPS, NTPC Ltd., P.O. Deepti Nagar, Dist. Bhagalpur, Bihar-813203
General Manager(O&M) FSTPS, NTPC Ltd., P.O. Nabarun, Dist. Murshidabad, West Bengal-742236	Dy. General Manager (Engineering), WBPDCL, OS Dept. Corporate Office, 3/C, L.A Block, Salt Lake-III, Kolkata-700098 (Fax-033-23350516)
General Manager (O&M) Barh STPS, NTPC Ltd., P.O. NTPC Barh, Dist. Patna, Bihar-803213	General Manager (OS), ERHQ-II, NTPC Ltd., 3 rd flr. OLIC Building, Plot no. N 17/2, Nayapalli, Unit-8 Bhubaneswar- 751012 (Fax No. 0674-2540919)
General Manager(O&M), TSTPS, NTPC Ltd., P.O.Kaniha, Dist. Angul, Orissa-759117	General Manager (O&M), POWERGRID, Odisha Projects, Sahid Nagar, Bhubaneswar – 751 007
General Manager (OS), ERHQ-I, NTPC Ltd.,	Manager (Electrical), Adhunik Power & Natural

LoknayaJaiprakashBhawan, (2 nd Floor), DakBunglowChawk, Patna-800001	Resources Ltd. "Lansdowne Towers, Kolkata-700020 (Fax No. 033-2289 0285)
Executive Director (O&M) NHPC Ltd., NHPC Office Complex, Sector-33, Faridabad, Haryana-121003 (Fax-01292272413)	Electrical Superintending Engineer, TTPS, TenughatVidyut Nigam Ltd., Lalpania, Dist. Bokaro, Jharkhand-829149
Dy. General Manager (Electrical) IB Thermal Power Station, OPGCL Banhapalli, Dist. Jharsuguda-768234, Orissa	General Manager (OS), ER-I Power Grid Corporation of India Ltd., Alankar Place, Boring Road, Patna-800001
Chief Engineer (Trans.) Power Deptt., Govt. of Sikkim, Gangtok-731010	Sr. Manager (CTMC) Durgapur Projects Limited, Durgapur-713201
Executive Director, ERLDC, POSOCO, Tollygunge, Kolkata-700033	Head Construction, ENCIL, Siliguri-7340051
General Manager (OS), ER-II Power Grid Corporation of India Ltd., J-I-15, Block-EP, Sector-V, Salt Lake, Kolkata-91	Shri A.K. Nayak/Shri Sumit S Ghosh Maithon Power Limited, Maithon Office, MA 5 Gogna, Dist. Dhanbad, Jharkhand State, PIN-828207
General Manager (P&O), PTC Ltd., Kanchanjunga Bldg., 18, Barakhamba Road, New Delhi-110001	Vice President, Vedanta Ltd. 1 st Floor, Module C/2, Fortune Tower, C S Pur, Bhubaneswar- 751023
Managing Director, Bhutan Power Corporation Post Box no. 580, Thimpu, Bhutan.	Managing Director, Druk Green Power Corprn. P.O. Box-1351, Thimpu, Bhutan.
General Manager, Darbhanga (Bihar), Darbhanga Motihari Transmission Company Limited (DMTCL)	Shri Brajesh Kumar Pande, Plant Head, JITPL. (FAX: 011-26139256-65)
Shri D. P. Bhagava, Chief Consultant (O&M), Teesta Urja Limited, New Delhi (FAX: 011- 46529744)	Director (GM Division), Central Electricity Authority Sewa Bhawan, R. K. Puram, New Delhi-110066
Director (NPC), CEA, NRPC Building, Katwaria Sarai, New Delhi- 110016	President, Dans Energy Pvt. Ltd, 5th Floor, DLF Building No. 8, Tower-C, Gurgaon - 722002
Director, Shiga Energy Pw. Ltd., 5th Floor, DLF Building No. 8, Tower-C, Gurgaon - 722002	DGM (E&I), HALDIA ENERGY LIMITED, BARIK BHAWAN, KOKATA-700072, FAX: 033-22360955