



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टालीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/8968

Date: 26.03.2021

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 08.03.2021-14.03.2021

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 19.03.2021.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This is issued with the approval of Member Secretary.

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)
SUPERINTENDING ENGINEER

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 08/03/21 to 14/03/21**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	1350150
JUVNL	POOL	621570
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	19335
WBSETCL	POOL	731160

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

SUPERINTENDING ENGINEER

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 08/03/21 to 14/03/21

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVAr H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-331	49650	0	0	49650
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-1916.3	287445	0	0	287445
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-690.3	103545	0	0	103545
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	28.8	-4320	0	0	-4320
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	14.4	-2160	0	0	-2160
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	63.8	-9570	0	0	-9570
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-317.1	47565	0	0	47565
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-117.5	17625	0	0	17625
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-105.1	15765	0	0	15765
	10	220 KV KHAGAULI(BSPHCL) - ARAH (PG)-I	NP8641A	-40.2	6030	0	0	6030
	11	220 KV KHAGAULI(BSPHCL) - ARAH (PG)-II	NP6060A	-475.6	71340	0	0	71340
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	0.4	-60	-285.3	-42795	-42855
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	178	-26700	0	0	-26700
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-519	77850	0	0	77850
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-417.8	62670	0	0	62670
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	100	-15000	0	0	-15000
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	0.2	-30	0	0	-30
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	1.2	-180	0	0	-180
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	-34.7	5205	0	0	5205
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1810.5	-271575	0	0	-271575
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1810.9	-271635	0	0	-271635
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1970	-295500	0	0	-295500
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1905.2	-285780	0	0	-285780
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-1	150	206.3	30945	31095
	27	HV side of 400/220 Patna ICT-1	ER1408A	753.9	-113085	0	0	-113085
	28	HV side of 400/220 Patna ICT-2	ER1407A	250.7	-37605	0	0	-37605
	29	HV side of 400/220 Patna ICT-3	ER1231A	233.5	-35025	0	0	-35025
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	0.4	-60	0	0	-60
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	1	-150	0	0	-150
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-2037.6	305640	0	0	305640
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-2082.7	312405	0	0	312405
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2006.3	-300945	0	0	-300945
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2014.2	-302130	0	0	-302130
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	0	0	0	0	0
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	0	0	0	0	0
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	57.8	-8670	0	0	-8670
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	378.1	-56715	0	0	-56715
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	359.7	-53955	0	0	-53955
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	3108.5	-466275	0	0	-466275
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	3243.5	-486525	0	0	-486525
	44	220 KV NADHOKHAR(BSPHCL)- ARA(PG) LINE-1	ER1305A	-80.6	12090	0	0	12090
	45	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	606.7	-91005	0	0	-91005
	46	HV side of 400/220 KV Biharsharff(PG) ICT-4	ER1386A	-2809.2	421380	0	0	421380
		TOTAL			-1338300		-11850	-1350150
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-138	20700	0	0	20700
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-23	3450	0	0	3450
	3	HV side meter of 400/220 Jamshedpur ICT-3	ER1297A	-195.1	29265	0	0	29265
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	340.9	-51135	0	0	-51135
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	429.4	-64410	0	0	-64410
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	1951.6	-292740	0	0	-292740
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	147.6	-22140	0	0	-22140
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	575.8	-86370	0	0	-86370
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	1054.6	-158190	0	0	-158190
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	0	0	0	0	0
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	0	0	0	0	0
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	0	0	0
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	0	0	0
		TOTAL			-621570	0	-621570	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-1663	249450	0	0	249450
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	146.2	-21930	0	0	-21930
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	0	0	0	0	0
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	0	0	0	0	0
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	0	0	0	0	0
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	316.2	-47430	0	0	-47430
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	236.2	-35430	0	0	-35430
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-3073.9	461085	0	0	461085
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-1697.2	254580	0	0	254580
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	798.3	-119745	0	0	-119745
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	889.1	-133365	0	0	-133365
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-III(MAIN)	NP6524A	-1219.2	182880	0	0	182880
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-1238.2	185730	0	0	185730
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	0	0	0	0	0
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	0	0	0	0	0
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-713.2	106980	0	0	106980
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	1760.4	-264060	0	0	-264060
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	1665	-249750	0	0	-249750
		TOTAL			568995	0	568995	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	-1	150	0	0	150
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jaypore ICT-1	ER1550A	-596.2	89430	0	0	89430
	6	HV side meter of 400/220 Jaypore ICT-2	ER1571A	-417.2	62580	0	0	62580
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	0	0	0	0	0
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	0	0	0	0	0
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-3688	553200	0	0	553200
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2066.8	310020	0	0	310020
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-1803.2	270480	0	0	270480
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-1813.8	272070	0	0	272070
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0	0	0	0	0
	15	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	1720.7	-258105	0	0	-258105
	17	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	1275.2	-191280	0	0	-191280
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	5559.6	-833940	0	0	-833940
	19	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	0	0	0	0	0
	20	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-56.9	8535	0	0	8535
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-85.7	12855	0	0	12855
	22	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-2483.7	372555	0	0	372555
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	168.4	25260	25260
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	166.4	24960	24960
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	-306.7	46005	0	0	46005
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	0	0	0	0	0
	28	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	0	0	0	0	0
	29	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	30	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	31	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	-73.2	10980	0	0	10980
	32	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	-185.2	27780	0	0	27780
		TOTAL		753315		50220	803535	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-69.10	10365	-5.2	-780	9585
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-31.70	4755	-209.9	-31485	-26730
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	14.60	-2190	0	0	-2190
		TOTAL		12930		-32265	-19335	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	-1404.8	-210720	-210720
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	58.1	-8715	0	0	-8715
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	68.1	-10215	0	0	-10215
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-923.5	138525	0	0	138525
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-957.3	143595	0	0	143595
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-409.5	61425	0	0	61425
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2360.1	354015	0	0	354015
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-496.3	74445	0	0	74445
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	0	0	0	0	0
	12	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	NP5881A	6806.6	-1020990	0	0	-1020990
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	12.6	-1890	0.8	120	-1770
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	1923.4	-288510	0	0	-288510
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	0	0	0	0	0
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-1099.4	164910	0	0	164910
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	-95.6	14340	0	0	14340
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	7.1	-1065	0	0	-1065
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-45.1	6765	0	0	6765
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	0	0	0	0	0
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	0.3	-45	0	0	-45
	22	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	NP7557A	0	0	0	0	0
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-1062.4	159360	0	0	159360
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-157.9	23685	0	0	23685
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	383	-57450	0	0	-57450
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	0	0	0	0	0
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-I	NP8723A	609.1	-91365	0	0	-91365
	31	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-II	NP8724A	410.7	-61605	0	0	-61605
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-1.4	210	0	0	210
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	0	0	0	0	0
	34	400 KV PPS NEW(WB)-RANCHI NEW(PG)-II	ER1040A	961.8	-144270	0	0	-144270
	35	400 KV PPS NEW(WB)-RANCHI NEW(PG)-I	ER1130A	906.2	-135930	0	0	-135930
	36	400 KV GOKARNA(WB)-FARAKKA(NTPC)-I	ER1133A	-1049.2	157380	0	0	157380
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-II	ER1138A	-1368.8	205320	0	0	205320
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	0	0	0	0	0
	39	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	64.8	-9720	0	0	-9720
	40	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	-192.6	28890	0	0	28890
	41	HV side of 400/220 KV RAJARHAT(PG) ICT-1	ER1526A	6.4	-960	0	0	-960
	42	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	-1150.3	172545	0	0	172545
	43	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	-1146.1	171915	0	0	171915
	44	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER1698A	1834.9	-275235	0	0	-275235
	45	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER1699A	1932.8	-289920	0	0	-289920
		TOTAL		-520560		-210600	-731160	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH,w.e.f. 01/04/2020

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting ,the methodology for computaion of Reactive Charges has been changed in conformity with other RPCs.