



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टालीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/8813

Date: 01.03.2021

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 15.02.2021-21.02.2021

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 26.02.2021.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This is issued with the approval of Member Secretary.

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)
SUPERINTENDING ENGINEER

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 15/02/21 to 21/02/21**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	304155
JUVNL	POOL	1418310
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	23145
WBSETCL	POOL	1041855

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

SUPERINTENDING ENGINEER

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 15/02/21 to 21/02/21

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-1596	239400	0	0	239400
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-3923	588450	0	0	588450
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-2793.8	419070	0	0	419070
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	235.8	-35370	0	0	-35370
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	243.2	-36480	0	0	-36480
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	302.5	-45375	0	0	-45375
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	289.3	-43395	0	0	-43395
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-517.3	77595	0	0	77595
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-586.2	87930	0	0	87930
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-684.5	102675	0	0	102675
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-965.6	144840	0	0	144840
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	14.8	-2220	0.3	45	-2175
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	774	-116100	0	0	-116100
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1262.3	189345	0	0	189345
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-729.6	109440	0	0	109440
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	201.9	-30285	0	0	-30285
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	11.3	-1695	0	0	-1695
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	9.6	-1440	0	0	-1440
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	-562.1	84315	0	0	84315
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1926	-288900	0	0	-288900
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1923.3	-288495	0	0	-288495
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	2089.7	-313455	0	0	-313455
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	2032.6	-304890	0	0	-304890
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-6.4	960	0	0	960
	27	HV side of 400/220 Patna ICT-1	ER1408A	2039.9	-305985	0	0	-305985
	28	HV side of 400/220 Patna ICT-2	ER1407A	1289.5	-193425	0	0	-193425
	29	HV side of 400/220 Patna ICT-3	ER1231A	1207.9	-181185	0	0	-181185
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	446.2	-66930	0	0	-66930
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	458.5	-68775	0	0	-68775
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1430.1	214515	0	0	214515
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1573.9	236085	0	0	236085
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	0	0	0	0	0
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1544.1	-231615	0	0	-231615
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	0	0	0	0	0
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	0	0	0	0	0
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	65.3	-9795	0	0	-9795
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	80.4	-12060	0	0	-12060
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-59.6	8940	0	0	8940
	42	220 KV PURNEA(PG)-BEGUSARAI(BSPTCL)-I	ER1348A	3258.7	-488805	0	0	-488805
	43	220 KV PURNEA(PG)-BEGUSARAI(BSPTCL)-II	ER1376A	3596.4	-539460	0	0	-539460
	44	220 KV NADHOKHAR(BSPHCL)- ARA(PG) LINE-1	ER1305A	-189.9	28485	0	0	28485
	45	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	827.1	-124065	0	0	-124065
	46	HV side of 400/220 KV Biharsharif(PG) ICT-4	ER1386A	-5959.7	893955	0	0	893955
		TOTAL			-304200		45	-304155
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-3368.9	505335	0	0	505335
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-2960.8	444120	0	0	444120
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-3532.1	529815	0	0	529815
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	3119.6	-467940	0	0	-467940
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	3638.3	-545745	0	0	-545745
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	2511.6	-376740	0	0	-376740
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	281.5	-42225	0	0	-42225
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	3053	-457950	0	0	-457950
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	3561.8	-534270	0	0	-534270
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	1623.5	-243525	0	0	-243525
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	1527.9	-229185	0	0	-229185
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	0	0	0
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	0	0	0
		TOTAL			-1418310		0	-1418310
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-5613.8	842070	0	0	842070
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	286.8	-43020	0	0	-43020
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	0	0	0	0	0
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	0	0	0	0	0
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	1960.2	-294030	0	0	-294030
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	0	0	0	0	0
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	0	0	0	0	0
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-6142.8	921420	0	0	921420
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-5560.3	834045	0	0	834045
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-775.7	116355	0	0	116355
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-1056.4	158460	0	0	158460
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-3202.5	480375	0	0	480375
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-3201.8	480270	0	0	480270
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-7553.2	1132980	0	0	1132980
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	4310.1	-646515	0	0	-646515
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	0	0	0	0	0
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	6016.2	-902430	0	0	-902430
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	5763.2	-864480	0	0	-864480
		TOTAL			2215500		0	2215500

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	610.9	-91635	0	0	-91635
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	-236.2	35430	0	0	35430
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	-13.3	1995	0	0	1995
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	-43.1	6465	0	0	6465
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H)	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	-26.5	3975	0	0	3975
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	0	0	0	0	0
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-3260	489000	0	0	489000
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2637.6	395640	0	0	395640
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-I	NP5112A	-2487	373050	0	0	373050
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-II	NP5101A	-2203.4	330510	0	0	330510
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0	0	0	0	0
	15	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	2132	-319800	0	0	-319800
	17	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	10516.7	-1577505	0	0	-1577505
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	15944	-2391600	0	0	-2391600
	19	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	0	0	0	0	0
	20	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-790.2	118530	0	0	118530
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-1018.5	152775	0	0	152775
	22	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-6228.7	934305	0	0	934305
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	-3936.3	590445	0	0	590445
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	-1255.6	188340	0	0	188340
	28	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	-1275.9	191385	0	0	191385
	29	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	30	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	31	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	-1993.7	299055	0	0	299055
	32	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	-2006.2	300930	0	0	300930
		TOTAL		31290		0	31290	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-27.50	4125	-167.5	-25125	-21000
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-14.00	2100	-17.9	-2685	-585
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	10.40	-1560	0	0	-1560
		TOTAL		4665		-27810	-23145	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	-284	-42600	-42600
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	1164.5	-174675	0	0	-174675
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	1102	-165300	0	0	-165300
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1586.7	238005	0	0	238005
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1614.2	242130	0	0	242130
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-1693.8	254070	0	0	254070
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-3074.1	461115	0	0	461115
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-1402.1	210315	0	0	210315
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	0	0	0	0	0
	12	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	NP5881A	7628.6	-1144290	0	0	-1144290
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-34.2	5130	0	0	5130
	14	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	7044.7	-1056705	0	0	-1056705
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	2004.3	-300645	0	0	-300645
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-1236.7	185505	0	0	185505
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	449.9	-67485	0	0	-67485
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-36.6	5490	0	0	5490
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-38.3	5745	0	0	5745
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	-366.5	54975	0	0	54975
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	2724	-408600	0	0	-408600
	22	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	NP7557A	0	0	0	0	0
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-564.7	84705	0	0	84705
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-286.6	42990	0	0	42990
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	691.7	-103755	0	0	-103755	
29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	0	0	0	0	0	
30	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-I	NP8723A	1923.1	-288465	0	0	-288465	
31	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-II	NP8724A	1647	-247050	0	0	-247050	
32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-1843.2	276480	0	0	276480	
33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-1811.9	271785	0	0	271785	
34	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	ER1040A	995.7	-149355	0	0	-149355	
35	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-I	ER1130A	1001.2	-150180	0	0	-150180	
36	400 KV GOKARNA(WB)-FARAKKA(NTPC)-I	ER1133A	-3164.3	474645	0	0	474645	
37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-II	ER1138A	-6228.8	934320	0	0	934320	
38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	0	0	0	0	0	
39	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	1274.6	-191190	0	0	-191190	
40	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	-972	145800	0	0	145800	
41	HV side of 400/220 KV RAJARHAT(PG) ICT-1	ER1526A	668.8	-100320	0	0	-100320	
42	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	-1756	263400	0	0	263400	
43	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	-1748.6	262290	0	0	262290	
44	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER1698A	2848.9	-427335	0	0	-427335	
45	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER1699A	2952	-442800	0	0	-442800	
		TOTAL		-999255		-42600	-1041855	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH.w.e.f. 01/04/2020

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting ,the methodology for computaion of Reactive Charges has been changed in conformity with other RPCs.