



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टालीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/8884

Date: 11.03.2021

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 22.02.2021-28.02.2021

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 05.03.2021.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

Encl: As above/ संलग्न यथोपरी

भवदीय/Yours faithfully,

(N. S. MONDAL)
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 22/02/20 to 28/02/21**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	970635
JUVNL	POOL	966660
DVC	POOL	0
GRIDCO	POOL	166035
SIKKIM	POOL	0
WBSETCL	POOL	62955

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 22/02/20 to 28/02/21

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-1102.8	165420	0	0	165420
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-3075.4	461310	0	0	461310
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1748.7	262305	0	0	262305
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	177.7	-26655	0	0	-26655
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	172	-25800	0	0	-25800
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	234.3	-35145	0	0	-35145
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	125	-18750	0	0	-18750
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-446.7	67005	0	0	67005
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-471.1	70665	0	0	70665
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-564.9	84735	0	0	84735
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-914.1	137115	0	0	137115
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	1.6	-240	1	150	-90
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	621.5	-93225	0.1	15	-93210
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-946.1	141915	0	0	141915
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-930.8	139620	0	0	139620
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	222.2	-33330	0	0	-33330
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	19.2	-2880	0	0	-2880
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	21.9	-3285	0	0	-3285
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	-140.9	21135	0	0	21135
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1960.7	-294105	0	0	-294105
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1956.1	-293415	0	0	-293415
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	2125.3	-318795	0	0	-318795
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	2064	-309600	0	0	-309600
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-3.4	510	0	0	510
	27	HV side of 400/220 Patna ICT-1	ER1408A	1476.1	-221415	0	0	-221415
	28	HV side of 400/220 Patna ICT-2	ER1407A	756.5	-113475	0	0	-113475
	29	HV side of 400/220 Patna ICT-3	ER1231A	708	-106200	0	0	-106200
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	78.3	-11745	0	0	-11745
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	79.4	-11910	0	0	-11910
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1034.5	155175	0	0	155175
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1155.7	173355	0	0	173355
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	952.7	-142905	0	0	-142905
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1896.4	-284460	0	0	-284460
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	0	0	0	0	0
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	0	0	0	0	0
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	7.9	-1185	0	0	-1185
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	15.9	-2385	0	0	-2385
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-84.5	12675	0	0	12675
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	3686.9	-553035	0	0	-553035
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	3961.3	-594195	0	0	-594195
	44	220 KV NADHOKHAR(BSPHCL)- ARA(PG) LINE-1	ER1305A	-203	30450	0	0	30450
	45	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	765	-114750	0	0	-114750
	46	HV side of 400/220 KV Biharshariff(PG) ICT-4	ER1386A	-4791.3	718695	0	0	718695
		TOTAL			-970800		165	-970635
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-1320.4	198060	0	0	198060
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-1003.8	150570	0	0	150570
	3	HV side meter of 400/220 Jamshedpur ICT-3	ER1297A	-2236.2	335430	0	0	335430
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	1376.7	-206505	0	0	-206505
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	1652.7	-247905	0	0	-247905
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	2553	-382950	0	0	-382950
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-70.2	10530	0	0	10530
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	1712	-256800	0	0	-256800
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	2627.8	-394170	0	0	-394170
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	607.5	-91125	0	0	-91125
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	545.3	-81795	0	0	-81795
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	0	0	0
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	0	0	0
		TOTAL			-966660		0	-966660
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-3978.4	596760	0	0	596760
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	17.4	-2610	0	0	-2610
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	0	0	0	0	0
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	0	0	0	0	0
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	1505.2	-225780	0	0	-225780
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-1201.9	180285	0	0	180285
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-1206.2	180930	0	0	180930
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-4940	741000	0	0	741000
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-4138.6	620790	0	0	620790
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-1192.3	178845	0	0	178845
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-1709.4	256410	0	0	256410
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-III(MAIN)	NP6524A	-2417.7	362655	0	0	362655
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-2438.1	365715	0	0	365715
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	0	0	0	0	0
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	0	0	0	0	0
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-1330.5	199575	0	0	199575
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	3519.5	-527925	0	0	-527925
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	3337.1	-500565	0	0	-500565
		TOTAL			2426085		0	2426085

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	227.4	-34110	0	0	-34110
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	-19.8	2970	0	0	2970
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	-899.2	134880	0	0	134880
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	-1590.4	238560	0	0	238560
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	-14.4	2160	0	0	2160
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	0	0	0	0	0
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-3959.6	593940	0	0	593940
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2226.2	333930	0	0	333930
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-1403.6	210540	0	0	210540
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-829	124350	0	0	124350
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0	0	0	0	0
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	2617	-392550	0	0	-392550
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	7914.5	-1187175	0	0	-1187175
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	14167.2	-2125080	0	0	-2125080
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	0	0	0	0	0
	20	400 KV MENDHASAL (GRIDCO)-PANDIABIL (PG)-I	NP5980A	-666.2	99930	0	0	99930
	21	400 KV MENDHASAL (GRIDCO)-PANDIABIL (PG)-II	NP7498A	-840.1	126015	0	0	126015
	22	400 KV DUBURI (GRIDCO)-PANDIABIL (PG)	NP7915A	-5861.5	879225	0	0	879225
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	-3552.4	532860	0	0	532860
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-95.8	14370	0	0	14370
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-96.5	14475	0	0	14475
	29	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	30	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	31	400 KV SUNDERGARH (PG)-OPGC-1	ER1117A	-881.8	132270	0	0	132270
	32	400 KV SUNDERGARH (PG)-OPGC-2	ER1119A	-882.7	132405	0	0	132405
		TOTAL		-166035		0	-166035	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-56.40	8460	-39.3	-5895	2565
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-52.70	7905	-4.2	-630	7275
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	10.10	-1515	0	0	-1515
		TOTAL		14850		-6525	8325	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	-599.8	-89970	-89970
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	364.4	-54660	0	0	-54660
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	340.6	-51090	0	0	-51090
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1281.5	192225	0	0	192225
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1350.3	202545	0	0	202545
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-638.7	95805	0	0	95805
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2899.7	434955	0	0	434955
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-898.8	134820	0	0	134820
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	0	0	0	0	0
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	7210.5	-1081575	0	0	-1081575
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	4577.8	-686670	0	0	-686670
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	407.2	-61080	0	0	-61080
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-1306.5	195975	0	0	195975
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	473.8	-71070	0	0	-71070
	18	132 KV KURSEONG (WBSETCL) - RANGIT (NHPC)	NP7541A	-22.6	3390	0	0	3390
	19	132 KV KURSEONG (WBSETCL) - SILIGURI (NHPC)	NP7542A	-22.2	3330	0	0	3330
	20	400 KV KHARAGPUR (WBSETCL) - BARIPADA (PG)	ER1043A	-356.9	53535	0	0	53535
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	415.5	-62325	0	0	-62325
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	0	0	0	0	0
	23	220 KV DALKHOLA (PG) - DALKHOLA (WBSETCL) LINE-I	ER1071A	-1169.5	175425	0	0	175425
	24	220 KV DALKHOLA (PG) - DALKHOLA (WBSETCL) LINE-II	ER1072A	-531.2	79680	0	0	79680
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG) - HALDIA CESC (WB) LINE-I	ER1141A	525.4	-78810	0	0	-78810
	29	400 KV SUBHASHGRAM (PG) - HALDIA CESC (WB) LINE-II	NP7937A	0	0	0	0	0
	30	400 KV SAGARDIGHI (WB) - BERHAMPORE (PG) LINE-I	NP8723A	-159.2	23880	0	0	23880
	31	400 KV SAGARDIGHI (WB) - BERHAMPORE (PG) LINE-II	NP8724A	-159.2	23880	0	0	23880
	32	400 KV KHARAGPUR (WB) - CHAIBASA (PG)-I	NP8731A	-736.4	110460	0	0	110460
	33	400 KV KHARAGPUR (WB) - CHAIBASA (PG)-II	NP8720A	-668.8	100320	0	0	100320
	34	400 KV PPSP NEW (WB) - RANCHI NEW (PG)-II	ER1040A	923.6	-138540	0	0	-138540
	35	400 KV PPSP NEW (WB) - RANCHI NEW (PG)-I	ER1130A	902.9	-135435	0	0	-135435
	36	400 KV GOKARNA (WB) - FARAKKA (NTPC)-I	ER1133A	-1969.8	295470	0	0	295470
	37	400 KV GOKARNA (WB) - FARAKKA (NTPC)-II	ER1138A	-4205.1	630765	0	0	630765
	38	220 KV ALIPURDUAR (PG) - ALIPURDUAR (WB)-I	ER1044A	0	0	0	0	0
	39	220 KV ALIPURDUAR (PG) - ALIPURDUAR (WB)-II	ER1047A	607.1	-91065	0	0	-91065
	40	400 KV SAGARDIGHI (WB) - FARAKKA (NTPC)-II	ER1131A	-846.8	127020	0	0	127020
	41	HV side of 400/220 KV RAJARHAT (PG) ICT-1	ER1526A	0	0	0	0	0
	42	220 KV GAZOLE (WB) - MALDA (PG)-1	ER1693A	-1644.5	246675	0	0	246675
	43	220 KV GAZOLE (WB) - MALDA (PG)-2	ER1696A	-1639.3	245895	0	0	245895
	44	220 KV GAZOLE (WB) - DALKHOLA (PG)-1	ER1698A	2649.6	-397440	0	0	-397440
	45	220 KV GAZOLE (WB) - DALKHOLA (PG)-2	ER1699A	2928.5	-439275	0	0	-439275
		TOTAL		27015		-89970	-62955	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH,w.e.f. 01/04/2020

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.