



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति
Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/282

Date: 02.06.2021

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comm & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comm), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comm), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 17.05.2021-23.05.2021

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 28.05.2021.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This is issued with the approval of Member Secretary.

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)
SUPERINTENDING ENGINEER

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 17/05/21 to 23/05/21**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)	AMOUNT RECEIVABLE(Rs.)	AMOUNT RECEIVABLE(Final After Adjustment)(Rs.)
BSPHCL	POOL	0	523234	456764
JUVNL	POOL	1027325	0	0
DVC	POOL	1611427	0	0
GRIDCO	POOL	0	3548477	3097696
SIKKIM	POOL	574	0	0
WBSETCL	POOL	915136	0	0
Total		3554460	4071711	3554460

Note:

a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC

**b) Final Receivables Amount After Adjustment from the Reactive Pool are done as per Methodology
Approved in the 43rd ERPC meeting held on 26.03.2021 at Kolkata.**

SUPERINTENDING ENGINEER

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 17/05/21 to 23/05/21

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVar H (Rs)	MVAH_LOW	REACTIVE CHARGE_MVarL (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-977	151435	0	0	151435
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-1172	181660	0	0	181660
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-2994	464070	0	0	464070
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	15.7	-2434	-157.6	-24428	-26862
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-6.2	961	-96.4	-14942	-13981
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	22.5	-3488	-137.7	-21343.5	-24831
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-471.1	73021	0	0	73021
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-128.1	19856	0	0	19856
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	0	0	0	0	0
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-225.3	34922	0	0	34922
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-470.5	72928	0	0	72928
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	4.8	-744	32.5	5037.5	4294
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	177.1	-27451	0	0	-27451
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-935.9	145065	0	0	145065
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-239	37045	0	0	37045
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	0	0	0	0	0
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	0	0	0	0	0
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	0	0	0	0	0
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	-123.2	19096	0	0	19096
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1265.6	-196168	0	0	-196168
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1256.3	-194727	0	0	-194727
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1379.9	-213885	0	0	-213885
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1320.7	-204709	0	0	-204709
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-3.6	558	-6.2	-961	-403
	27	HV side of 400/220 Patna ICT-1	ER1408A	0	0	-745	-115475	-115475
	28	HV side of 400/220 Patna ICT-2	ER1407A	-975.1	151141	0	0	151141
	29	HV side of 400/220 Patna ICT-3	ER1231A	-902.8	139934	0	0	139934
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	2.8	-434	0	0	-434
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	3	-465	0	0	-465
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-2543.3	394212	0	0	394212
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-2417.1	374651	0	0	374651
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	796.7	-123489	0	0	-123489
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1661.8	-257579	0	0	-257579
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	0	0	0	0	0
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	0	0	0	0	0
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	125.9	-19515	0	0	-19515
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	140	-21700	0	0	-21700
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-19.7	3054	0	0	3054
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	2475.5	-383703	0	0	-383703
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	1873.1	-290331	0	0	-290331
	44	220 KV NADHOKHAR(BSPHCL)- ARA(PG) LINE-1	ER1305A	-230.1	35666	0	0	35666
	45	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	281.7	-43664	0	0	-43664
	46	HV side of 400/220 KV Biharshariff(PG) ICT-4	ER1386A	-2455.2	380556	0	0	380556
		TOTAL			695346		-172112	523234
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-21.5	3333	0	0	3333
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-1.4	217	0	0	217
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-6.4	992	0	0	992
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	1632.1	-252976	0	0	-252976
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	2046.8	-317254	0	0	-317254
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	0	0	0	0	0
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	363.5	-56343	0	0	-56343
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	1314.2	-203701	0	0	-203701
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	1291	-200105	0	0	-200105
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	0	0	0	0	0
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	0	0	0	0	0
	12	HV side meter of 400/220 Dalitonganj ICT-1	ER1197A	0	0	-4.5	-698	-698
	13	HV side meter of 400/220 Dalitonganj ICT-2	ER1317A	0	0	-5.1	-791	-791
		TOTAL			-1025837		-1488	-1027325
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-5301.6	821748	0	0	821748
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-2204.8	341744	0	0	341744
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	0	0	0	0	0
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	0	0	0	0	0
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	0	0	0	0	0
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	0	0	0	0	0
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	0	0	0	0	0
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-1589.4	246357	0	0	246357
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-1265.7	196184	0	0	196183.5
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	354.6	-54963	0	0	-54963
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	817.9	-126775	0	0	-126774.5
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	853.5	-132293	0	0	-132292.5
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-III(MAIN)	NP6522A	891.3	-138152	0	0	-138151.5
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	0	0	0	0	0
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	0	0	0	0	0
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	0	0	0	0	0
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	9219.1	-1428961	0	0	-1428960.5
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	8621.4	-1336317	0	0	-1336317
		TOTAL			-1611427		0	-1611427

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	-1830.6	283743	0	0	283743
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	-647.5	100362.5	0	0	100362.5
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	0	0	0	0	0
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	0	0	0	0	0
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-3109.8	482019	0	0	482019
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2122.4	328972	0	0	328972
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-2002.2	310341	0	0	310341
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-1511.4	234267	0	0	234267
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0	0	0	0	0
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA(PG)	NP7916A	-548.8	85064	0	0	85064
	17	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	4.6	-713	0	0	-713
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	0	0	2460.2	381331	381331
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)	NP7932A	0	0	0	0	0
	20	400 KV MENDHASAL (GRIDCO)-PANDIABIL(PG)-I	NP5980A	0	0	0	0	0
	21	400 KV MENDHASAL (GRIDCO)-PANDIABIL(PG)-II	NP7498A	0	0	0	0	0
	22	400 KV DUBRI (GRIDCO)-PANDIABIL(PG)	NP7915A	-667.3	103431.5	0	0	103431.5
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	1	-155	75.6	11718	11563
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0.2	-31	73.4	11377	11346
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	-8.6	1333	0	0	1333
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH(PG)-STERLITE (GRIDCO)-I	ER1059A	-335.7	52033.5	0	0	52033.5
	28	400KV SUNDERGARH(PG)-STERLITE (GRIDCO)-II	ER1058A	-582.8	90334	0	0	90334
	29	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	30	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	31	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	-3466.5	537307.5	0	0	537307.5
	32	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	-3456.4	535742	0	0	535742
		TOTAL			3144051		404426	3548477
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-10.50	1628	0	0	1628
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-9.00	1395	0	0	1395
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	23.20	-3596	0	0	-3596
		TOTAL			-574		0	-574
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	0	0	0
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	-7.5	1163	-46.6	-7223	-6061
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	0	0	-72.2	-11191	-11191
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1379.8	213869	0	0	213869
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1509.8	234019	0	0	234019
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-66.4	10292	0	0	10292
	8	132 KV SILIGURI (PG) - NBV (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-1614.2	250201	0	0	250201
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-97.2	15066	0	0	15066
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	0	0	0	0	0
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	3234.5	-501348	0	0	-501348
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	14	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	3658.6	-567083	0	0	-567083
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	0	0	0	0	0
	16	400 KV SAGARDIGHI(WBSETCL) - FARAKKA (NTPC)	NP6482A	-689.9	106935	0	0	106935
	17	400 KV SAGARDIGHI(WBSETCL) - SUBHASGRAM (PG)	NP6483A	540.2	-83731	0	0	-83731
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-12.6	1953	0	0	1953
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-3.5	543	0	0	543
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	0	0	0	0	0
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	0	0	0	0	0
	22	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	NP7557A	0	0	0	0	0
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-495.4	76787	0	0	76787
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-196.9	30520	0	0	30520
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	58.7	-9099	12.3	1907	-7192
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	0	0	0	0	0
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-I	NP8723A	1647	-255285	0	0	-255285
	31	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-II	NP8724A	827.4	-128247	0	0	-128247
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-2.8	434	0	0	434
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	0	0	0	0	0
	34	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	ER1040A	1261.7	-195564	0	0	-195564
	35	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	ER1130A	635.6	-98518	0	0	-98518
	36	400 KV GOKARNA(WB)-FARAKKA(NTPC)-I	ER1133A	0	0	0	0	0
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-II	ER1138A	0	0	0	0	0
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	46.3	-7177	0	0	-7177
	39	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	118.3	-18337	0	0	-18337
	40	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	-172.8	26784	0	0	26784
	41	HV side of 400/220 KV RAJARHAT(PG) ICT-1	ER1526A	0	0	-18.1	-2806	-2806
	42	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	0	0	0	0	0
	43	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	0	0	0	0	0
	44	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER1698A	0	0	0	0	0
	45	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER1699A	0	0	0	0	0
		TOTAL			-895823		-19313	-915136

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVArH,w.e.f. 01/04/2021

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting ,the methodology for computaion of Reactive Charges has been changed in conformity with other RPCs.