



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टालीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/1008

Date: 28.10.2021

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 11.10.2021-17.10.2021

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 28.10.2021.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This is issued with the approval of Member Secretary.

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)
SUPERINTENDING ENGINEER

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 11/10/21 to 17/10/21**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)	AMOUNT RECEIVABLE(Rs.)	AMOUNT RECEIVABLE(Final After Adjustment)(Rs.)
BSPHCL	POOL	0	1384135	1384135
JUVNL	POOL	218364	0	0
DVC	POOL	4797328	0	0
GRIDCO	POOL	8964890	0	0
SIKKIM	POOL	0	47353	47353
WBSETCL	POOL	0	338086	338086
Total		13980582	1769573	1769573

Note:

a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC

b) Final Receivables Amount After Adjustment from the Reactive Pool are done as per Methodology Approved in the 43rd ERPC meeting held on 26.03.2021 at Kolkata.

SUPERINTENDING ENGINEER

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 11/10/21 to 17/10/21

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAh (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAh (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-787.6	122078	0	0	122078
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-1119.6	173538	0	0	173538
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-2507.5	388663	0	0	388663
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-3.8	589	-3.8	-589	0
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-75.2	11656	0	0	11656
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	-4.3	667	-1.9	-294.5	372
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-1884.9	292160	0	0	292160
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-19.9	3085	0	0	3085
	9	220 KV side of 220/132 Arah ICT-2	ER1882A	-21.7	3364	0	0	3364
	10	220 KV KHAGAULI(BSPHCL) - ARAH (PG)-I	NP8641A	-9.8	1519	0	0	1519
	11	220 KV KHAGAULI(BSPHCL) - ARAH (PG)-II	NP6060A	-233.2	36146	0	0	36146
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	0	0	-178.5	-27667.5	-27668
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	-31	4805	0	0	4805
	16	220 KV NADHOKHAR(BSPHCL)- PUSAULI (PG)-2	NP8665A	-1343.1	208181	0	0	208181
	17	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	ER1872A	-4.1	636	0	0	636
	18	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	ER1873A	-4.6	713	0	0	713
	19	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1205.3	-186822	0	0	-186822
	20	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1208.6	-187333	0	0	-187333
	21	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1299.7	-201454	0	0	-201454
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1268.7	-196649	0	0	-196649
	23	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-4.4	682	103.8	16089	16771
	24	HV side of 400/220 Patna ICT-1	ER1877A	-1207.2	187116	0	0	187116
	25	HV side of 400/220 Patna ICT-2	ER1407A	-1781.6	276148	0	0	276148
	26	HV side of 400/220 Patna ICT-3	ER1231A	-1637.1	253751	0	0	253751
	27	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	0	0	0	0	0
	28	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	0	0	0	0	0
	29	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-2071.3	321052	0	0	321052
	30	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1943.4	301227	0	0	301227
	31	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1302.2	-201841	0	0	-201841
	32	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1300.9	-201640	0	0	-201640
	33	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	2.2	-341	0	0	-341
	34	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	9.5	-1473	0	0	-1473
	35	220 KV NEW PURNEA(PG)-BEGUSARAI(BSPTCL)-I	ER1348A	1445.3	-224022	0	0	-224022
	36	220 KV NEW PURNEA(PG)-KHAGARIA(BSPTCL)	ER1376A	1215.3	-188372	0	0	-188372
	37	220 KV DUMRAON NEW (BSPHCL)- ARA(PG) LINE-1	ER1305A	129.5	-20073	0	0	-20073
	38	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	-1748.1	270956	0	0	270956
	39	HV side of 400/220 KV Biharshariff (PG) ICT-4	ER1386A	-1981.5	307133	0	0	307133
	40	400 KV SIDE OF 400/220 500 MVA GAYA(PG) ICT-3	ER1442A	0	0	0	0	0
	41	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-1	ER1247A	-59.3	9192	0	0	9192
	42	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-2	ER1243A	-56.1	8696	0	0	8696
	43	220 KV DUMRAON NEW (BSPHCL)- ARA (PG)-2	ER1866A	124.6	-19313	0	0	-19313
	44	400 KV SIDE OF LAKHISARAI(PG) 315 MVA 400/132 ICT-3	ER1309A	-3.9	605	0	0	605
	45	400 KV SIDE BANKA(PG) 400/132 KV 315 MVA ICT-3	ER1362A	0	0	0	0	0
	46	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-1	ER1395A	15.3	-2372	0	0	-2372
	47	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-2	ER1933A	16.3	-2527	0	0	-2527
	48	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-3	ER1934A	15.3	-2372	0	0	-2372
	49	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-2	ER1875A	9.8	-1519	0	0	-1519
	50	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-1	ER1816A	9.8	-1519	0	0	-1519
	51	400 KV HV SIDE OF 315 MVA MOTIHARI(DMTCL) ICT-3	ER1819A	0	0	0	0	0
	52	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-1	ER1806A	477.8	-74059	0	0	-74059
	53	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-2	ER1823A	477.8	-74059	0	0	-74059
		TOTAL			1396597		-12462	1384135
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-7346.8	1138754	0	0	1138754
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-6440.4	998262	0	0	998262
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-5748	890940	0	0	890940
	4	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	0	0	0	0	0
	5	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	3352.2	-519591	0	0	-519591
	6	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	3358.4	-520552	0	0	-520552
	7	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-2	NP8637A	1466.1	-227246	0	0	-227246
	8	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-1	NP8678A	1458.4	-226052	0	0	-226052
	9	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	13.1	-2031	0	0	-2031
	10	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	9.6	-1488	0	0	-1488
	11	220 KV RANCHI(PG)-HATIA(JUVNL)-I	NP5879A	3457.9	-535975	0	0	-535975
	12	221 KV RANCHI(PG)-HATIA(JUVNL)-II	ER1252A	2989.3	-463342	0	0	-463342
	13	222 KV RANCHI(PG)-HATIA(JUVNL)-III	NP7880A	3018.2	-467821	0	0	-467821
	14	223 KV RANCHI(PG)-CHANDIL(JUVNL)	NP5874A	1820.8	-282224	0	0	-282224
		TOTAL			-218364		0	-218364
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-6214.4	963232	0	0	963232
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	ER1668A	480.2	-74431	0	0	-74431
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	682	-105710	0	0	-105710
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	ER1711A	-829	128495	0	0	128495
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	ER1717A	-910.2	141081	0	0	141081
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	ER1808A	-2328.1	360856	0	0	360856
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	ER1802A	4724.3	-732267	0	0	-732267
	9	400 KV MEJIA(DVC)-MAITHON(PG)	ER1659A	-3411.6	528798	0	0	528798
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1657A	-2154.9	334010	0	0	334010
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1658A	-2341	362855	0	0	362855
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	129.4	-20057	0	0	-20057
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-230.7	35759	0	0	35759
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-1701.2	263886	0	0	263886
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-2141.8	331979	0	0	331979
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	1733.8	-268739	0	0	-268739
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-III(MAIN)	NP6522A	1670.7	-258959	0	0	-258959
	18	400 KV RTPS(DVC)-RANCHI(PG)	ER1653A	0	0	0	0	0
	19	400 KV RTPS(DVC)-MAITHON(PG)	ER1652A	21376.7	-3313389	0	0	-3313389
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	ER1656A	-4642.8	719634	0	0	719634
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	14126.4	-2189592	0	0	-2189592
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	14003.6	-2170558	0	0	-2170558
23	220 KV RANCHI(PG)-RAMGARH(DVC)	ER1798A	-1070.9	165990	0	0	165990	
24	221 KV RANCHI(PG)-MTPS(DVC)	ER1796A	0	0	0	0	0	
		TOTAL			-4797328		0	-4797328

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-1 AND ICT-3	ER1563A	141.3	-21901.5	0	0	-21902
	2	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-2 AND ICT-4	ER1565A	-479.2	74276	0	0	74276
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	400 KV SIDE OF JEYPORE (PG) 400/220 KV ICT-1 AND ICT-3	ER1550A	4820.5	-747177.5	0	0	-747178
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	631.7	-97913.5	0	0	-97914
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H)	ER1759A	18178.3	-2817636.5	0	0	-2817637
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	0	0	0	0	0
	9	HV side meter of 400/220 Baripada ICT-2	ER1746A	0	0	0	0	0
	10	HV side meter of 400/220 Baripada ICT-3	ER1747A	0	0	0	0	0
	11	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	12	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	ER1900A	-2455.2	380556	0	0	380556
	13	400 KV MERAMUNDALI (GRIDCO)-BOLANGIR(PG)	ER1054A	9407.3	-1458131.5	0	0	-1458132
	14	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)-2	ER1055A	16599.6	-2572938	0	0	-2572938
	15	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	ER1758A	21510	-3334050	0	0	-3334050
	16	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	0	0	0	0	0
	17	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	0	0	0	0	0
	18	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	ER1897A	-4174.2	647001	0	0	647001
	19	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	-0.2	-31	-31
	20	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	-0.2	-31	-31
	21	HV side of 400/220 Pandiabil ICT-1	ER1583A	2162.9	-335249.5	0	0	-335250
	22	HV side of 400/220 Pandiabil ICT-2	ER1776A	2242.3	-347556.5	0	0	-347557
	23	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	-932.4	144522	0	0	144522
	24	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	-1246.5	193207.5	0	0	193208
	25	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	26	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	27	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	-4266.3	661276.5	0	0	661277
	28	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	-4302.5	666887.5	0	0	666888
		TOTAL		-8964828		-62	-8964890	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-221.20	34286	0	0	34286
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-11.40	1767	0	0	1767
	3	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	ER1490A	-36.80	5704	0	0	5704
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	ER1489A	-36.10	5596	0	0	5596
		TOTAL		47353		0	47353	
WBSETCL	1	400 KV JEERAT (WBSETCL) - RAJARAHAT(PG)	ER1471A	0	0	-6.5	-1008	-1008
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-1	ER1534A	-18	2790	0	0	2790
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-2	ER1483A	-7.6	1178	0	0	1178
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1600.4	248062	0	0	248062
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1705.3	264322	0	0	264322
	6	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-300.3	46547	0	0	46547
	7	132 KV SILIGURI (PG) - NBU (WBSETCL)	ER1675A	-730	113150	0	0	113150
	8	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-1982.3	307257	0	0	307257
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-13.4	2077	0	0	2077
	10	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	ER1739A	2250	-348750	0	0	-348750
	11	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	NP5881A	3278	-508090	0	0	-508090
	12	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	13	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	8525.9	-1321515	0	0	-1321515
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	211.3	-32752	0	0	-32752
	15	400 KV SAGARDIGHI(WB) - FARAKKA (NTPC)-1(MAIN)	NP6482A	-1615.4	250387	0	0	250387
	16	400 KV JEERAT(PG) - SUBHASHGRAM (PG)	ER1477A	0	0	0	0	0
	17	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	168.9	-26180	0	0	-26180
	18	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-316.5	49058	0	0	49058
	19	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	-165	25575	0	0	25575
	20	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	172.7	-26769	0	0	-26769
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	ER1637A	476.4	-73842	0	0	-73842
	22	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-1060.2	164331	0	0	164331
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-518.9	80430	0	0	80430
	24	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-3	ER1486A	-6.8	1054	0	0	1054
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-4	ER1537A	-7.1	1101	0	0	1101
	26	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	ER1484A	-25.4	3937	0	0	3937
	27	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	-134.1	20786	0	0	20786
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	ER1679A	-33.1	5131	0	0	5131
	29	400 KV SAGARDIGHI(WB)-BERHAMPORE (PG) LINE-I	NP8723A	-459.1	71161	0	0	71161
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE (PG) LINE-II	NP8724A	-221	34255	0	0	34255
	31	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-2781.9	431195	0	0	431195
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-2678.6	415183	0	0	415183
	33	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-I	ER1040A	692.8	-107384	0	0	-107384
	34	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	ER1130A	568.4	-88102	0	0	-88102
	35	400 KV GOKARNA(WB)-RAJARHAT(PG)	ER1133A	-621.9	96395	0	0	96395
	36	400 KV GOKARNA(WB)-PURNEA(PG)	ER1138A	-720	111600	0	0	111600
	37	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	-0.7	109	0	0	109
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	0	0	0	0	0
	39	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	-290.2	44981	0	0	44981
	40	HV side of 400/220 KV RAJARHAT(PG) ICT-1	ER1526A	-8.4	1302	0	0	1302
	41	220 KV SIDE OF 50 MVA MALDA(PG) 220/132 ICT-4	ER1639A	-1213.2	188046	0	0	188046
	42	400 KV SIDE OF RAJARHAT(PG) 400/220 500 MVA ICT-2	ER1650A	-1.1	171	0	0	171
	43	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	1450.8	-224874	0	0	-224874
	44	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	1391.4	-215667	0	0	-215667
	45	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER1698A	0	0	0	0	0
	46	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER1699A	-2143.9	332305	0	0	332305
	47	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-1	ER1683A	0	0	0	0	0
	48	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-2	ER1685A	0	0	0	0	0
	49	400 KV JEERAT(WB)-NEW JEERAT(PMJTL) CKT-1	ER2101A	0	0	0	0	0
	50	401 KV JEERAT(WB)-NEW JEERAT(PMJTL) CKT-2	ER2103A	5.5	-853	0	0	-853
		TOTAL		339094		-1008	338086	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVArh.w.e.f. 01/04/2021

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting ,the methodology for compusion of Reactive Charges has been changed in conformity with other RPCs.