



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टालीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/1188

Date: 29.11.2021

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 08.11.2021-14.11.2021

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 19.11.2021.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This is issued with the approval of Member Secretary.

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)
SUPERINTENDING ENGINEER

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 08/11/21 to 14/11/21**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)	AMOUNT RECEIVABLE(Rs.)	AMOUNT RECEIVABLE(Final After Adjustment)(Rs.)
BSPHCL	POOL	4568207	0	0
JUVNL	POOL	2504785	0	0
DVC	POOL	0	200957	200957
GRIDCO	POOL	8128433	0	0
SIKKIM	POOL	2699542	0	0
WBSETCL	POOL	1623377	0	0
Total		19524343	200957	200957

Note:

a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC

b) Final Receivables Amount After Adjustment from the Reactive Pool are done as per Methodology Approved in the 43rd ERPC meeting held on 26.03.2021 at Kolkata.

SUPERINTENDING ENGINEER

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA
DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 08/11/21 to 14/11/21

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAh (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAh (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-1950.4	302312	0	0	302312
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-522	80910	0	0	80910
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-3507.7	543694	0	0	543694
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-69.1	10711	0	0	10711
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-130	20150	0	0	20150
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	15.3	-2372	0	0	-2372
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-61.4	9517	0	0	9517
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-475.1	73641	0	0	73641
	9	220 KV side of 220/132 Arah ICT-2	ER1882A	-490	75950	0	0	75950
	10	220 KV KHAGAULI(BSPHCL) - ARAH (PG)-I	NP8641A	-326.4	50592	0	0	50592
	11	220 KV KHAGAULI(BSPHCL) - ARAH (PG)-II	NP6060A	-721.4	111817	0	0	111817
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	0	0	-15.3	-2371.5	-2372
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	-667.6	103478	0	0	103478
	16	220 KV NADHOKHAR(BSPHCL)- PUSAULI (PG)-2	NP8665A	896	-138880	0	0	-138880
	17	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	ER1872A	50.2	-7781	0	0	-7781
	18	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	ER1873A	55.4	-8587	0	0	-8587
	19	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	2927.7	-453794	0	0	-453794
	20	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	2920.6	-452693	0	0	-452693
	21	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	3143.7	-487274	0	0	-487274
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	3109.1	-481911	0	0	-481911
	23	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	15.9	-2465	0	0	-2465
	24	HV side of 400/220 Patna ICT-1	ER1877A	2120.8	-328724	0	0	-328724
	25	HV side of 400/220 Patna ICT-2	ER1407A	1452.1	-225076	0	0	-225076
	26	HV side of 400/220 Patna ICT-3	ER1231A	1359.9	-210785	0	0	-210785
	27	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	40	-6200	0	0	-6200
	28	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	45.4	-7037	0	0	-7037
	29	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1107.8	171709	0	0	171709
	30	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1233.1	191131	0	0	191131
	31	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2235.1	-346441	0	0	-346441
	32	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2243.6	-347758	0	0	-347758
	33	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	2639.3	-409092	0	0	-409092
	34	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	2789.1	-432311	0	0	-432311
	35	220 KV NEW PURNEA(PG)-BEGUSARAI(BSPTCL)-I	ER1348A	3034.6	-470363	0	0	-470363
	36	220 KV NEW PURNEA(PG)-KHAGARIA(BSPTCL)	ER1376A	2536.3	-393127	0	0	-393127
	37	220 KV DUMRAON NEW (BSPHCL)- ARA(PG) LINE-1	ER1305A	50.2	-7781	0	0	-7781
	38	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	1313	-203515	0	0	-203515
	39	HV side of 400/220 KV Biharsharif(PG) ICT-4	ER1386A	-731.5	113383	0	0	113383
	40	400 KV SIDE OF 400/220 500 MVA GAYA(PG) ICT-3	ER1442A	0	0	0	0	0
	41	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-1	ER1247A	-250.1	38766	0	0	38766
	42	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-2	ER1243A	-240.6	37293	0	0	37293
	43	220 KV DUMRAON NEW (BSPHCL)- ARA (PG)-2	ER1866A	48.8	-7564	0	0	-7564
	44	400 KV SIDE OF LAKHISARAI(PG) 315 MVA 400/132 ICT-3	ER1309A	130.3	-20197	0	0	-20197
	45	400 KV SIDE BANKA(PG) 400/132 KV 315 MVA ICT-3	ER1362A	77.1	-11951	0	0	-11951
	46	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-1	ER1395A	0	0	0	0	0
	47	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-2	ER1933A	0	0	0	0	0
	48	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-3	ER1934A	0	0	0	0	0
	49	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-2	ER1875A	1389.8	-215419	0	0	-215419
	50	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-1	ER1816A	1430.1	-221666	0	0	-221666
	51	400 KV HV SIDE OF 315 MVA MOTIHARI(DMTCL) ICT-3	ER1819A	0	0	0	0	0
	52	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-1	ER1806A	1940.8	-300824	0	0	-300824
	53	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-2	ER1823A	1931	-299305	0	0	-299305
		TOTAL		-4565835		-2372	-4568207	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-3923.8	608189	0	0	608189
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-2982.5	462288	0	0	462288
	3	HV side meter of 400/220 Jamshedpur ICT-3	ER1297A	-2707.3	419632	0	0	419632
	4	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	0	0	0	0	0
	5	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	6231.2	-965836	0	0	-965836
	6	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	6322.8	-980034	0	0	-980034
	7	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-2	NP8637A	0	0	0	0	0
	8	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-1	NP8678A	1158.5	-179568	0	0	-179568
	9	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	0.2	31	31
	10	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	0	0	0
	11	220 KV RANCHI(PG)-HATIA(JUVNL)-I	NP5879A	3605.2	-558806	0	0	-558806
	12	221 KV RANCHI(PG)-HATIA(JUVNL)-II	ER1252A	3171	-491505	0	0	-491505
	13	222 KV RANCHI(PG)-HATIA(JUVNL)-III	NP7880A	3195.2	-495256	0	0	-495256
	14	223 KV RANCHI(PG)-CHANDIL(JUVNL)	NP5874A	2089.8	-323919	0	0	-323919
		TOTAL		-2504816		31	-2504785	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-6316.8	979104	0	0	979104
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	ER1668A	271.6	-42098	0	0	-42098
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	408.6	-63333	0	0	-63333
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	ER1711A	-1713.8	265639	0	0	265639
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	ER1717A	-2010.6	311643	0	0	311643
	7	400 KV TATA JAMSHEDPUR (DVC)- BARI PADA(PG)	ER1808A	-3796	588380	0	0	588380
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	ER1802A	3512.7	-544469	0	0	-544469
	9	400 KV MEJIA(DVC)-MAITHON(PG)	ER1659A	-2461.1	381471	0	0	381471
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1657A	-857.5	132913	0	0	132913
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1658A	-1022.6	158503	0	0	158503
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-2407.2	373116	0	0	373116
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-1585.4	245737	0	0	245737
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-553.4	85777	0	0	85777
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-933.8	144739	0	0	144739
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-2003.7	310574	-286.5	-44407.5	266166
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-III(MAIN)	NP6522A	-2110.6	327143	0	0	327143
	18	400 KV RTPS(DVC)-RANCHI(PG)	ER1653A	-3661.1	567471	0	0	567471
	19	400 KV RTPS(DVC)-MAITHON(PG)	ER1652A	17043.7	-2641774	0	0	-2641774
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	ER1656A	-3592.7	556889	0	0	556889
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	6449.4	-999657	0	0	-999657
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	6295.3	-975772	0	0	-975772
	23	220 KV RANCHI(PG)-RAMGARH(DVC)	ER1798A	-538	83390	0	0	83390
	24	221 KV RANCHI(PG)-MTPS(DVC)	ER1796A	0	0	0	0	0
		TOTAL		245365		0	200957	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-1 AND ICT-3	ER1563A	1.8	-279	0	0	-279
	2	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-2 AND ICT-4	ER1565A	-1.1	170.5	0	0	171
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	400 KV SIDE OF JEYPORE (PG) 400/220 KV ICT-1 AND ICT-3	ER1550A	5792.3	-897806.5	0	0	-897807
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	4682.6	-725803	0	0	-725803
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	ER1759A	20017.1	-3102650.5	0	0	-3102651
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	3.9	-604.5	0	0	-605
	9	HV side meter of 400/220 Baripada ICT-2	ER1746A	0.7	-108.5	0	0	-109
	10	HV side meter of 400/220 Baripada ICT-3	ER1747A	0	0	0	0	0
	11	220 KV BALIMELA (GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	12	400 KV DUBURI (GRIDCO)-BARIPADA(PG)	ER1900A	319	-49445	0	0	-49445
	13	400 KV MERAMUNDALI (GRIDCO)-BOLANGIR(PG)	ER1054A	1668.4	-258602	0	0	-258602
	14	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)-2	ER1055A	13245.5	-2053052.5	0	0	-2053053
	15	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)	ER1758A	7614.4	-1180232	0	0	-1180232
	16	400 KV MENDHASAL (GRIDCO)-PANDIABIL(PG)-I	NP5980A	0	0	0	0	0
	17	400 KV MENDHASAL (GRIDCO)-PANDIABIL(PG)-II	NP7498A	0	0	0	0	0
	18	400 KV DUBURI (GRIDCO)-PANDIABIL(PG)	ER1897A	-5271.1	817020.5	0	0	817021
	19	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	20	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	21	HV side of 400/220 Pandiabil ICT-1	ER1583A	3024	-468720	0	0	-468720
	22	HV side of 400/220 Pandiabil ICT-2	ER1776A	3018.8	-467914	0	0	-467914
	23	400KV SUNDERGARH(PG)-STERLITE (GRIDCO)-I	ER1059A	0	0	0	0	0
	24	400KV SUNDERGARH(PG)-STERLITE (GRIDCO)-II	ER1058A	0	0	0	0	0
	25	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	26	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	27	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	-776.7	120388.5	0	0	120389
	28	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	-898.1	139205.5	0	0	139206
		TOTAL		-8128433		0	-8128433	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	17757.00	-2752335	0	0	-2752335
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	5.40	-837	0	0	-837
	3	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	ER1490A	-173.50	26893	0	0	26893
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	ER1489A	-172.50	26738	0	0	26738
		TOTAL		-2699542		0	-2699542	
WBSETCL	1	400 KV JEERAT (WBSETCL) - RAJARAHAT(PG)	ER1471A	0	0	-68.8	-10664	-10664
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-1	ER1534A	556.9	-86320	0	0	-86320
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-2	ER1483A	372.6	-57753	0	0	-57753
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-2054.1	318386	0	0	318386
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-2071.3	321052	0	0	321052
	6	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-1818.1	281806	0	0	281806
	7	132 KV SILIGURI (PG) - NBU (WBSETCL)	ER1675A	-1508	233740	0	0	233740
	8	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2692.2	417291	0	0	417291
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-1222.5	189488	0	0	189488
	10	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	ER1739A	7632.8	-1183084	0	0	-1183084
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	8401.3	-1302202	0	0	-1302202
	12	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-16.6	2573	0	0	2573
	13	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	7450.9	-1154890	0	0	-1154890
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	289.5	-44873	0	0	-44873
	15	400 KV SAGARDIGHI(WB) - FARAKKA (NTPC)-1(MAIN)	NP6482A	-2962.3	459157	0	0	459157
	16	400 KV JEERAT(PG) - SUBHASHGRAM (PG)	ER1477A	0	0	0	0	0
	17	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	118.2	-16321	0	0	-16321
	18	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-195.4	30287	0	0	30287
	19	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	105.4	-16337	0	0	-16337
	20	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	440.4	-68262	0	0	-68262
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	ER1637A	1367.7	-211994	0	0	-211994
	22	220 KV DALKHOLOA(PG)-DALKHOLOA(WBSETCL)LINE-I	ER1071A	60.7	-9409	0	0	-9409
	23	220 KV DALKHOLOA(PG)-DALKHOLOA(WBSETCL)LINE-II	ER1072A	-40.3	6247	0	0	6247
	24	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-3	ER1486A	359.1	-55661	0	0	-55661
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-4	ER1537A	377.1	-58451	0	0	-58451
	26	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	ER1484A	609.8	-94519	0	0	-94519
	27	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	385.4	-59737	0	0	-59737
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	ER1679A	1115	-172825	0	0	-172825
	29	400 KV SAGARDIGHI(WB)-BERHAMPORE (PG) LINE-I	NP8723A	-1394.3	216117	0	0	216117
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE (PG) LINE-II	NP8724A	-1210.2	187581	0	0	187581
	31	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-1965.7	304684	0	0	304684
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-1946.9	301770	0	0	301770
	33	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-I	ER1040A	1107.4	-171647	0	0	-171647
	34	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	ER1130A	1070.2	-165881	0	0	-165881
	35	400 KV GOKARNA(WB)-RAJARHAT(PG)	ER1133A	-3136.3	486127	0	0	486127
	36	400 KV GOKARNA(WB)-PURNEA(PG)	ER1138A	-5992.3	928807	0	0	928807
	37	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	509.6	-78988	0	0	-78988
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	557.2	-86366	0	0	-86366
	39	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	-1776	275280	0	0	275280
	40	HV side of 400/220 KV RAJARHAT(PG) ICT-1	ER1526A	0	0	0	0	0
	41	220 KV SIDE OF 50 MVA MALDA(PG) 220/132 ICT-4	ER1639A	-1302.1	201826	0	0	201826
	42	400 KV SIDE OF RAJARHAT(PG) 400/220 500 MVA ICT-2	ER1650A	0	0	0	0	0
	43	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	4364.8	-676544	0	0	-676544
	44	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	4315.9	-668965	0	0	-668965
	45	220 KV GAZOLE(WB)-DALKHOLOA(PG)-1	ER2125A	2141.3	-331902	0	0	-331902
	46	220 KV GAZOLE(WB)-DALKHOLOA(PG)-2	ER1699A	0	0	0	0	0
	47	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-1	ER1683A	0	0	0	0	0
	48	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-2	ER1685A	0	0	0	0	0
	49	400 KV JEERAT(WB)-NEW JEERAT(PMJTL) CKT-1	ER2101A	0	0	0	0	0
	50	401 KV JEERAT(WB)-NEW JEERAT(PMJTL) CKT-2	ER2103A	0	0	0	0	0
		TOTAL		-1612713		-10664	-1623377	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVAh,w.e.f. 01/04/2021

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting ,the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.