



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टालीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/1274

Date: 13.12.2021

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 22.11.2021-28.11.2021

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 03.12.2021.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This is issued with the approval of Member Secretary.

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)
SUPERINTENDING ENGINEER

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 22/11/21 to 28/11/21**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)	AMOUNT RECEIVABLE(Rs.)	AMOUNT RECEIVABLE(Final After Adjustment)(Rs.)
BSPHCL	POOL	4897272	0	0
JUVNL	POOL	1945901	0	0
DVC	POOL	1504260	0	0
GRIDCO	POOL	5428271	0	0
SIKKIM	POOL	0	78260	78260
WBSETCL	POOL	2155043	0	0
Total		15930745	78260	78260

Note:

a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC

b) Final Receivables Amount After Adjustment from the Reactive Pool are done as per Methodology Approved in the 43rd ERPC meeting held on 26.03.2021 at Kolkata.

SUPERINTENDING ENGINEER

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA
DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 22/11/21 to 28/11/21

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAh (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAh (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-2412.8	373984	0	0	373984
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-433.3	67162	0	0	67162
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-3620.5	561178	0	0	561178
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	13.2	-2046	0	0	-2046
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-30	4650	0	0	4650
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	87.4	-13547	0	0	-13547
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	591.6	-91698	0	0	-91698
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-422.9	65550	0	0	65550
	9	220 KV side of 220/132 Arah ICT-2	ER1882A	-434.1	67286	0	0	67286
	10	220 KV KHAGAULI(BSPHCL) - ARAH (PG)-I	NP8641A	-275.6	42718	0	0	42718
	11	220 KV KHAGAULI(BSPHCL) - ARAH (PG)-II	NP6060A	-529.1	82011	0	0	82011
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	27.2	-4216	-5.1	-790.5	-5007
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	-585.5	90753	0	0	90753
	16	220 KV NADHOKHAR(BSPHCL)- PUSAULI (PG)-2	NP8665A	473.6	-73408	0	0	-73408
	17	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	ER1872A	99.8	-15469	0	0	-15469
	18	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	ER1873A	104.6	-16213	0	0	-16213
	19	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	2820.8	-437224	0	0	-437224
	20	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	2822.4	-437472	0	0	-437472
	21	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	3032.4	-470022	0	0	-470022
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	2997.4	-464597	0	0	-464597
	23	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	6.7	-1039	0	0	-1039
	24	HV side of 400/220 Patna ICT-1	ER1877A	1857.6	-287928	0	0	-287928
	25	HV side of 400/220 Patna ICT-2	ER1407A	1290.5	-200028	0	0	-200028
	26	HV side of 400/220 Patna ICT-3	ER1231A	1202.2	-186341	0	0	-186341
	27	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	79.2	-12276	0	0	-12276
	28	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	75	-11625	0	0	-11625
	29	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1192.9	184900	0	0	184900
	30	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1289.7	199904	0	0	199904
	31	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2180.2	-337931	0	0	-337931
	32	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2186.2	-338861	0	0	-338861
	33	HV side of 400/220 Darhanaga DMTCL ICT-1	ER1274A	3346.8	-518754	0	0	-518754
	34	HV side of 400/220 Darhanaga DMTCL ICT-2	ER1275A	3584.4	-555582	0	0	-555582
	35	220 KV NEW PURNEA(PG)-BEGUSARAI(BSPTCL)-I	ER1348A	2727.9	-422825	0	0	-422825
	36	220 KV NEW PURNEA(PG)-KHAGARIA(BSPTCL)	ER1376A	2629.9	-407635	0	0	-407635
	37	220 KV DUMRAON NEW (BSPHCL)- ARA(PG) LINE-1	ER1305A	-48	7440	0	0	7440
	38	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	729.3	-113042	0	0	-113042
	39	HV side of 400/220 KV Biharshariff (PG) ICT-4	ER1386A	-515	79825	0	0	79825
	40	400 KV SIDE OF 400/220 500 MVA GAYA(PG) ICT-3	ER1442A	0	0	0	0	0
	41	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-1	ER1247A	1.3	-202	0	0	-202
	42	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-2	ER1243A	1.4	-217	0	0	-217
	43	220 KV DUMRAON NEW (BSPHCL)- ARA (PG)-2	ER1866A	-48.9	7580	0	0	7580
	44	400 KV SIDE OF LAKHISARAI(PG) 315 MVA 400/132 ICT-3	ER1309A	226.3	-35077	0	0	-35077
	45	400 KV SIDE BANKA(PG) 400/132 KV 315 MVA ICT-3	ER1362A	151.7	-23514	0	0	-23514
	46	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-1	ER1395A	0	0	0	0	0
	47	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-2	ER1933A	0	0	0	0	0
	48	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-3	ER1934A	0	0	0	0	0
	49	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-2	ER1875A	2232	-345960	0	0	-345960
	50	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-1	ER1816A	2228.8	-345464	0	0	-345464
	51	400 KV HV SIDE OF 315 MVA MOTIHARI(DMTCL) ICT-3	ER1819A	0	0	0	0	0
	52	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-1	ER1806A	1814.2	-281201	0	0	-281201
	53	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-2	ER1823A	1806.5	-280008	0	0	-280008
		TOTAL			-4896481		-791	-4897272
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-6346.8	983754	0	0	983754
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-5515.1	854841	0	0	854841
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-4615.9	715465	0	0	715465
	4	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	0	0	0	0	0
	5	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	6620.4	-1026162	0	0	-1026162
	6	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	6715.2	-1040856	0	0	-1040856
	7	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-2	NP8637A	0	0	0	0	0
	8	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-1	NP8678A	2935.1	-454941	0	0	-454941
	9	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	4.9	760	760
	10	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	7	1085	1085
	11	220 KV RANCHI(PG)-HATIA(JUVNL)-I	NP5879A	3863.6	-598858	0	0	-598858
	12	221 KV RANCHI(PG)-HATIA(JUVNL)-II	ER1252A	3352.2	-519591	0	0	-519591
	13	222 KV RANCHI(PG)-HATIA(JUVNL)-III	NP7880A	3381.6	-524148	0	0	-524148
	14	223 KV RANCHI(PG)-CHANDIL(JUVNL)	NP5874A	2175.8	-337249	0	0	-337249
		TOTAL			-1947746		1845	-1945901
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-6602.2	1023341	0	0	1023341
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	ER1668A	37.2	-5766	0	0	-5766
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	77.8	-12059	0	0	-12059
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	ER1711A	-1537.8	238359	0	0	238359
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	ER1717A	-1910.6	296143	0	0	296143
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIKADA(PG)	ER1808A	-3711.4	575267	0	0	575267
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	ER1802A	4949.7	-767204	0	0	-767204
	9	400 KV MEJIA(DVC)-MAITHON(PG)	ER1659A	-2132.3	330507	0	0	330507
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1657A	-247.3	38332	0	0	38332
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1658A	-421.1	65271	0	0	65271
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-2452.4	380122	0	0	380122
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-1568.7	243149	0	0	243149
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-3.7	574	0	0	574
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-140.3	21747	0	0	21747
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-I(MAIN)	ER2046A	3765.1	-583591	0	0	-583591
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	ER2044A	0	0	0	0	0
	18	400 KV RTPS(DVC)-RANCHI(PG)	ER1653A	0	0	0	0	0
	19	400 KV RTPS(DVC)-MAITHON(PG)	ER1652A	15286.4	-2369392	0	0	-2369392
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	ER1656A	-5264	815920	0	0	815920
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	6512	-1009360	0	0	-1009360
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	6331	-981305	0	0	-981305
23	220 KV RANCHI(PG)-RAMGARH(DVC)	ER1798A	-1262.5	195688	0	0	195688	
24	221 KV RANCHI(PG)-MTPS(DVC)	ER1796A	0	0	0	0	0	
		TOTAL			-1504260		0	-1504260

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-1 AND ICT-3	ER1563A	115	-17825	0	0	-17825
	2	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-2 AND ICT-4	ER1565A	-212.1	32875.5	0	0	32876
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	400 KV SIDE OF JEYPORE (PG) 400/220 KV ICT-1 AND ICT-3	ER1550A	3027.2	-469216	0	0	-469216
	6	HV side meter of 400/220 Jeyore ICT-2	ER1571A	2625.9	-407014.5	0	0	-407015
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	ER1759A	1134.1	-175785.5	0	0	-175786
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	70.5	-10927.5	0	0	-10928
	9	HV side meter of 400/220 Baripada ICT-2	ER1746A	36	-5580	0	0	-5580
	10	HV side meter of 400/220 Baripada ICT-3	ER1747A	0	0	0	0	0
	11	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	12	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	ER1900A	-592.3	91806.5	0	0	91807
	13	400 KV MERAMUNDALI (GRIDCO)-BOLANGIR(PG)	ER1054A	5158.9	-799629.5	0	0	-799630
	14	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)-2	ER1055A	14601.8	-2263279	0	0	-2263279
	15	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	ER1758A	9596.6	-1487473	0	0	-1487473
	16	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	0	0	0	0	0
	17	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	0	0	0	0	0
	18	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	ER1897A	-4163	645265	0	0	645265
	19	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	-0.4	-62	-62
	20	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	-0.2	-31	-31
	21	HV side of 400/220 Pandiabil ICT-1	ER1583A	3159.4	-489707	0	0	-489707
	22	HV side of 400/220 Pandiabil ICT-2	ER1776A	3123.7	-484173.5	0	0	-484174
	23	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	-66.2	10261	0	0	10261
	24	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	-146.2	22661	0	0	22661
	25	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	26	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	27	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	-1212.5	187937.5	0	0	187938
	28	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	-1236.3	191626.5	0	0	191627
		TOTAL		-5428178		-93	-5428271	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	0.00	0	0	0	0
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-230.30	35697	0	0	35697
	3	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	ER1490A	-136.60	21173	0	0	21173
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	ER1489A	-138.00	21390	0	0	21390
		TOTAL		78260		0	78260	
WBSETCL	1	400 KV JEERAT (WBSETCL) - RAJARAHAT(PG)	ER1471A	0	0	794.9	123210	123210
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-1	ER1534A	318.7	-49399	0	0	-49399
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-2	ER1483A	113.9	-17655	0	0	-17655
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-2465.7	382184	0	0	382184
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-2484.2	385051	0	0	385051
	6	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-1954.1	302886	0	0	302886
	7	132 KV SILIGURI (PG) - NBU (WBSETCL)	ER1675A	-1448.8	224564	0	0	224564
	8	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2508	388740	0	0	388740
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-1057.7	163944	0	0	163944
	10	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	ER1739A	8014.7	-1242279	0	0	-1242279
	11	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	NP5881A	7971.8	-1235629	0	0	-1235629
	12	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	13	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	7856.1	-1217696	0	0	-1217696
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	581.4	-90117	0	0	-90117
	15	400 KV SAGARDIGHI(WB) - FARAKKA (NTPC)-1(MAIN)	NP6482A	-2801.4	434217	0	0	434217
	16	400 KV JEERAT(PG) - SUBHASHGRAM (PG)	ER1477A	0	0	0	0	0
	17	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	134.8	-20894	0	0	-20894
	18	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-211.5	32783	0	0	32783
	19	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	-186.2	28861	0	0	28861
	20	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	925.3	-143422	0	0	-143422
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	ER1637A	1979.3	-306792	0	0	-306792
	22	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	28.5	-4418	0	0	-4418
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-25.5	3953	0	0	3953
	24	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-3	ER1486A	108.5	-16818	0	0	-16818
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-4	ER1537A	123.2	-19096	0	0	-19096
	26	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	ER1484A	175.3	-27172	0	0	-27172
	27	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	180	-27900	0	0	-27900
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	ER1679A	951.7	-147514	0	0	-147514
	29	400 KV SAGARDIGHI(WB)-BERHAMPORE (PG) LINE-I	NP8723A	965.9	-149715	0	0	-149715
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE (PG) LINE-II	NP8724A	834.2	-129301	0	0	-129301
	31	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-2714.1	420686	0	0	420686
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-2689.4	416857	0	0	416857
	33	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-I	ER1040A	799.6	-123938	0	0	-123938
	34	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	ER1130A	708	-109740	0	0	-109740
	35	400 KV GOKARNA(WB)-RAJARHAT(PG)	ER1133A	-1950.6	302343	0	0	302343
	36	400 KV GOKARNA(WB)-PURNEA(PG)	ER1138A	-5525.4	856437	0	0	856437
	37	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	601.2	-93186	0	0	-93186
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	652.6	-101153	0	0	-101153
	39	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	-1839.2	285076	0	0	285076
	40	HV side of 400/220 KV RAJARHAT(PG) ICT-1	ER1526A	0	0	37.1	5751	5751
	41	220 KV SIDE OF 50 MVA MALDA(PG) 220/132 ICT-4	ER1639A	-1692.3	262307	0	0	262307
	42	400 KV SIDE OF RAJARHAT(PG) 400/220 500 MVA ICT-2	ER1650A	0	0	50.5	7828	7828
	43	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	4771.1	-739521	0	0	-739521
	44	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	4711.7	-730314	0	0	-730314
	45	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER2125A	2832.6	-439053	0	0	-439053
	46	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER1699A	0	0	0	0	0
	47	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-1	ER1683A	0	0	0	0	0
	48	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-2	ER1685A	0	0	0	0	0
	49	400 KV JEERAT(WB)-NEW JEERAT(PMJTL) CKT-1	ER2101A	0	0	0	0	0
	50	401 KV JEERAT(WB)-NEW JEERAT(PMJTL) CKT-2	ER2103A	0	0	0	0	0
		TOTAL		-2291630		136788	-2155043	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVArh.w.e.f. 01/04/2021

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTs.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting ,the methodology for compusion of Reactive Charges has been changed in conformity with other RPCs.