



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति

**Eastern Regional Power Committee**  
14, गोल्फ क्लब रोड, टालीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008  
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: [www.erpc.gov.in](http://www.erpc.gov.in)

NO: ERPC/COM-II/VARH/1408

Date: 19.01.2022

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

**Sub: Provisional Reactive Energy (VARH) Charges for the period 03.01.2022-09.01.2022**

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 14.01.2022.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.  
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

**This is issued with the approval of Member Secretary.**

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)  
SUPERINTENDING ENGINEER

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 03/01/22 to 09/01/22**

**REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL**

<b>FROM</b>	<b>TO</b>	<b>AMOUNT PAYABLE (Rs.)</b>	<b>AMOUNT RECEIVABLE(Rs.)</b>	<b>AMOUNT RECEIVABLE(Final After Adjustment)(Rs.)</b>
BSPHCL	POOL	3215940	0	0
JUVNL	POOL	2208843	0	0
DVC	POOL	2140349	0	0
GRIDCO	POOL	6443753	0	0
SIKKIM	POOL	0	127782	127782
WBSETCL	POOL	2671813	0	0
<b>Total</b>		<b>16680697</b>	<b>127782</b>	<b>127782</b>

Note:

a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC

**b) Final Receivables Amount After Adjustment from the Reactive Pool are done as per Methodology Approved in the 43rd ERPC meeting held on 26.03.2021 at Kolkata.**

**SUPERINTENDING ENGINEER**

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

for the period 03/01/22 to 09/01/22

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAh (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAh (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-2904.5	450198	0	0	450198
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-884.8	137144	0	0	137144
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-3775.8	585249	0	0	585249
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-151	23405	0	0	23405
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-218	33790	0	0	33790
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	-87.6	13578	0	0	13578
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-188.5	29218	0	0	29218
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-323.4	50127	0	0	50127
	9	220 KV side of 220/132 Arah ICT-2	ER1882A	-332.6	51553	0	0	51553
	10	220 KV KHAGAULI(BSPHCL) - ARAH (PG)-I	NP8641A	-325.7	50484	0	0	50484
	11	220 KV KHAGAULI(BSPHCL) - ARAH (PG)-II	NP6060A	-566.6	87823	0	0	87823
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	-0.4	62	-301.8	-46779	-46717
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	-444.8	68944	0	0	68944
	16	220 KV NADHOKHAR(BSPHCL)- PUSAULI (PG)-2	NP8665A	-212.2	32891	0	0	32891
	17	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	ER1872A	92.7	-14369	0	0	-14369
	18	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	ER1873A	97.5	-15113	0	0	-15113
	19	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	2282.2	-353741	0	0	-353741
	20	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	2275.8	-352749	0	0	-352749
	21	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	2462.1	-381626	0	0	-381626
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	2420.5	-375178	0	0	-375178
	23	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	31.9	-4945	230.7	35758.5	30814
	24	HV side of 400/220 Patna ICT-1	ER1877A	1735.6	-269018	0	0	-269018
	25	HV side of 400/220 Patna ICT-2	ER1407A	1359	-210645	0	0	-210645
	26	HV side of 400/220 Patna ICT-3	ER1231A	1266.5	-196308	0	0	-196308
	27	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	228.1	-35356	0	0	-35356
	28	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	225.6	-34968	0	0	-34968
	29	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1622.1	251426	0	0	251426
	30	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1712.6	265453	0	0	265453
	31	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1407.9	-218225	0	0	-218225
	32	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2295.3	-355772	0	0	-355772
	33	HV side of 400/220 Darhanaga DMTCL ICT-1	ER1274A	2233.8	-346239	0	0	-346239
	34	HV side of 400/220 Darhanaga DMTCL ICT-2	ER1275A	2282.7	-353819	0	0	-353819
	35	220 KV NEW PURNEA(PG)-BEGUSARAI(BSPTCL)-I	ER1348A	2432.7	-377069	0	0	-377069
	36	220 KV NEW PURNEA(PG)-KHAGARIA(BSPTCL)	ER1376A	1961.2	-303986	0	0	-303986
	37	220 KV DUMRAON NEW (BSPHCL)- ARA(PG) LINE-1	ER1305A	106.4	-16492	0	0	-16492
	38	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	-208.5	32318	0	0	32318
	39	HV side of 400/220 KV Biharshariff (PG) ICT-4	ER1386A	-1294.1	200586	0	0	200586
	40	400 KV SIDE OF 400/220 500 MVA GAYA(PG) ICT-3	ER1442A	0	0	0	0	0
	41	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-1	ER1247A	128.7	-19949	0	0	-19949
	42	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-2	ER1243A	139.3	-21592	0	0	-21592
	43	220 KV DUMRAON NEW (BSPHCL)- ARA (PG)-2	ER1866A	105.7	-16384	0	0	-16384
	44	400 KV SIDE OF LAKHISARAI(PG) 315 MVA 400/132 ICT-3	ER1309A	215.1	-33341	0	0	-33341
	45	400 KV SIDE BANKA(PG) 400/132 KV 315 MVA ICT-3	ER1362A	159.5	-24723	0	0	-24723
	46	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-1	ER1395A	0	0	0	0	0
	47	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-2	ER1933A	0	0	0	0	0
	48	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-3	ER1934A	0	0	0	0	0
	49	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-2	ER1875A	2186.2	-338861	0	0	-338861
	50	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-1	ER1816A	2189.5	-339373	0	0	-339373
	51	400 KV HV SIDE OF 315 MVA MOTIHARI(DMTCL) ICT-3	ER1819A	0	0	0	0	0
	52	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-1	ER1806A	1811.9	-280845	0	0	-280845
	53	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-2	ER1823A	1796.7	-278489	0	0	-278489
		<b>TOTAL</b>		<b>-3204920</b>		<b>-11021</b>	<b>-3215940</b>	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-3462.1	536626	0	0	536626
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-3186	493830	0	0	493830
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-2583.2	400396	0	0	400396
	4	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	0	0	0	0	0
	5	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	5609.2	-869426	0	0	-869426
	6	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	5831.4	-903867	0	0	-903867
	7	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-2	NP8637A	917.6	-142228	0	0	-142228
	8	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-1	NP8678A	628.5	-97418	0	0	-97418
	9	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0.4	-62	29.5	4573	4511
	10	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0.2	-31	31	4805	4774
	11	220 KV RANCHI(PG)-HATIA(JUVNL)-I	NP5879A	2963.1	-459281	0	0	-459281
	12	221 KV RANCHI(PG)-HATIA(JUVNL)-II	ER1252A	2802.4	-434372	0	0	-434372
	13	222 KV RANCHI(PG)-HATIA(JUVNL)-III	NP7880A	2973	-460815	0	0	-460815
	14	223 KV RANCHI(PG)-CHANDIL(JUVNL)	NP5874A	1816.6	-281573	0	0	-281573
		<b>TOTAL</b>		<b>-2218221</b>		<b>9378</b>	<b>-2208843</b>	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-4321.2	669786	0	0	669786
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	ER1668A	457.6	-70928	0	0	-70928
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	612.4	-94922	0	0	-94922
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	ER1711A	-717	111135	0	0	111135
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	ER1717A	-895	138725	0	0	138725
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	ER1808A	-3816.3	591527	0	0	591527
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	ER1802A	5106.6	-791523	0	0	-791523
	9	400 KV MEJIA(DVC)-MAITHON(PG)	ER1659A	-2303.9	357105	0	0	357105
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1657A	-1778.2	275621	0	0	275621
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1658A	-1933.9	299755	0	0	299755
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	ER2042A	639.3	-99092	0	0	-99092
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	ER2128A	724.4	-112282	0	0	-112282
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	ER2129A	1648.8	-255564	0	0	-255564
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	ER2130A	1388.5	-215218	0	0	-215218
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-I(MAIN)	ER2046A	2151.9	-333545	0	0	-333545
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	ER2044A	0	0	0	0	0
	18	400 KV RTPS(DVC)-RANCHI(PG)	ER1653A	0	0	0	0	0
	19	400 KV RTPS(DVC)-MAITHON(PG)	ER1652A	10373	-1607815	0	0	-1607815
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	ER1656A	-2249.5	348673	0	0	348673
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	4827	-748185	0	0	-748185
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	4694.5	-727648	0	0	-727648
	23	220 KV RANCHI(PG)-RAMGARH(DVC)	ER1798A	-800.3	124047	0	0	124047
	24	221 KV RANCHI(PG)-MTPS(DVC)	ER1796A	0	0	0	0	0
		<b>TOTAL</b>		<b>-2140349</b>		<b>0</b>	<b>-2140349</b>	

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

GRIDCO	1	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-1 AND ICT-3	ER1563A	0.4	-62	0	0	-62
	2	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-2 AND ICT-4	ER1565A	-8.8	1364	0	0	1364
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	400 KV SIDE OF JEYPORE (PG) 400/220 KV ICT-1 AND ICT-3	ER1550A	1.8	-279	0	0	-279
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	1.5	-232.5	0	0	-233
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	ER1759A	142.9	-22149.5	0	0	-22150
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	119.6	-18538	0	0	-18538
	9	HV side meter of 400/220 Baripada ICT-2	ER1746A	63.4	-9827	0	0	-9827
	10	HV side meter of 400/220 Baripada ICT-3	ER1747A	0	0	0	0	0
	11	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	12	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	ER1900A	4348.6	-674033	0	0	-674033
	13	400 KV MERAMUNDALI (GRIDCO)-BOLANGIR(PG)	ER1054A	4790.1	-742465.5	0	0	-742466
	14	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)-2	ER1055A	14662.9	-2272749.5	0	0	-2272750
	15	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	ER1758A	19384	-3004520	0	0	-3004520
	16	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	0	0	0	0	0
	17	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	0	0	0	0	0
	18	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	ER1897A	-4956.4	768242	0	0	768242
	19	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	-5.2	806	-14.8	-2294	-1488
	20	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	-4.1	635.5	-15.5	-2402.5	-1767
	21	HV side of 400/220 Pandiabil ICT-1	ER1583A	4432	-686960	0	0	-686960
	22	HV side of 400/220 Pandiabil ICT-2	ER1776A	4409.4	-683457	0	0	-683457
	23	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	-1768.7	274148.5	0	0	274149
	24	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	-1812.4	280922	0	0	280922
	25	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	1.3	201.5	202
	26	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	1.5	232.5	233
	27	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	-1122.8	174034	0	0	174034
	28	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	-1133.1	175630.5	0	0	175631
		<b>TOTAL</b>		<b>-6439491</b>		<b>-4263</b>	<b>-6443753</b>	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-195.90	30365	-224.2	-34751	-4387
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-133.20	20646	119.7	18553.5	39200
	3	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	ER1490A	-375.30	58172	-74.4	-11532	46640
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	ER1489A	-370.40	57412	-71.5	-11082.5	46330
		<b>TOTAL</b>		<b>166594</b>		<b>-38812</b>	<b>127782</b>	
WBSETCL	1	400 KV JEERAT (WBSETCL) - RAJARAHAT(PG)	ER1471A	0	0	-993.4	-153977	-153977
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-1	ER1534A	559.8	-86769	0	0	-86769
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-2	ER1483A	450.1	-69766	0	0	-69766
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-2507.8	388709	0	0	388709
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-2543.6	394258	0	0	394258
	6	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	0	358391	0	0	358391
	7	132 KV SILIGURI (PG) - NBU (WBSETCL)	ER1675A	-1605.8	248899	0	0	248899
	8	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2632.1	407976	0	0	407976
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-1236.1	191596	0	0	191596
	10	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	ER1739A	7509.4	-1163957	0	0	-1163957
	11	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	NP5881A	9127.2	-1414716	0	0	-1414716
	12	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	13	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	5223.2	-809596	0	0	-809596
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	8	-1240	0	0	-1240
	15	400 KV SAGARDIGHI(WB) - FARAKKA (NTPC)-1(MAIN)	NP6482A	-2716.4	421042	0	0	421042
	16	400 KV JEERAT(PG) - SUBHASHGRAM (PG)	ER1477A	0	0	0	0	0
	17	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-64.9	10060	2.3	357	10416
	18	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-37.7	5844	-2.3	-357	5487
	19	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	-1168.8	181164	0	0	181164
	20	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	14.9	-2310	0	0	-2310
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	ER1637A	543	-84165	0	0	-84165
	22	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	148.4	-23002	0	0	-23002
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	47.3	-7332	0	0	-7332
	24	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-3	ER1486A	424.3	-65767	0	0	-65767
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-4	ER1537A	437.8	-67859	0	0	-67859
	26	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	ER1484A	710.8	-110174	0	0	-110174
	27	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	639.3	-99092	0	0	-99092
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	ER1679A	1506.3	-233477	0	0	-233477
	29	400 KV SAGARDIGHI(WB)-BERHAMPORE (PG) LINE-I	NP8723A	442.4	-68572	0	0	-68572
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE (PG) LINE-II	NP8724A	402.9	-62450	0	0	-62450
	31	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-2271.9	352145	0	0	352145
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-2263.2	350796	0	0	350796
	33	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-I	ER1040A	-137.4	21297	0	0	21297
	34	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	ER1130A	88.4	-13702	0	0	-13702
	35	400 KV GOKARNA(WB)-RAJARAHAT(PG)	ER1133A	-2155.7	334134	0	0	334134
	36	400 KV GOKARNA(WB)-PURNEA(PG)	ER1138A	-4021.2	623286	0	0	623286
	37	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	1116.3	-173027	0	0	-173027
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	1117.3	-173182	0	0	-173182
	39	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	-1307.6	202678	0	0	202678
	40	HV side of 400/220 KV RAJARAHAT(PG) ICT-1	ER1526A	0	0	0	0	0
	41	220 KV SIDE OF 50 MVA MALDA(PG) 220/132 ICT-4	ER1639A	-1771.7	274614	0	0	274614
	42	400 KV SIDE OF RAJARAHAT(PG) 400/220 500 MVA ICT-2	ER1650A	0	0	0	0	0
	43	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	5081.4	-787617	0	0	-787617
	44	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	5049.9	-782735	0	0	-782735
	45	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER2125A	3327.7	-515794	0	0	-515794
	46	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER2045A	3022.1	-468426	0	0	-468426
	47	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-1	ER1683A	0	0	0	0	0
	48	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-2	ER1685A	0	0	0	0	0
	49	400 KV JEERAT(WB)-NEW JEERAT(PMJTL) CKT-1	ER2101A	0	0	0	0	0
	50	401 KV JEERAT(WB)-NEW JEERAT(PMJTL) CKT-2	ER2103A	0	0	0	0	0
		<b>TOTAL</b>		<b>-2517836</b>		<b>-153977</b>	<b>-2671813</b>	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVArh.w.e.f. 01/04/2021

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting ,the methodology for compusion of Reactive Charges has been changed in conformity with other RPCs.