



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति
Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No. :033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/ABT-DC/86

Date: 13.04.2022

To: As per List / संलग्न सूची के अनुसार

Sub: Adj DSM charges of GRIDCO for the period from 23.10.2017 to 31.10.2018.

Sir,

Statement of Adjusted DSM charges of GRIDCO for the period from 23.10.2017 to 31.10.2018 has been issued as per methodology approved in the special meeting dated 24.02.2022 held through MS Team Platform for settlement of DSM accounts of GRIDCO due to excess energy shown in the drawal of tertiary of ICT-I of Sundergarh S/s of PGCIL due to different CT & PT ratio considered at ERLDC and actual site.

Observations, if any, may be intimated to ERPC Secretariat within a fortnight.

यदि कोई अवलोकन हो, पंद्रह दिनों के भीतर ईआरपीसी सचिवालय को सूचित किया जा सकता है।

This issues with the approval of Member Secretary.

Encl: As above

भवदीय / Yours faithfully,

(S. KEJRIWAL)
SUPERINTENDING ENGINEER

List of Addressee

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-01. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 001. (Fax 0612-2504557)
3. CE (Comml & Revenue), JBVNL, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand . (Fax : 0651-2490486 / 2400799)
4. GM-cum-CE (Trans), JUSNL, Kusai Colony, Duranda, Ranchi, Jharkhand (Fax:0651-2490486)
5. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
6. CE (SLDC), DVC, P.O.: Danesh Seikh Lane, Andul Road, Howrah - 71110 9. FAX-033-2688-5094
7. Sr. GM(PP), GRIDCO, 4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
8. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2748509)
9. Sr. General Manager(Finance), OPGC, Odisha (Fax: 06645 222225)
10. CE (Trans.), Energy & Power Deptt., Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148 / 202927)
11. CE (SLDC), WBSETCL, PO. Danesh Sheikh Lane, Howrah-109. (Fax: 033-26886232)
12. Chief (Finance), NHPC Ltd, Sector-33, Faridabad-121003 (Fax: 0129-2254668)
13. ED (Comml), NHPC Ltd, Sector-33, Faridabad-121003 (Fax No. 0129-2254668)
14. AGM (Comml), NTPC Ltd, Loknaya Jaiprakash Bhawan, 2nd floor, Dak Banglow Chowk, Fraser Road, Patna-800 001. (Fax : 0612-2230035 / 2224287 , 2211807)
15. GM (Comml), NTPC Ltd, 7 Institutional Area, Lodhi Road, New Delhi-3 (Fax: 011-24360318 / 24368417)
16. AGH (Comml), Maithon Power Ltd, MA-5, Gonga, PO: Maithon Dam-828207 (Fax: 06540-276606, 08860004758)
17. DGM (Electrical), APNRL, P.O. kandra, Behind 400kV PGCIL S/s, Tata-Kandra road, Dist: Saraikela, Kharsanwa (Jharkhand) – 832 105 (FAX: 0657 – 6628440)
18. AGM(Comml.), ER-I, Powergrid, Patna (Fax: 0612 2227630)
19. AGM(Comml.), ER-II, Powergrid, Kolkata (Fax NO. 033 2357 2827)
20. AGM(E&M), GATI Infrastructure Ltd., Sundung, Rongli, East Sikkim, Sikkim-737131(Fax: 08066885455)
21. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235809)
22. ED, NRLDC, 18A, Shaheed JSS Marg, Katwaria Sarai, New Delhi-110 016. (Fax:011-26852747)
23. GM, SRLDC, 29 Race Course Road, Bangalore-560009 (Fax : 080-22268725).
24. GM, WRLDC, MIDC Area, Marol, Andheri (E), Mumbai-490093 (Fax: 022-28235434)
25. GM, NERLDC, Dongtieh, Lower Nongrah, Laplang, Shillong-793006 (Fax:0364-2537470)
26. GM(Electrical), Ind Barath Energy Utkal Ltd., Vill: Sahajbahal P.O: Charpali-Barpali, Dist: Jharsuguda – 768211 (Fax: 0674-2532174)
27. GM(Power Sales), GMRKEL, Plot no 29, Satya Nagar, Bhubaneswar- 751 007(Fax: 0674- 2572794)
28. Head(Power Sales), JITPL, Local shopping centre, Sector-B1, Vasant kunj, New Delhi- 110 070
29. AGM, SO, NVVN, SCOPE Complex, Core-5, 1st & 2nd Floor, Lodhi Road, New Delhi-110003 (Fax: 011-24367021)
30. Head(Commercial), TPTCL, Tata Power Co Ltd, B12 & 13, 2nd Floor, Shatabdi Bhawan, Sector 4, NOIDA – 201 301 (Fax: 0120-2540085/0050)
31. ED, DANS Energy Pvt Ltd, 5th Floor, Building no.8, Tower-C, DLF Cyber City, Phase-II, GURGAON – 122 002
32. GM, Teesta Urja Limited, 2nd Floor, Vijaya Building. 17, Barakhamba Road. New Delhi – 110001 (Ph. 9810519283; 011- 46529600/46529700)
33. AGM, BRBCL, Nabinagar, Aurangabad BIHAR (Fax : 06332 233002)
34. Director, Shiga Energy Pvt. Ltd., 5th Floor, DLF Building No. 8, Tower-C, DLF Cyber City, Phase-II, Gurgaon – 122002
35. CEO, Sneha Kinetic Power Projects Pvt.Ltd. #31 -A, National Highway, Behind SNOD building,. Deorali, Gangtok, Sikkim-737102
36. ED(Commercial), PTC india Limited, 2nd Floor NBCC Tower, Bikaji Cama Palace, New Delhi-110066

EASTERN REGIONAL POWER COMMITTEE, KOLKATA
Adj DSM A/c of GRIDCO for the period 23.10.2017-31.10.2018

Month	Avg Freq of Month	PGCIL Drawl through Sundergarh Tertiary T/F (Pre Revised)	PGCIL Revised/ Corrected Drawl through Sundergarh Tertiary T/F with corrected CTR & PTR	Extra Energy Billed to Gridco	DSM Rate	Total DSM Charges Receivable by GRIDCO(Rs. In Lakhs)
A	B	C	D	E = (Difference between D & C)	F	G
	Hz	MWH	MWH	MWH	Rs/MWH	Rs. In Lakhs
Oct'17	49.96	0.000000	0.000000	0	2613.6	0
Nov'17	49.96	51.302400	12.903331	38.39906875	2613.6	1.00360
Dec'17	49.97	93.789525	23.589482	70.20004275	2405.2	1.68845
Jan'18	49.97	81.733800	20.557285	61.176515	2405.2	1.47142
Feb'18	49.97	96.881962	24.367282	72.51468025	2405.2	1.74412
Mar'18	49.96	113.320275	28.501763	84.818512	2613.6	2.21682
April'18	49.96	130.535250	32.831591	97.70365925	2613.6	2.55358
May'18	49.94	146.247413	36.783433	109.4639795	3030.4	3.31720
jun'18	49.97	140.274413	35.281141	104.993271	2405.2	2.52530
July'18	49.97	142.509375	35.843268	106.6661068	2405.2	2.56553
Aug'18	49.97	143.333475	36.050541	107.2829343	2405.2	2.58037
Sept'18	49.96	90.442435	34.837877	55.60455875	2613.6	1.45328
Oct'18	49.96	40.930230	40.930230	0	2613.6	0.00000
Total		1271.300553	362.477225	908.8233283	33143.2	23.11967

Note: The adjustment of DSM A/c of GRIDCO for the period from 23.10.2017 to 31.10.2018 has been done due to excess energy shown in the drawal of tertiary of ICT-I of Sundergarh S/s of PGCIL due to different CT & PT ratio considered at ERLDC and actual site.

SUPERINTENDING ENGINEER