



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति
Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/83

Date: 13.04.2022

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comm & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comm), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comm), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 07.03.2022-13.03.2022

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 18.03.2022.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This issues with the approval of Member Secretary.

Encl: As above/ संलग्न यथोपरी

भवदीय/Yours faithfully,

(S. KEJRIWAL)
SUPERINTENDING ENGINEER

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 07/03/22 to 13/03/22**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)	AMOUNT RECEIVABLE(Rs.)	AMOUNT RECEIVABLE(Final After Adjustment)(Rs.)
BSPHCL	POOL	1891155	0	0
JUVNL	POOL	3335213	0	0
DVC	POOL	0	549460	549460
GRIDCO	POOL	654720	0	0
SIKKIM	POOL	0	115863	115863
WBSETCL	POOL	3395477	0	0
Total		9276564	665322	665322

Note:

a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC

**b) Final Receivables Amount After Adjustment from the Reactive Pool are done as per Methodology
Approved in the 43rd ERPC meeting held on 26.03.2021 at Kolkata.**

SUPERINTENDING ENGINEER

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 07/03/22 to 13/03/22

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-668.6	103633	0	0	103633
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-230.2	35681	0	0	35681
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1149.3	178142	0	0	178142
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	14	-2170	0	0	-2170
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	11.9	-1845	0	0	-1845
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	39.9	-6185	-0.1	-15.5	-6200
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	145.3	-22522	0	0	-22522
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-16.9	2620	0	0	2620
	9	220 KV side of 220/132 Arah ICT-2	ER1882A	-18.7	2899	0	0	2899
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	0	0	0	0	0
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-53	8215	0	0	8215
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	6.2	-961	177.4	27497	26536
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	-24.2	3751	0	0	3751
	16	220 KV NADHOKHAR(BSPHCL)- PUSAULI (PG)-2	NP8665A	-979	151745	0	0	151745
	17	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	ER1872A	0	0	0	0	0
	18	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	ER1873A	0	0	0	0	0
	19	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1786.9	-276970	0	0	-276970
	20	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1772.5	-274738	0	0	-274738
	21	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1944.3	-301367	0	0	-301367
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1846.8	-286254	0	0	-286254
	23	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-266.5	41308	-47.5	-7362.5	33945
	24	HV side of 400/220 Patna ICT-1	ER1877A	333.1	-51631	0	0	-51631
	25	HV side of 400/220 Patna ICT-2	ER1407A	235.6	-36518	0	0	-36518
	26	HV side of 400/220 Patna ICT-3	ER1231A	232.1	-35976	0	0	-35976
	27	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	0	0	0	0	0
	28	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	0	0	0	0	0
	29	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1759.3	272692	0	0	272692
	30	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1857.8	287959	0	0	287959
	31	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2077.9	-322075	0	0	-322075
	32	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2081	-322555	0	0	-322555
	33	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	0	0	0	0	0
	34	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	0	0	0	0	0
	35	220 KV NEW PURNEA(PG)-BEGUSARAI(BSPTCL)-I	ER1348A	2759.7	-427754	0	0	-427754
	36	220 KV NEW PURNEA(PG)-KHAGARIA(BSPTCL)	ER1376A	1519.7	-235554	0	0	-235554
	37	220 KV DUMRAON NEW (BSPHCL)- ARA(PG) LINE-1	ER1305A	115.7	-17934	0	0	-17934
	38	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	-1189.2	184326	0	0	184326
	39	HV side of 400/220 KV Biharshariff(PG) ICT-4	ER1386A	-212.7	32969	0	0	32969
	40	400 KV SIDE OF 400/220 500 MVA GAYA(PG) ICT-3	ER1442A	0	0	0	0	0
	41	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-1	ER1247A	1.5	-233	0	0	-233
	42	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-2	ER1243A	1.1	-171	-0.7	-108.5	-279
	43	220 KV DUMRAON NEW (BSPHCL)- ARA (PG)-2	ER1866A	110.9	-17190	0	0	-17190
	44	400 KV SIDE OF LAKHISARAI(PG) 315 MVA 400/132 ICT-3	ER1309A	0	0	0	0	0
	45	400 KV SIDE BANKA(PG) 400/132 KV 315 MVA ICT-3	ER1362A	0	0	0	0	0
	46	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-1	ER1395A	0	0	0	0	0
	47	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-2	ER1933A	0	0	0	0	0
	48	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-3	ER1934A	0	0	0	0	0
	49	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-2	ER1875A	0	0	0	0	0
	50	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-1	ER1816A	0	0	0	0	0
	51	400 KV HV SIDE OF 315 MVA MOTIHARI(DMTCL) ICT-3	ER1819A	0	0	0	0	0
	52	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-1	ER1806A	884.7	-137129	0	0	-137129
	53	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-2	ER1823A	855.4	-132587	0	0	-132587
	54	220 KV PUSAULI(PG)-KARAMNASHA NEW(BSPHCL)	NP6092A	1979.3	-306792	0	0	-306792
		TOTAL			-1911166		20011	-1891155
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-357.2	55366	0	0	55366
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-43.7	6774	0	0	6774
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-102.2	15841	0	0	15841
	4	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	0	0	0	0	0
	5	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	5339.2	-827576	0	0	-827576
	6	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	6513	-1009515	0	0	-1009515
	7	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-2	NP8637A	0	0	0	0	0
	8	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-1	NP8678A	0	0	0	0	0
	9	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	0	0	0
	10	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	0	0	0
	11	220 KV RANCHI(PG)-HATIA(JUVNL)-I	NP5879A	2922.7	-453019	0	0	-453019
	12	221 KV RANCHI(PG)-HATIA(JUVNL)-II	ER1252A	2849.7	-441704	0	0	-441704
	13	222 KV RANCHI(PG)-HATIA(JUVNL)-III	NP7880A	2946.4	-456692	0	0	-456692
	14	223 KV RANCHI(PG)-CHANDIL(JUVNL)	NP5874A	1403.1	-217481	0	0	-217481
	15	400 KV RANCHI NEW(PG)-PATRATU NEW(JUVNL) LINE-1	ER1221A	24.7	-3829	0	0	-3829
	16	400 KV RANCHI NEW(PG)-PATRATU NEW(JUVNL) LINE-2	ER1230A	21.8	-3379	0	0	-3379
		TOTAL			-3335213		0	-3335213
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2966.4	459792	0	0	459792
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	ER1668A	-32.8	5084	0	0	5084
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-60.8	9424	0	0	9424
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	ER1711A	-659.4	102207	0	0	102207
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	ER1717A	-1249.2	193626	0	0	193626
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIKADA(PG)	ER1808A	-334.9	51910	0	0	51910
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	ER1802A	378.2	-58621	0	0	-58621
	9	400 KV MEJIA(DVC)-MAITHON(PG)	ER1659A	-1770.2	274381	0	0	274381
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1657A	-1671.4	259067	0	0	259067
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1658A	-1742.5	270088	0	0	270088
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	ER2042A	284.3	-44067	0	0	-44067
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	ER2128A	386.9	-59970	0	0	-59970
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	ER2129A	932.4	-144522	0	0	-144522
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	ER2130A	274.2	-42501	0	0	-42501
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-I(MAIN)	ER2046A	0	0	0	0	0
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	ER2044A	0	0	0	0	0
	18	400 KV RTPS(DVC)-RANCHI(PG)	ER1653A	-146.2	22661	0	0	22661
	19	400 KV RTPS(DVC)-MAITHON(PG)	ER1652A	1877.2	-290966	0	0	-290966
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	ER1656A	-919.3	142492	0	0	142492
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	2248.8	-348564	0	0	-348564
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	3137.5	-486313	0	0	-486313
	23	220 KV RANCHI(PG)-RAMGARH(DVC)	ER1798A	-1511.3	234252	0	0	234252
	24	221 KV RANCHI(PG)-MTPS(DVC)	ER1796A	0	0	0	0	0
		TOTAL			549460		0	549460

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-1 AND ICT-3	ER1563A	0	0	0	0	0
	2	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-2 AND ICT-4	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	400 KV SIDE OF JEYPORE (PG) 400/220 KV ICT-1 AND ICT-3	ER1550A	0	0	0	0	0
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	0	0	0	0	0
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	ER1759A	0.7	-108.5	0	0	-109
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	0	0	0	0	0
	9	HV side meter of 400/220 Baripada ICT-2	ER1746A	0	0	0	0	0
	10	HV side meter of 400/220 Baripada ICT-3	ER1747A	0	0	0	0	0
	11	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	12	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	ER1900A	2470.1	-382865.5	0	0	-382866
	13	400 KV MERAMUNDALI (GRIDCO)-BOLANGIR(PG)	ER1054A	95.6	-14818	0	0	-14818
	14	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)-2	ER1055A	3973.5	-615892.5	0	0	-615893
	15	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	ER1758A	134.5	-20847.5	0	0	-20848
	16	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	ER2072A	-111.7	17313.5	0	0	17314
	17	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	ER2071A	-37.4	5797	0	0	5797
	18	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	ER1897A	-2205.4	341837	0	0	341837
	19	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	-7	1085	0	0	1085
	20	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	-2.2	341	0	0	341
	21	HV side of 400/220 Pandiabil ICT-1	ER1583A	444.4	-68882	0	0	-68882
	22	HV side of 400/220 Pandiabil ICT-2	ER1776A	413	-64015	0	0	-64015
	23	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	0	0	0	0	0
	24	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	0	0	0	0	0
	25	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	26	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	27	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	-469.9	72834.5	0	0	72835
	28	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	-474.2	73501	0	0	73501
TOTAL					-654720		0	-654720
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-91.90	14245	0	0	14245
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-129.20	20026	0	0	20026
	3	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	ER1490A	-263.80	40889	0	0	40889
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	ER1489A	-262.60	40703	0	0	40703
TOTAL					115863		0	115863
WBSETCL	1	400 KV JEERAT (WBSETCL) - RAJARAHAT(PG)	ER1471A	0	0	-4.4	-682	-682
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	0	0	0	0	0
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	0	0	0	0	0
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1752.1	271576	0	0	271576
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1847.1	286301	0	0	286301
	6	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-1589	246295	0	0	246295
	7	132 KV SILIGURI (PG) - NBU (WBSETCL)	ER1675A	-1054.1	163386	0	0	163386
	8	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2662.2	412641	0	0	412641
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-753.3	116762	0	0	116762
	10	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	ER1739A	7087.3	-1098532	0	0	-1098532
	11	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	ER2039A	10394	-1611070	0	0	-1611070
	12	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	13	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	ER2109A	0	0	0	0	0
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	ER2111A	0	0	0	0	0
	15	400 KV SAGARDIGHI(WB) - FARAKKA (NTPC)-1(MAIN)	NP6482A	0	0	0	0	0
	16	400 KV JEERAT(PG) - SUBHASGRAM (PG)	ER1477A	0	0	0	0	0
	17	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-111	17205	0	0	17205
	18	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	54.7	-8479	0	0	-8479
	19	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	0	0	0	0	0
	20	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	0	0	0	0	0
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	ER1637A	1.5	-233	0	0	-233
	22	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-1312.2	203391	0	0	203391
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-264.9	41060	0	0	41060
	24	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	ER1486A	0	0	0	0	0
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	ER1537A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	ER1484A	0	0	0	0	0
	27	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	0.4	-62	0	0	-62
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	ER1679A	538.2	-83421	0	0	-83421
	29	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-I	NP8723A	0	0	0	0	0
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-II	NP8724A	0	0	0	0	0
	31	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-33.5	5193	0	0	5193
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	0	0	0	0	0
	33	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-I	ER1040A	105.9	-16415	0	0	-16415
	34	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	ER1130A	246.6	-38223	0	0	-38223
	35	400 KV GOKARNA(WB)-RAJARHAT(PG)	ER1133A	0	0	0	0	0
	36	400 KV GOKARNA(WB)-PURNEA(PG)	ER1138A	0	0	0	0	0
	37	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	678.7	-105199	0	0	-105199
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	714.4	-110732	0	0	-110732
	39	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	0	0	0	0	0
	40	HV side of 400/220 KV RAJARHAT(PG) ICT-1	ER1526A	0	0	0	0	0
	41	220 KV SIDE OF 50 MVA MALDA(PG) 220/132 ICT-4	ER1639A	-1148.1	177956	0	0	177956
	42	400 KV SIDE OF RAJARHAT(PG) 400/220 500 MVA ICT-2	ER1650A	0	0	0	0	0
	43	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	4201.9	-651295	0	0	-651295
	44	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	4058.5	-629068	0	0	-629068
	45	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER2125A	3210.4	-497612	0	0	-497612
	46	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER2045A	3136.9	-486220	0	0	-486220
	47	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-1	ER1683A	0	0	0	0	0
	48	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-2	ER1685A	0	0	0	0	0
	49	400 KV JEERAT(WB)-NEW JEERAT(PMJTL) CKT-1	ER2101A	0	0	0	0	0
	50	401 KV JEERAT(WB)-NEW JEERAT(PMJTL) CKT-2	ER2103A	0	0	0	0	0
TOTAL					-3394795		-682	-3395477

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVArH,w.e.f. 01/04/2021

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting ,the methodology for compauion of Reactive Charges has been changed in conformity with other RPCs.