



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टालीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/144

Date: 29.04.2022

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 11.04.2022-17.04.2022

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 22.04.2022.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This issues with the approval of Member Secretary.

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)
SUPERINTENDING ENGINEER

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 11/04/22 to 17/04/22**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)	AMOUNT RECEIVABLE(Rs.)	AMOUNT RECEIVABLE(Final After Adjustment)(Rs.)
BSPHCL	POOL	88320	0	0
JUVNL	POOL	807616	0	0
DVC	POOL	110848	0	0
GRIDCO	POOL	6000	0	0
SIKKIM	POOL	0	14752	14752
WBSETCL	POOL	1172112	0	0
Total		2184896	14752	14752

Note:

a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC

b) Final Receivables Amount After Adjustment from the Reactive Pool are done as per Methodology Approved in the 43rd ERPC meeting held on 26.03.2021 at Kolkata.

SUPERINTENDING ENGINEER

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 11/04/22 to 17/04/22

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAh (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAh (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-130.7	20912	0	0	20912
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-26.2	4192	0	0	4192
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-229.9	36784	0	0	36784
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	0	0	-80.4	-12864	-12864
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	0	0	-8.6	-1376	-1376
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	0	0	-56.8	-9088	-9088
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-200	32000	0	0	32000
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	0	0	-2.8	-448	-448
	9	220 KV side of 220/132 Arah ICT-2	ER1882A	0	0	-2.5	-400	-400
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	0	0	-0.3	-48	-48
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-2.6	416	0	0	416
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	43.1	-6896	214.6	34336	27440
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	0	0	-3.4	-544	-544
	16	220 KV NADHOKHAR(BSPHCL)- PUSAULI (PG)-2	NP8665A	-349.6	55936	0	0	55936
	17	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	ER1872A	0	0	0	0	0
	18	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	ER1873A	0	0	0	0	0
	19	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	596.1	-95376	0	0	-95376
	20	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	575.1	-92016	0	0	-92016
	21	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	650.2	-104032	0	0	-104032
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	574.4	-91904	0	0	-91904
	23	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-83.4	13344	-68.7	-10992	2352
	24	HV side of 400/220 Patna ICT-1	ER1877A	-453.3	72528	0	0	72528
	25	HV side of 400/220 Patna ICT-2	ER1407A	-539.6	86336	0	0	86336
	26	HV side of 400/220 Patna ICT-3	ER1231A	-511.6	81856	0	0	81856
	27	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	0	0	0	0	0
	28	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	0	0	0	0	0
	29	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-3306.4	529024	0	0	529024
	30	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-2915	466400	0	0	466400
	31	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1570.6	-251296	0	0	-251296
	32	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1561.2	-249792	0	0	-249792
	33	HV side of 400/220 Darbhanga DMTCL ICT-1	ER1274A	0.4	-64	0	0	-64
	34	HV side of 400/220 Darbhanga DMTCL ICT-2	ER1275A	0.4	-64	0	0	-64
	35	220 KV NEW PURNEA(PG)-BEGUSARAI(BSPTCL)-I	ER1348A	1461.2	-233792	0	0	-233792
	36	220 KV NEW PURNEA(PG)-KHAGARIA(BSPTCL)	ER1376A	19.5	-3120	0	0	-3120
	37	220 KV DUMRAON NEW (BSPHCL)- ARA(PG) LINE-1	ER1305A	54	-8640	0	0	-8640
	38	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	-453.6	72576	0	0	72576
	39	HV side of 400/220 KV Biharsharif(PG) ICT-4	ER1386A	-38.9	6224	0	0	6224
	40	400 KV SIDE OF 400/220 500 MVA GAYA(PG) ICT-3	ER1442A	0	0	0	0	0
	41	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-1	ER1247A	-74.3	11888	0	0	11888
	42	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-2	ER1243A	-36	5760	0	0	5760
	43	220 KV DUMRAON NEW (BSPHCL)- ARA (PG)-2	ER1866A	52.6	-8416	0	0	-8416
	44	400 KV SIDE OF LAKHISARAI(PG) 315 MVA 400/132 ICT-3	ER1309A	0	0	0	0	0
	45	400 KV SIDE BANKA(PG) 400/132 KV 315 MVA ICT-3	ER1362A	0	0	0	0	0
	46	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-1	ER1395A	0	0	0	0	0
	47	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-2	ER1933A	0	0	0	0	0
	48	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-3	ER1934A	0	0	0	0	0
	49	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-2	ER1875A	16.4	-2624	0	0	-2624
	50	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-1	ER1816A	16.4	-2624	0	0	-2624
	51	400 KV HV SIDE OF 315 MVA MOTIHARI(DMTCL) ICT-3	ER1819A	0	0	0	0	0
	52	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-1	ER1806A	732	-117120	0	0	-117120
	53	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-2	ER1823A	669.9	-107184	0	0	-107184
	54	220 KV PUSAULI(PG)-KARAMNASHA NEW(BSPHCL)	NP6092A	813.4	-130144	0	0	-130144
	55	400 KV NAUBATPUR(BGCL)-PATNA(PG)-1	ER1879A	245.1	-39216	0	0	-39216
	56	401 KV NAUBATPUR(BGCL)-PATNA(PG)-2	ER1848A	242.2	-38752	0	0	-38752
		TOTAL			-86896		-1424	-88320
JUVNL	1	HV side meter of 400/220 Jamshepur ICT-1	NP6106A	-550	88000	0	0	88000
	2	HV side meter of 400/220 Jamshepur ICT-2	NP6105A	-237.6	38016	0	0	38016
	3	HV side meter of 400/220 Jamshepur ICT- 3	ER1297A	-340.6	54496	0	0	54496
	4	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	0	0	0	0	0
	5	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	0.6	-96	0	0	-96
	6	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	101.4	-16224	0	0	-16224
	7	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-2	NP8637A	0	0	0	0	0
	8	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-1	NP8678A	0	0	0	0	0
	9	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	-0.2	-32	-32
	10	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	0.2	32	32
	11	220 KV RANCHI(PG)-HATIA(JUVNL)-I	NP5879A	1428.4	-228544	0	0	-228544
	12	221 KV RANCHI(PG)-HATIA(JUVNL)-II	ER1252A	1704.9	-272784	0	0	-272784
	13	222 KV RANCHI(PG)-HATIA(JUVNL)-III	NP7880A	2213.9	-354224	0	0	-354224
	14	223 KV RANCHI(PG)-CHANDIL(JUVNL)	NP5874A	726.6	-116256	0	0	-116256
	15	400 KV RANCHI NEW(PG)-PATRATU NEW(JUVNL) LINE-1	ER1221A	0	0	0	0	0
	16	400 KV RANCHI NEW(PG)-PATRATU NEW(JUVNL) LINE-2	ER1230A	0	0	0	0	0
		TOTAL			-807616	0	-807616	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-199	31840	0	0	31840
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	ER1668A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	0	0	0	0	0
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	ER1711A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	ER1717A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIKADA(PG)	ER1808A	-1162.6	186016	0	0	186016
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	ER1802A	883.2	-141312	0	0	-141312
	9	400 KV MEJIA(DVC)-MAITHON(PG)	ER1659A	1.5	-240	0	0	-240
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1657A	21.8	-3488	0	0	-3488
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1658A	16	-2560	0	0	-2560
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	ER2042A	5.8	-928	0	0	-928
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	ER2128A	24.7	-3952	0	0	-3952
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	ER2129A	142.5	-22800	0	0	-22800
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	ER2130A	5.8	-928	0	0	-928
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-I(MAIN)	ER2046A	-1622.6	259616	0	0	259616
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	ER2044A	0	0	0	0	0
	18	400 KV RTPS(DVC)-RANCHI(PG)	ER1653A	0	0	0	0	0
	19	400 KV RTPS(DVC)-MAITHON(PG)	ER1652A	2907.6	-465216	0	0	-465216
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	ER1656A	-2.9	464	0	0	464
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	170.8	-27328	0	0	-27328
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	490	-78400	0	0	-78400
	23	220 KV RANCHI(PG)-RAMGARH(DVC)	ER1798A	-989.8	158368	0	0	158368
	24	221 KV RANCHI(PG)-MTPS(DVC)	ER1796A	0	0	0	0	0
		TOTAL			-110848	0	-110848	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-1 AND ICT-3	ER1563A	0	0	0	0	0
	2	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-2 AND ICT-4	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	400 KV SIDE OF JEYPORE (PG) 400/220 KV ICT-1 AND ICT-3	ER2062A	429.3	-68688	0	0	-68688
	6	HV side meter of 400/220 Jeyore ICT-2	ER1571A	120	-19200	0	0	-19200
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H)	ER1759A	88.3	-14128	0	0	-14128
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	0	0	0	0	0
	9	HV side meter of 400/220 Baripada ICT-2	ER1746A	0	0	0	0	0
	10	HV side meter of 400/220 Baripada ICT-3	ER1747A	0	0	0	0	0
	11	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	12	400 KV DUBURI (GRIDCO) - BARIPADA(PG)	ER1900A	-1314.1	210256	0	0	210256
	13	400 KV MERAMUNDALI (GRIDCO)-BOLANGIR(PG)	ER1054A	309.1	-49456	0	0	-49456
	14	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)-2	ER1055A	4.7	-752	0	0	-752
	15	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	ER1758A	0	0	0	0	0
	16	400 KV MENDHASAL (GRIDCO) - PANDIABIL(PG)-I	ER2072A	11.6	-1856	0.7	112	-1744
	17	400 KV MENDHASAL (GRIDCO) - PANDIABIL(PG)-II	ER2071A	23.6	-3776	0	0	-3776
	18	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	ER1897A	-7.6	1216	-403.5	-64560	-63344
	19	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	-14.6	2336	0	0	2336
	20	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	-9.8	1568	0	0	1568
	21	HV side of 400/220 Pandiabil ICT-1	ER1583A	2.9	-464	0	0	-464
	22	HV side of 400/220 Pandiabil ICT-2	ER1776A	2.2	-352	0	0	-352
	23	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	0	0	0	0	0
	24	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	0	0	0	0	0
	25	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	26	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	27	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	-5.1	816	0	0	816
	28	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	-5.8	928	0	0	928
		TOTAL		58448		-64448	-6000	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-34.90	5584	-11.4	-1824	3760
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-12.70	2032	0	0	2032
	3	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	ER1490A	-28.50	4560	0	0	4560
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	ER1489A	-27.50	4400	0	0	4400
		TOTAL		16576		-1824	14752	
WBSETCL	1	400 KV JEERAT (WBSETCL) - RAJARAHAT(PG)	ER1471A	0	0	56	8960	8960
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-1	ER1534A	0	0	-189.3	-30288	-30288
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-2	ER1483A	0	0	-183.1	-29296	-29296
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-297.5	47600	0	0	47600
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-342.4	54784	0	0	54784
	6	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-128.5	20560	0	0	20560
	7	132 KV SILIGURI (PG) - NBU (WBSETCL)	ER1675A	-199.7	31952	0	0	31952
	8	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-1947.1	311536	0	0	311536
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-1	160	0	0	160
	10	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	ER1739A	2827.2	-452352	0	0	-452352
	11	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	ER2039A	4566.5	-730640	0	0	-730640
	12	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	13	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	ER2109A	956.4	-153024	0	0	-153024
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	ER2111A	0	0	0	0	0
	15	400 KV SAGARDIGHI(WB) - FARAKKA (NTPC)-1(MAIN)	NP6482A	0	0	0	0	0
	16	400 KV JEERAT(PG) - SUBHASHGRAM (PG)	ER1477A	0	0	0	0	0
	17	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-8.6	1376	0.1	16	1392
	18	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-35.8	5728	0	0	5728
	19	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	0.7	-112	0	0	-112
	20	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	0	0	0	0	0
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	ER1637A	0	0	0	0	0
	22	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-576.5	92240	0	0	92240
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-3.2	512	0	0	512
	24	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-3	ER1486A	0	0	-177.3	-28368	-28368
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-4	ER1537A	0	0	-167.8	-26848	-26848
	26	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	ER1484A	-0.4	64	-2.2	-352	-288
	27	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	-5.8	928	0	0	928
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	ER1679A	132.6	-21216	0	0	-21216
	29	400 KV SAGARDIGHI(WB)-BERHAMPORE (PG) LINE-I	NP8723A	0	0	0	0	0
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE (PG) LINE-II	NP8724A	0	0	0	0	0
	31	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-148.4	23744	0	0	23744
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-105.4	16864	0	0	16864
	33	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-I	ER1040A	742.8	-118848	0	0	-118848
	34	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	ER1130A	698.2	-111712	0	0	-111712
	35	400 KV GOKARNA(WB)-RAJARAHAT(PG)	ER1133A	0	0	0	0	0
	36	400 KV GOKARNA(WB)-PURNEA(PG)	ER1138A	0	0	0	0	0
	37	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	61.7	-9872	0	0	-9872
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	14.9	-2384	0	0	-2384
	39	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	0	0	0	0	0
	40	HV side of 400/220 KV RAJARAHAT(PG) ICT-1	ER1526A	0	0	0	0	0
	41	220 KV SIDE OF 50 MVA MALDA(PG) 220/132 ICT-4	ER1639A	-181.6	29056	0	0	29056
	42	400 KV SIDE OF RAJARAHAT(PG) 400/220 500 MVA ICT-2	ER1650A	0	0	-2.2	-352	-352
	43	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	146.4	-23424	0	0	-23424
	44	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	139.3	-22288	0	0	-22288
	45	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER2125A	182.3	-29168	0	0	-29168
	46	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER2045A	172.8	-27648	0	0	-27648
	47	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-1	ER1683A	0	0	0	0	0
	48	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-2	ER1685A	0	0	0	0	0
	49	400 KV JEERAT(WB)-NEW JEERAT(PMJTL) CKT-1	ER2101A	0	0	0	0	0
	50	401 KV JEERAT(WB)-NEW JEERAT(PMJTL) CKT-2	ER2103A	0	0	0	0	0
		TOTAL		-1065584		-106528	-1171212	

Note: 1) Rate of Reactive Energy Charge has been considered @ 16 paise/KVArh.w.e.f. 01/04/2022

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting ,the methodology for compusion of Reactive Charges has been changed in conformity with other RPCs.