



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टालीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/85

Date: 13.04.2022

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 21.03.2022-27.03.2022

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 01.04.2022.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This issues with the approval of Member Secretary.

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)
SUPERINTENDING ENGINEER

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 21/03/22 to 27/03/22**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)	AMOUNT RECEIVABLE(Rs.)	AMOUNT RECEIVABLE(Final After Adjustment)(Rs.)
BSPHCL	POOL	0	336567	336567
JUVNL	POOL	2373190	0	0
DVC	POOL	522939	0	0
GRIDCO	POOL	0	47616	47616
SIKKIM	POOL	0	53568	53568
WBSETCL	POOL	2808817	0	0
Total		5704946	437751	437751

Note:

a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC

b) Final Receivables Amount After Adjustment from the Reactive Pool are done as per Methodology Approved in the 43rd ERPC meeting held on 26.03.2021 at Kolkata.

SUPERINTENDING ENGINEER

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 21/03/22 to 27/03/22

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAh (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAh (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-361.3	56002	0	0	56002
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-321.8	49879	0	0	49879
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-711.9	110345	0	0	110345
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	0	0	-3.8	-589	-589
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-0.6	93	0	0	93
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	0	0	-2.2	-341	-341
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-902.6	139903	0	0	139903
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-19	2945	0	0	2945
	9	220 KV side of 220/132 Arah ICT-2	ER1882A	-19.7	3054	0	0	3054
	10	220 KV KHAGAULI(BSPHCL) - ARAH (PG)-I	NP8641A	-4.8	744	0	0	744
	11	220 KV KHAGAULI(BSPHCL) - ARAH (PG)-II	NP6060A	-70.3	10890	0	0	10890
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	0	0	-152.4	-23622	-23622
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	-28	4340	0	0	4340
	16	220 KV NADHOKHAR(BSPHCL)- PUSAULI (PG)-2	NP8665A	-1166.2	180761	0	0	180761
	17	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	ER1872A	0	0	0	0	0
	18	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	ER1873A	0	0	0	0	0
	19	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	0	0	0	0	0
	20	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	980.2	-151931	0	0	-151931
	21	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1075.3	-166672	0	0	-166672
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1025	-158875	0	0	-158875
	23	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	3.6	-558	59	9145	8587
	24	HV side of 400/220 Patna ICT-1	ER1877A	-113	17515	0	0	17515
	25	HV side of 400/220 Patna ICT-2	ER1407A	-189.5	29373	0	0	29373
	26	HV side of 400/220 Patna ICT-3	ER1231A	-178.5	27668	0	0	27668
	27	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	0	0	0	0	0
	28	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	0	0	0	0	0
	29	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-2989	463295	0	0	463295
	30	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-3015.1	467341	0	0	467341
	31	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1695.1	-262741	0	0	-262741
	32	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1685.5	-261253	0	0	-261253
	33	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	68.8	-10664	2.9	449.5	-10215
	34	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	71.7	-11114	2.5	387.5	-10726
	35	220 KV NEW PURNEA(PG)-BEGUSARAI(BSPTCL)-I	ER1348A	2044.2	-316851	0	0	-316851
	36	220 KV NEW PURNEA(PG)-KHAGARIA(BSPTCL)	ER1376A	457.5	-70913	0	0	-70913
	37	220 KV DUMRAON NEW (BSPHCL)- ARA(PG) LINE-1	ER1305A	44.8	-6944	0	0	-6944
	38	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	-1379.1	213761	0	0	213761
	39	HV side of 400/220 KV Biharshariff(PG) ICT-4	ER1386A	-414.2	64201	0	0	64201
	40	400 KV SIDE OF 400/220 500 MVA GAYA(PG) ICT-3	ER1442A	0	0	0	0	0
	41	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-1	ER1247A	-601.2	93186	-1.7	-263.5	92923
	42	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-2	ER1243A	-577.6	89528	-1.7	-263.5	89265
	43	220 KV DUMRAON NEW (BSPHCL)- ARA (PG)-2	ER1866A	45	-6975	0	0	-6975
	44	400 KV SIDE OF LAKHISARAI(PG) 315 MVA 400/132 ICT-3	ER1309A	0	0	0	0	0
	45	400 KV SIDE BANKA(PG) 400/132 KV 315 MVA ICT-3	ER1362A	0	0	0	0	0
	46	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-1	ER1395A	0	0	0	0	0
	47	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-2	ER1933A	0	0	0	0	0
	48	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-3	ER1934A	0	0	0	0	0
	49	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-2	ER1875A	293.4	-45477	4.4	682	-44795
	50	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-1	ER1816A	297.8	-46159	5.5	852.5	-45307
	51	400 KV HV SIDE OF 315 MVA MOTIHARI(DMTCL) ICT-3	ER1819A	0	0	0	0	0
	52	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-1	ER1806A	29.4	-4557	0	0	-4557
	53	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-2	ER1823A	35	-5425	0	0	-5425
	54	220 KV PUSAULI(PG)-KARAMNANA NEW(BSPHCL)	NP6092A	952.2	-147591	0	0	-147591
		TOTAL		350130		-13563	336567	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-35.7	5534	0	0	5534
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-4.7	729	0	0	729
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-8.8	1364	0	0	1364
	4	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	0	0	0	0	0
	5	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	1882.8	-291834	0	0	-291834
	6	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	3700.4	-573562	0	0	-573562
	7	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-2	NP8637A	0	0	0	0	0
	8	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-1	NP8678A	0	0	0	0	0
	9	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	0	0	0
	10	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	0	0	0
	11	220 KV RANCHI(PG)-HATIA(JUVNL)-I	NP5879A	2689.3	-416842	0	0	-416842
	12	221 KV RANCHI(PG)-HATIA(JUVNL)-II	ER1252A	2750.3	-426297	0	0	-426297
	13	222 KV RANCHI(PG)-HATIA(JUVNL)-III	NP7880A	2928.3	-453887	0	0	-453887
	14	223 KV RANCHI(PG)-CHANDIL(JUVNL)	NP5874A	1409	-218395	0	0	-218395
	15	400 KV RANCHI NEW (PG)-PATRATU NEW(JUVNL) LINE-1	ER1221A	0	0	0	0	0
	16	400 KV RANCHI NEW (PG)-PATRATU NEW(JUVNL) LINE-2	ER1230A	0	0	0	0	0
		TOTAL		-2373190		0	-2373190	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2580.2	399931	0	0	399931
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	ER1668A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	0.2	-31	0	0	-31
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	ER1711A	-1.2	186	0	0	186
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	ER1717A	-22.2	3441	0	0	3441
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIKADA(PG)	ER1808A	-495.9	76865	0	0	76865
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	ER1802A	306.2	-47461	0	0	-47461
	9	400 KV MEJIA(DVC)-MAITHON(PG)	ER1659A	-86.6	13423	0	0	13423
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1657A	-213.1	33031	0	0	33031
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1658A	-239.2	37076	0	0	37076
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	ER2042A	170.9	-26490	0	0	-26490
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	ER2128A	246.4	-38192	0	0	-38192
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	ER2129A	733.9	-113755	0	0	-113755
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	ER2130A	290.2	-44981	0	0	-44981
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-I(MAIN)	ER2046A	-396.4	61442	0	0	61442
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	ER2044A	0	0	0	0	0
	18	400 KV RTPS(DVC)-RANCHI(PG)	ER1653A	-8.8	1364	0	0	1364
	19	400 KV RTPS(DVC)-MAITHON(PG)	ER1652A	4162.2	-645141	0	0	-645141
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	ER1656A	-11.6	1798	0	0	1798
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	1204.4	-186682	0	0	-186682
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	2103.2	-325996	0	0	-325996
	23	220 KV RANCHI(PG)-RAMGARH(DVC)	ER1798A	-1788.6	277233	0	0	277233
24	221 KV RANCHI(PG)-MTPS(DVC)	ER1796A	0	0	0	0	0	
		TOTAL		-522939		0	-522939	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-1 AND ICT-3	ER1563A	0	0	0	0	0
	2	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-2 AND ICT-4	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	400 KV SIDE OF JEYPORE (PG) 400/220 KV ICT-1 AND ICT-3	ER1550A	0	0	59.6	9238	9238
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	-20.7	3208.5	0	0	3209
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H)	ER1759A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	0	0	0	0	0
	9	HV side meter of 400/220 Baripada ICT-2	ER1746A	0	0	0	0	0
	10	HV side meter of 400/220 Baripada ICT-3	ER1747A	0	0	0	0	0
	11	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	12	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	ER1900A	-545.8	84599	0	0	84599
	13	400 KV MERAMUNDALI (GRIDCO)-BOLANGIR(PG)	ER1054A	0	0	0	0	0
	14	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)-2	ER1055A	1.1	-170.5	0	0	-171
	15	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	ER1758A	0	0	0	0	0
	16	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	ER2072A	0	0	0	0	0
	17	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	ER2071A	0	0	0	0	0
	18	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	ER1897A	-9.9	1534.5	0	0	1535
	19	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	-164.3	-25466.5	-25467
	20	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	-163.6	-25358	-25358
	21	HV side of 400/220 Pandiabil ICT-1	ER1583A	0	0	0	0	0
	22	HV side of 400/220 Pandiabil ICT-2	ER1776A	0	0	0	0	0
	23	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	0	0	0	0	0
	24	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	0	0	0	0	0
	25	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	26	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0.2	31	31
	27	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	0	0	0	0	0
	28	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	0	0	0	0	0
		TOTAL		89172		-41556	47616	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-76.20	11811	0	0	11811
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-73.00	11315	-10.2	-1581	9734
	3	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	ER1490A	-102.10	15826	0	0	15826
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	ER1489A	-104.50	16198	0	0	16198
		TOTAL		55149		-1581	53568	
WBSETCL	1	400 KV JEERAT (WBSETCL) - RAJARAHAT(PG)	ER1471A	0	0	499.6	77438	77438
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-1	ER1534A	2.4	-372	-55.9	-8665	-9037
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-2	ER1483A	0	0	-5818.3	-901837	-901837
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-462.2	71641	0	0	71641
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-518.3	80337	0	0	80337
	6	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-569	88195	0	0	88195
	7	132 KV SILIGURI (PG) - NBU (WBSETCL)	ER1675A	-520.6	80693	0	0	80693
	8	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2191.1	339621	0	0	339621
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-24.8	3844	0	0	3844
	10	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	ER1739A	3793.9	-588055	0	0	-588055
	11	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	ER2039A	5273.3	-817362	0	0	-817362
	12	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	13	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	ER2109A	4254.6	-659463	0	0	-659463
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	ER2111A	3.3	-512	0	0	-512
	15	400 KV SAGARDIGHI(WB) - FARAKKA (NTPC)-1(MAIN)	NP6482A	-1.5	233	0	0	233
	16	400 KV JEERAT(PG) - SUBHASHGRAM (PG)	ER1477A	0	0	5.1	791	791
	17	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-73.7	11424	0	0	11424
	18	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	6.4	-992	0	0	-992
	19	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	-0.7	109	0	0	109
	20	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	2.6	-403	0	0	-403
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	ER1637A	10.6	-1643	0	0	-1643
	22	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-344.6	53413	0	0	53413
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-17.9	2775	0	0	2775
	24	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-3	ER1486A	1.1	-171	-63.3	-9812	-9882
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-4	ER1537A	1.1	-171	-55.4	-8587	-8758
	26	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	ER1484A	2.2	-341	-95.7	-14834	-15175
	27	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	-10.9	1690	118.9	18430	20119
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	ER1679A	77.4	-11997	0	0	-11997
	29	400 KV SAGARDIGHI(WB)-BERHAMPORE (PG) LINE-I	NP8723A	0	0	0	0	0
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE (PG) LINE-II	NP8724A	0	0	0	0	0
	31	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-14.5	2248	0	0	2248
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-1.5	233	0	0	233
	33	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-I	ER1040A	927.2	-143716	0	0	-143716
	34	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	ER1130A	1360.4	-210862	0	0	-210862
	35	400 KV GOKARNA(WB)-RAJARHAT(PG)	ER1133A	0	0	0	0	0
	36	400 KV GOKARNA(WB)-PURNEA(PG)	ER1138A	0	0	0	0	0
	37	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	120.2	-18631	0	0	-18631
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	48	-7440	0	0	-7440
	39	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	0	0	0	0	0
	40	HV side of 400/220 KV RAJARHAT(PG) ICT-1	ER1526A	0	0	-10.2	-1581	-1581
	41	220 KV SIDE OF 50 MVA MALDA(PG) 220/132 ICT-4	ER1639A	-329.5	51073	0	0	51073
	42	400 KV SIDE OF RAJARHAT(PG) 400/220 500 MVA ICT-2	ER1650A	0	0	-10.9	-1690	-1690
	43	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	373.1	-57831	0	0	-57831
	44	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	264.4	-40982	0	0	-40982
	45	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER2125A	612.1	-94876	0	0	-94876
	46	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER2045A	582.9	-90350	0	0	-90350
	47	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-1	ER1683A	0	0	0	0	0
	48	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-2	ER1685A	0	0	0	0	0
	49	400 KV JEERAT(WB)-NEW JEERAT(PMJTL) CKT-1	ER2101A	0	0	1.1	171	171
	50	401 KV JEERAT(WB)-NEW JEERAT(PMJTL) CKT-2	ER2103A	0	0	0	0	0
		TOTAL		-1958642		-850175	-2808817	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVArh.w.e.f. 01/04/2021

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting ,the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.