



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति
Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/142

Date: 29.04.2022

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comm & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comm), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comm), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 28.03.2022-03.04.2022

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 08.04.2022.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This issues with the approval of Member Secretary.

Encl: As above/ संलग्न यथोपरी

भवदीय/Yours faithfully,

(S. KEJRIWAL)
SUPERINTENDING ENGINEER

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 28/03/22 to 03/04/22**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)	AMOUNT RECEIVABLE(Rs.)	AMOUNT RECEIVABLE(Final After Adjustment)(Rs.)
BSPHCL	POOL	402993	0	0
JUVNL	POOL	1389532	0	0
DVC	POOL	1082436	0	0
GRIDCO	POOL	45930	0	0
SIKKIM	POOL	0	62192	62192
WBSETCL	POOL	1843877	0	0
Total		4764767	62192	62192

Note:

a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC

**b) Final Receivables Amount After Adjustment from the Reactive Pool are done as per Methodology
Approved in the 43rd ERPC meeting held on 26.03.2021 at Kolkata.**

SUPERINTENDING ENGINEER

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 28/03/22 to 31/03/22

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-1.3	202	0	0	202
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-2.7	419	0	0	419
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-58.7	9099	0	0	9099
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	0	0	0	0	0
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-0.6	93	0	0	93
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	0	0	0	0	0
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-1049.4	162657	0	0	162657
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	0	0	0	0	0
	9	220 KV side of 220/132 Arah ICT-2	ER1882A	0	0	0	0	0
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	0	0	0	0	0
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-1.8	279	0	0	279
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	27	-4185	-168.2	-26071	-30256
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	0	0	0	0	0
	16	220 KV NADHOKHAR(BSPHCL)- PUSAULI (PG)-2	NP8665A	-365.3	56622	0	0	56622
	17	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	ER1872A	0	0	0	0	0
	18	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	ER1873A	0	0	0	0	0
	19	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	789.1	-122311	0	0	-122311
	20	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	780.8	-121024	0	0	-121024
	21	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	853.1	-132231	0	0	-132231
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	818.5	-126868	0	0	-126868
	23	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-83.7	12974	76.5	11857.5	24831
	24	HV side of 400/220 Patna ICT-1	ER1877A	-72.7	11269	0	0	11269
	25	HV side of 400/220 Patna ICT-2	ER1407A	-102.6	15903	0	0	15903
	26	HV side of 400/220 Patna ICT-3	ER1231A	-100.7	15609	0	0	15609
	27	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	0	0	0	0	0
	28	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	0	0	0	0	0
	29	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1471	228005	0	0	228005
	30	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1481.1	229571	0	0	229571
	31	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1249.3	-193642	0	0	-193642
	32	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1248.8	-193564	0	0	-193564
	33	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	2.2	-341	0	0	-341
	34	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	4.7	-729	0	0	-729
	35	220 KV NEW PURNEA(PG)-BEGUSARAI(BSPTCL)-I	ER1348A	1574.2	-244001	0	0	-244001
	36	220 KV NEW PURNEA(PG)-KHAGARIA(BSPTCL)	ER1376A	408	-63240	0	0	-63240
	37	220 KV DUMRAON NEW (BSPHCL)- ARA(PG) LINE-1	ER1305A	1	-155	0	0	-155
	38	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	-443.5	68743	0	0	68743
	39	HV side of 400/220 KV Biharshariff(PG) ICT-4	ER1386A	0	0	0	0	0
	40	400 KV SIDE OF 400/220 500 MVA GAYA(PG) ICT-3	ER1442A	0	0	0	0	0
	41	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-1	ER1247A	-468.6	72633	0	0	72633
	42	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-2	ER1243A	-437.3	67782	0	0	67782
	43	220 KV DUMRAON NEW (BSPHCL)- ARA (PG)-2	ER1866A	0.6	-93	0	0	-93
	44	400 KV SIDE OF LAKHISARAI(PG) 315 MVA 400/132 ICT-3	ER1309A	0	0	0	0	0
	45	400 KV SIDE BANKA(PG) 400/132 KV 315 MVA ICT-3	ER1362A	0	0	0	0	0
	46	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-1	ER1395A	0	0	0	0	0
	47	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-2	ER1933A	0	0	0	0	0
	48	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-3	ER1934A	0	0	0	0	0
	49	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-2	ER1875A	37.1	-5751	0	0	-5751
	50	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-1	ER1816A	38.2	-5921	0	0	-5921
	51	400 KV HV SIDE OF 315 MVA MOTIHARI(DMTCL) ICT-3	ER1819A	0	0	0	0	0
	52	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-1	ER1806A	4.4	-682	0	0	-682
	53	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-2	ER1823A	4.4	-682	0	0	-682
	54	220 KV PUSAULI(PG)-KARAMNASA NEW(BSPHCL)	NP6092A	626.9	-97170	0	0	-97170
		TOTAL			-360732		-14214	-374945
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	0	0	0	0	0
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	0	0	0	0	0
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	0	0	0	0	0
	4	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	0	0	0	0	0
	5	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	100	-15500	0	0	-15500
	6	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	535	-82925	0	0	-82925
	7	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-2	NP8637A	0	0	0	0	0
	8	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-1	NP8678A	0	0	0	0	0
	9	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	-0.2	-31	-31
	10	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	-0.2	-31	-31
	11	220 KV RANCHI(PG)-HATIA(JUVNL)-I	NP5879A	1208.7	-187349	0	0	-187349
	12	221 KV RANCHI(PG)-HATIA(JUVNL)-II	ER1252A	1311.2	-203236	0	0	-203236
	13	222 KV RANCHI(PG)-HATIA(JUVNL)-III	NP7880A	1577.6	-244528	0	0	-244528
	14	223 KV RANCHI(PG)-CHANDIL(JUVNL)	NP5874A	583.1	-90381	0	0	-90381
	15	400 KV RANCHI NEW(PG)-PATRATU NEW(JUVNL) LINE-1	ER1221A	0	0	0	0	0
	16	400 KV RANCHI NEW(PG)-PATRATU NEW(JUVNL) LINE-2	ER1230A	0	0	0	0	0
		TOTAL			-823918		-62	-823980
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-545	84475	0	0	84475
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	ER1668A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	0	0	0	0	0
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	ER1711A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	ER1717A	-0.2	31	0	0	31
	7	400 KV TATA JAMSHEDPUR (DVC)- BARI PADA(PG)	ER1808A	-22.9	3550	0	0	3550
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	ER1802A	0	0	0	0	0
	9	400 KV MEJIA(DVC)-MAITHON(PG)	ER1659A	0	0	0	0	0
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1657A	-0.7	109	0	0	109
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1658A	-0.7	109	0	0	109
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	ER2042A	2.2	-341	0	0	-341
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	ER2128A	23.9	-3705	0	0	-3705
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	ER2129A	31.2	-4836	0	0	-4836
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	ER2130A	0	0	0	0	0
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-I(MAIN)	ER2046A	-280.8	43524	0	0	43524
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	ER2044A	0	0	0	0	0
	18	400 KV RTPS(DVC)-RANCHI(PG)	ER1653A	0	0	0	0	0
	19	400 KV RTPS(DVC)-MAITHON(PG)	ER1652A	2343.4	-363227	0	0	-363227
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	ER1656A	0	0	0	0	0
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	428.4	-66402	0	0	-66402
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	729.4	-113057	0	0	-113057
	23	220 KV RANCHI(PG)-RAMGARH(DVC)	ER1798A	-667.3	103432	0	0	103432
	24	221 KV RANCHI(PG)-MTPS(DVC)	ER1796A	0	0	0	0	0
		TOTAL			-316340		0	-316340

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-1 AND ICT-3	ER1563A	0	0	0	0	0
	2	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-2 AND ICT-4	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	400 KV SIDE OF JEYPORE (PG) 400/220 KV ICT-1 AND ICT-3	ER1550A	0	0	0.4	62	62
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	104.4	-16182	0	0	-16182
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	ER1759A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	0	0	0	0	0
	9	HV side meter of 400/220 Baripada ICT-2	ER1746A	0	0	0	0	0
	10	HV side meter of 400/220 Baripada ICT-3	ER1747A	0	0	0	0	0
	11	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	12	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	ER1900A	-46.9	7269.5	0	0	7270
	13	400 KV MERAMUNDALI (GRIDCO)-BOLANGIR(PG)	ER1054A	0	0	0	0	0
	14	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)-2	ER1055A	0	0	0	0	0
	15	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	ER1758A	0	0	0	0	0
	16	400 KV MENDHASAL (GRIDCO)- PANDIABILI(PG)-I	ER2072A	0	0	0	0	0
	17	400 KV MENDHASAL (GRIDCO)- PANDIABILI(PG)-II	ER2071A	0	0	0	0	0
	18	400 KV DUBURI(GRIDCO)-PANDIABILI(PG)	ER1897A	-4.7	728.5	0	0	729
	19	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	-6.8	1054	-92.7	-14368.5	-13315
	20	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	-5.4	837	-93.8	-14539	-13702
	21	HV side of 400/220 Pandiabili ICT-1	ER1583A	0	0	0.7	108.5	109
	22	HV side of 400/220 Pandiabili ICT-2	ER1776A	0	0	0.7	108.5	109
	23	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	0	0	0	0	0
	24	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	0	0	0	0	0
	25	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	26	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	27	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	0	0	0	0	0
	28	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	0	0	0	0	0
		TOTAL			-6293		-28629	-34922
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-45.90	7115	0	0	7115
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-60.40	9362	0	0	9362
	3	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	ER1490A	-109.30	16942	0	0	16942
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	ER1489A	-107.60	16678	0	0	16678
		TOTAL			50096		0	50096
WBSETCL	1	400 KV JEERAT (WBSETCL) - RAJARAHAT(PG)	ER1471A	0	0	238.6	36983	36983
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	0	0	0	0	0
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	0	0	0	0	0
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-139.2	21576	0	0	21576
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-161.8	25079	0	0	25079
	6	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-499.3	77392	0	0	77392
	7	132 KV SILIGURI (PG) - NBU (WBSETCL)	ER1675A	-380.4	58962	0	0	58962
	8	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-1257.4	194897	0	0	194897
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-168.6	26133	0	0	26133
	10	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	ER1739A	2479.1	-384261	0	0	-384261
	11	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	ER2039A	3387.2	-525016	0	0	-525016
	12	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	13	400 KV DURGA PUR(PG) - BIDHANNAGAR(WBSETCL)-I	ER2109A	1582.5	-245288	0	0	-245288
	14	400 KV DURGA PUR (PG) - BIDHANNAGAR(WBSETCL)-II	ER2111A	0	0	0	0	0
	15	400 KV SAGARDIGHI(WB) - FARAKKA (NTPC)-1(MAIN)	NP6482A	0	0	0	0	0
	16	400 KV JEERAT(PG) - SUBHASGRAM (PG)	ER1477A	0	0	0	0	0
	17	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-75.7	11734	0	0	11734
	18	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	21.7	-3364	0	0	-3364
	19	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	0	0	0	0	0
	20	400 KV DURGA PUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	0	0	0	0	0
	21	400 KV DURGA PUR(PG)- SAGARDIGHI(WBSETCL)-II	ER1637A	0	0	0	0	0
	22	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-94	14570	0	0	14570
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-6.3	977	0	0	977
	24	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	ER1486A	0	0	0	0	0
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	ER1537A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	ER1484A	0	0	0	0	0
	27	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	-0.4	62	0	0	62
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	ER1679A	67	-10385	0	0	-10385
	29	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-I	NP8723A	0	0	0	0	0
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-II	NP8724A	0	0	0	0	0
	31	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	0	0	0	0	0
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	0	0	0	0	0
	33	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-I	ER1040A	567.2	-87916	0	0	-87916
	34	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	ER1130A	544.4	-84382	0	0	-84382
	35	400 KV GOKARNA(WB)-RAJARHAT(PG)	ER1133A	0	0	0	0	0
	36	400 KV GOKARNA(WB)-PURNEA(PG)	ER1138A	0	0	0	0	0
	37	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	142.2	-22041	0	0	-22041
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	146.8	-22754	0	0	-22754
	39	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	0	0	0	0	0
	40	HV side of 400/220 KV RAJARHAT(PG) ICT-1	ER1526A	0	0	0	0	0
	41	220 KV SIDE OF 50 MVA MALDA(PG) 220/132 ICT-4	ER1639A	-93.1	14431	0	0	14431
	42	400 KV SIDE OF RAJARHAT(PG) 400/220 500 MVA ICT-2	ER1650A	0	0	0	0	0
	43	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	37.4	-5797	0	0	-5797
	44	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	35.8	-5549	0	0	-5549
	45	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER2125A	296.2	-45911	0	0	-45911
	46	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER2045A	276.8	-42904	0	0	-42904
	47	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-1	ER1683A	0	0	0	0	0
	48	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-2	ER1685A	0	0	0	0	0
	49	400 KV JEERAT(WB)-NEW JEERAT(PMJTL) CKT-1	ER2101A	0	0	0	0	0
	50	401 KV JEERAT(WB)-NEW JEERAT(PMJTL) CKT-2	ER2103A	0	0	0	0	0
		TOTAL			-1039756		36983	-1002773

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVArh,w.e.f. 01/04/2021

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting ,the methodology for computaion of Reactive Charges has been changed in conformity with other RPCs.

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 01/04/22 to 03/04/22

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-356.5	57040	0	0	57040
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-106.2	16992	0	0	16992
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-967.1	154736	0	0	154736
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	0	0	0	0	0
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-8	1280	0	0	1280
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	0	0	0	0	0
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-607.7	97232	0	0	97232
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	0	0	0	0	0
	9	220 KV side of 220/132 Arah ICT-2	ER1882A	0	0	0	0	0
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	0	0	0	0	0
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	1	-160	0	0	-160
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	30.5	-4880	-51.5	-8240	-13120
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	0	0	0	0	0
	16	220 KV NADHOKHAR(BSPHCL)- PUSAULI (PG)-2	NP8665A	-301.1	48176	0	0	48176
	17	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	ER1872A	0	0	0	0	0
	18	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	ER1873A	0	0	0	0	0
	19	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	732.8	-117248	0	0	-117248
	20	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	726.4	-116224	0	0	-116224
	21	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	794.8	-127168	0	0	-127168
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	769.9	-123184	0	0	-123184
	23	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-61.9	9904	37.8	6048	15952
	24	HV side of 400/220 Patna ICT-1	ER1877A	-484	77440	0	0	77440
	25	HV side of 400/220 Patna ICT-2	ER1407A	-722.9	115664	0	0	115664
	26	HV side of 400/220 Patna ICT-3	ER1231A	-677.5	108400	0	0	108400
	27	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	0	0	0	0	0
	28	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	0	0	0	0	0
	29	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-963.9	154224	0	0	154224
	30	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-988.7	158192	0	0	158192
	31	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	840.7	-134512	0	0	-134512
	32	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	840.6	-134496	0	0	-134496
	33	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	57.1	-9136	-2.5	-400	-9536
	34	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	69.5	-11120	-2.9	-464	-11584
	35	220 KV NEW PURNEA(PG)-BEGUSARAI(BSPTCL)-I	ER1348A	1351.6	-216256	0	0	-216256
	36	220 KV NEW PURNEA(PG)-KHAGARIA(BSPTCL)	ER1376A	571.2	-91392	0	0	-91392
	37	220 KV DUMRAON NEW (BSPHCL)- ARA(PG) LINE-1	ER1305A	8.1	-1296	0	0	-1296
	38	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	-370.5	59280	0	0	59280
	39	HV side of 400/220 KV Biharshariff(PG) ICT-4	ER1386A	-127.9	20464	0	0	20464
	40	400 KV SIDE OF 400/220 500 MVA GAYA(PG) ICT-3	ER1442A	0	0	0	0	0
	41	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-1	ER1247A	-530.7	84912	0	0	84912
	42	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-2	ER1243A	-515.1	82416	0	0	82416
	43	220 KV DUMRAON NEW (BSPHCL)- ARA (PG)-2	ER1866A	7.7	-1232	0	0	-1232
	44	400 KV SIDE OF LAKHISARAI(PG) 315 MVA 400/132 ICT-3	ER1309A	0	0	0	0	0
	45	400 KV SIDE BANKA(PG) 400/132 KV 315 MVA ICT-3	ER1362A	0	0	0	0	0
	46	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-1	ER1395A	0	0	0	0	0
	47	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-2	ER1933A	0	0	0	0	0
	48	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-3	ER1934A	0	0	0	0	0
	49	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-2	ER1875A	218.2	-34912	0	0	-34912
	50	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-1	ER1816A	220.3	-35248	0	0	-35248
	51	400 KV HV SIDE OF 315 MVA MOTIHARI(DMTCL) ICT-3	ER1819A	0	0	0	0	0
	52	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-1	ER1806A	90.5	-14480	0	0	-14480
	53	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-2	ER1823A	89.4	-14304	0	0	-14304
	54	220 KV PUSAULI(PG)-KARAMNAGA NEW(BSPHCL)	NP6092A	525.6	-84096	0	0	-84096
		TOTAL			-24992		-3056	-28048
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	0	0	0	0	0
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	0	0	0	0	0
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	0	0	0	0	0
	4	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	0	0	0	0	0
	5	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	0	0	0	0	0
	6	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	28	-4480	0	0	-4480
	7	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-2	NP8637A	0	0	0	0	0
	8	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-1	NP8678A	0	0	0	0	0
	9	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	18.8	3008	3008
	10	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	19	3040	3040
	11	220 KV RANCHI(PG)-HATIA(JUVNL)-I	NP5879A	1026.8	-164288	0	0	-164288
	12	221 KV RANCHI(PG)-HATIA(JUVNL)-II	ER1252A	1018.5	-162960	0	0	-162960
	13	222 KV RANCHI(PG)-HATIA(JUVNL)-III	NP7880A	1059.2	-169472	0	0	-169472
	14	223 KV RANCHI(PG)-CHANDIL(JUVNL)	NP5874A	440	-70400	0	0	-70400
	15	400 KV RANCHI NEW(PG)-PATRATU NEW(JUVNL) LINE-1	ER1221A	0	0	0	0	0
	16	400 KV RANCHI NEW(PG)-PATRATU NEW(JUVNL) LINE-2	ER1230A	0	0	0	0	0
		TOTAL			-571600		6048	-565552
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-898	143680	0	0	143680
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	ER1668A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	0	0	0	0	0
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	ER1711A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	ER1717A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC)- BARI PADA(PG)	ER1808A	-40.7	6512	0	0	6512
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	ER1802A	1.5	-240	0	0	-240
	9	400 KV MEJIA(DVC)-MAITHON(PG)	ER1659A	0	0	0	0	0
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1657A	0	0	0	0	0
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1658A	0	0	0	0	0
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	ER2042A	53.1	-8496	0	0	-8496
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	ER2128A	163.7	-26192	0	0	-26192
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	ER2129A	249.5	-39920	0	0	-39920
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	ER2130A	31.3	-5008	0	0	-5008
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-I(MAIN)	ER2046A	44.4	-7104	0	0	-7104
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	ER2044A	0	0	0	0	0
	18	400 KV RTPS(DVC)-RANCHI(PG)	ER1653A	-34.2	5472	0	0	5472
	19	400 KV RTPS(DVC)-MAITHON(PG)	ER1652A	4313.5	-690160	0	0	-690160
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	ER1656A	0	0	0	0	0
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	527.3	-84368	0	0	-84368
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	863.3	-138128	0	0	-138128
	23	220 KV RANCHI(PG)-RAMGARH(DVC)	ER1798A	-486.6	77856	0	0	77856
	24	221 KV RANCHI(PG)-MTPS(DVC)	ER1796A	0	0	0	0	0
		TOTAL			-766096		0	-766096

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-1 AND ICT-3	ER1563A	0	0	0	0	0
	2	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-2 AND ICT-4	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	400 KV SIDE OF JEYPORE (PG) 400/220 KV ICT-1 AND ICT-3	ER1550A	0	0	0	0	0
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	-115.9	18544	0	0	18544
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	ER1759A	360.7	-57712	0	0	-57712
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	0	0	0	0	0
	9	HV side meter of 400/220 Baripada ICT-2	ER1746A	0	0	0	0	0
	10	HV side meter of 400/220 Baripada ICT-3	ER1747A	0	0	0	0	0
	11	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	12	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	ER1900A	-321.8	51488	0	0	51488
	13	400 KV MERAMUNDALI (GRIDCO)-BOLANGIR(PG)	ER1054A	0	0	0	0	0
	14	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)-2	ER1055A	11.2	-1792	0	0	-1792
	15	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	ER1758A	0	0	0	0	0
	16	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	ER2072A	0	0	0	0	0
	17	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	ER2071A	0	0	0	0	0
	18	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	ER1897A	-7.3	1168	0	0	1168
	19	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	-8.9	1424	-80.5	-12880	-11456
	20	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	-8.7	1392	-80.5	-12880	-11488
	21	HV side of 400/220 Pandiabil ICT-1	ER1583A	0	0	0	0	0
	22	HV side of 400/220 Pandiabil ICT-2	ER1776A	0	0	0	0	0
	23	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	0	0	0	0	0
	24	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	0	0	0	0	0
	25	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	26	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	27	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	0	0	0	0	0
	28	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	-1.5	240	0	0	240
		TOTAL			14752		-25760	-11008
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-12.00	1920	-42.3	-6768	-4848
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	0.00	0	0	0	0
	3	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	ER1490A	-53.20	8512	0	0	8512
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	ER1489A	-52.70	8432	0	0	8432
		TOTAL			18864		-6768	12096
WBSETCL	1	400 KV JEERAT (WBSETCL) - RAJARAHAT(PG)	ER1471A	0	0	0	0	0
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	0	0	0	0	0
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	0	0	0	0	0
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-463.5	74160	0	0	74160
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-514.6	82336	0	0	82336
	6	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-295.8	47328	0	0	47328
	7	132 KV SILIGURI (PG) - NBU (WBSETCL)	ER1675A	-296	47360	0	0	47360
	8	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-825.9	132144	0	0	132144
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-33.6	5376	0	0	5376
	10	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	ER1739A	1615	-258400	0	0	-258400
	11	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	ER2039A	2282.9	-365264	0	0	-365264
	12	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	13	400 KV DURGA PUR(PG) - BIDHANNAGAR(WBSETCL)-I	ER2109A	1535.2	-245632	0	0	-245632
	14	400 KV DURGA PUR (PG) - BIDHANNAGAR(WBSETCL)-II	ER2111A	0	0	0	0	0
	15	400 KV SAGARDIGHI(WB) - FARAKKA (NTPC)-1(MAIN)	NP6482A	0	0	0	0	0
	16	400 KV JEERAT(PG) - SUBHASGRAM (PG)	ER1477A	0	0	0	0	0
	17	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-20.1	3216	0	0	3216
	18	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-39.9	6384	0	0	6384
	19	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	0	0	0	0	0
	20	400 KV DURGA PUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	0	0	0	0	0
	21	400 KV DURGA PUR(PG)- SAGARDIGHI(WBSETCL)-II	ER1637A	0	0	0	0	0
	22	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-199.8	31968	0	0	31968
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-42.1	6736	0	0	6736
	24	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	ER1486A	0	0	0	0	0
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	ER1537A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	ER1484A	0	0	0	0	0
	27	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	1.1	-176	0	0	-176
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	ER1679A	136.1	-21776	0	0	-21776
	29	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-I	NP8723A	0	0	0	0	0
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-II	NP8724A	0	0	0	0	0
	31	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-9.5	1520	0	0	1520
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	0	0	0	0	0
	33	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-I	ER1040A	537.8	-86048	0	0	-86048
	34	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	ER1130A	518.1	-82896	0	0	-82896
	35	400 KV GOKARNA(WB)-RAJARHAT(PG)	ER1133A	0	0	0	0	0
	36	400 KV GOKARNA(WB)-PURNEA(PG)	ER1138A	0	0	0	0	0
	37	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	119.8	-19168	0	0	-19168
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	51.8	-8288	0	0	-8288
	39	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	0	0	0	0	0
	40	HV side of 400/220 KV RAJARHAT(PG) ICT-1	ER1526A	0	0	0	0	0
	41	220 KV SIDE OF 50 MVA MALDA(PG) 220/132 ICT-4	ER1639A	-345.9	55344	0	0	55344
	42	400 KV SIDE OF RAJARHAT(PG) 400/220 500 MVA ICT-2	ER1650A	0	0	0	0	0
	43	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	276.5	-44240	0	0	-44240
	44	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	273.4	-43744	0	0	-43744
	45	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER2125A	508.2	-81312	0	0	-81312
	46	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER2045A	487.7	-78032	0	0	-78032
	47	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-1	ER1683A	0	0	0	0	0
	48	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-2	ER1685A	0	0	0	0	0
	49	400 KV JEERAT(WB)-NEW JEERAT(PMJTL) CKT-1	ER2101A	0	0	0	0	0
	50	401 KV JEERAT(WB)-NEW JEERAT(PMJTL) CKT-2	ER2103A	0	0	0	0	0
		TOTAL			-841104		0	-841104

Note: 1) Rate of Reactive Energy Charge has been considered @ 16 paise/KVArH,w.e.f. 01/04/2022

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting ,the methodology for computaion of Reactive Charges has been changed in conformity with other RPCs.