



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

75
Azadi Ka
Amrit Mahotsav



Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033

Tel. No.: 033-24239651, 24239658 FAX No.: 033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/ 607

Date: 02.08.2022

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP), GRIDCO, 4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91. (Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 18.07.2022-24.07.2022

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 29.07.2022.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This issues with the approval of Member Secretary.

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)

SUPERINTENDING ENGINEER

14 गोल्फ क्लब रोड, टॉलीगंज, कोलकाता - 700 033 | 14 Golf Club Road, Tollygunge, Kolkata - 700 033.

Tele: 24239657, 24239651, 24239650. Fax: 24239652, 24239653. www.erpc.gov.in, Email: mserpc-power@nic.in

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 18/07/22 to 24/07/22**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)	AMOUNT RECEIVABLE(Rs.)	AMOUNT RECEIVABLE(Final After Adjustment)(Rs.)
BSPHCL	POOL	0	1213616	1213616
JUVNL	POOL	1914288	0	0
DVC	POOL	1491808	0	0
GRIDCO	POOL	2592240	0	0
SIKKIM	POOL	3280	0	0
WBSETCL	POOL	132960	0	0
Total		6134576	1213616	1213616

Note:

a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC

b) Final Receivables Amount After Adjustment from the Reactive Pool are done as per Methodology Approved in the 43rd ERPC meeting held on 26.03.2021 at Kolkata.

SUPERINTENDING ENGINEER

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 18/07/22 to 24/07/22

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVAf H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVAfL (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-1412.9	226064	0	0	226064
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-370.8	59328	0	0	59328
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1848.9	295824	0	0	295824
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	0	0	-147.1	-23536	-23536
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-2.6	416	-47.1	-7536	-7120
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	0	0	-123.5	-19760	-19760
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-1685.8	269728	0	0	269728
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-0.2	32	-4.8	-768	-736
	9	220 KV side of 220/132 Arah ICT-2	ER1882A	-0.3	48	-4.6	-736	-688
	10	220 KV NAUBATPUR(BGCL) - ARAH(PG) LINE-1	ER1829A	-16.6	2656	0	0	2656
	11	220 KV NAUBATPUR(BGCL) - ARAH(PG) LINE-2	ER1871A	-17.4	2784	0	0	2784
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	5.7	-912	-622.2	-99552	-100464
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	-0.5	80	-6.6	-1056	-976
	16	220 KV NADHOKHAR(BSPHCL) - PUSAULI (PG)-2	NP8665A	-1555.5	248880	0	0	248880
	17	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	ER1872A	0	0	0	0	0
	18	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	ER1873A	0	0	0	0	0
	19	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	627.8	-100448	0	0	-100448
	20	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	625.3	-100048	0	0	-100048
	21	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	690.6	-110496	0	0	-110496
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	647.9	-103664	0	0	-103664
	23	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-27.5	4400	547.9	87664	92064
	24	HV side of 400/220 Patna ICT-1	ER1877A	0	0	0	0	0
	25	HV side of 400/220 Patna ICT-2	ER1407A	-630.1	100816	0	0	100816
	26	HV side of 400/220 Patna ICT-3	ER1231A	-589.7	94352	0	0	94352
	27	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	0	0	0	0	0
	28	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	0	0	0	0	0
	29	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-3767.7	602832	0	0	602832
	30	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-3776.3	604208	0	0	604208
	31	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1450.1	-232016	0	0	-232016
	32	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1440.6	-230496	0	0	-230496
	33	HV side of 400/220 Darthanaga DMTCL ICT-1	ER1274A	5.5	-880	-0.4	-64	-944
	34	HV side of 400/220 Darthanaga DMTCL ICT-2	ER1275A	6.5	-1040	0	0	-1040
	35	220 KV NEW PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	1167.8	-186848	0	0	-186848
	36	220 KV NEW PURNEA(PG)-KHAGARIA(BSPTCL)	ER1376A	812	-129920	0	0	-129920
	37	220 KV DUMRAON NEW(BSPHCL) - ARA(PG) LINE-1	ER1305A	48	-7680	0	0	-7680
	38	220 KV NADHOKHAR(BSPHCL) - PUSAULI(PG) LINE-1	ER1310A	-1876.9	300304	0	0	300304
	39	HV side of 400/220 KV Biharsharif(PG) ICT-4	ER1386A	-538.1	86096	0	0	86096
	40	400 KV SIDE OF 400/220 500 MVA GAYA(PG) ICT-3	ER1442A	0	0	0	0	0
	41	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-1	ER1247A	-182	29120	0	0	29120
	42	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-2	ER1243A	-172.4	27584	0	0	27584
	43	220 KV DUMRAON NEW(BSPHCL) - ARA (PG)-2	ER1866A	43.3	-6928	0	0	-6928
	44	400 KV SIDE OF LAKHISARAI(PG) 315 MVA 400/132 ICT-3	ER1309A	0	0	0	0	0
	45	400 KV SIDE BANKA(PG) 400/132 KV 315 MVA ICT-3	ER1362A	0	0	0	0	0
	46	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-1	ER1395A	0	0	0	0	0
	47	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-2	ER1933A	0	0	0	0	0
	48	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-3	ER1934A	0	0	0	0	0
	49	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-2	ER1875A	880.4	-140864	0	0	-140864
	50	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-1	ER1816A	929.4	-148704	0	0	-148704
	51	400 KV HV SIDE OF 315 MVA MOTIHARI(DMTCL) ICT-3	ER1819A	-266.2	42592	0	0	42592
	52	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-1	ER1806A	885.9	-141744	0	0	-141744
	53	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-2	ER1823A	879.4	-140704	0	0	-140704
	54	220 KV PUSAULI(PG)-KARAMNANA NEW(BSPHCL)	NP6092A	793.5	-126960	0	0	-126960
	55	400 KV NAUBATPUR(BGCL)-PATNA(PG)-1	ER1879A	1308.4	-209344	0	0	-209344
	56	400 KV NAUBATPUR(BGCL)-PATNA(PG)-2	ER1848A	1261.9	-201904	0	0	-201904
	57	400 KV JAKKANPUR(BGCL)-PATNA(PG)-1	ER1941A	-1154.9	184784	0	0	184784
	58	400 KV JAKKANPUR(BGCL)-PATNA(PG)-2	ER1942A	-903.3	144528	0	0	144528
	59	220 KV MUZAFFARPUR(PG)-GORAUL(BSPHCL)-1	ER1945A	-1706.9	273104	0	0	273104
		TOTAL			1278960		-65344	1213616
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-964.8	154368	0	0	154368
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-543.3	86928	0	0	86928
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-530.2	84832	0	0	84832
	4	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	0	0	0	0	0
	5	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	209.6	-33536	0	0	-33536
	6	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	576	-92160	0	0	-92160
	7	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-2	NP8637A	0	0	0	0	0
	8	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-1	NP8678A	0	0	0	0	0
	9	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0.2	-32	42.2	6752	6720
	10	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0.2	-32	42.4	6784	6752
	11	220 KV RANCHI(PG)-HATIA(JUVNL)-I	NP5879A	4249.1	-679856	0	0	-679856
	12	221 KV RANCHI(PG)-HATIA(JUVNL)-II	ER1252A	3691.3	-580608	0	0	-580608
	13	222 KV RANCHI(PG)-HATIA(JUVNL)-III	NP7880A	3761	-601780	0	0	-601780
	14	223 KV RANCHI(PG)-CHANDIL(JUVNL)	NP5874A	1107.3	-177168	0	0	-177168
	15	400 KV RANCHI NEW(PG)-PATRATU NEW(JUVNL) LINE-1	ER1221A	269.9	-43184	0	0	-43184
	16	400 KV RANCHI NEW(PG)-PATRATU NEW(JUVNL) LINE-2	ER1230A	222.6	-35616	0	0	-35616
		TOTAL			-1927824		13536	-1914288
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-744.2	119072	0	0	119072
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	ER1668A	0.6	-96	0	0	-96
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	3	-480	0	0	-480
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	ER1711A	-50.6	8096	0	0	8096
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	ER1717A	-80.4	12864	0	0	12864
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	ER1808A	-800	128000	0	0	128000
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	ER1802A	0	0	0	0	0
	9	400 KV MEJIA(DVC)-MAITHON(PG)	ER1659A	0	0	0	0	0
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1657A	-128	20480	0	0	20480
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1658A	-145.4	23264	0	0	23264
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	ER2042A	204.5	-32720	0	0	-32720
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	ER2128A	405.9	-64944	0	0	-64944
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	ER2129A	-472	75520	0	0	75520
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	ER2130A	-171.7	27472	0	0	27472
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-I(MAIN)	ER2046A	-1881.3	301008	0	0	301008
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	ER2044A	0	0	0	0	0
	18	400 KV RTPS(DVC)-RANCHI(PG)	ER1653A	-1490.8	238528	0	0	238528
	19	400 KV RTPS(DVC)-MAITHON(PG)	ER1652A	8150.5	-1304080	0	0	-1304080
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	ER1656A	-237.1	37936	0	0	37936
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	4343.4	-694944	0	0	-694944
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	5140.4	-822464	0	0	-822464
	23	220 KV RANCHI(PG)-RAMGARH(DVC)	ER1798A	-3874.9	619984	0	0	619984
	24	221 KV RANCHI(PG)-MTPS(DVC)	ER1796A	1151.9	-184304	0	0	-184304
		TOTAL			-1491808		0	-1491808

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-1 AND ICT-3	ER1563A	0	0	0	0	0
	2	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-2 AND ICT-4	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	400 KV SIDE OF JEYPORE (PG) 400/220 KV ICT-1 AND ICT-3	ER2062A	5770.1	-923216	0	0	-923216
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	4634.5	-741520	0	0	-741520
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	ER1759A	4066.1	-650576	0	0	-650576
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	0	0	0	0	0
	9	HV side meter of 400/220 Baripada ICT-2	ER1746A	0	0	0	0	0
	10	HV side meter of 400/220 Baripada ICT-3	ER1747A	0	0	0	0	0
	11	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	12	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	ER1900A	-683.2	109312	0	0	109312
	13	400 KV MERAMUNDALI (GRIDCO)-BOLANGIR(PG)	ER1054A	0	0	0	0	0
	14	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)-2	ER1055A	4864.7	-778352	0	0	-778352
	15	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	ER1758A	126.5	-20240	0	0	-20240
	16	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	ER2072A	573.1	-91696	0	0	-91696
	17	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	ER2071A	759.3	-121488	0	0	-121488
	18	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	ER1897A	-1060.8	169728	0	0	169728
	19	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	20	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	21	HV side of 400/220 Pandiabil ICT-1	ER1583A	504.1	-80656	0	0	-80656
	22	HV side of 400/220 Pandiabil ICT-2	ER1776A	501.7	-80272	0	0	-80272
	23	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	-119.2	19072	0	0	19072
	24	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	-194.9	31184	0	0	31184
	25	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	26	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	27	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	-1749.1	279856	0	0	279856
	28	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	-1791.4	286624	0	0	286624
		TOTAL		-2592240	0	0	-2592240	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-35.30	5648	0	0	5648
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-8.30	1328	-64.1	-10256	-8928
	3	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	ER1490A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	ER1489A	0.00	0	0	0	0
		TOTAL		6976	-10256	-3280		
WBSETCL	1	400 KV JEERAT (WBSETCL) - RAJARHAT(PG)	ER1471A	0	0	-312	-49920	-49920
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	7.3	-1168	0	0	-1168
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	17.1	-2736	0	0	-2736
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-108.2	17312	0	0	17312
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-128	20480	0	0	20480
	6	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	6.7	-1072	0	0	-1072
	7	132 KV SILIGURI (PG) - NBU (WBSETCL)	ER1675A	-33.3	5328	0	0	5328
	8	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-1797.5	287600	0	0	287600
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	0	0	0	0	0
	10	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	ER1739A	-2547	407520	0	0	407520
	11	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	ER2039A	285	-45600	0	0	-45600
	12	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	13	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	ER2109A	2783.2	-445312	0	0	-445312
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	ER2111A	0	0	0	0	0
	15	400 KV SAGARDIGHI(WB) - FARAKKA (NTPC)-1(MAIN)	NP6482A	0	0	0	0	0
	16	400 KV JEERAT(PG) - SUBHASGRAM (PG)	ER1477A	0	0	0	0	0
	17	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	ER2122A	23.3	-3728	0	0	-3728
	18	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	ER2096A	-60.6	9696	0	0	9696
	19	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	84.4	-13504	0	0	-13504
	20	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	0	0	0	0	0
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	ER1637A	38.5	-6160	0	0	-6160
	22	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-272.4	43584	0	0	43584
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-8.5	1360	0	0	1360
	24	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	ER1486A	6	-960	0	0	-960
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	ER1537A	4.2	-672	0	0	-672
	26	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	ER1484A	20.7	-3312	0	0	-3312
	27	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	224.4	-35904	0	0	-35904
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	ER1679A	1118.3	-178928	0	0	-178928
	29	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-I	NP8723A	0	0	0	0	0
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-II	NP8724A	0	0	0	0	0
	31	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-404.3	64688	0	0	64688
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-379	60640	0	0	60640
	33	400 KV PPS NEW(WB)-RANCHI NEW(PG)-I	ER1040A	826.9	-132304	0	0	-132304
	34	400 KV PPS NEW(WB)-RANCHI NEW(PG)-II	ER1130A	806	-128960	0	0	-128960
	35	400 KV GOKARNA(WB)-RAJARHAT(PG)	ER1133A	0	0	0	0	0
	36	400 KV GOKARNA(WB)-PURNEA(PG)	ER1138A	0	0	0	0	0
	37	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	0	0	0	0	0
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	0	0	0	0	0
	39	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	0	0	0	0	0
	40	HV side of 400/220 KV RAJARHAT(PG) ICT-1	ER1526A	13.8	-2208	0	0	-2208
	41	220 KV SIDE OF 50 MVA MALDA(PG) 220/132 ICT-4	ER1639A	-62.9	10064	0	0	10064
	42	400 KV SIDE OF RAJARHAT(PG) 400/220 500 MVA ICT-2	ER1650A	12.4	-1984	0	0	-1984
	43	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	-54.1	8656	0	0	8656
	44	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	-52.2	8352	0	0	8352
	45	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER2125A	76.6	-12256	0	0	-12256
	46	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER2045A	72.2	-11552	0	0	-11552
	47	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-1	ER1683A	0	0	0	0	0
	48	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-2	ER1685A	0	0	0	0	0
	49	400 KV JEERAT(WB)-NEW JEERAT(PM/JTL) CKT-1	ER2101A	0	0	0	0	0
	50	401 KV JEERAT(WB)-NEW JEERAT(PM/JTL) CKT-2	ER2103A	0	0	0	0	0
		TOTAL		-83040	-49920	-132960		

Note: 1) Rate of Reactive Energy Charge has been considered @ 16 paise/KVARh.w.e.f. 01/04/2022

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an IGS have not been considered for computation of reactive exchange with ISTs.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.