



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033



Tel. No.: 033-24239651, 24239658 FAX No.: 033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/ 681

Date: 24.08.2022

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP), GRIDCO, 4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91. (Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 01.08.2022-07.08.2022

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 12.08.2022.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This issues with the approval of Member Secretary.

Encl: As above/ संलग्न यथोपरी

भवदीय/Yours faithfully,

(S. KEJRIWAL)

SUPERINTENDING ENGINEER

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 01/08/22 to 07/08/22**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)	AMOUNT RECEIVABLE(Rs.)	AMOUNT RECEIVABLE(Final After Adjustment)(Rs.)
BSPHCL	POOL	0	509280	509280
JUVNL	POOL	3143360	0	0
DVC	POOL	842960	0	0
GRIDCO	POOL	244448	0	0
SIKKIM	POOL	5216	0	0
WBSETCL	POOL	0	207056	207056
Total		4235984	716336	716336

Note:

a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC

**b) Final Receivables Amount After Adjustment from the Reactive Pool are done as per Methodology
Approved in the 43rd ERPC meeting held on 26.03.2021 at Kolkata.**

SUPERINTENDING ENGINEER

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 01/08/22 to 07/08/22

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVA/H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVA/H (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-650.8	104128	0	0	104128
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-298.9	47824	0	0	47824
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-991.8	158688	0	0	158688
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	0	0	-149	-23840	-23840
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-0.3	48	-76.5	-12240	-12192
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	0	0	-126.4	-20224	-20224
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-615.7	98512	0	0	98512
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	0	0	-34.2	-5472	-5472
	9	220 KV side of 220/132 Arah ICT-2	ER1882A	0	0	-33.2	-5312	-5312
	10	220 KV NAUBATPUR(BGCL) - ARAH(PG) LINE-1	ER1829A	19.8	-3168	0	0	-3168
	11	220 KV NAUBATPUR(BGCL) - ARAH(PG) LINE-2	ER1871A	19.8	-3168	0	0	-3168
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	6.9	-1104	-686.4	-109824	-110928
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	0	0	-49.1	-7856	-7856
	16	220 KV NADHOKHAR(BSPHCL)- PUSAULI (PG)-2	NP8665A	-679.7	108752	0	0	108752
	17	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	ER1872A	0	0	0	0	0
	18	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	ER1873A	0	0	0	0	0
	19	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	797.3	-127568	0	0	-127568
	20	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	798	-127680	0	0	-127680
	21	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	870.7	-139312	0	0	-139312
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	828.5	-132560	0	0	-132560
	23	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-12.3	1968	554.1	88656	90624
	24	HV side of 400/220 Patna ICT-1	ER1877A	0	0	0	0	0
	25	HV side of 400/220 Patna ICT-2	ER1407A	-307.3	49168	0	0	49168
	26	HV side of 400/220 Patna ICT-3	ER1231A	-291	46560	0	0	46560
	27	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	0	0	0	0	0
	28	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	0	0	0	0	0
	29	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-3592.5	574800	0	0	574800
	30	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-3478.1	556496	0	0	556496
	31	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1157.2	-185152	0	0	-185152
	32	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1156.7	-185072	0	0	-185072
	33	HV side of 400/220 Darthanaga DMTCL ICT-1	ER1274A	36	-5760	0	0	-5760
	34	HV side of 400/220 Darthanaga DMTCL ICT-2	ER1275A	38.9	-6224	0	0	-6224
	35	220 KV NEW PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	1554.2	-248672	0	0	-248672
	36	220 KV NEW PURNEA(PG)-KHAGARIA(BSPTCL)	ER1376A	1180	-188800	0.5	80	-188720
	37	220 KV DUMRAON NEW(BSPHCL)- ARA(PG) LINE-1	ER1305A	1	-160	5.9	944	784
	38	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	-823.7	131792	0	0	131792
	39	HV side of 400/220 KV Biharsharif(PG) ICT-4	ER1386A	-521.5	83440	0	0	83440
	40	400 KV SIDE OF 400/220 500 MVA GAYA(PG) ICT-3	ER1442A	0	0	0	0	0
	41	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-1	ER1247A	-227.2	36352	0	0	36352
	42	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-2	ER1243A	-220.1	35216	0	0	35216
	43	220 KV DUMRAON NEW(BSPHCL)- ARA (PG)-2	ER1866A	0.7	-112	6.2	992	880
	44	400 KV SIDE OF LAKHISARAI(PG) 315 MVA 400/132 ICT-3	ER1309A	0	0	0	0	0
	45	400 KV SIDE BANKA(PG) 400/132 KV 315 MVA ICT-3	ER1362A	0	0	0	0	0
	46	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-1	ER1395A	0	0	0	0	0
	47	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-2	ER1933A	0	0	0	0	0
	48	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-3	ER1934A	0	0	0	0	0
	49	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-2	ER1875A	137.5	-22000	0	0	-22000
	50	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-1	ER1816A	151.7	-24272	0	0	-24272
	51	400 KV HV SIDE OF 315 MVA MOTIHARI(DMTCL) ICT-3	ER1819A	-352.4	56384	0	0	56384
	52	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-1	ER1806A	1188	-190080	0	0	-190080
	53	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-2	ER1823A	1133.4	-181344	0	0	-181344
	54	220 KV PUSAULI(PG)-KARAMNESA NEW(BSPHCL)	NP6092A	329.2	-52672	0	0	-52672
	55	400 KV NAUBATPUR(BGCL)-PATNA(PG)-1	ER1879A	1020.3	-163248	0	0	-163248
	56	400 KV NAUBATPUR(BGCL)-PATNA(PG)-2	ER1848A	976.8	-156288	0	0	-156288
	57	400 KV JAKKANPUR(BGCL)-PATNA(PG)-1	ER1941A	-800.1	128016	0	0	128016
	58	400 KV JAKKANPUR(BGCL)-PATNA(PG)-2	ER1942A	-552.7	88432	0	0	88432
	59	220 KV MUZAFFARPUR(PG)-GORAUL(BSPHCL)-1	ER1945A	-2757.6	441216	0	0	441216
TOTAL					603376		-94096	509280
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-1363.3	218128	0	0	218128
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-818.8	131008	0	0	131008
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-946.9	151504	0	0	151504
	4	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	0	0	0	0	0
	5	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	3698.8	-591808	0	0	-591808
	6	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	4725.6	-756096	0	0	-756096
	7	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-2	NP8637A	16.1	-2576	0	0	-2576
	8	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-1	NP8678A	1.7	-272	0	0	-272
	9	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	11.3	1808	1808
	10	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	13.1	2096	2096
	11	220 KV RANCHI(PG)-HATIA(JUVNL)-I	NP5879A	4312.3	-689968	0	0	-689968
	12	221 KV RANCHI(PG)-HATIA(JUVNL)-II	ER1252A	3710.5	-593680	0	0	-593680
	13	222 KV RANCHI(PG)-HATIA(JUVNL)-III	NP7880A	3747	-599520	0	0	-599520
	14	223 KV RANCHI(PG)-CHANDIL(JUVNL)	NP5874A	587.5	-94000	0	0	-94000
	15	400 KV RANCHI NEW(PG)-PATRATU NEW(JUVNL) LINE-1	ER1221A	1081.4	-173024	0	0	-173024
	16	400 KV RANCHI NEW(PG)-PATRATU NEW(JUVNL) LINE-2	ER1230A	918.5	-146960	0	0	-146960
TOTAL					-3147264		3904	-3143360
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-3503.8	560608	0	0	560608
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	ER1668A	-2	320	0	0	320
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-54.4	8704	0	0	8704
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	ER1711A	-570.4	91264	0	0	91264
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	ER1717A	-1529.2	244672	0	0	244672
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	ER1808A	-1372	219520	0	0	219520
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	ER1802A	0	0	0	0	0
	9	400 KV MEJIA(DVC)-MAITHON(PG)	ER1659A	0	0	0	0	0
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1657A	-3026.1	484176	0	0	484176
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1658A	-3215.1	514416	0	0	514416
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	ER2042A	226.1	-36176	0	0	-36176
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	ER2128A	332.5	-53200	0	0	-53200
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	ER2129A	471.4	-75424	0	0	-75424
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	ER2130A	96	-15360	0	0	-15360
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-I(MAIN)	ER2046A	-1221.1	195376	0	0	195376
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	ER2044A	0	0	0	0	0
	18	400 KV RTPS(DVC)-RANCHI(PG)	ER1653A	-3784.8	605568	0	0	605568
	19	400 KV RTPS(DVC)-MAITHON(PG)	ER1652A	12250.2	-1960032	0	0	-1960032
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	ER1656A	-2019.7	323152	0	0	323152
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	6080.6	-972896	0	0	-972896
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	6544	-1047040	0	0	-1047040
	23	220 KV RANCHI(PG)-RAMGARH(DVC)	ER1798A	-2107.8	337248	0	0	337248
	24	221 KV RANCHI(PG)-MTPS(DVC)	ER1796A	1674.1	-267856	0	0	-267856
TOTAL					-842960		0	-842960

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-1 AND ICT-3	ER1563A	0	0	0	0	0
	2	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-2 AND ICT-4	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	400 KV SIDE OF JEYPURE (PG) 400/220 KV ICT-1 AND ICT-3	ER2062A	2351.9	-376304	0	0	-376304
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	1876	-300160	0	0	-300160
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	ER1759A	1858.6	-297376	0	0	-297376
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	-46.4	7424	0	0	7424
	9	HV side meter of 400/220 Baripada ICT-2	ER1746A	0	0	0	0	0
	10	HV side meter of 400/220 Baripada ICT-3	ER1747A	0	0	0	0	0
	11	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	12	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	ER1900A	-1301.5	208240	0	0	208240
	13	400 KV MERAMUNDALI (GRIDCO)-BOLANGIR(PG)	ER1054A	0	0	0	0	0
	14	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)-2	ER1055A	773.8	-123808	0	0	-123808
	15	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	ER1758A	339.3	-54288	0	0	-54288
	16	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	ER2072A	67.6	-10816	0	0	-10816
	17	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	ER2071A	122.9	-19664	0	0	-19664
	18	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	ER1897A	-753.9	120624	0	0	120624
	19	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	-48.4	7744	-78.7	-12592	-4848
	20	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	-41.9	6704	-80.1	-12816	-6112
	21	HV side of 400/220 Pandiabil ICT-1	ER1583A	81.4	-13024	0	0	-13024
	22	HV side of 400/220 Pandiabil ICT-2	ER1776A	80.7	-12912	0	0	-12912
	23	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	-80.7	12912	0	0	12912
	24	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	-109.1	17456	0	0	17456
	25	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	26	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	27	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	-1887.9	302064	0	0	302064
	28	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	-1913.4	306144	0	0	306144
TOTAL					-219040		-25408	-244448
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-106.80	17088	-126.8	-20288	-3200
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-47.30	7568	-59.9	-9584	-2016
	3	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	ER1490A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	ER1489A	0.00	0	0	0	0
TOTAL					24656		-29872	-5216
WBSETCL	1	400 KV JEERAT (WBSETCL) - RAJARAHAT(PG)	ER1471A	0	0	-38.6	-6176	-6176
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	-27.3	4368	0	0	4368
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	-18.7	2992	0	0	2992
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-682.5	109200	0	0	109200
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-717.6	114816	0	0	114816
	6	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	35	-5600	0	0	-5600
	7	132 KV SILIGURI (PG) - NBU (WBSETCL)	ER1675A	-131.1	20976	0	0	20976
	8	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-1505.9	240944	0	0	240944
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	0	0	0	0	0
	10	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	ER1739A	-3305.3	528848	0	0	528848
	11	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	ER2039A	152	-24320	0	0	-24320
	12	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	13	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	ER2109A	4826.9	-772304	0	0	-772304
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	ER2111A	0	0	0	0	0
	15	400 KV SAGARDIGHI(WB) - FARAKKA (NTPC)-1(MAIN)	NP6482A	-52.4	8384	0	0	8384
	16	400 KV JEERAT(PG) - SUBHASGRAM (PG)	ER1477A	-9.5	1520	0	0	1520
	17	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	ER2122A	17	-2720	0	0	-2720
	18	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	ER2096A	-85.6	13696	0	0	13696
	19	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	110.6	-17696	0	0	-17696
	20	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	0	0	0	0	0
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	ER1637A	30.6	-4896	0	0	-4896
	22	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-351.6	56256	0	0	56256
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-21.6	3456	0	0	3456
	24	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	ER1486A	-37.8	6048	0	0	6048
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	ER1537A	-40.1	6416	0	0	6416
	26	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	ER1484A	-46.5	7440	0	0	7440
	27	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	-28.4	4544	0	0	4544
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	ER1679A	-15.7	2512	0	0	2512
	29	400 KV SAGARDIGHI(WB)-BERHAMPUR(PG) LINE-I	NP8723A	13.8	-2208	0	0	-2208
	30	400 KV SAGARDIGHI(WB)-BERHAMPUR(PG) LINE-II	NP8724A	3.6	-576	0	0	-576
	31	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-490.9	78544	0	0	78544
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-460.3	73648	0	0	73648
	33	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-I	ER1040A	872.8	-139648	0	0	-139648
	34	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	ER1130A	849.8	-135968	0	0	-135968
	35	400 KV GOKARNA(WB)-RAJARHAT(PG)	ER1133A	-109.1	17456	0	0	17456
	36	400 KV GOKARNA(WB)-PURNEA(PG)	ER1138A	-10.9	1744	0	0	1744
	37	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	0	0	0	0	0
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	0	0	0	0	0
	39	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	0	0	0	0	0
	40	HV side of 400/220 KV RAJARHAT(PG) ICT-1	ER1526A	-20.3	3248	0	0	3248
	41	220 KV SIDE OF 50 MVA MALDA(PG) 220/132 ICT-4	ER1639A	-451.7	72272	0	0	72272
	42	400 KV SIDE OF RAJARHAT(PG) 400/220 500 MVA ICT-2	ER1650A	-13.8	2208	0	0	2208
	43	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	-201.9	32304	0	0	32304
	44	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	-209.5	33520	0	0	33520
	45	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER2125A	444.3	-71088	0	0	-71088
	46	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER2045A	439.3	-70288	0	0	-70288
	47	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-1	ER1683A	-54.2	8672	0	0	8672
	48	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-2	ER1685A	-27.1	4336	0	0	4336
	49	400 KV JEERAT(WB)-NEW JEERAT(PMJTL) CKT-1	ER2101A	-1.1	176	0	0	176
	50	401 KV JEERAT(WB)-NEW JEERAT(PMJTL) CKT-2	ER2103A	0	0	0	0	0
TOTAL					213232		-6176	207056

Note: 1) Rate of Reactive Energy Charge has been considered @ 16 paise/KVARh,w.e.f. 01/04/2022

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IECG, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting ,the methodology for computaion of Reactive Charges has been changed in conformity with other RPCs.