



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

75
Azadi Ka
Amrit Mahotsav



Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033

Tel. No.: 033-24239651, 24239658 FAX No.: 033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/925

Date: 20.10.2022

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 03.10.2022-09.10.2022

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 14.10.2022.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This issues with the approval of Member Secretary.

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)

SUPERINTENDING ENGINEER

14 गोल्फ क्लब रोड, टॉलीगंज, कोलकाता - 700 033 | 14 Golf Club Road, Tollygunge, Kolkata – 700 033.

Tele: 24239657, 24239651, 24239650. Fax: 24239652, 24239653. www.erpc.gov.in, Email: mserpc-power@nic.in

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 03/10/22 to 09/10/22**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)	AMOUNT RECEIVABLE(Rs.)	AMOUNT RECEIVABLE(Final After Adjustment)(Rs.)
BSPHCL	POOL	750688	0	0
JUVNL	POOL	3836784	0	0
DVC	POOL	2074064	0	0
GRIDCO	POOL	2101440	0	0
SIKKIM	POOL	0	39248	39248
WBSETCL	POOL	678496	0	0
Total		9441472	39248	39248

Note:

a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC

b) Final Receivables Amount After Adjustment from the Reactive Pool are done as per Methodology Approved in the 43rd ERPC meeting held on 26.03.2021 at Kolkata.

SUPERINTENDING ENGINEER

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 03/10/22 to 09/10/22

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVAf H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVAf (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-1577.8	252448	0	0	252448
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6068A	-1056.2	168992	0	0	168992
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-2145.5	343280	0	0	343280
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-15	2400	-0.3	-48	2352
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-30.4	4864	0	0	4864
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	-8.4	1344	0	0	1344
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-1900.8	304128	0	0	304128
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-22.9	3664	0	0	3664
	9	220 KV side of 220/132 Arah ICT-2	ER1882A	-24.2	3872	0	0	3872
	10	220 KV NAUBATPUR(BGCL) - ARAH(PG) LINE-1	ER1829A	-201.6	32256	0	0	32256
	11	220 KV NAUBATPUR(BGCL) - ARAH(PG) LINE-2	ER1871A	-204.5	32720	0	0	32720
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	3.1	-496	-70.2	-11232	-11728
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	-32.4	5184	0	0	5184
	16	220 KV NADHOKHAR(BSPHCL) - PUSAULI (PG)-2	NP8665A	-1562.1	249936	0	0	249936
	17	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	ER1872A	-5.4	864	0	0	864
	18	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	ER1873A	-5.9	944	0	0	944
	19	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1788A	1594	-255040	0	0	-255040
	20	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1608.8	-257408	0	0	-257408
	21	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1742.1	-278736	0	0	-278736
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1682.6	-269216	0	0	-269216
	23	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-43.5	6960	33.6	5376	12336
	24	HV side of 400/220 Patna ICT-1	ER1877A	0	0	0	0	0
	25	HV side of 400/220 Patna ICT-2	ER1407A	167.6	-26816	0	0	-26816
	26	HV side of 400/220 Patna ICT-3	ER1231A	144.4	-23104	0	0	-23104
	27	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	0	0	0	0	0
	28	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	0	0	0	0	0
	29	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-2695.9	431344	0	0	431344
	30	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-2427.7	388432	-0.2	-32	388400
	31	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1038.9	-166224	0	0	-166224
	32	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1038.4	-166144	0	0	-166144
	33	HV side of 400/220 Darthanaga DMTCL ICT-1	ER1274A	0	0	0	0	0
	34	HV side of 400/220 Darthanaga DMTCL ICT-2	ER1275A	0	0	0	0	0
	35	220 KV NEW PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	2674.9	-427984	0	0	-427984
	36	220 KV NEW PURNEA(PG)-KHAGARIA(BSPTCL)	ER1376A	2120.4	-339264	0	0	-339264
	37	220 KV DUMRAON NEW(BSPHCL) - ARA(PG) LINE-1	ER1305A	262	-41920	0	0	-41920
	38	220 KV NADHOKHAR(BSPHCL) - PUSAULI(PG) LINE-1	ER1310A	-2001.4	320224	0	0	320224
	39	HV side of 400/220 KV Biharsharif(PG) ICT-4	ER1386A	0	0	0	0	0
	40	400 KV SIDE OF 400/220 500 MVA GAYA(PG) ICT-3	ER1442A	0	0	0	0	0
	41	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-1	ER1247A	0.8	-128	0	0	-128
	42	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-2	ER1243A	0.6	-96	0	0	-96
	43	220 KV DUMRAON NEW(BSPHCL) - ARA (PG)-2	ER1866A	244.6	-39136	0	0	-39136
	44	400 KV SIDE OF LAKHISARAI(PG) 315 MVA 400/132 ICT-3	ER1309A	-6.3	1008	0	0	1008
	45	400 KV SIDE BANKA(PG) 400/132 KV 315 MVA ICT-3	ER1362A	0	0	0	0	0
	46	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-1	ER1395A	0	0	0	0	0
	47	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-2	ER1933A	0	0	0	0	0
	48	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-3	ER1934A	0	0	0	0	0
	49	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-2	ER1875A	18.5	-2960	0	0	-2960
	50	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-1	ER1816A	19.6	-3136	0	0	-3136
	51	400 KV HV SIDE OF 315 MVA MOTIHARI(DMTCL) ICT-3	ER1819A	1.1	-176	0	0	-176
	52	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-1	ER1806A	2147	-343520	0	0	-343520
	53	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-2	ER1823A	2025.8	-324128	0	0	-324128
	54	220 KV PUSAULI(PG)-KARAMNANA NEW(BSPHCL)	NP6092A	1734.1	-277456	0	0	-277456
	55	400 KV NAUBATPUR(BGCL)-PATNA(PG)-1	ER1879A	1135.2	-181632	0	0	-181632
	56	400 KV NAUBATPUR(BGCL)-PATNA(PG)-2	ER1848A	1130.9	-180944	0	0	-180944
	57	400 KV JAKKANPUR(BGCL)-PATNA(PG)-1	ER1941A	-189.9	30384	0	0	30384
	58	400 KV JAKKANPUR(BGCL)-PATNA(PG)-2	ER1942A	-102.5	16400	0	0	16400
	59	220 KV MUZAFFARPUR(PG)-GORAUL(BSPHCL)-1	ER1945A	-1620.4	259264	0	0	259264
		TOTAL			-744752		-5936	-750688
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-1785.8	285728	0	0	285728
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-962	153920	0	0	153920
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-1205	192800	0	0	192800
	4	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	0	0	0	0	0
	5	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	5403.4	-864544	0	0	-864544
	6	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	6364.4	-1018304	0	0	-1018304
	7	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-2	NP8637A	0	0	0	0	0
	8	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-1	NP8678A	0	0	0	0	0
	9	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	0	0	0
	10	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	0	0	0
	11	220 KV RANCHI(PG)-HATIA(JUVNL)-I	NP5879A	740.2	-118432	0	0	-118432
	12	221 KV RANCHI(PG)-HATIA(JUVNL)-II	ER1252A	6408.8	-1025408	0	0	-1025408
	13	222 KV RANCHI(PG)-HATIA(JUVNL)-III	NP7880A	6447.1	-1031536	0	0	-1031536
	14	223 KV RANCHI(PG)-CHANDIL(JUVNL)	NP5874A	1478.5	-236560	0	0	-236560
	15	400 KV RANCHI NEW(PG)-PATRATU NEW(JUVNL) LINE-1	ER1221A	597.2	-95552	0	0	-95552
	16	400 KV RANCHI NEW(PG)-PATRATU NEW(JUVNL) LINE-2	ER1230A	493.1	-78896	0	0	-78896
		TOTAL			-3836784		0	-3836784
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-1988.4	318144	0	0	318144
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	ER1668A	98	-15680	0	0	-15680
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	301.6	-48256	0	0	-48256
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	ER1711A	-599	95840	0	0	95840
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	ER1717A	-1202	192320	0	0	192320
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	ER1808A	-1975	316000	0	0	316000
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	ER1802A	0	0	0	0	0
	9	400 KV MEJIA(DVC)-MAITHON(PG)	ER1659A	0	0	0	0	0
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1657A	-1394.2	223072	0	0	223072
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1658A	-1488	238080	0	0	238080
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	ER2042A	1381	-220960	0	0	-220960
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	ER2128A	1845.9	-295344	0	0	-295344
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	ER2129A	1094.5	-175120	0	0	-175120
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	ER2130A	576.8	-92288	0	0	-92288
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-I(MAIN)	ER2046A	-2634.8	421568	0	0	421568
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	ER2044A	0	0	0	0	0
	18	400 KV RTPS(DVC)-RANCHI(PG)	ER1653A	-954.2	152672	0	0	152672
	19	400 KV RTPS(DVC)-MAITHON(PG)	ER1652A	8755.6	-1400896	0	0	-1400896
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	ER1656A	-757.9	121264	0	0	121264
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	6205.1	-992816	0	0	-992816
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	6980.5	-1116880	0	0	-1116880
	23	220 KV RANCHI(PG)-RAMGARH(DVC)	ER1798A	-2777.4	444384	0	0	444384
	24	221 KV RANCHI(PG)-MTPS(DVC)	ER1796A	1494.8	-239168	0	0	-239168
		TOTAL			-2074064		0	-2074064

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-1 AND ICT-3	ER1563A	0	0	0	0	0
	2	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-2 AND ICT-4	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	400 KV SIDE OF JEYPORE (PG) 400/220 KV ICT-1 AND ICT-3	ER2062A	5202.5	-832400	0	0	-832400
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	4209.4	-673504	0	0	-673504
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	ER1759A	4849.9	-775984	0	0	-775984
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	0	0	0	0	0
	9	HV side meter of 400/220 Baripada ICT-2	ER1746A	0	0	0	0	0
	10	HV side meter of 400/220 Baripada ICT-3	ER1747A	0	0	0	0	0
	11	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	12	400 KV DUBURI (GRIDCO) - BARIPADA(PG)	ER1900A	-2148.7	343792	0	0	343792
	13	400 KV MERAMUNDALI (GRIDCO)-BOLANGIR(PG)	ER1054A	0	0	0	0	0
	14	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)-2	ER1055A	1420.3	-227248	0	0	-227248
	15	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	ER1758A	825.1	-132016	0	0	-132016
	16	400 KV MENDHASAL (GRIDCO) - PANDIABIL(PG)-I	ER2072A	-199.6	31936	0	0	31936
	17	400 KV MENDHASAL (GRIDCO) - PANDIABIL(PG)-II	ER2071A	-182.2	29152	0	0	29152
	18	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	ER1897A	-1662.9	266064	0	0	266064
	19	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	20	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	21	HV side of 400/220 Pandiabil ICT-1	ER1583A	789.7	-126352	0	0	-126352
	22	HV side of 400/220 Pandiabil ICT-2	ER1776A	762.9	-122064	0	0	-122064
	23	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	0	0	0	0	0
	24	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	0	0	0	0	0
	25	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	26	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	27	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	-341.1	54576	0	0	54576
	28	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	-391.3	62608	0	0	62608
		TOTAL		-2101440	0	0	-2101440	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-222.80	35648	0	0	35648
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-22.50	3600	0	0	3600
	3	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	ER1490A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	ER1489A	0.00	0	0	0	0
		TOTAL		39248	0	0	39248	
WBSETCL	1	400 KV JEERAT (WBSETCL) - RAJARAHAT(PG)	ER1471A	0	0	-0.7	-112	-112
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	6.5	-1040	0	0	-1040
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	0	0	0	0	0
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1846.9	295504	0	0	295504
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1903.6	304576	0	0	304576
	6	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-113.2	18112	0	0	18112
	7	132 KV SILIGURI (PG) - NBU (WBSETCL)	ER1675A	-351.3	56208	0	0	56208
	8	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-1579.3	252688	0	0	252688
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	0	0	0	0	0
	10	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	ER1739A	-5.8	928	0	0	928
	11	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	ER2039A	1098.2	-175712	0	0	-175712
	12	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	13	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	ER2109A	9746.9	-1559504	0	0	-1559504
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	ER2111A	0	0	0	0	0
	15	400 KV SAGARDIGHI(WB) - FARAKKA (NTPC)-1(MAIN)	NP6482A	0	0	0	0	0
	16	400 KV JEERAT(PG) - SUBHASGRAM (PG)	ER1477A	0	0	0	0	0
	17	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	ER2122A	81	-12960	0	0	-12960
	18	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	ER2096A	-169.1	27056	0	0	27056
	19	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	86.6	-13856	0	0	-13856
	20	400 KV DURGAPUR(PG)-SAGARDIGHI(WBSETCL)-I	NP6548A	0	0	0	0	0
	21	400 KV DURGAPUR(PG)-SAGARDIGHI(WBSETCL)-II	ER1637A	50.2	-8032	0	0	-8032
	22	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-641.9	102704	0	0	102704
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-200.6	32096	0	0	32096
	24	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	ER1486A	2	-320	0	0	-320
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	ER1537A	2.8	-448	0	0	-448
	26	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	ER1484A	1.8	-288	0	0	-288
	27	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	15.7	-2512	0	0	-2512
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	ER1679A	0	0	0	0	0
	29	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-I	NP8723A	0	0	0	0	0
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-II	NP8724A	0	0	0	0	0
	31	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-1063.1	170096	0	0	170096
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-939.7	150352	0	0	150352
	33	400 KV PPS NEW(WB)-RANCHI NEW(PG)-I	ER1040A	364.5	-58320	0	0	-58320
	34	400 KV PPS NEW(WB)-RANCHI NEW(PG)-II	ER1130A	395	-63200	0	0	-63200
	35	400 KV GOKARNA(WB)-RAJARHAT(PG)	ER1133A	-168.1	26896	0	0	26896
	36	400 KV GOKARNA(WB)-PURNEA(PG)	ER1138A	-51.3	8208	0	0	8208
	37	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	0	0	0	0	0
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	0	0	0	0	0
	39	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	0	0	0	0	0
	40	HV side of 400/220 KV RAJARHAT(PG) ICT-1	ER1526A	0	0	0	0	0
	41	220 KV SIDE OF 50 MVA MALDA(PG) 220/132 ICT-4	ER1639A	-1314.8	210368	0	0	210368
	42	400 KV SIDE OF RAJARHAT(PG) 400/220 500 MVA ICT-2	ER1650A	0	0	0	0	0
	43	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	348.9	-55824	0	0	-55824
	44	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	316.8	-50688	0	0	-50688
	45	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER2125A	1035.7	-165712	0	0	-165712
	46	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER2045A	1036	-165760	0	0	-165760
	47	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-1	ER1683A	0	0	0	0	0
	48	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-2	ER1685A	0	0	0	0	0
	49	400 KV JEERAT(WB)-NEW JEERAT(PM/JTL) CKT-1	ER2101A	0	0	0	0	0
	50	401 KV JEERAT(WB)-NEW JEERAT(PM/JTL) CKT-2	ER2103A	0	0	0	0	0
		TOTAL		-678384	-112	-112	-678496	

Note: 1) Rate of Reactive Energy Charge has been considered @ 16 paise/KVARH,w.e.f. 01/04/2022

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an IGS have not been considered for computation of reactive exchange with ISTs.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.