



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

75
Azadi Ka
Amrit Mahotsav



Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033

Tel. No.: 033-24239651, 24239658 FAX No.: 033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/1034

Date: 10.11.2022

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 24.10.2022-30.10.2022

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 04.11.2022.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This issues with the approval of Member Secretary.

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)

SUPERINTENDING ENGINEER

14 गोल्फ क्लब रोड, टॉलीगंज, कोलकाता - 700 033 | 14 Golf Club Road, Tollygunge, Kolkata – 700 033.

Tele: 24239657, 24239651, 24239650. Fax: 24239652, 24239653. www.erpc.gov.in, Email: mserpc-power@nic.in

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 24/10/22 to 30/10/22**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)	AMOUNT RECEIVABLE(Rs.)	AMOUNT RECEIVABLE(Final After Adjustment)(Rs.)
BSPHCL	POOL	2743776	0	0
JUVNL	POOL	3209232	0	0
DVC	POOL	0	1510368	1510368
GRIDCO	POOL	2941584	0	0
SIKKIM	POOL	0	121040	121040
WBSETCL	POOL	1978544	0	0
Total		10873136	1631408	1631408

Note:

a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC

b) Final Receivables Amount After Adjustment from the Reactive Pool are done as per Methodology Approved in the 43rd ERPC meeting held on 26.03.2021 at Kolkata.

SUPERINTENDING ENGINEER

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 24/10/22 to 30/10/22

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVA/H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVA/H (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-4094.8	655168	0	0	655168
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-1238	198080	0	0	198080
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-5044	807040	0	0	807040
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-138.2	22112	0	0	22112
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-221.1	35376	0	0	35376
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	-76	12160	0	0	12160
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-493.3	78928	0	0	78928
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-385.2	61632	0	0	61632
	9	220 KV side of 220/132 Arah ICT-2	ER1882A	-397.8	63648	0	0	63648
	10	220 KV NAUBATPUR(BGCL) - ARAH(PG) LINE-1	ER1829A	-392.7	62832	0	0	62832
	11	220 KV NAUBATPUR(BGCL) - ARAH(PG) LINE-2	ER1871A	-396.8	63488	0	0	63488
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	0.5	-80	-67.2	-10752	-10832
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	-550.2	88032	0	0	88032
	16	220 KV NADHOKHAR(BSPHCL) - PUSAULI (PG)-2	NP8665A	318.1	-50896	0	0	-50896
	17	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	ER1872A	-260.9	41744	0	0	41744
	18	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	ER1873A	-271.3	43408	0	0	43408
	19	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1788A	2690.5	-430480	0	0	-430480
	20	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	2702.4	-432384	0	0	-432384
	21	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	2912.7	-466032	0	0	-466032
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	2875.9	-460144	0	0	-460144
	23	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-18.8	3008	38.7	6192	9200
	24	HV side of 400/220 Patna ICT-1	ER1877A	0	0	0	0	0
	25	HV side of 400/220 Patna ICT-2	ER1407A	1499.9	-239984	0	0	-239984
	26	HV side of 400/220 Patna ICT-3	ER1231A	1401.5	-224240	0	0	-224240
	27	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	82	-13120	0	0	-13120
	28	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	85.5	-13680	0	0	-13680
	29	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1596.8	255488	0	0	255488
	30	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1776.1	284176	0	0	284176
	31	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1682.4	-269184	0	0	-269184
	32	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1688.9	-270224	0	0	-270224
	33	HV side of 400/220 Darthanaga DMTCL ICT-1	ER1274A	2.2	-352	0	0	-352
	34	HV side of 400/220 Darthanaga DMTCL ICT-2	ER1275A	10.2	-1632	0	0	-1632
	35	220 KV NEW PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	2814.4	-450304	0	0	-450304
	36	220 KV NEW PURNEA(PG)-KHAGARIA(BSPTCL)	ER1376A	2791.3	-446608	0	0	-446608
	37	220 KV DUMRAON NEW(BSPHCL) - ARA(PG) LINE-1	ER1305A	49.5	-7920	0	0	-7920
	38	220 KV NADHOKHAR(BSPHCL) - PUSAULI(PG) LINE-1	ER1310A	516.3	-82608	0	0	-82608
	39	HV side of 400/220 KV Biharsharif(PG) ICT-4	ER1386A	0	0	0	0	0
	40	400 KV SIDE OF 400/220 500 MVA GAYA(PG) ICT-3	ER1442A	0	0	0	0	0
	41	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-1	ER1247A	-50.2	8032	0	0	8032
	42	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-2	ER1243A	-48.7	7792	0	0	7792
	43	220 KV DUMRAON NEW(BSPHCL) - ARA (PG)-2	ER1866A	47.5	-7600	0	0	-7600
	44	400 KV SIDE OF LAKHISARAI(PG) 315 MVA 400/132 ICT-3	ER1309A	-349	55840	0	0	55840
	45	400 KV SIDE BANKA(PG) 400/132 KV 315 MVA ICT-3	ER1362A	172.1	-27536	0	0	-27536
	46	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-1	ER1395A	0	0	0	0	0
	47	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-2	ER1933A	0	0	0	0	0
	48	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-3	ER1934A	0	0	0	0	0
	49	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-2	ER1875A	493.2	-78912	0	0	-78912
	50	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-1	ER1816A	553.2	-88512	0	0	-88512
	51	400 KV HV SIDE OF 315 MVA MOTIHARI(DMTCL) ICT-3	ER1819A	-85.3	13648	0	0	13648
	52	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-1	ER1806A	5957.5	-953200	0	0	-953200
	53	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-2	ER1823A	5883.3	-941328	0	0	-941328
	54	220 KV PUSAULI(PG)-KARAMNASA NEW(BSPHCL)	NP6092A	1191.3	-196080	0	0	-196080
	55	400 KV NAUBATPUR(BGCL)-PATNA(PG)-1	ER1879A	3455.4	-552864	0	0	-552864
	56	400 KV NAUBATPUR(BGCL)-PATNA(PG)-2	ER1848A	3479.3	-556688	0	0	-556688
	57	400 KV JAKKANPUR(BGCL)-PATNA(PG)-1	ER1941A	-6064	970240	0	0	970240
	58	400 KV JAKKANPUR(BGCL)-PATNA(PG)-2	ER1942A	-5377.5	860400	0	0	860400
	59	220 KV MUZAFFARPUR(PG)-GORAUL(BSPHCL)-1	ER1945A	1089.8	-174368	0	0	-174368
		TOTAL			-2739216		-4560	-2743776
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-3875.5	620080	0	0	620080
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-3081.9	493104	0	0	493104
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-3041.7	486672	0	0	486672
	4	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	0	0	0	0	0
	5	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	5662	-905920	0	0	-905920
	6	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	6379.2	-1020672	0	0	-1020672
	7	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-2	NP8637A	389.2	-62272	0	0	-62272
	8	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-1	NP8678A	260.3	-41648	0	0	-41648
	9	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	0	0	0
	10	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	0	0	0
	11	220 KV RANCHI(PG)-HATIA(JUVNL)-I	NP5879A	744	-119040	0	0	-119040
	12	221 KV RANCHI(PG)-HATIA(JUVNL)-II	ER1252A	6183.4	-989344	0	0	-989344
	13	222 KV RANCHI(PG)-HATIA(JUVNL)-III	NP7880A	6220.3	-995248	0	0	-995248
	14	223 KV RANCHI(PG)-CHANDIL(JUVNL)	NP5874A	1960.3	-313648	0	0	-313648
	15	400 KV RANCHI NEW(PG)-PATRATU NEW(JUVNL) LINE-1	ER1221A	1196.4	-191424	0	0	-191424
	16	400 KV RANCHI NEW(PG)-PATRATU NEW(JUVNL) LINE-2	ER1230A	1061.7	-169872	0	0	-169872
		TOTAL			-3209232		0	-3209232
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-3184.6	509536	0	0	509536
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	ER1668A	88.4	-14144	0	0	-14144
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	0	0	0	0	0
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	ER1711A	-930	148800	0	0	148800
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	ER1717A	-1456.8	233088	0	0	233088
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	ER1808A	-2010.8	321728	0	0	321728
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	ER1802A	0	0	0	0	0
	9	400 KV MEJIA(DVC)-MAITHON(PG)	ER1659A	0	0	0	0	0
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1657A	-2336	373760	0	0	373760
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1658A	-2398.5	383760	0	0	383760
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	ER2042A	-310.5	49680	0	0	49680
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	ER2128A	-351.3	56208	0	0	56208
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	ER2129A	-2783.2	445312	0	0	445312
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	ER2130A	-1109.8	177568	0	0	177568
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-I(MAIN)	ER2046A	-2988.4	478144	0	0	478144
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	ER2044A	0	0	0	0	0
	18	400 KV RTPS(DVC)-RANCHI(PG)	ER1653A	-2474.2	395872	0	0	395872
	19	400 KV RTPS(DVC)-MAITHON(PG)	ER2682A	2309.1	-369456	0	0	-369456
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	ER1656A	-2279.2	364672	0	0	364672
	21	400 KV RANCHI(PG)-RTPS(DVC)-I	NP7871A	6522.8	-1043648	0	0	-1043648
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	7005.9	-1120944	0	0	-1120944
	23	220 KV RANCHI(PG)-RAMGARH(DVC)	ER1798A	-2611.6	417856	0	0	417856
	24	221 KV RANCHI(PG)-MTPS(DVC)	ER1796A	1858.9	-297424	0	0	-297424
		TOTAL			1510368		0	1510368

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-1 AND ICT-3	ER1563A	0	0	0	0	0
	2	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-2 AND ICT-4	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	400 KV SIDE OF JEYPORE (PG) 400/220 KV ICT-1 AND ICT-3	ER2062A	5194.7	-831152	0	0	-831152
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	4145.1	-663216	0	0	-663216
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	ER1759A	5356.7	-857072	0	0	-857072
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	0.9	-144	0	0	-144
	9	HV side meter of 400/220 Baripada ICT-2	ER1746A	0	0	0	0	0
	10	HV side meter of 400/220 Baripada ICT-3	ER1747A	0	0	0	0	0
	11	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	12	400 KV DUBURI (GRIDCO)-BARIPADA(PG)	ER1900A	-2731	436960	0	0	436960
	13	400 KV MERAMUNDALI (GRIDCO)-BOLANGIR(PG)	ER1054A	0	0	0	0	0
	14	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)-2	ER1055A	3132	-501120	0	0	-501120
	15	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	ER1758A	1733.9	-277424	0	0	-277424
	16	400 KV MENDHASAL (GRIDCO)-PANDIABIL(PG)-I	ER2072A	-462.2	73952	0	0	73952
	17	400 KV MENDHASAL (GRIDCO)-PANDIABIL(PG)-II	ER2071A	-496.3	79408	0	0	79408
	18	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	ER1897A	0	0	0	0	0
	19	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	-5.7	912	-2.8	-448	464
	20	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	-5.2	832	-2.8	-448	384
	21	HV side of 400/220 Pandiabil ICT-1	ER1583A	1490.9	-238544	0	0	-238544
	22	HV side of 400/220 Pandiabil ICT-2	ER1776A	1443.5	-230960	0	0	-230960
	23	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	0	0	0	0	0
	24	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	0	0	0	0	0
	25	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	26	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	27	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	-234.1	37456	0	0	37456
	28	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	-183.9	29424	0	0	29424
		TOTAL		-2940688		-896	-2941584	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-378.20	60512	0	0	60512
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-58.00	9280	0	0	9280
	3	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	ER1490A	-160.20	25632	0	0	25632
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	ER1489A	-160.10	25616	0	0	25616
		TOTAL		121040		0	121040	
WBSETCL	1	400 KV JEERAT (WBSETCL) - RAJARAHAT(PG)	ER1471A	0	0	18.9	3024	3024
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	598.9	-95824	0	0	-95824
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	417.5	-66800	0	0	-66800
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-2330.8	372928	0	0	372928
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-2351.3	376208	0	0	376208
	6	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-1077.9	172464	0	0	172464
	7	132 KV SILIGURI (PG) - NBU (WBSETCL)	ER1675A	-1279.2	204672	0	0	204672
	8	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2062.5	330000	0	0	330000
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-118.2	18912	0	0	18912
	10	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	ER1739A	4543	-726880	0	0	-726880
	11	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	ER2039A	3364.9	-538384	0	0	-538384
	12	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	13	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	ER2109A	6617.5	-1058800	0	0	-1058800
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	ER2111A	463.7	-74192	0	0	-74192
	15	400 KV SAGARDIGHI(WB) - FARAKKA (NTPC)-1(MAIN)	NP6482A	0	0	0	0	0
	16	400 KV JEERAT(PG) - SUBHASGRAM (PG)	ER1477A	0	0	0	0	0
	17	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	ER2122A	107.2	-17152	0	0	-17152
	18	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	ER2096A	-267.5	42800	0	0	42800
	19	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	188.4	-30144	0	0	-30144
	20	400 KV DURGAPUR(PG)-SAGARDIGHI(WBSETCL)-I	NP6548A	72.4	-11584	0	0	-11584
	21	400 KV DURGAPUR(PG)-SAGARDIGHI(WBSETCL)-II	ER1637A	1116	-178560	0	0	-178560
	22	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-800.8	128128	0	0	128128
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-479.3	76688	0	0	76688
	24	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	ER1486A	401.7	-64272	0	0	-64272
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	ER1537A	418	-66880	0	0	-66880
	26	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	ER1484A	645.1	-103216	0	0	-103216
	27	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	395.8	-63328	0	0	-63328
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	ER1679A	21.1	-3376	0	0	-3376
	29	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-I	NP8723A	0	0	0	0	0
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-II	NP8724A	0	0	0	0	0
	31	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	0	0	0	0	0
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	0	0	0	0	0
	33	400 KV PPS NEW(WB)-RANCHI NEW(PG)-I	ER1040A	93.9	-15024	0	0	-15024
	34	400 KV PPS NEW(WB)-RANCHI NEW(PG)-II	ER1130A	110.2	-17632	0	0	-17632
	35	400 KV GOKARNA(WB)-RAJARAHAT(PG)	ER1133A	-2257.1	361136	0	0	361136
	36	400 KV GOKARNA(WB)-PURNEA(PG)	ER1138A	-439.6	70336	0	0	70336
	37	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	0	0	0	0	0
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	433.1	-69296	0	0	-69296
	39	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	-1096.6	175456	0	0	175456
	40	HV side of 400/220 KV RAJARAHAT(PG) ICT-1	ER1526A	36	-5760	0	0	-5760
	41	220 KV SIDE OF 50 MVA MALDA(PG) 220/132 ICT-4	ER1639A	-1612.7	258032	0	0	258032
	42	400 KV SIDE OF RAJARAHAT(PG) 400/220 500 MVA ICT-2	ER1650A	0.4	-64	0	0	-64
	43	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	1574.3	-251888	0	0	-251888
	44	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	1527.1	-244336	0	0	-244336
	45	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER2125A	2710.6	-433696	0	0	-433696
	46	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER2045A	2701.5	-432240	0	0	-432240
	47	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-1	ER1683A	0	0	0	0	0
	48	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-2	ER1685A	0	0	0	0	0
	49	400 KV JEERAT(WB)-NEW JEERAT(PM/JTL) CKT-1	ER2101A	0	0	0	0	0
	50	401 KV JEERAT(WB)-NEW JEERAT(PM/JTL) CKT-2	ER2103A	0	0	0	0	0
		TOTAL		-1981568		3024	-1978544	

Note: 1) Rate of Reactive Energy Charge has been considered @ 16 paise/KVARH, w.e.f. 01/04/2022

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an IGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.