

भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power पूर्वी क्षेत्रीय विद्युत समिति





Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टालीगज, कोलकाता-700033

Tel. No.: 033-24239651,24239659 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

सं./NO. पू.क्षे.वि.स./PROTECTION/2023/13 9 6

दिनांक /DATE: 03.02.2023

सेवा में / To. संलग्न सूची के अनुसार / As per list enclosed.

विषय : पू. क्षे.वि.स. की 123 वीं संरक्षण समन्वय उप-समिति (पीसीसी) की बैठक हेतु सूचना 1

Sub: Notice for 123rd Protection Coordination sub-Committee (PCC) meeting of ERPC.

Sir/Madam.

Notice is hereby given that 123rd PCC meeting of ERPC will be held in physical mode on 21st February 2023 (Tuesday) at 11:00 hrs at ERPC Conference Hall, Kolkata.

The tentative agenda items for discussion will be as follows:

- 1) Confirmation of the minutes of 122nd Protection sub-Committee Meeting of ERPC
- 2) Analysis of following grid disturbances of January 2023:
- ➤ Disturbance at 220 kV Bantala (WBSETCL) S/s on 04.01.23 at)4:42 hrs and at 05:42 hrs.
- Disturbance at 220 kV Ramchandrapur S/s(JUSNL) on 04.01.23 at 13:41 hrs and at 14:24 hrs
- 3) Follow up of decision of previous Protection Coordination sub-Committee Meetings.
- 4) Single line tripping incidences of transmission elements for January 2023 as enclosed at Annexure-1.

You are requested to kindly furnish the detail report along with all records (SLD, SOE, DR, Relay and schematic diagram of auxiliary supply, wherever applicable) related to above tripping well in advance for meaningful analysis. You are also requested to upload the details in on-line tripping incident reporting system implemented in Protection Database Management System(www.erpcprotectiondb.in.)

Your participation in the meeting is highly solicited.

भवदीय / Yours faithfully,

(पी.पी.जेना / P.P.Jena) **Executive Engineer (PS)** कार्यपालक अभियंता(पी.एस)

14 गोल्फ क्लब रोड, टॉलीगंज, कोलकाता - 700 033 । 14 Golf Club Road, Tollygunge, Kolkata – 700 033.

Tele: 24239657, 24239651, 24239650. Fax: 24239652, 24239653. www.erpc.gov.in, Email: mserpc-power@nic.in

Annexure 1

List of important transmission lines in ER which tripped in January-2023 D R Co DR/ DR/ EL EL RE RE UT **Fault** CEI CEI Relay VE VE Clear REST TRIP TRIP RESTORA D **Indication** LINE **Relay Indication** ORA ance RE TION Remarks FR FR as DATE TIME TION LOCAL END time **NAME** REMOTE DATE OM OM TIME on in RE **END** LO MO CA msec SE TE L re EN EN pa D D nc After 200 msec of fault in Patna: DT received Barh-Kahalgaon, tie bay LBB operated. 400 KV BARH-No PATNA-1 01-01-2023 02:48 01-01-2023 04:24 fault NA Yes Yes After 200 msec, LBB of tie Barh: Y_N, Zone-1, 10.28 km, bay operated. LBB logic was Kahalgaon: DT received 400 KV BARH-19.59 kA rectified. Barh may explain. Y-KAHALGAON (KHSTPP)-1 01-01-2023 Earth 01-01-2023 02:48 04:33 100 Yes No After 200 msec of fault in Barh-Kahalgaon, tie bay Patna: DT received 400 KV BARH-No LBB operated. 3 PATNA-1 01-01-2023 04:38 01-01-2023 06:02 fault NA Yes Yes

400 KV BARH- KAHALGAON (KHSTPP)-1	01-01-2023	04:38	01-01-2023		Barh: Y_N, Zone-1, 10.08 km, 20.33 kA	Kahalgaon: DT received	Y- Earth	100	After 200 msec, LBB of tie bay operated. LBB logic was rectified. Barh may explain.	Yes	No
400 KV BIHARSHARIF- VARANASI-2	01-01-2023	06:26	01-01-2023		Biharsharif: B_N, 112.5 km, 3.345 kA		B- Earth	100	A/r failed after 1 second	Yes	NA
220 KV SUBHASHGRAM- BARUIPUR-1	01-01-2023	17:04	02-01-2023		Subnasngram: R_Y, 1.2 km, Ir:	Baruipur: R_Y, Zone-2, 29.35 km, Ir: 5.45 kA, Iy: 5.6 kA	R-Y	100	Phase to phase fault	No	Yes
400 KV BIHARSHARIF- VARANASI-2	01-01-2023	23:25	02-01-2023		Biharsharif: B_N, 36.59 km, 7.433 kA		B- Earth	100	A/r failed after 1 second	Yes	NA
400 KV MUZAFFARPUR- GORAKHPUR-1	02-01-2023	00:20	02-01-2023		Muzaffarpur: Y_N, 261 km (100%), 1.732 kA	Gorakhpur: Y_N, 2 km, 16 kA	Y- Earth	100	A/r failed after 1 second	Yes	NA
400 KV SASARAM- ALLAHABAD-1	02-01-2023	00:40	02-01-2023	10:48	Sasaram: Y_N, 22.6 km, 3.5 kA		Y- Earth	100	A/r failed after 1 second	Yes	
400 KV BIHARSHARIF- VARANASI-1	02-01-2023	00:46	02-01-2023		Biharsharif: R_N, 52.31 km, 6.036 km		R- Earth	100	A/r failed after 1 second	Yes	NA

11	400 KV BIHARSHARIF- SASARAM-2	02-01-2023	01:18	02-01-2023		Biharsharif: Tie bay LBB operated. 400 kV Biharsharif- Balia-2 is in same dia	Sasaram: DT received	No fault	NA	During A/r of 400 kV Biharsharif-Balia-2, tie bay LBB operated at Biharsharif. PG ER-1 may explain.	Y	<i>Y</i> es	Yes
12	400 KV BIHARSHARIF- BALIA-2	02-01-2023	01:18	02-01-2023		Biharsharif: Y_N, 0.5 km, 20.38 kA		Y- Earth	100	Fault in Y_ph during A/r	Y	Yes !	NA
13	400 KV BIHARSHARIF- KODERMA-2	02-01-2023	02:18	02-01-2023		Biharsharif: Y_N, 17.9 km, 7.3 kA	Koderma: Y_N, 18.8 km, 6.6 kA	Y- Earth	100	A/r successful from Biharsharif only. Other two phase tripped at Koderma after 3.5 seconds. PD time may be reviewed by DVC.	Y	Zes -	Yes
14	400 KV BIHARSHARIF- KODERMA-1	02-01-2023	02:34	02-01-2023	18:11		Koderma: Y_N, 96.7 km, 6.92 kA	Y- Earth	100	Three phase tripping at Biharsharif, A/r successful from Koderma.	Y	Yes	Yes

	400 KV BIHARSHARIF- KODERMA-2	02-01-2023	03:45	02-01-2023	05:08		Koderma: Y_N, 100.75 km, 4.32 kA	Y- Earth	100	A/r successful from Biharsharif only. Other two phase tripped at Koderma after 3.5 seconds. PD time may be reviewed by DVC.	Yes	Yes
	400 KV NEW PURNEA- FARAKKA-1	02-01-2023	04:36	03-01-2023	14:28	10.2 kA, Ib: 10.12 kA	Farakka: R_B, 130 km, Ir: 4.45 kA, Ib: 4.25 kA	R-B	100	Phase to phase fault	Yes	Yes
	400 KV NEW PURNEA- MUZAFFARPUR- 1	02-01-2023	08:00	03-01-2023		New Purnea: Y_N, 169 km, 2.04 kA	57.29 km, 6.346 kA	Y- Earth	100	A/r failed after 1 second	No	Yes
18	400 KV ARAMBAG- BAKRESWAR-1	03-01-2023	05:18	03-01-2023		kA	Bakreswar: R_N, 52.5 km, 4.31 kA	R- Earth	100	A/r failed after 1 second	Yes	No
	400 KV FARAKKA- RAJARHAT-1	03-01-2023	06:14	03-01-2023		Farakka: Y_N, 2 kA	Rajarhat: Y_N, 169 km, 2.46 kA	Y- Earth	100	A/r failed after 1 second	Yes	Yes

					Ranchi: R_N, A/r successful	Ramgarh: R_N, 22.35 km			Three phase tripping at Ramgarh. A/r attempted but only 2 phase closed. DVC may explain.		
220 KV RANCHI- RAMGARH-1	05-01-2023	02:35	05-01-2023	03:21			R- Earth	100		Yes	Yes
400 KV SASARAM- BRBCL-2	07-01-2023	02:58	08-01-2023	17:00	Sasaram: R_N, 51.35 km, 5.7 kA		R- Earth	100	A/r failed after 1 second	Yes	No
400 KV BIHARSHARIF- VARANASI-1	07-01-2023	04:21	07-01-2023	21:45	Biharsharif: Y_N, 152.49 km, 2.79 kA		Y- Earth	100	A/r failed after 1 second	Yes	NA
400 KV BIHARSHARIF- VARANASI-1	09-01-2023	06:13	09-01-2023		Biharsharif: Y_N, 148.8 km, 2.9 kA		Y- Earth	100	A/r failed after 1 second	Yes	NA
400 KV BIHARSHARIF- VARANASI-2	10-01-2023	00:24	11-01-2023	00:19	Biharsharif: R_N, 172 km, 2.5 kA	Varanasi: R_N, 128 km, 3.5 kA	R- Earth	100	A/r failed after 1 second	Yes	NA
400 KV BIHARSHARIF- VARANASI-1	10-01-2023	01:56	10-01-2023		Biharsharif: Y_N, 156 km, 2.6 kA		Y- Earth	100	A/r failed after 1 second	Yes	NA
SASARAM- BRBCL-1	10-01-2023	02:46	10-01-2023	17:37	Sasaram: Y N 50 8 km 6 4 kA	BRBCL: Y_N, 47 km, 4.07 kA	Y- Earth	100	A/r failed after 1 second	Yes	No
400 KV SASARAM- DALTONGANJ-2	10-01-2023	03:24	10-01-2023		Sasaram: Y_N, 7.54 km, 13.15 kA		Y- Earth	100	A/r failed after 1 second	Yes	No
400 KV BIHARSHARIF- KODERMA-2	10-01-2023	05:57	10-01-2023		kA, A/r successful	Koderma: Y_N, 85.17 km, 4.45 kA	Y- Earth		A/r successful from Biharsharif only. Other two phase tripped at Koderma after 3.5 seconds. PD time may be reviewed by DVC.	Yes	Yes

400 KV BIHARSHARIF- 29 KODERMA-2	11-01-2023	03:50	11-01-2023		Biharsharif: Y_N, 18.18 km, 8.66 kA, A/r successful	Koderma: Y_N, 85.66 km, 4.37 kA	Y- Earth	100	A/r successful from Biharsharif only. Other two phase tripped at Koderma after 3.5 seconds. PD time may be reviewed by DVC.	Y	es N	Yes
765 KV GAYA- 30 VARANASI-2	11-01-2023	04:31	11-01-2023		Gaya: R_N, 236.7 km, 3.6 kA	Varanasi: A/r successful	R- Earth	100	Three phase tripping for single phase fault. PG ER-1 may explain.	Y	es 1	NA
400 KV BIHARSHARIF- 31 KODERMA-2	11-01-2023	04:49	11-01-2023		Biharsharif: Y_N, 18.79 km, 9.52 kA	Koderma: Y_N, 74.4 km, 6.02 kA	Y- Earth	100	A/r failed after 1 second	Y	es Y	Yes
220 KV KARMNASHA- 32 SAHUPURI-1	12-01-2023	05:14	12-01-2023		Karmnasha: Didn't trip	Sahupuri: R_N, 36.36 km, 3.211 kA	R- Earth	100	A/r couldn't be ascertained from PMU. BSPTCL may confirm.	N	o M	NA
400 KV NORTH KARNPURA- 33 CHANDWA-1	12-01-2023	12:27	12-01-2023	13:03		Chandwa: DT received	No fault	NA	JUSNL/NTPC may explain	N	o l	No
220 KV MUZAFFARPUR- 34 HAZIPUR-2	12-01-2023	13:04	12-01-2023	14:26	Muzaffarpur: DT received	Hazipur: Bus bar protection operated	No fault	NA	BSPTCL may explain	N	o I	NA

220 KV RANCHI- 35 RAMGARH-1	12-01-2023	16:20	12-01-2023	16:35	Ranchi: DT received		No fault	NA	DVC may explain		Yes	NA
400 KV NEW DUBURI- MERAMUNDALI- 36 1	14-01-2023	05:06	14-01-2023	19:13	New Duburi: B_N, 30.6 km, 9.06 kA, A/r attempt unsuccessful		B- Earth	100	A.r failed after 1 sec		Yes	Yes
220 KV NEW PURNEA- 37 KHAGARIA-1	14-01-2023	06:26	14-01-2023	07:51	New Purnea: B_N, 94.5 km, 2.35 kA	6.31 kA, A/r successful	B- Earth	350	Tripped in Zone-2 time from New Purnea. A/r successful from Khagaria.		Yes	Yes
400 KV RANGPO- 38 TEESTA 3-1	14-01-2023	16:51	15-01-2023	11:00	Rangpo: R_N, 38.06 km, 4.96 kA		R- Earth	100	A/r under shutdown for OPGW work	,	Yes	Yes
220 KV RAJARHAT- 39 BARASAT-1	15-01-2023	03:49	15-01-2023	07:49	Rajarhat: B_N, 3 km, 14.4 kA	Barasat: B_N, Zone-2, 16 km, 5 kA	B- Earth	100	Three phase tripping for single phase fault. DT received at Rajarhat after 150 msec. WBSETCL may explain.		Yes	Yes
220 KV MUZAFFARPUR- 40 HAZIPUR-2	15-01-2023	22:59	15-01-2023	23:21	Muzaffarpur: DT received		No fault	NA	BSPTCL may explain		No	NA
220 KV MUZAFFARPUR- 41 HAZIPUR-2	15-01-2023	23:52	16-01-2023	18:39	Muzaffarpur: DT received		No fault	NA	BSPTCL may explain	-	No	NA

	220 KV SANTALDIH- CHANDIL-1	18-01-2023	05:19	18-01-2023	11:53	Santaldih: R_N, 22.9 km	Chandil: R_N, 82 km, 1.09 kA	R- Earth	100	Other two phase at Chandil tripped after 200 msec. JUSNL/WBPDCL may explain.	No	Yes	5
	400 KV KOLAGHAT- KHARAGPUR-1	18-01-2023	07:10	18-01-2023	07:22	Tripped during diversion through TBC at Kolaghat		No fault	NA	WBPDCL may explain	No	Yes	S
44	400 KV RANGPO- TEESTA 3-1	18-01-2023	14:45	18-01-2023	16:13	Rangpo: R_N, 42.77 km, 5.3 kA	2.0.101	R- Earth	100	A/r under shutdown for OPGW work	Ye	s Yes	S
	220 KV JEYPORE- JAYNAGAR-1	19-01-2023	13:25	19-01-2023	13:58	Jeypore: Didn't trip	Jayanagar: DT received	No fault	NA	After bay swapping b/w Ckt-1 & 2, necessary changes in carrier protection was not done. OPTCL may explain.	N.A	No	
	400 KV RANCHI- RAGHUNATHPU R-1	19-01-2023	16:19	19-01-2023		Ranchi: DT received	Raghunathpur: Didn't trip	No fault	NA	DVC may explain	Ye	s NA	L
	400 KV SASARAM- ALLAHABAD-1	21-01-2023	00:15	21-01-2023	01:06	Sasaram: R_B, 101.4 km, Ir: 2.2 kA, Ib: 2.3 kA		R-B	100	Phase to phase fault	Ye	s NA	
	220 KV JODA- RAMCHANDRA PUR-1	22-01-2023	13:20	22-01-2023	14:35	Joda: R_N, 2.058 km, 5.745 kA	Ramchandrapur: R_N, Zone-2, 122 km, 1.35 kA	R- Earth	400	Tripped in Zone-2 time from Ramchandrapur.	No	Yes	3

	1	1							1	1			-
49	400 KV BARH- MOTIHARI-1	23-01-2023	02:25	23-01-2023	02:55		Motihari: R_Y, 8.9 km, Ir: 11.75 kA, Iy: 12.15 kA	R-Y	100	Phase to phase fault	Y	es `	Yes
	220 KV MUZAFFARPUR- HAZIPUR-2	23-01-2023	12:33				Hazipur: B_N, 24.7 km, 3.11 kA	B- Earth	100	A/r couldn't be ascertained from PMU. PG ER-1/BSPTCL may explain.	N	To 1	No
51	400 KV MERAMUNDALI- JSPL-1	25-01-2023	13:03	25-01-2023	15:06	Meramundali: B_N, 17.3 km, 11.88 kA		B- Earth	100	A/r attempt failed after 500 msec. A/r dead time may be reviewed.	Y	es l	No
	220 KV MAITHON- DHANBAD-2	26-01-2023	05:03			Maithon: R_N, 37.25 km, 3.41 kA		R- Earth	100	A/r successful from Dhanbad. Three phase tripping at Maithon. PG ER- 2 may explain.	Y	es `	Yes
	400 KV RANCHI- RAGHUNATHPU R-2	27-01-2023	17:16	27-01-2023			Raghunathpur: Didn't trip	No fault	NA	DVC may explain	Y	es `	Yes

400 KV BIDHANNAGAI NEW		12:14	20.01.2022	12.22	New Chanditala: R 48 km, 6.1 kA	R		100	A /r failed often 900 mass	Yes	Yes	
54 CHANDITALA-	1 29-01-2023	12:14	29-01-2023	12:33		E	arth	100	A/r failed after 800 msec			