



सत्यमेव जयते  
भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

पूर्वी क्षेत्रीय विद्युत समिति

**Eastern Regional Power Committee**

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033

14 Golf Club Road, Tollygunj, Kolkata-700033

Tel. No.:033-24239651,24239658 FAX No.:033-24239652, 24239653 Web: [www.erpcc.gov.in](http://www.erpcc.gov.in)



सं /NO. ERPC/EE/OPERATION/2026/1885

दिनांक/DATE:08.01.2026

सेवा में /To  
संलग्न सूची के अनुसार /As per list enclosed.

**विषय : 23.12.2025 (मंगलवार) को ईआरपीसी सचिवालय, कोलकाता में भौतिक रूप से आयोजित 234वीं ओसीसी बैठक के कार्यवृत्त – के संबंध में**

**Sub: Minutes of 234<sup>th</sup> OCC Meeting held on 23.12.2025 (Tuesday) physically at ERPC Secretariat, Kolkata – reg**

महोदय/महोदया,  
Sir(s)/Madam,

कृपया अपनी जानकारी और आवश्यक कार्रवाई के लिए **23 दिसंबर 2025 (मंगलवार)** को आयोजित **234वीं ओसीसी बैठक** के कार्यवृत्त संलग्न देखें। यह ईआरपीसी वेबसाइट ([www.erpcc.gov.in](http://www.erpcc.gov.in)) पर भी उपलब्ध है।  
Please find enclosed **Minutes of 234<sup>th</sup> OCC Meeting** held on **23.12.2025 (Tuesday)** physically at ERPC Secretariat, Kolkata at **10:30 hrs.** This is for your **kind information** and **necessary action**. The same is also available at ERPC website ([www.erpcc.gov.in](http://www.erpcc.gov.in)).

टिप्पणियाँ, यदि कोई हों, कृपया यथाशीघ्र इस कार्यालय को अग्रेषित करें।  
Observations, if any, may please be forwarded to this office at the earliest.

इसे सदस्य सचिव के अनुमोदन से जारी किया जाता है।  
This issues with the approval of Member Secretary.

भवदीय /Yours faithfully

(R.K.Meena)  
SE(Operation)  
एसई (ऑपरेशन)

## **LIST OF ADDRESSES:**

1. CHIEF ENGINEER (TRANS., O&M), BSPTCL, PATNA, (FAX NO. 0612-2504557/2504937)
2. CHIEF ENGINEER (System Operation), BSPTCL, PATNA, (FAX NO. 0612-2504557/2504937)
3. CHIEF ENGINEER, TRANSMISSION (O&M), JUSNL, RANCHI (FAX NO.-0651-2490486/2490863)
4. CHIEF ENGINEER, TVNL, DORANDA, RANCHI - 834102 (FAX NO. 06544-225414)
5. CHIEF LOAD DISPATCHER, SLDC, OPTCL, BHUBANESWAR (FAX NO.0674-2748509)
6. CHIEF GENERAL MANAGER (O&M), OPTCL, BHUBANESWAR
7. SR. GENERAL MANAGER (PP), GRIDCO, JANPATH, BHUBANESWAR (0674-2547180)
8. DIRECTOR (OPERATION), IB TPS, AT/PO BANHARPALI, JHARSUGUDA, (FAX NO. 06645-222225/222230)
9. GENERAL MANAGER, TTPS, TALCHER, (FAX NO. 06760-243212)
10. SR. GENERAL MANAGER (ELECTRICAL), OHPC LTD., BHUBANESWAR, (FAX NO.0674-2542102)
11. CHIEF ENGINEER, CLD, WBSETCL, HOWRAH, (FAX NO. 033-26886232)
12. CHIEF ENGINEER, CENTRAL PLANNING WING, WBSETCL, SALT LAKE (FAX NO.: 033-23591955)
13. CHIEF ENGINEER (PTR), WBSEDCL, SALT LAKE, KOLKATA ( FAX:033-23345862)
14. CHIEF GENERAL MANAGER (OS), WBPDC, KOLKATA-98 (FAX NO. 033-23393286/2335-0516)
15. GM, KOLAGHAT TPS, WBPDC, KOLAGHAT (FAX NO.03228231280)
16. DGM (OPERATION), DPL, DURGAPUR, (FAX NO. 0343-2555052)
17. GM (SYS OPERATION), CESC, CHOWRINGHEE SQUARE, KOLKATA (FAX NO.033-22253756/22129871)
18. CHIEF ENGINEER, SLDC, DVC, HOWRAH (FAX NO. 033-2688-5094)
19. ADDL.CHIEF ENGINEER, SLDC, POWER DEPT., GOVT. OF SIKKIM, GANGTOK, (FAX NO. 03592-228186/201148/202284)
20. EXECUTIVE DIRECTOR, ERLDC, POSOCO, KOLKATA, (FAX NO. 033-2423-5809)
21. GENERAL MANAGER, FSTPP, NTPC, FARAKKA, (FAX NO. 03512-224214/226085/226124)
22. GENERAL MANAGER , KhSTPP, NTPC, KAHALGAON (FAX NO.06429-226082)
23. GENERAL MANAGER, TSTPP, NTPC, TALCHER, (FAX NO. 06760-249053)
24. GENERAL MANAGER (OS), POWERGRID, ER-II, KOLKATA( Fax no: 033-23572827)
25. GENERAL MANAGER , POWERGRID, ER-I, PATNA, (FAX NO.0612-2531192)
26. GENERAL MANAGER (O&M), POWERGRID, ODISHA PROJECTS, SAHID NAGAR, BHUBANESWAR – 751 007
27. EXECUTIVE DIRECTOR (O&M), NHPC, FARIDABAD (FAX No.:0129-2272413)

28. GENERAL MANAGER, TEESTA –V POWER STATION, NHPC, SINGTAM, EAST SIKKIM (FAX 03592 - 247377)
29. CHIEF ENGINEER, RANGIT POWER STATION, NHPC, P.O. RANGIT NAGAR, SOUTH SIKKIM (FAX NO.03595-259268)
30. SENIOR VICE PRESIDENT, PTC LTD., NBCC TOWERS, 15-BHIKAJI KAMA PLACE, NEW DELHI- 110066 (FAX NO. 011-41659504)
31. PLANT HEAD, ADHUNIK POWER & NATUARAL RESOURCES, JHARKHAND( FAX NO.: 0657-6628440)
32. AGM (OPERATION), MAITHON POWER LTD, DHANBAD (FAX: 08860004758)
33. VICE PRESIDENT(POWER), VEDANTA LIMITED, BHUBANESWAR- 751023 ( FAX NO 0674-2302920)
34. CHIEF ELECTRICAL ENGINEER, EASTERN RAILWAY, KOLKATA-700 001 (FAX NO.: 033-22300446)
35. CHIEF ELECTRICAL ENGINEER, SOUTH EASTERN RAILWAY, KOLKATA-43 (FAX: 033-24391566)
36. GENERAL MANAGER (O&M), NHPC LTD, FARIDABAD, FAX: 0129-2272413
37. ASSOCIATE VICE PRESIDENT, GMR KEL, BHUBANESWAR-751007. (FAX NO: 0674-2572794)
38. GM (SO & COMML), NTPC VVNL, NEW DELHI-110033. Fax:011-24367021
39. SHRI D. P. BHAGAVA, CHIEF CONSULTANT (O&M), TEESTA URJA LIMITED, NEW DELHI-110 001 (FAX:011-46529744)
40. SHRI BRAJESH KUMAR PANDE, PLANT HEAD, JITPL. (FAX:011-26139256-65)
41. DIRECTOR (NPC), CEA, NRPC BUILDING, KATWARIA SARAI, NEW DELHI- 110016
42. VP (OS), HALDIA ENERGY LIMITED, BARIK BHAWAN, KOKATA-700072, FAX: 033-22360955
43. GENERAL MANAGER(O&M),BRBCL,NABINAGAR,BIHAR-824003,FAX-06332- 233026

CC:

Chief Engineer, OPM, CEA	Chief Engineer, NPC, CEA	ASSISTANT SECRETARY,ERPC
--------------------------	--------------------------	-----------------------------

**ERPC:: Kolkata**

## पतों की सूची:

1. मुख्य अभियंता (ट्रांस., ओ एंड एम), बीएसपीटीसीएल, पटना, (फैक्स नं. 0612- 2504557/2504937)।
2. मुख्य अभियंता (सिस्टम ऑपरेशन), बीएसपीटीसीएल, पटना, (फैक्स नं. 0612- 2504557/2504937)।
3. मुख्य अभियंता, ट्रांसमिशन (ओ एंड एम), जेयूएसएनएल, रांची (फैक्स नं.-0651- 2490486/2490863)।
4. मुख्य अभियंता, टीवीएनएल, डोरंडा, रांची - 834102 (फैक्स नंबर 06544-225414)
5. मुख्य लोड डिस्पैचर, एसएलडीसी, ओपीटीसीएल, भुवनेश्वर (फैक्स नंबर 0674-2748509)
6. मुख्य महाप्रबंधक (ओ एंड एम), ओपीटीसीएल, भुवनेश्वर
7. एसआर. महाप्रबंधक (पीपी), ग्रिडको, जनपथ, भुवनेश्वर (0674-2547180)
8. निदेशक (संचालन), आईबी टीपीएस, एटी/पीओ बनहरपाली, झारसुगुड़ा, (फैक्स नंबर 06645-222225/222230)
9. महाप्रबंधक, टीटीपीएस, तालचेर, (फैक्स नंबर 06760-243212)
10. एसआर. महाप्रबंधक (विद्युत), ओएचपीसी लिमिटेड, भुवनेश्वर, (फैक्स नंबर 0674-2542102)
11. मुख्य अभियंता, सीएलडी, डब्ल्यूबीएसईटीसीएल, हावड़ा, (फैक्स नंबर 033-26886232)।
12. मुख्य अभियंता, केंद्रीय योजना विंग, डब्ल्यूबीएसईटीसीएल, साल्ट लेक (फैक्स नंबर: 033-23591955);
13. मुख्य अभियंता (पीटीआर), डब्ल्यूबीएसईटीसीएल, साल्ट लेक, कोलकाता (फैक्स:033-23345862)।
14. मुख्य महाप्रबंधक (ओएस), डब्ल्यूबीपीडीसीएल, कोलकाता-98 (फैक्स नंबर 033- 23393286/2335-0516)।
15. जीएम, कोलाघाट टीपीएस, डब्ल्यूबीपीडीसीएल, कोलाघाट (फैक्स नंबर 03228231280)
16. डीजीएम (ऑपरेशंस), डीपीएल, दुर्गापुर, (फैक्स नंबर 0343-2555052)
17. जीएम (एसवाईएस ऑपरेशन), सीईएससी, चौरंगी स्क्रायर, कोलकाता (फैक्स नंबर 033- 22253756/22129871)।
18. मुख्य अभियंता, एसएलडीसी, डीवीसी, हावड़ा (फैक्स नंबर 033-2688-5094)।
19. अपर मुख्य अभियंता, एसएलडीसी, विद्युत विभाग, शासन। सिक्किम, गंगटोक, (फैक्स नंबर 03592-228186/201148/202284)
20. कार्यकारी निदेशक, ईआरएलडीसी, पोसोको, कोलकाता, (फैक्स नंबर 033-2423-5809)
21. महाप्रबंधक, एफएसटीपीपी, एनटीपीसी, फरक्का, (फैक्स नंबर 03512- 224214/226085/226124)
22. महाप्रबंधक, खएसटीपीपी, एनटीपीसी, कहलगांव (फैक्स नंबर 06429-226082)
23. महाप्रबंधक, टीएसटीपीपी, एनटीपीसी, तालचेर, (फैक्स नंबर 06760-249053)
24. महाप्रबंधक (ओएस), पावरग्रिड, ईआर-II, कोलकाता (फैक्स नंबर: 033-23572827)
25. महाप्रबंधक, पावरग्रिड, ईआर-I, पटना, (फैक्स नं.0612-2531192)
26. महाप्रबंधक (ओ एंड एम), पावरग्रिड, ओडिशा प्रोजेक्ट्स, साहिद नगर, भुवनेश्वर - 751 007
27. कार्यकारी निदेशक (ओ एंड एम), एनएचपीसी, फरीदाबाद (फैक्स नंबर:0129-2272413)
28. महाप्रबंधक, तीस्ता-वी पावर स्टेशन, एनएचपीसी, सिंगतम, पूर्वी सिक्किम (फैक्स 03592 - 247377)।
29. मुख्य अभियंता, रंगीत पावर स्टेशन, एनएचपीसी, पी.ओ. रंगीत नगर, दक्षिण सिक्किम (फैक्स नंबर 03595-259268)
30. वरिष्ठ उपाध्यक्ष, पीटीसी लिमिटेड, एनबीसीसी टावर्स, 15-भीकाजी काम प्लेस, नई दिल्ली-110066 (फैक्स नंबर 011-41659504)।
31. प्लांट हेड, आधुनिक पावर एवं नेचुरल रिसोर्सेज, झारखंड (फैक्स नं.: 0657-6628440)।

32. एजीएम (ऑपरेशंस), मैथन पावर लिमिटेड।
33. उपाध्यक्ष (विद्युत), वेदांता लिमिटेड, भुवनेश्वर- 751023 (फैक्स नंबर 0674-2302920)।
34. मुख्य विद्युत अभियंता, पूर्वी रेलवे, कोलकाता-700 001 (फैक्स नं.: 033-22300446)
35. मुख्य विद्युत अभियंता, दक्षिण पूर्व रेलवे, कोलकाता-43 (फैक्स: 033-24391566)।
36. उप निदेशक, पूर्वी आरपीएसएच, 14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
37. महाप्रबंधक (ओ एंड एम), एनएचपीसी लिमिटेड, फरीदाबाद, फैक्स: 0129-2272413
38. एसोसिएट वाइस प्रेसिडेंट, जीएमआर केईएल, भुवनेश्वर-751007। (फैक्स नंबर: 0674-2572794)
39. जीएम (एसओ एवं सीओएमएल), एनटीपीसी वीवीएनएल, नई दिल्ली-110033। फैक्स:011-24367021
40. श्री डी. पी. भागवा, मुख्य सलाहकार (ओ एंड एम), टेस्टा ऊर्जा लिमिटेड, नई दिल्ली-110 001 (फैक्स:011-46529744)।
41. श्री ब्रजेश कुमार पांडे, प्लांट हेड, जीतपीएल। (फैक्स:011-26139256-65)
42. निदेशक (एनपीसी), सीईए, एनआरपीसी बिल्डिंग, कटवारिया सराय, नई दिल्ली-110016
43. उपाध्यक्ष (ओएस), हल्दिया एनर्जी लिमिटेड, बारीक भवन, कोकाता-700072, फैक्स: 033-22360955
44. महाप्रबंधक (ओ एंड एम), बीआरबीसीएल, नबीनगर, बिहार-824003, फैक्स-06332- 233026

### सीसी:

मुख्य अभियंता, ओपीएम, सीईए	मुख्य अभियंता, एनपीसी, सीईए	सहायक सचिव,ईआरपीसी
----------------------------	-----------------------------	--------------------

**ईआरपीसी:: कोलकाता**



**Eastern Regional Power Committee**

**MINUTES  
OF  
234<sup>th</sup> OCC MEETING**

**Venue: ERPC Secretariat, Kolkata**

**Date: 23.12.2025**

## Contents

<b>1. PART-A: CONFIRMATION OF MINUTES .....</b>	<b>3</b>
1.1. Confirmation of Minutes of 233 <sup>rd</sup> OCC Meeting held physically at ERPC Secretariat on 21 <sup>st</sup> November 2025 .....	3
<b>2. PART-B: ITEMS FOR DISCUSSION.....</b>	<b>3</b>
2.1 Update on follow up agenda: ERPC .....	3
2.2 Shifting of load from all India load ramp period to prevent over-drawal and critical low frequency operation of the grid: ERPC .....	9
2.3 Methodology for Cost calculation with respect to the already commissioned 7 <sup>th</sup> ICT (500 MVA,400/220 KV ) at Subhashgram(PG) Substation: CESC .....	11
2.4 Black start of ER Units in Sikkim Complex: ERLDC.....	12
2.5 Shutdown proposal of Thermal generating units from the month of January to March 2026: ERPC .....	15
2.6 Shutdown Program of Hydro power plants .....	15
<b>3. PART-C: ITEMS FOR UPDATE/FOLLOW-UP/INFORMATION .....</b>	<b>17</b>
3.1. ER Grid performance during November 2025 .....	17
3.2. Non-Submission of FRC data in stipulated time-frame: ERLDC .....	17
3.3. Regarding Non-Submission of Forecasting Data from States: ERLDC.....	18
<b>4. PART-D: OPERATIONAL PLANNING.....</b>	<b>20</b>
4.1. Anticipated power supply position for January-2025.....	20
4.2. Major Thermal Generating Units/Transmission Element outages/shutdown in ER Grid (as on 21-12-2025).....	20
4.3. Long outage report of transmission Element (MORE THAN 01 WEEK) (As on 21.12.2025):.....	22
4.4. Commissioning of new units and transmission elements in Eastern Grid in the month of November-2025.....	25
4.5. UFR operation during the month of November 2025 .....	33

## EASTERN REGIONAL POWER COMMITTEE

### MINUTES OF 234<sup>th</sup> OCC MEETING HELD ON 23.12.2025 (TUESDAY) AT 10:30 HRS

Member Secretary, ERPC welcomed all OCC members and other participants who were present physically as well as those who had joined virtually to the **234<sup>th</sup> OCC Meeting**. He appreciated the valuable contribution rendered by Shri Rajiv Sutradhar, ED , ERLDC who was going to be superannuated by the end of Dec 2025 and his contribution in various fora of ERPC is put on record. He further wished him active and healthy post retirement life.

There after he requested all the participants to give brief introduction.

□ He outlined the performance of ER grid during **November 2025** highlighting the following points:

❖ In **November-2025**, Energy consumption of ER was **13646 MU** which is **almost same** as **November -2024**.

❖ In **November -2025**, Peak demand met of ER was **24143 MW** which is **7 % less** than **November -2024**.

❖ Thermal **PLF** of ER during **November -2025** was **72.2 %** w.r.t All India PLF of **59.1%**.

❖ Generating stations whose PLF was more than **90%** during **November -2025**:

Utility	Generating station	PLF(%)
WBPDC	SANTALDIH TPS	98
NTPC	DARLIPALI STPS	99
	TALCHER STPS	92
OPGC	IB TPS	94
IPP	KAMALANGA TPS (GMR)	92

❖ During **November-2025**, **79.4%** of the time, the ER grid frequency was within IEGC Band (49.90Hz-50.05Hz).

**Coal stock position** (As on 16.12.2025) was as follows:

SL.	Name of States/Power Stns.	% of Actual Stock vis-à-vis Normative Stock
1.	Jharkhand (TVNL)	133%
2.	Odisha (IB TPS )	122%
3.	West Bengal (WBPDC )	75% (Min. Bakreswar TPS -58 %, Max. Sagardighi TPS –111%)
4.	D.P.L. TPS	24%
5.	DVC	90%(Min.Mejia TPS-71%, Max. Bokaro TPS `A -152%)
6.	NTPC	85% (Max. Darlipalli TPP -130% , Min. North Karanpura TPP- 43%)

□ He urged all thermal generating units on maintaining optimal coal stock to ensure generation as per schedule in the Summer 2026, which is most likely to witness a steep demand surge. DPL

and North Karanpura TPP were advised to build up the coal stock as per normative requirement. WBSLDC was also advised for monitoring coal stock positions as well as operational performance of DPL units.

- He emphasized the significance of comprehensive planning of maintenance of transmission assets well in advance to facilitate timely mobilization of men & material as well as preparedness on part of all stakeholders. In this regard, he advised ERLDC to closely monitor the progress of reconductoring works of **400 kV Farakka-Kahalgaon** and **400 kV Talcher-Meramundali** lines for strictly adhering to the completion timeline and thereby strengthening ISTS network in ER during the upcoming summer for reliable power supply to Odisha, the need for complete reconductoring of ckt#1 of **400 kV Talcher-Meramandali** with HTLS before end of Feb 2025 was emphasized.

At the outset, ED, ERLDC welcomed all participants to the 234<sup>th</sup> OCC Meeting, shared his invaluable experience in real time grid operation over his tenure and underlined the significance of forging consensus to arrive at feasible solutions addressing the diverse interests of Generators, Transmission utilities, DISCOMs and other stakeholders. Thereafter, following major issues were highlighted for prudent consideration in the OCC forum:

- ✦ Commercialization of the 7<sup>th</sup> ICT at Subhasgram (PG)
- ✦ Construction of 765 kV Nawada–Durgapur–Jeerat corridor
- ✦ Construction of 220/132/33 kV SS TCF-II ( WBSETCL)

❖ List of participants is attached at **Annexure-A**.

## 1. PART-A: CONFIRMATION OF MINUTES

### 1.1. Confirmation of Minutes of 233<sup>rd</sup> OCC Meeting held physically at ERPC Secretariat on 21<sup>st</sup> November 2025

The Minutes of 233<sup>rd</sup> Operation Coordination Sub-Committee meeting held on 21.11.2025 was circulated vide letter dated 03.12.2025.

Members may confirm the minutes of 233<sup>rd</sup> OCC meeting.

#### **Deliberations in the meeting**

*Since no comments have been received so far, the Minutes of 233<sup>rd</sup> OCC meeting were confirmed.*

## 2. PART-B: ITEMS FOR DISCUSSION

### 2.1 Update on follow up agenda: ERPC

#### a) **Reconductoring of 400KV Talcher-Meramundali and 400KV Farakka-Kahalgaon D/C**

- 400kV Farakka-Kahalgaon D/C and 400kV Talcher-Meeramundali D/C transmission corridors are critical for power import to West Bengal and Odisha, respectively. During recent summers, these lines have experienced high power flows nearing their thermal limits. To address this, reconductoring with HTLS conductors has been approved under ERES-43 scheme with SCOD of 02.03.2026. POWERGRID has been entrusted with executing this reconductoring work under RTM. As demand remains lower between November and February due to favourable weather condition, it was discussed that the reconductoring work for both lines need to be completed by February 2026 to ensure reliable power supply.
- The matter was discussed in 232<sup>nd</sup> OCC Transmission line outage meeting wherein It was decided to discuss detailed outage plan in separate coordination meeting involving all stakeholders. Kick off meetings were conducted with POWERGRID on 29<sup>th</sup> Oct'25 and 4<sup>th</sup> Nov'25 for efficient outage planning. The coordination meetings involving all the parties were scheduled on 18<sup>th</sup> November 2025.

#### ▪ **As per 233<sup>rd</sup> OCC:**

##### ➤ **Reconductoring of 400KV Talcher-Meramundali D/C**

ERLDC informed that a special meeting was convened on 18th Nov 2025 via online mode (MS Teams) to discuss reconductoring plan of 400kV Talcher-Meramundali D/C. The minutes of the meeting is attached in **Annexure B.2.2.a**

- ❖ ERLDC further updated that LILO portion of Talcher-Meramundali Ckt-2 (17.158 KM) has already been taken under shutdown from 21<sup>st</sup> November 2025 by PG Odisha.
- ❖ PGCIL informed that reconductoring of 400KV Talcher-Meramundali#1 will commence from 21<sup>st</sup> Dec 2025 after completion of ongoing reconductoring of LILO portion and it is expected that reconductoring of the said line will be completed by end of January 2026.
- ✓ **233<sup>rd</sup> OCC decision:**
- OCC advised PGCIL to complete the reconductoring of LILO part by 20th Dec'25 and instructed to start the work of 400KV Talcher-Meramundali circuit-1 from 21st Dec 2025 and complete by 5th Feb'26 and strictly adhere to the agreed time lines.

- OCC also advised PGCIL to submit progress report on weekly basis and share all revised supply schedule and execution details to ERPC/ERLDC.

### **Deliberations in the meeting**

*Powergrid Odisha submitted:*

- ✓ Presently 4 teams have been deployed and from 28<sup>th</sup> Dec 2025, additional 4 teams will join after which S/D of circuit-1 will be availed.
- ✓ ROW issues has been resolved now.
- ✓ There are a number of crossings with LT lines which is hindering progress as per planned schedule.
- ✓ After completion of the LILO portion, reconductoring in circuit-1 will start as all pending materials have been received.

*SLDC Odisha submitted:*

- ✓ Reconductoring of the LILO portion may not be required as of now.
- ✓ Every possible cooperation will be extended i.r.o availing S/D of distribution feeders by Powergrid for reconductoring in line crossings.

SLDC Odisha also urged that at least one ckt (ckt#1) of 400KV Talcher-Meramundali D/C must be restored by 15<sup>th</sup> Feb 2026.

ERLDC deliberated that simultaneous shutdown of the LILO portion of Circuit-2 and Circuit-1 is not feasible, as it would necessitate curtailment at Talcher STPP due to higher power flows in the event of tripping of the HVDC Talcher–Kolar bipole.

### **OCC Decision**

- Powergrid Odisha was advised to expedite reconductoring works and make circuit-I of 400KV Talcher-Meramundali D/C along with bay equipment ready for service by 15<sup>th</sup> Feb 2026.
- Powergrid Odisha was advised to share the detailed work schedule i.r.o reconductoring, clearly delineating the details of constraints at each location.
- Powergrid Odisha was advised to coordinate with NTPC and OPTCL i.r.o bay upgradation at Talcher end in due course.
- SLDC Odisha was advised to grant shutdown of all transmission line crossings the Powergrid lines on priority on D-2 basis.
- OCC advised ERLDC to convene weekly monitoring meeting to assess the progress.

### **➤ Reconductoring of 400KV Farakka-Kahalgaon D/C**

ERLDC apprised that a special meeting was convened on 18<sup>th</sup> November 2025 via online mode to discuss reconductoring plan of 400KV Farakka-Kahalgaon D/C involving stakeholders from NTPC, PGCIL, ERLDC & ERPC. The MoM of the meeting is attached in **Annexure B.2.2.b**.

### **Deliberation in 233<sup>rd</sup> OCC:**

- PGCIL submitted that Line shutdown earlier planned from 20.11.25 could not be taken up due to **non-availability of material**. Material expected to reach by last week of Nov'26.

➤ PG ER1 also informed that outage 400KV Farakka-Kahalgaon#1 required for 2 months starting 1<sup>st</sup> week of Dec'26 and Circuit#2 outage required for 2 months after completion of Circuit#1.

**233<sup>rd</sup> OCC decision:**

OCC advised PGCIL to strictly adhere to the said timeline and complete the reconductoring of at least one circuit before February 2026 with simultaneous upgradation of bay equipments at both ends in coordination with NTPC.

Powergrid may update. Members may discuss.

**Deliberations in the meeting**

*Powergrid ER-I submitted:*

- ✓ *Shutdown has been availed on 2<sup>nd</sup> Dec 2025 and reconductoring work has commenced in 400KV Farakka-Kahalgaon D/C.*
- ✓ *Out of 94 ckt km of 400 kV Farakka-Kahalgaon D/C, reconductoring in 9 km has already been completed and work is under progress in 6 km.*
- ✓ *As materials have been received now, 2 additional gangs will be deployed to expedite progress in work.*

**OCC Decision**

- *Powergrid was advised to share the detailed work schedule i.r.o reconductoring, clearly delineating the details of constraints at each location.*
- *OCC advised ERLDC to convene weekly monitoring meeting to assess the progress.*
- *NTPC was advised to finalize the plan for Jackbus replacement at Farakka and accordingly communicate to Powergrid. ERLDC was requested to hold a separate meeting for further deliberation on the same.*

**b) Restoration status of 220kV Rajarhat (PG) - New Town IIC cable.**

**Reference:**

Vide 221<sup>st</sup> OCC dated 27.11.24:

The faulty B phase cable already is isolated at both ends. As, the repair of the b phase cable involves kits and spares (particularly for the jointing portion of two different sized cables) from abroad, which is time consuming, so to keep the other two phase UG cables healthy, it was extremely necessary to keep those in no load charging condition. • Repair of the faulty cable (B phase) is getting delayed due to non-availability of the imported cable jointing kit. • Neither charging the cable at low voltage nor charging from WBSETCL end was feasible • The said no load charging may please be allowed within shortest possible time to reduce any possibility of damage of R, Y phase cables in respect of Rajarhat (PG)-New Town AAIC circuit II.

As per 229<sup>th</sup> OCC:

WBSETCL updated that the said line was charged on 09.07.2025 after rectification of cable fault. However, on 10.07.2025 B phase of circuit 1 of Rajarhat-New Town IIC developed a cable fault.

WBSETCL may update. Members may discuss.

### **Deliberations in the meeting**

WBSLDC apprised that the faulty B phase of 220kV Rajarhat (PG) - New Town IIC cable shall be restored by the end of February 2026.

### **OCC Decision**

OCC advised that the faulty B- phase of the cable should be reinstated to service as per submitted timeline.

### **c) Intrastate Transmission Network Assessment & Mitigation – DVC:**

#### **Implementation of SPS scheme for N-1 compliance of ICTs at Bokaro**

A joint study was conducted on 22<sup>nd</sup> October 2025 where SPS proposal was discussed.

#### **As per 233<sup>rd</sup> OCC:**

DVC updated that SPS implementation time line will be shared shortly with ERPC & ERLDC.

#### **233<sup>rd</sup> OCC decision:**

OCC advised SLDC, DVC to finalise the timeline for the implementation of the SPS and same may be communicated to ELDC & ERPC at the earliest.

DVC may update. Members may discuss.

### **Deliberations in the meeting**

*DVC informed:*

- ✓ *The SPS will be implemented in two phases sequentially.*
- ✓ *In the first phase, SPS will be operational in two lines of Ramgarh ( within next 20 days)*
- ✓ *The Second phase of SPS can be implemented only after Koderma ICT is put in service( expected by 15<sup>th</sup> Feb 2025)*

### **OCC Decision**

OCC advised DVC to implement SPS as per submitted timeline and expedite in putting the Koderma ICT to service.

### **d) Intrastate Transmission Network Assessment & Mitigation – West Bengal**

#### **Reference:**

#### **Modification of Existing SPS Scheme at Subhasgram (PG) with Undervoltage Logic**

ERLDC Proposed modification of existing SPS at Subhasgram (PG) to include undervoltage logic with time delay to prevent voltage collapse. OCC advised SLDC, West Bengal, WBSEDCL and CESC to meet after puja for discussing the proposed modified SPS scheme at Subhasgram and share the outcome in next OCC.

*Update:*

*State-level meeting already done by SLDC.*

WB may share the update. Members may discuss.

### **Deliberations in the meeting**

Powergrid ER-II updated that the undervoltage logic of SPS has been finalized that shall be shared by next week and the same shall be implemented at Subhasgram (PG) by the last week of January 2026, just after commissioning of the 6<sup>th</sup> ICT.

### **OCC Decision**

OCC advised Powergrid along with all concerned stakeholders to strictly adhere to the timeline for UVLS implementation in intra-state network of WB, as submitted in the 55<sup>th</sup> TCC meeting dated 16.12.2025.

#### **e) Intrastate Transmission Network Assessment & Mitigation-Odisha**

##### **Reference:**

As deliberated in 231<sup>st</sup> OCC meeting held on 22.09.2025, OPTCL and SLDC Odisha were directed to submit actions taken report i.r.o. near miss event in Odisha on 12th August 2025 and constitute the committee as recommended earlier, comprising of members of ERPC, ERLDC, SLDC, & OPTCL to review the protection settings and the short-term/long-term measures as suggested by ERLDC. OCC also advised SLDC Odisha to obtain approval from appropriate authority for implementation of UVLS scheme proposed for safeguarding the load of capital city and nearby areas from cascaded failure.

##### **In 233<sup>rd</sup> OCC Meeting,**

OPTCL informed that UVLS scheme is still purview of their higher management and if any progress is made, the same shall be communicated to ERPC/ERLDC.

➤ OCC took a serious note on the inordinate delay in decision making in the implementation of UVLS scheme as a contingency measure, considering the growing demand and increased congestion in the Odisha system.

➤ OCC further advised OPTCL to pursue the issue with their higher management with utmost priority and the matter was referred to TCC for detailed deliberations.

OPTCL & Odisha SLDC may update. Members may discuss.

##### **Deliberations in the meeting**

*SLDC Odisha submitted:*

*The UVLS scheme will be made operational by March 2026.*

##### **OCC Decision**

*OCC directed SLDC Odisha to install the UVLS before summer 26 i.e. March 26.*

#### **f) Interim arrangement for evacuation of JSWEUL Generation**

Ind-Barath Energy (Utkal) Limited (IBEUL) (2 × 350 MW) has been evacuating power from Unit-1 and Unit-2 through an interim arrangement, i.e., by connecting one circuit of the 400kV OPGC–Sundargarh D/C ISTS line LILO at IBEUL, thereby forming an OPGC–IBEUL–Sundargarh 400 kV S/C line.

In view of the delay in completion of the Dedicated Transmission Line (DTL), the Central Electricity Authority (CEA) has approved continuation of the above interim arrangement for evacuation of power through LILO of the 400 kV OPGC–Sundargarh line at IBEUL with SPS, only up to 31.12.2025, as recorded in the Minutes of Meeting dated 15.07.2025 (Annexure-2.1. E).

JSWEUL may update. Member may discuss.

##### **OCC Decision**

*OCC opined that the existing interim arrangement of power evacuation from JSWEUL had been approved by CEA upto 31.12.2025 as per the last approval of extension from CEA dated 15.07.2025. Accordingly, JSWEUL was urged to take up the matter with CEA for further consideration.*

**g) Construction of Nawada–Durgapur–Jeerat (New) 765kV corridor for improved reliability in the Eastern Region and improve reliability of power supply to Kolkata:**

To improve reliability of Kolkata and adjacent area, one alternate 765kV corridor was planned after several joint study meeting organised by CTU. Nawada S/s along with Nawada – Durgapur – Jeerat (New) 765kV corridor was agreed to be taken up for strengthening 765kV interconnection to Kolkata area. Accordingly, the “ERES-47: Nawada – Durgapur – Jeerat (New) 765kV corridor” scheme was agreed to be implemented as a strengthening scheme in the 47th CMETS-ER held on 29-09-2025. The final scope of works was discussed and agreed in 48th CMETS-ER held on 30-10-2025.

This project was discussed in 55th TCC/ERPC meeting dated 16.12.2025 and 17.12.2025 for final approval. However, West Bengal deliberated that proposed 765KV lines will have very less impact for ensuring a stable and reliable supply to Kolkata.

TCC advised CTU to conduct a joint study for exploring all the pros and cons of implementation of the scheme in consultation with WBSETCL & ERLDC and this scheme may be clubbed with RE power evacuation scheme from Bikaner phase-VI up to Eastern Region and a detailed report may be shared with ERPC latest by 31st December 2025.

WBSETCL may update. Member may discuss.

**Deliberations in the meeting**

*WBSLDC submitted:*

*The proposed 765 kV corridor will definitely aid in ensuring reliable power supply to Kolkata if it is extended upto 765 kV New Jeerat(PG). Along with the proposed 765 kV corridor, associated 400 kV lines are also needed to support the system in event of crisis by catering to all critical load points.*

**OCC Decision**

*As directed in the 55<sup>th</sup> ERPC meeting, it was decided that a special meeting shall be convened involving ERPC, CTU, ERLDC, WBSETCL and WB SLDC wherein joint study report by CTU shall be discussed for stakeholder views/opinion. CTU was also requested to complete the study at the earliest.*

**h) Establishment of proposed TCF-II 220/132/33 KV SS by WBSETCL**

The proposal for the TCF-II 220/132 kV intra-state substation with ISTS connectivity (through D/C LILO of Siliguri PG–Kishanganj PG 220 kV HTLS line) proposed to meet the rising demand in the Ghoshpukur–TCF and adjacent areas. The scheme has undergone detailed discussion at CMETS-ER since May 2025, considering multiple operational scenarios. Studies indicate that, under N-1 contingency, the Binaguri PG–Siliguri PG line would load to 426 MW, which is above within 90% of the HTLS line’s thermal limit (450 MW) assuming a 1500 MW APD–Agra HVDC link setting.

The same matter was again discussed in West Bengal Resource Adequacy Studies, and it was proposed to set up a 400/220/132kV substation. The same matter was discussed in **55th TCC & ERPC meeting**. The matter was referred to West Bengal Resource Adequacy Studies held on **22nd December 2025**.

WBSETCL may update. Member may discuss.

**Deliberations in the meeting**

WBSLDC stressed the urgent need of TCF-II 220/132/33 KV S/S as there is no other source( adjacent generating station/line) to meet the load of upcoming 132 kV S/S at Ghoshpukur. This S/S is most likely to cater to the load of Data Centres to be setup in line with extant norms of Govt of India.

#### **OCC Decision**

OCC opined that the issue will be taken up in the special meeting to be convened by CEA on 24.12.2025. Based on the deliberations, further course of action will be framed in the next OCC.

#### **i)Commissioning of an additional 250 MVA ICT at Tenughat**

##### **Reference:**

On 06.08.2025 a special meeting was convened to decide on the future course of the 400 kV Tenughat–PVUNL interim line.

##### **As per 232<sup>nd</sup> OCC :**

- JUSNL updated that testing of the 250MVA ICT at Tenughat has been completed and test report is to submitted to the State power department for electrical clearances.
- SLDC, Ranchi further updated that ICT commissioning is expected to be completed by 15<sup>th</sup> December 2025.

##### **OCC Decision**

OCC advised JUSNL to expedite the commissioning of 250MVA ICT at Tenughat so that the said ICT shall be operational at the earliest.

JUSNL may update. Members may discuss.

##### **Deliberations in the meeting**

*TVNL apprised:*

- The 250 MVA ICT is very old (procured around 1996) and the same has not been charged till now.
- Electrical clearance of the ICT is pending as test reports are still awaited. Once electrical clearance is received, the ICT will be charged tentatively by 15<sup>th</sup> Jan 2026.

*ERLDC informed:*

One of the two ICTs procured at the same time,i.e 1996 was charged two years ago.

##### **OCC Decision**

- ✓ OCC expressed serious concern on the healthiness of the ICT which has not been loaded since procurement that may have exhausted its useful life.
- ✓ OCC also opined that this 250 MVA ICT is utmost essential to ensure reliable power evacuation from upcoming PVUNL unit-II.
- ✓ TVNL was urged to put the ICT to service but only after prudently assessing its healthiness and useful life to avoid recurrent outage followed by replacement in future. The same set of procedure for charging may be followed as for the other ICT charged two years back.

#### **2.2 Shifting of load from all India load ramp period to prevent over-drawal and critical low frequency operation of the grid: ERPC**

As per direction of **Ministry of Power** dated **01.02.2024 ( Annex 2.1 )**:

In order to combat global warming, it is necessary to shift from coal based power generation to Renewables. India has pledged that by 2030, it will have 50% of its installed capacity from non-fossil (Renewable) sources.

It is expected that the All India demand will continue growing at a rapid pace because of the increase in the pace of growth of the economy. Thermal capacity addition cannot keep pace – because the gestation period of constructing a thermal power plant is 6 to 7 years. Renewable Energy- especially solar – has a lower gestation period – so the increase in solar capacity will keep pace with the growth in demand. This will ensure that there will be no shortage of power during solar hours. Keeping all factors in view, it has been decided that agricultural load be shifted to solar hours. This will have the following advantages:

- i. The farmers will be able to irrigate their fields during daylight hours.
- ii. This will prevent depletion and help in conservation of precious ground water resource.
- iii. Solar power is cheaper than thermal/hydro – so the cost of supply during daylight hours is cheaper – so the cost of power supplied for irrigation will come down.

There shall be no curtailment in the hours of supply for agriculture. The farmers will keep getting the same number of hours of supply which they are getting now. Because of the large capacity additions in RE, there shall be no shortage of Solar/RE during the solar hours.

Further, as it is proposed to shift the Time of Day(TOD) tariff, under which tariff during solar hours will be less, it may also be analyzed as to what other load can be shifted to solar hours; and this may be done.

An analysis has been done by NLDC (on one minute SCADA data) for the evening all India load ramping hours and that of drawal of the state control area of Bihar and Odisha from Nov-24 to Oct-25. Analysis is attached as **Annexure-2.1**. Based on the analysis, the following observations have been highlighted by NLDC:

#### **For Bihar**

- Average Over Drawal (OD) remained between 80-170 MW.
- OD persisting for a significant portion of the ramp interval during these months, around 46% of the time overdrawal during ramp in last 12 months.

#### **For Odisha**

- Average Over Drawal (OD) remained between 110-160 MW.
- OD persisting for a significant portion of the ramp interval during these months, around 54% of the time overdrawal during ramp in last 12 months.

The above situation indicates, gap in Resource Adequacy (RA) exercise for ramping hours. Since, higher resources are available during solar hours, following is requested to be explored:

1. Shifting of loads from all India load ramping hours to high solar hours.
2. Keeping enough ramping resources and reserves during net load ramping hours and non-solar peak hours.

It has been requested that concerned utilities may please be advised to take action on the above suggestions and a brief action plan may be shared with concerned RLDC and NLDC.

Members may discuss.

#### **Deliberations in the meeting**

*ERLDC delivered a brief presentation outlining the seasonal as well as diurnal variation of load.*

*It was apprised:*

- *In the evening, the ramp performance of all state generators( thermal, hydro) should align with surge in load and corresponding dip in solar generation.*
- *All India agricultural load is around 20% whereas only 4-5% of the total demand of ER is agricultural load.*

*SLDC Bihar submitted that presently there is amalgamation of both agricultural and non-agricultural loads on 132 kV feeders. Construction of dedicated 11 kV feeders catering to agricultural loads is in progress under RDSS (Revamped Distribution Sector Scheme) and to be completed by end of 2026.*

*SLDC Odisha submitted :*

- ✓ *There is no dedicated agricultural feeder.*
- ✓ *A total of 125 MW of battery storage system at 6 locations (20MW\*5 + 25MW\*1) is under procurement(at consumer end). Also, few pumped storage plants are planned to be commissioned by 2027.*

### **OCC Decision**

- *All thermal generating units were advised to achieve the desired ramp rate of 3%( to the closest extent) as mandated in IEGC 2023.The ramping should start at an appropriate instant ( neither too early nor too late) matching the rate of fall of solar generation in non-solar hours so as to ensure frequency is being confined in the IEGC band.*
- *OCC advised ERLDC to put up a comparative analysis on ramping performance of thermal generating units of ER during non-solar peak hours.*
- *OCC advised all ER states to explore shifting of the maximum possible quantum of agricultural load in solar hours with proper segregation of feeders for agricultural and non-agricultural loads. SLDCs need to coordinate with respective DISCOMs in this regard.*
- *OCC opined that storage mechanisms like BESS (Battery Energy storage) should be leveraged to provide support to the grid in the crucial non-solar peak hours.*
- *All ER states were advised to assess the exact quantum of energy storage necessary for avoiding overdrawl during non-solar peak hours. Accordingly, a detailed plan to be shared with ERPC Secretariat for implementing energy storage systems.*
- *OCC also opined that implementation of TOD (Time of the Day) tariff can encourage the consumers for load shifting to solar hours and thereby easing the burden on the grid in non-solar peak hours through Demand side management.*

### **2.3 Methodology for Cost calculation with respect to the already commissioned 7<sup>th</sup> ICT (500 MVA,400/220 KV ) at Subhashgram(PG) Substation: CESC**

- *As per MOM of the Meeting held at Vidyut Bhavan on 25.08.2023 under the Chairmanship of the Secretary, Dept. of Power, Govt. of West Bengal, it was decided that incremental charges associated with this will be borne by CESC. But..."as Powergrid cannot claim the cost related to this interim arrangement directly from CESC and can claim only from WBSEDCL as DIC Discom, WBSEDCL shall pay all cost / incremental charges to PGCIL after realising the same from CESC through bilteral arrangement between CESC & WBSEDCL"...*
- *It was also decided in the said Meeting that realisation of incremental cost from CESC shall commence after the subject ICT is commissioned as interim measure ICT at Subhashgram till commissioning of the 6<sup>th</sup> 500 MVA 400/220 KV ICT thereafter.*
- *Now the said 7<sup>th</sup> ICT has already been commissioned on 21.06.2024 and as per the latest communication received from PGCIL, the 6<sup>th</sup> ICT is scheduled to be commissioned thereafter by the second half of January, 2026.*

- So, guidance on the methodology for calculation of the incremental cost is sought.

CESC may explain. Members may discuss.

### **Deliberations in the meeting**

*ERLDC summarized the deliberation in the special meeting convened by CEA on 22.12.2025 wherein the continuation of 7th ICT on permanent basis at Subhasgram(PG) after 2030 came up, though final decision to be taken by Member (Power System), CEA.*

*It was apprised that the exact load relief at Subhasgram(PG) can be ascertained in study only after getting the information on which lines will be shifted from Subhasgram(PG) to New Laxmikantapur .*

*WBSLDC submitted:*

*CEA's prediction on non-requirement of the 7<sup>th</sup> ICT at Subhasgram(PG) after 2030 takes into account the commissioning of New Laxmikantapur S/S by 2029 that is expected to provide around 30% load relief to Subhasgram(PG) . But, if timely commissioning of New Laxmikantapur S/S doesn't take place, there shall be extreme network congestion in absence of 7<sup>th</sup> ICT and hindering reliable power supply to Kolkata. Also this load relief to Subhasgram(PG) is computed considering all generators in service and in absence of any of the generators, data on power drawl pattern of CESC from all the drawl points is needed for predicting the exact quantum of load relief.*

*CESC affirmed the need of 7<sup>th</sup> ICT at Subhasgram(PG) to meet the rising demand of Kolkata city. As per their study, rise in their load beyond 2400 MW will entail increased power drawl from Subhasgram (PG).*

*It was further intimated that CESC has already paid Rs 12 crores to WBSETCL ( comprising installation and PGCIL consultancy charges) and guidance was sought on modalities of incremental cost & VAR charges sharing with reference to the discussion held in the meeting dated 25.08.2023 under chairmanship of Secretary(Power), Govt of WB.*


### **OCC Decision**

- ✓ *As the planned transformation capacity is 500X2 MVA at the proposed New Laxmikantapur S/S, maximum 400 MW of load relief will be feasible from Subhasgram(PG) even after commissioning of New Laxmikantapur S/S( considering N-1 contingency). Also considering steady load growth, OCC assessed the permanent need of 7<sup>th</sup> ICT at Subhasgram(PG) that needs to be conveyed to CEA with all accessory data.*
- ✓ *OCC opined that after the final decision is taken i.r.o. the 7<sup>th</sup> ICT at Subhasgram(PG) by CEA , the modalities of cost sharing between the two DISCOMs i.e WBSEDCL and CESC shall be finalized.*

### **2.4 Black start of ER Units in Sikkim Complex: ERLDC**

A black start capable resource and its readiness are essential for grid resilience. As mandated under Clause 34(3) of the IEGC 2023, all users must conduct mock black start exercises annually, coordinated by the SLDC for state-level stations and by the RLDC for ISGS and IPP stations. In the Eastern Region, all black start capable ISGS and IPP units are located in Sikkim and are connected to the 400/220/132 kV Rangpo substation.

In eastern region all black start capable ISGS and IPP units are located in Sikkim and connected to 400/220/132 kV Rangpo substation as shown below:



During 2024–25, mock black start exercises were conducted at Jorethang, Tashiding, Chuzachen, and Dikchu HEPs. Only Tashiding could synchronize with Rangpo, and that too after an hour's delay, while the other HEPs could not complete synchronization.

During this year, on 12 December 2025, Tashiding also failed to synchronize despite frequency matching within 0.01 Hz, due to the Rangpo BCU hanging repeatedly even after multiple restarts. (Report attached)

Following key challenges were identified:

**Key Challenges:**

- Synchronization at the Rangpo end is based on a **Bay Control Unit (BCU)** which checks for: Voltage difference, Frequency difference, Angle difference.
- Only after the BCU confirms all three criteria are met, a **manual closing command** is issued by the operator.
- To accommodate operator reaction time and prevent out-of-phase synchronization, a tight frequency difference setting of 0.01 Hz is enforced. This ensures that within the operator's response window, the angle difference remains within  $\pm 15$  degrees.
- However, such stringent synchronization settings are difficult to satisfy during a black start, as both generator and grid frequencies varies continuously. This leads to either: Excessive delay in synchronization or Failure to meet synchronization criteria altogether.
- The black-start capable generating units faced difficulty in maintaining a stable frequency, which further complicated the synchronization process.

**Remedial Measures:**

**1. Installation of Auto-Synchronization Facilities:**

- Deployment of automatic synchronization systems at strategic substations such as Rangpo, for all existing and future feeders connected to black-start capable generating stations, is required.
- At plant end auto synchronization facilities are available and difference of frequency Setting is kept at 0.1 Hz, therefore it synchronizes smoothly while bringing the unit on bar. Accordingly, at Rangpo end, with installation of auto synchronization, frequency setting can also be increased which will enable faster and smoother synchronisation.

**2. Finalization of Synchronization Parameter Thresholds:**

- A review and finalization of realistic and achievable synchronization parameter settings (voltage, angle, frequency difference) is essential.

- These thresholds should balance the need for operational safety with practical synchronization feasibility during black start conditions.

In consecutive 2 years, mock black start test failure has been observed in such an important hydro complex in the eastern region, which will be vital for restoration during actual blackout scenario.

Members may discuss.

### **Deliberations in the meeting**

*ERLDC apprised:*

- ✓ *Attempt was made for mock black start of Tashiding HEP on 12<sup>th</sup> December 2025 but synchronization was not possible due to large magnitude of angular difference (160 degrees) between the incoming machine and Rangpo(PG) bus. The BCU witnessed technical disruption and leading to failure of synchronization.*
- ✓ *Substantial delay is caused due to manual command in BCU, making frequency band too stringent for feasible synchronisation. Increasing frequency range in manual synchronization poses risk of machine falling out of step with the bus.*
- ✓ *On the other hand, implementation of auto-synchronization facilities at Rangpo(PG) will aid in smooth and faster synchronization with a wider range of frequency. Auto-synchronization facility is highly essential for successfully carrying out actual black start.*
- ✓ *This is leading to failure of mock black start exercise( as mandated in IEGC 2023) of all surrounding hydro generating stations in Sikkim connected to 400 kV Rangpo bus, which acts as the only synchronization point with rest of the grid.*
- ✓ *Last year mock black start of Tashiding HEP was successful but with long delay and generation loss.*
- ✓ *The issue was put in NCT meeting but was not agreed for the proposed modifications facilitating Auto-synchronization.*

*Powergrid stated:*

- *Implementation of Auto-synchronization facility is not feasible as per prevailing technical specifications and guidelines of CEA transmission planning criteria. With modification in technical specifications, procurement of dedicated synchronization panel can be done accordingly.*
- *Parameters and settings at the generator end should also be checked for proper synchronization.*

### **OCC Decision**

*Powergrid was advised to explore feasibility of implementing auto-synchronization facility through BCU upgradation or other means at Rangpo in consultation with concerned OEM as well as considering the prevailing procedure being practised in other regions of the country for mock black start with auto-synchronization. A detailed assessment report should be shared in the next OCC for further deliberation.*

## 2.5 Shutdown proposal of Thermal generating units from the month of January to March 2026: ERPC

### Deliberations in the meeting

OCC approved the shutdown schedule as detailed below:

<b>Maintenance Schedule of Thermal Generating Units of ER during 2025-26</b>									
System	Station	Unit	Capacity (MW)	LGBR Approved		No. of Days (as per OCC)	OCC Approved		Reason
				From	To		From	To	
NTPC	NABINAGAR STPP	2	660	5-Jan-26	18-Feb-26	–	Not required.		AOH
	FARAKKA STPS	6	500	15-Jan-26	18-Feb-26	30	15.01.2026	14.02.2026	AOH
	BARAUNI TPS	9	250	01.12.2025	30.12.2025	45	01.01.2026	15.02.2026	AOH
	BARAUNI TPS	8	250	15.03.26	31.03.26	–	Not required.		AOH
DVC	MEJIA TPS	8	500	11-Jan-26	4-Feb-26	–	Not required.		BOH
	MEJIA TPS	6	250	03-12-2025	06-01-2026	34	28.12.2025	31.01.2026	AOH-R&M
	MEJIA TPS	7	500	29-08-2025	25-09-2025	34	06.02.2026	12.03.2026	AOH-R&M
	KODARMA TPP	2	500	11-Feb-26	17-Mar-26	–	Not required.		AOH
	KODARMA TPP	1	500	05-10-2025	01-11-2025	34	10.12.2025	13.01.2026	AOH
WBPDC	BANDEL TPS	5	210	3-Feb-26	9-Mar-26	7	05.02.2026	12.02.2026	Boiler License renewal
	SANTALDIH	5	210	27.12.25	30.01.26	34	03.01.2026	06.02.2026	BTG OH+De-Nox
	SAGARDIGHI	1	210	05.08.25	08.09.25	34	04.01.2026	07.02.2026	AOH
	KOLAGHAT	3	210	10.02.26	16.03.26	35	08.12.2025	11.01.2026	AOH
	KOLAGHAT	4	210	15-07-2025	08-08-2025	25	Not required now. To be availed in next FY.		ESP R&M

## 2.6 Shutdown Program of Hydro power plants

### Annual maintenance of Rongnichu HEP

Rongnichu has submitted:

- ✓ A reduction in river inflow in coming months is anticipated, particularly during the leanest period in February, they have strategically planned the Annual Maintenance activities for the Rongnichu HEP to coincide with this opportunity.
- ✓ Accordingly, the plant will undergo a complete shutdown from **15th February 2026 to 28th February 2026** to facilitate the required Annual Maintenance work.
- ✓ If the maintenance work is completed earlier or requires additional time the plant will be restored accordingly. Any changes to the schedule will be communicated to ERPC/ERLDC in advance.

Rongnichu may update. Members may discuss.

### **Deliberations in the meeting**

*OCC granted the shutdown of Rongnichu HEP to be availed from 15.02.2026 to 28.02.2026 (13 days) for annual maintenance.*

### **Annual maintenance of Tashiding HEP**

This is in reference to the approved annual maintenance shutdown of Tashiding HEP – Unit-2 from 15.12.2025 to 31.01.2026 (46 days), as consented in the 233rd OCC Meeting dated 21.11.2025. During this period, Unit-1 was planned to remain operational.

It is now proposed to undertake a complete shutdown of Tashiding HEP during February 2026, as detailed below:

- Unit-1: Shutdown from 01.02.2026 to 28.02.2026
- Unit-2: Extension of shutdown from 01.02.2026 to 28.02.2026

The shutdown is required for essential maintenance and overhauling works to ensure reliable plant operation.

### **Deliberations in the meeting**

*OCC consented to the shutdown requests of both units of Tashiding HEP as per submitted timeline. Therefore, both the units of Tashiding will be under shutdown during the entire month of Feb-26.*

### **Annual maintenance of Jorethang Loop HEP**

It is also proposed to plan shutdown of Jorethang Loop HEP – Unit-1 from 02.01.2026 to 31.01.2026 for under-water parts maintenance.

The above shutdowns are required for essential maintenance and overhauling works to ensure safe and reliable operation of the plants.

Unit-2 of JLHEP is planned to remain operational during the shutdown period.

### **Deliberations in the meeting**

*OCC granted shutdown of Jorethang Loop HEP – Unit-1 from 02.01.2026 to 31.01.2026.*

*As per the deliberations of the special meeting held on 26.11.2025, Powergrid may complete the HV test at Rangpo S/s by taking 220 kV double bus shutdown.*

### 3. PART-C: ITEMS FOR UPDATE/FOLLOW-UP/INFORMATION

#### 3.1. ER Grid performance during November 2025

The average and maximum consumption of Eastern Region and Max/Min Demand (MW), Energy Export for the month November -2025 were as follows:

AVERAGE CONSUMPTION (MU)	MAXIMUM CONSUMPTION(MU)/ DATE	MAXIMUM DEMAND (MW)	MINIMUM DEMAND (MW)	SCHEDULE EXPORT	ACTUAL EXPORT
		DATE / TIME	DATE / TIME	(MU)	(MU)
455 MU	511 MU, 10.11.2025	24143 MW, 01.11.2025 at 18:01 Hrs.	14209 MW, 17.11.2025 at 02:37 Hrs.	5198	5724

ERLDC/ERPC may highlight the performance of the ER grid.

#### **Deliberations in the meeting**

*The grid performance of ER for the month of November 2025 was highlighted.*

#### 3.2. Non-Submission of FRC data in stipulated time-frame: ERLDC

Adhering to IEGC clauses 30.8 and 30.10.(a) to 30.10.(q), generating stations within the Eastern region are required to submit essential data to ERLDC within two days of receiving a notification regarding a reportable frequency event. Additionally, according to clause 30.10.(n), all control areas within the eastern region must assess their frequency response characteristics and share the evaluation, along with high-resolution data, with the ERLDC. Therefore, timely submission of primary response data is crucial for compliance with the IEGC.

Hence all are again requested to follow the stipulated timeline and submit the data to ERLDC and also fill the google sheet below to include the email address where notifications of reportable events should be sent.

The latest data receipt status is given below: (as on **15.12.2025**):

STATIONS		11-05-2025 16:51 HRS	12-06-2025 13:34 HRS	16-06-2025 11:51 HRS	22-07-2025 19:46 HRS	29-07-2025 14:55 HRS	01-09-2025 14:57 HRS	24-09-2025 11:04 HRS	24-09-2025 11:32 HRS	15-10-2025 12:11 HRS
FSTPP #STG 1 & 2	ISGS									
FSTPP # STG 3	ISGS									
KhSTPP #STG 1	ISGS									
KhSTPP #STG 2	ISGS									
TSTPP #STG 1	ISGS									
Barh stage-1	ISGS									
Barh stage-2	ISGS									
BRBCL	ISGS									
Daripalli	ISGS									
North Karanpura	ISGS									
NPGC	ISGS									
TEESTA V	ISGS									
Dikchu	ISGS									
IBEUL (JSW UTKAL)/INDBHARAT	JPP									
GMR	CPP									
MPL	CPP									
ADHUNIK	CPP									
JITPL	CPP									
TEESTA III	CPP									
Bihar	STATE									
Jharkhand	STATE									
DVC	STATE									
OPTCL	STATE									
WB	STATE									
Updated as on	15.12.2025									
	Received									
	Not Received									
	Plant Out									
	Data freeze at plant									

Hence all are again requested to follow the stipulated timeline and submit the data to ERLDC and also fill in the google sheet below to include the email address where notifications of reportable events should be sent.

[https://docs.google.com/spreadsheets/d/1slvAOmQIEQVIMn0LnB78eKMa2sz2QYICZ-sPEpeV\\_jk/edit?usp=sharing](https://docs.google.com/spreadsheets/d/1slvAOmQIEQVIMn0LnB78eKMa2sz2QYICZ-sPEpeV_jk/edit?usp=sharing)

ERLDC may explain and all SLDCs may update. Members may discuss.

**Deliberations in the meeting**

**OCC Decision: -**

- All generators were advised to regularly share high resolution data against each reportable frequency event with ERLDC on time to facilitate accurate assessment of FRP for respective control areas.
- All generating utilities were also urged to update the google sheet (link mentioned above) with email address where notifications of reportable events will be shared.

**3.3. Regarding Non-Submission of Forecasting Data from States: ERLDC**

Clause 2 of Regulation 31 of IEGC 2023 has mandated all the SLDCs to timely submit the demand estimate data to the respective RLDC and RPC.

Current data submission status is given in the table below: Hence it is again requested to all the concerned for timely submission of demand estimation data to ERLDC. This collaboration is essential for effective planning and preparedness to meet the region's electricity demands efficiently and reliably.

Latest Forecast and Resource Adequacy Data receipt status at ERLDC is shown below:



#### 4. PART-D: OPERATIONAL PLANNING

##### 4.1. Anticipated power supply position for January-2025

The abstract of peak demand (MW) vis-à-vis availability and energy requirement vis-à-vis availability (MU) for the month of January -2025 is prepared by ERPC Secretariat (**Annexure D.1**) on the basis of LGBR for 2025-26 and feedback of constituents, keeping in view that the units are available for generation and expected load growth etc.

Members may update.

##### **Deliberations in the meeting**

*All states were requested to provide their anticipated power supply position for January 2025 within a week. Updated anticipated power supply position will be shared accordingly.*

##### 4.2. Major Thermal Generating Units/Transmission Element outages/shutdown in ER Grid (as on 21-12-2025)

SL No	STATION	STATE	AGENCY	UNIT NO	CAPACITY (MW)	REASON(S)	OUTAGE DATE
1	TSTPP	ODISHA	NTPC	1	500	Annual Overhauling	15-Dec-2025
2	NABINAGAR(NPGC)	BIHAR	NTPC	1	660	Annual Overhauling	01-Dec-2025
3	ADHUNIK	JHARKHAND	APNRL	1	270	Capital Overhauling	30-Nov-2025
4	JIPL	ODISHA	JIPL	1	600	Annual overhauling	30-Nov-2025
5	KBUNL	BIHAR	NTPC,BSPHCL	1	195	Annual overhauling	15-Nov-2025
6	KODERMA	DVC	DVC	1	500	Annual Overhauling	17-Dec-2025
7	KOLAGHAT	WEST BENGAL	WBPDCL	3	210	Capital Overhauling	11-Dec-2025
8	NABINAGAR(BRBC L)	BIHAR	NTPC	3	250	Tripped on boiler tube leakage	20-Dec-2025
9	NABINAGAR(BRBC L)	BIHAR	NTPC	1	250	generator stator earth fault	04-Dec-2025
10	BAKRESHWAR	WEST BENGAL	WBPDCL	5	210	Miscellaneous maintenance job	19-Dec-2025
11	Buxar TPP	BIHAR	SJVN	1	660	Low Coal Stock	14-Dec-2025

All Generating stations are requested to update expected restoration time and reason outage to ERLDC/ERPC on weekly basis in case of any change at their end.

Major Generating stations Out on Reserve Shutdown due to low system demand:

SL No	STATION	STATE	AGENCY	UNIT NO	CAPACITY (MW)	REASON(S)	OUTAGE DATE
1	SOUTHERN	WEST BENGAL	CESC	2	67.5	Reserve Shut Down	12-Nov-2025
2	SOUTHERN	WEST BENGAL	CESC	1	67.5	Reserve Shut Down	03-Oct-2025

Hydro Unit Outage Report: -

S. NO	STATION	STATE	AGENCY	UNIT NO	CAPACITY (MW)	REASON(S)	OUTAGE DATE
1	TEESTA STG III Hep	SIKKIM	TUL	1 to 6	200 X6	Sudden cloudburst at glacier fed LOHNAK Lake followed by huge inrush of water in Teesta River and damage of Teesta III Dam & downstream Powerhouses	04-Oct-2023
2	TEESTA STG III Hep	SIKKIM	TUL				
3	TEESTA STG III Hep	SIKKIM	TUL				
4	TEESTA STG III Hep	SIKKIM	TUL				
5	TEESTA STG III Hep	SIKKIM	TUL				
6	TEESTA STG III Hep	SIKKIM	TUL				
7	TEESTA HPS	SIKKIM	NHPC	1 to 3	170 X3	Sudden cloudburst at glacier fed LOHNAK Lake followed by huge inrush of water in Teesta River and damage of Teesta III Dam &	04-Oct-2023
8	TEESTA HPS	SIKKIM	NHPC				
9	TEESTA HPS	SIKKIM	NHPC				

						downstream Powerhouses	
10	BURLA HPS/HIRAKUD I	ODISHA	OHPC	7	37.5	Abnormal sound from slip ring area	18-Sep-2025
11	CHIPLIMA HPS / HIRAKUD II	ODISHA	OHPC	1	24	Capital Overhauling	15-Dec-2023
12	BALIMELA HPS	ODISHA	OHPC	5	60	Repair and maintenance work	16-Jan-2025
13	RENGALI HPS	ODISHA	OHPC	5	50	Annual Overhauling	01-Dec-2025
14	BALIMELA HPS	ODISHA	OHPC	4	60	Annual maintenance	25-Oct-2025
15	CHIPLIMA HPS / HIRAKUD II	ODISHA	OHPC	1	24	Capital Overhauling	15-Dec-2023
16	SUBARNREKHA HPS	JHARKHAND	JUUNL	1	65	Damage in civil structure near penstock blocking water flow.	20-Mar-2025
17	SUBARNREKHA HPS	JHARKHAND	JUUNL	2	65	Damage in civil structure near penstock blocking water flow.	20-Mar-2025
18	RENGALI HPS	ODISHA	OHPC	5	50	Annual Overhauling	01-Dec-2025
19	CHIPLIMA HPS / HIRAKUD II	ODISHA	OHPC	1	24	Capital Overhauling	15-Dec-2023

**4.3. Long outage report of transmission Element (MORE THAN 01 WEEK) (As on 21.12.2025):**

Transmission Element / ICT	Outage From	Reasons for Outage
220/132 KV 100 MVA ICT II AT LALMATIA	22-01-2019	220/132KV, 100MVA Transformer (NTPC side) is charged on 07.02.2024 from HV side on no load. Now, it is in idle charged condition
220KV-FSTPP-LALMATIA-I	21-04-2021	Two nos. of tower collapsed on 29.05.2024 near to Lalmatia GSS in the Loc. No. 246 & 247.  Presently 220 kV Farakka-Lalmatia line is charged(from loc no 241 to loc 84) at 132 kV voltage level for anti-theft purpose by tapping

		at loc. No. 100-101.
132KV-BARHI-RAJGIR-1	25-03-2023	Dismantling of tower no. 227, 228, and 229 crossing the premises of Mahabodhi Cultural centre along with Destrining of conductor of both circuits and Earthwire between tension tower no. 218-237 in same line.
132KV-NALANDA-BARHI(DVC)-1	25-03-2023	Dismantling of tower no. 227, 228, and 229 crossing the premises of Mahabodhi Cultural centre along with Destrining of conductor of both circuits and Earthwire between tension tower no. 218-237 in same line.
400KV-RANGPO-TEESTA-V-1	04-10-2023	Tower near gantry of Teesta V powerhouse collapsed due to sudden cloudburst at glacier fed LOHNAK Lake followed by huge inrush of water in TEESTA river and damage of Teesta III Dam & downstream Powerhouses
400KV-RANGPO-TEESTA-V-2	04-10-2023	Tower near gantry of Teesta V powerhouse collapsed due to sudden cloudburst at glacier fed LOHNAK Lake followed by huge inrush of water in TEESTA river and damage of Teesta III Dam & downstream Powerhouses
132KV-CHANDIL-MANIQUEI-1	05-06-2024	Power assistance withdrawn
400KV/220KV 315 MVA ICT 1 AT NORTH KARANPURA	12-09-2024	Tripped on Differential protection
132KV-MADHEPURA (BH)-SAHARSA(PMTL)-1	23-09-2024	To control loading on 132kv Madhepura-Sahrsa line
400KV/220KV 315 MVA ICT 1 AT TSTPP	01-11-2024	Tripped on PRD protection
132KV-PATRATU-PATRATU-1	16-11-2024	Diversion/Heightening of line due to inadequate clearance from under construction railway Line by PVUNL
400KV/220KV 315 MVA ICT 2 AT MEJIA-B	20-01-2025	Tripped during charging of ICT#1 bay with cable from 220 kv GIS side
400KV/220KV 315 MVA ICT 1 AT LATEHAR	22-04-2025	R phase LA of 400/220/33 KV ICT - I got bursted
400KV/220KV 315 MVA ICT 2 AT LATEHAR	16-04-2025	Transformer REF protection operated
400KV/220KV 315 MVA ICT 2 AT KODERMA	02-06-2025	Transformer Differential Protection operated
132KV-RAXAUL(NEW)-PARWANIPUR-2	03-07-2025	To carry out Gantry erection works at near by Parsauni 132/66/33 kV Substation of Nepal
132KV-RAXAUL(NEW)-PARWANIPUR-1	03-07-2025	To carry out Gantry erection works at near by Parsauni 132/66/33 kV Substation of Nepal

220KV-RAJARHAT-NEW TOWN(AA-II)-1	10-07-2025	Emergency shutdown for BCU replacement work at Rajarhat. Charging attempted but tripped on SOTF. B_ph cable faulty
220KV-PATNA-KHAGAUL-1	02-08-2025	Tower No. 63 has bent significantly on one side
400KV/220KV 315 MVA ICT 2 AT KEONJHOR(PG)	05-08-2025	Buchholz relay operated
400KV MAIN BUS - 2 AT DIKCHU	05-08-2025	Bus bar protection operated
400KV-DIKCHU-RANGPO-2	05-08-2025	Damaged insulator replacement work. While charging the line bus bar protection operated at Dikchu
400KV-ARAMBAGH-NEW PPSP-2	04-01-2025	Damage in GIS chamber at new ppsp ss for Arambag ckt.Expected in January 2026
220KV-PATNA-KHAGAUL-1	24.09.2025	LBB relay operated during rectification of DC grounding defect by M/S KRR at GSS khagaul. Earlier w.e.f 02-08-2025 12:06 Hrs, Tower No. 63 has bent significantly on one side
220KV-CHANDAUTI (PMTL)-BODHGAYA-2	13.10.2025	Emergency tree trimming work
220KV-CHANDAUTI (PMTL)-BODHGAYA-1	13.10.2025	Emergency tree trimming work
132KV-PATRATU-PATRATU-2	18-10-2025	Power support withdrawn, open from DVC end
220KV-DALTONGANJ-LATEHAR(JUSNL)-2	23-10-2025	To avoid overloading of 400/200 kV ICT-I at Latehar
400KV/220KV 315 MVA ICT 1 AT INDRAVATI HEP	25-10-2025	Due to oil leakage from Tan delta test tap of R phase 400 kV Bushing
220KV-BIDHANNAGAR-WARIA-1	29-10-2025	To control loading of 220 kV Waria-Mejia D/C (Anti-theft charged from Waria end.)
220KV-BIDHANNAGAR-WARIA-2	29-10-2025	Initially line was opened to control line loading. In between B-phase CT Blast at Bidhannagar end. Now Line is charged as anti-theft from Waria end to control loading of 220 kV Waria-Mejia D/C.
132KV-CHANDAULI-KARMANASA-1	06-11-2025	Power assistance not required
HVDC 800KV ALIPURDUAR (PG) Pole 3	11-11-2025	For system requirement due to lean hydro season.
HVDC 800KV ALIPURDUAR (PG) Pole 4	11-11-2025	For system requirement due to lean hydro season.
220KV-BALIMELA-UPPER SILERU-1	21-11-2025	Idle charged from U. Sileru end. Power drawl by Odisha halted due to non-concurrence by Andhra Pradesh.
LILO of Talcher Meramundali at Angul	21-11-2025	Reconductoring work,400 kV Talcher-Meeramundali-2 has been made direct

		bypassing LILO part.
220KV/132KV 160 MVA ICT 4 AT MALDA	19-12-2025	CRP Upgradation work
400KV-BINAGURI-TALA-4	30-11-2025	H/T ON VOLTAGE REGULATION
400KV-FSTPP-KHSTPP-1	02-12-2025	Reconductoring works by HTLS Conductor.
220KV-BUDHIPADAR-KORBA-2	08-12-2025	For erection of online tower line ckt-2(earlier ckt-3)
220KV-GAYA(PG)-BODHGAYA-4	11-12-2025	Bodhgaya end relay: Y_N fault, F Current 5.3 kA, F Distance 23.5 km
220KV-KATAPALLI-BOLANGIR(PG)-1	20-12-2025	To restrict loading of 220kV Budhipadar-Lapanga ckt-1&2 due to hotspot observed in 220kV Budhipadar-Lapanga ckt-1.
400KV/220KV 315 MVA ICT 2 AT TSL KALINGANAGAR	16-12-2025	Emergency shutdown to attend oil leakage

Transmission licensees/ Utilities are requested to update expected restoration date & work progress regarding restoration regularly to ERPC/ERLDC on monthly basis by 5<sup>th</sup> of each month so that status of restoration can be reviewed in OCC. Utilities are also requested to update outage of any elements within their substation premises like isolator/breaker to ERPC/ERLDC regularly. (Reported as per Clause 5.2(e) of IEGC).

**OCC Decision:**

Members noted.

**4.4. Commissioning of new units and transmission elements in Eastern Grid in the month of November-2025.**

The details of new units/transmission elements commissioned in the month of November-2025 based on the inputs received from beneficiaries:

NEW ELEMENTS COMMISSIONED DURING NOVEMBER, 2025							
उत्पादन इकाइयाँ / GENERATING UNITS							
Sl. No.	स्थान Location / Pooling Station	मालिक/यूनिट का नाम OWNER/UNIT NAME	यूनिट संख्या/स्रोत Unit No/Sou rce	संकलित क्षमता (मेगा वाट) Capacity added (MW)	कुल/स्थापित क्षमता (मेगावाट) Total/Installe d Capacity (MW)	दिनांक DATE	टिप्पणी Remarks क्र
1	ACPP	JSL(Jindal steel Limited)/ACPP	Unit-1/Coal	525	525	03-11-2025	This is an intrastate

	Angul, Odisha						captive generator connected to the JSPL system, which is further interconnected to the Meramandali substation of OPTCL.
--	---------------	--	--	--	--	--	---

### आई.सी.टी./जी.टी./एस.टी / ICTs/ GTs / STs

क्र. Sl. No.	एजेसी/मालिक Agency/Owner	उप-केन्द्र SUB-STATION	आईसीटी संख्या ICT NO	वोल्टेज (केवी) Voltage Level (kV)	क्षमता (एमवीए) CAPACITY (MVA)	दिनांक DATE	टिप्पणी Remarks
1	PVUNL	PVUNL	ST-01	400/11	144	01-11-2025	
2	JSL (Jindal steel Limited)	JSPL	ST-01	400/34.5	160	13-11-2025	
3		ACPP II	ST-02	400/11	80	25-11-2025	
4		JSPL	ST-03	400/34.5	230	21-11-2025	
5		JSPL	ST-03	400/34.5	160	25-11-2025	
6		JSPL	ST-02	400/34.5	160	11-11-2025	
7		ACPP II	GT-01	400/21	630	03-11-2025	

NIL

### प्रेषण लाइन / TRANSMISSION LINES

क्र. Sl. No.	एजेसी/मालिक Agency	लाइन का नाम LINE NAME	लंबाई (किमी) Length	कंडक्टर प्रकार Conductor Type	दिनांक DATE	टिप्पणी Remarks
--------------	--------------------	-----------------------	---------------------	-------------------------------	-------------	-----------------

	cy/O wner		(KM)			
NIL						
<b>लिलो / प्रेषण लाइन की पुनर्व्यवस्था / LILO/RE-ARRANGEMENT OF TRANSMISSION LINES</b>						
क्र. Sl. No.	एजेंसी/ मालि क Agen cy/O wner	लाइन का नाम / लिलो पर Line Name/LILO at	लंबाई (किमी) Lengt h (KM)	कंडक्टर प्रकार Conductor Type	दिनांक DATE	टिप्पणी Remarks
1	PGCI L+DV C	400KV NEW RANCHI- RAGHUNATHPUR-1	230.7 6	Quad Moose	17-11- 2025	This circuit is formed by the 400 kV Ranchi–Raghunathpur–2 line (155 km) and the 400 kV Ranchi–New Ranchi–3 line (78.5 km), after bypassing the Ranchi substation.
2	PGCI L+DV C	400KV NEW RANCHI- RAGHUNATHPUR-2	231	Quad Moose	17-11- 2025	This circuit is formed by the 400 kV Ranchi–Raghunathpur–3 line (155 km) and the 400 kV Ranchi–New Ranchi–4 line (78.5 km), bypassing the Ranchi substation
3	PGCI L Odish a Projec ts	400 KV TSTPP– MERAMUNDALI CKT–2 (AFTER BYPASSING ANGUL SUBSTATION)	51.60 8	ACSR Moose	20-11- 2025	

4	PGCIL ERTS -1	NORMALIZATION OF 400 KV NEW PURNEA– FARAKKA CKT-1 AND NEW PURNEA– GOKARNA CKT-1	171.6 23  248.7 13	Tripple ACSR  Snowbird Conductor	22-11- 2025  22-11- 2025	Normalizatio n of the 400 kV New Purnea– Farakka and New Purnea– Gokarna lines, which are currently in service through temporary interconnecti on as the 400 kV Farakka– Gokarna circuit.
---	---------------------	---	--------------------------------	---	--------------------------------------	--

**बस/लाइन रिएक्टर / BUS/LINE REACTOR**

क्र. Sl. No.	एजेंसी/मालिक Agency/Owner	एलेमेंट का नाम Element Name	उप-केन्द्र SUB-STATION	वोल्टेज (केवी) Voltage Level (kV)	दिनांक DATE	टिप्पणी Remarks
1	PVUNL	125 MVAR, 400 KV BUS REACTOR - 1 AT PVUNL	PVUNL	125	14-11-2025	

NIL

**बस / BUS**

क्र. Sl. No.	एजेंसी/मालिक Agency/Owner	एलेमेंट का नाम Element Name	उप-केन्द्र SUB-STATION	वोल्टेज (केवी) Voltage Level (kV)	दिनांक DATE	टिप्पणी Remarks
1	JSL(Jindal steel Limited)	400KV MAIN BAY OF 160MVA ST-3 AT JSPL	JSPL	400	25-11-2025	
2	JSL(Jindal steel Limited)	400KV MAIN BAY OF 630 MVA GT-1 AT ACPP II	JSPL	400	03-11-2025	
3	JSL(Jindal steel Limited)	BAY NO-408 AT ACPP-II	ACPP	400	05-11-2025	
4	JSL(Jindal steel Limited)	BAY NO-409 AT ACPP-II	ACPP	400	05-11-2025	

5	d)	400 KV MAIN BAY OF 160MVA ST-1 AT JSPL	JSPL	400	13-11- 2025	
6		400KV MAIN BAY OF 160MVA ST-1 AT JSPL	JSPL	400	13-11- 2025	
7		400KV MAIN BAY OF 160MVA ST-2 AT JSPL	JSPL	400	11-11- 2025	
8		400KV MAIN BAY OF 160MVA ST-4 AT JSPL	JSPL	400	06-11- 2025	
9	PVUN L	400KV MAIN BAY OF 125MVAR B/R-1 AT PVUNL	PVUN L	400	14-11- 2025	
10	PVUN L	400KV TIE BAY OF 125MVAR B/R-1 AND 125MVAR B/R-2 AT PVUNL	PVUN L	400	14-11- 2025	
NIL						
<b>एच.वी.डी.सी/ए.सी फिल्टर बैंक/फैक्ट्स डिवाइस संबद्ध प्रणाली / HVDC /AC Filter bank / FACTS DEVICE associated System</b>						
क्र. Sl. No.	एजेंसी/ मालि क Agen cy/O wner	एलेमेंट का नाम Element Name	उप- केन्द्र SUB- STATI ON	वोल्टेज (केवी) Voltage Level (kV)	दिनांक DATE	टिप्पणी Remarks
NIL						

NEW ELEMENTS COMMISSIONED DURING September, 2025							
उत्पादन इकाइयाँ / GENERATING UNITS							
S I. N o.	स्थान Location / Pooling Station	मालिक/यूनिट का नाम OWNER/UNIT NAME	यूनि ट सं ख्या/ स्रोत Unit No/ Sou rce	संकलित क्षमता (मेगावाट) Capacity added (MW)	कुल/स्थापित क्षमता (मेगावाट) Total/Installe d Capacity (MW)	दिनांक DATE	टिप्पणी Remarks क्र

NIL							
आई.सी.टी/जी.टी/एस.टी / ICTs/ GTs / STs							
क्र . S I. N O.	एजेंसी/मालिक Agency/O wner	उप-केन्द्र SUB- STATION	आईसीटी संख्या ICT NO	वोल्टेज (केवी) Voltage Level (kV)	क्षमता (एमवीए) CAPACITY (MVA)	दिनांक DATE	टिप्पणी Remarks
1.	JSL (Jindal steel Limited) (Intra- state Generator under Odisha)	ACPP II	ST 1	400/ 11kV	80	25-10- 2025 18:55	The Angul Captive Power Plant (ACPP II-2x525 MW), consisting of two generating units of 525 MW each, is a captive power generating station located at Angul. It is connected to the JSPL system, which is further interconnected with the 400 kV Meeramandali substation.
प्रेषण लाइन / TRANSMISSION LINES							
क्र . S I. N O.	एजेंसी/मालिक Agency/O wner	लाइन का नाम LINE NAME	लंबाई (किमी) Length (KM)	कंडक्टर प्रकार Conductor Type	दिनांक DATE	टिप्पणी Remarks	
1	JSL (Jindal steel Limited)	400KV-JSPL-ACPP II- 1	4.7	Twin ACSR Moose	25-10- 2025 14:15		
2	JSL(Jindal	400KV-JSPL-ACPP II-	4.7	Twin ACSR	25-10-		

	steel Limited)	2		Moose	2025 17:09	
<b>लिलो / प्रेषण लाइन की पुनर्व्यवस्था / LILO/RE-ARRANGEMENT OF TRANSMISSION LINES</b>						
क्र . S I. N O.	एजेंसी/मालिक Agency/O wner	लाइन का नाम / लिलो पर Line Name/LILO at	लंबाई (किमी) Length (KM)	कंडक्टर प्रकार Conductor Type	दिनांक DATE	टिप्पणी Remarks
1	PGCIL ER-I	400KV-FSTPP- GOKARNA (N Purnea bypass)	299.5	Snow Birds	02-10- 2025 14:17	Temporary arrangement of 400 kV New Purnea - Farakka & 400 kV New Purnea- Gokarna line after bypassing New Purnea through jumpering at Tower No. - 1063
<b>बस/लाइन रिएक्टर / BUS/LINE REACTOR</b>						
क्र . S I. N O.	एजेंसी/मालिक Agency/O wner	एलेमेंट का नाम Element Name	उप-केन्द्र SUB- STATIO N	वोल्टेज (केवी) Voltage Level (kV)	दिनांक DATE	टिप्पणी Remarks
NIL						
<b>बस / BUS</b>						
क्र . S I. N O.	एजेंसी/मालिक Agency/O wner	एलेमेंट का नाम Element Name	उप-केन्द्र SUB- STATIO N	वोल्टेज (केवी) Voltage Level (kV)	दिनांक DATE	टिप्पणी Remarks
1	JSL(Jindal steel Limited)	ACPP II - 400KV - Bus 1	ACPP II	400	30-10- 2025 04:57	The Angul Captive Power Plant (ACPP II- 2x525 MW), consisting of two generating
2	JSL(Jindal steel Limited)	ACPP II - 400KV - Bus 2	ACPP II	400	30-10- 2025 04:58	

						units of 525 MW each, is a captive power generating station located at Angul. It is connected to the JSPL system, which is further interconnected with the 400 kV Meeramandali substation.
--	--	--	--	--	--	--

**एच.वी.डी.सी/ए.सी फिल्टर बैंक/फैक्ट्स डिवाइस संबद्ध प्रणाली / HVDC /AC Filter bank / FACTS DEVICE associated System**

क्र . S I. N O.	एजेंसी/मालिक Agency/O wner	एलेमेंट का नाम Element Name	उप-केन्द्र SUB- STATIO N	वोल्टेज (केवी) Voltage Level (kV)	दिनांक DATE	टिप्पणी Remarks
-----------------------------	----------------------------------	--------------------------------	-----------------------------------	---	----------------	--------------------

NIL

**बे / BAYS**

क्र . S I. N O.	एजेंसी/मालिक Agency/O wner	एलेमेंट का नाम Element Name	उप-केन्द्र SUB- STATIO N	वोल्टेज (केवी) Voltage Level (kV)	दिनांक DATE	टिप्पणी Remarks
1	Limited JSL(Jindal steel)	400KV MAIN BAY OF JSPL-2 AT ACPP II	ACPP II	400	25-10-2025 17:09	The Angul Captive Power Plant (ACPP II-2x525 MW), consisting of two generating units of 525 MW each, is a captive power generating
2	JSL(Jindal steel Limited)	400KV MAIN BAY OF JSPL-1 AT ACPP II	ACPP II	400	25-10-2025 15:22	
3	JSL(Jindal steel Limited)	400KV MAIN BAY OF ACPP II-2 AT JSPL	JSPL	400	26-10-2025 14:57	
4	JSL(Jindal	400KV MAIN BAY OF	JSPL	400	26-10-	

	steel Limited)	ACPP II-1 AT JSPL			2025 14:13	station located at Angul. It is connected to the JSPL system, which is further interconnected with the 400 kV Meeramandali substation.
5	JSL(Jindal steel Limited)	400KV BUS SECTIONALIZER BAY OF ( MAIN BUS - 2 AND EXTENDED GIS MAIN BUS - 2) AT JSPL	JSPL	400	25-10-2025 16:26	
6	JSL(Jindal steel Limited)	400KV BUS SECTIONALIZER BAY OF ( MAIN BUS - 1 AND EXTENDED GIS MAIN BUS - 1) AT JSPL	JSPL	400	25-10-2025 12:39	

Members may note.

**Deliberations in the meeting**

*Members noted.*

**4.5. UFR operation during the month of November 2025**

Frequency profile for the month as follows:

MONTH	MAX	MIN	% LESS IEGC BAND	% WITHIN IEGC BAND	% MORE IEGC BAND
	(DATE/TIME)	(DATE/TIME)			
<b>November 2025</b>	50.4 Hz on 28-11-25 at 06:02 Hrs.	49.54 Hz on 21-11-25 at 17:22 Hrs.	5.7	79.4	14.9

Hence, no report of operation of UFR has been received from any of the constituents.

Members may note.

**Deliberations in the meeting**

*Members noted.*

The meeting ended with a vote of thanks to the chair.

\*\*\*\*\*

# Annex A

## Participants in 234th OCC Meeting

Venue: ERPC Conference Hall, Kolkata

Time: 10:30 Hrs.

Date: 23.12.2025 (Tuesday)
















Sl.	Name	Designation	Organisation	Contact No.	E-mail Id	Signature
1	N S Mondal	Member Secretary	ERPC	9958389967	mserpc-power@nic.in	
2	R Sutradhar	Executive Director	ERLDC	9436302714	rajibsutradhar@grid-india.in	
3	S. KEJRIWAL	SE	ERPC	9831919509	shyam.kejriwal@gov.in	
4	Surajit Banerjee	ED	ERLDC	9432041823	surajit.banerjee@grid-india.in	
5	S Chakrabarti	CGM	4	9436385369	sdc@grid-india.in	
6	D. BISWAS	GM	ERLDC	9434740241	dbiswas@grid-india.in	
7	Bilash Achari	DGM	ERLDC	7003472016	bilash.achari@grid-india.in	
8	MANAS DAS	DGM	ERLDC, GRID-INDIA	9007070925	manasdas@grid-india.in	
9	CHANDAN MALICK	CM	ERLDC, GRID-INDIA	9007059660	chandan.mallick@grid-india.in	
10	ARNAB BASU	DE(E)	SLDC, WBSETCL	9434910978	arnab.basu@wbsetcl.in	
11	UTSAB ADITYA	SE (E)	SLDC, WBSETCL	9434910880	utsabaditya@gmail.com	
12	SHOUVIK BANERJEE	CE, SLDC, WB	SLDC, WBSETCL	9434910379	svkbanerjee@yahoo.com	
13	SANJIB ROY	ACE, SLDC, WB	SLDC, WBSETCL	9331905657	sanjibroy12235@gmail.com	
14	Jaydeep Sengupta	ACE, CPD	WBSETCL	9474910547	cecpdwbsetcl@gmail.com	
15	Rajat Kr. Koley	SM(OS)	WBPDC	9474860642	rk.koley@wbpdcl.co.in	

## Participants in 234th OCC Meeting

Venue: ERPC Conference Hall, Kolkata

Time: 10:30 Hrs.

Date: 23.12.2025 (Tuesday)

Sl.	Name	Designation	Organisation	Contact No.	E-mail Id	Signature
16	MANOJ PODDER	AGM (OS)	WBPDCL	8336904077	mpodder@wbpdcl.co.in	
17	KOUSHIK BANERJEE	GM(SO-EM)	CESC LIMITED	9831003281	koushik.banerjee@spsg.in	 23/12/25
18	DEBARSHI DE	DGM (SU)	CESC LTD	9230521123	debarshi.de@spsg.in	 23/12/25
19	DINESH LAHA	GM	INDIGRID	8918720645	dinesh.laha@indigrd.com	 23-12-25
20	Diptikanta Panda	Manager	GMR, Odisha	8114918762	diptikanta.panda@gmrgroup.in	 D.K. Panda
21	P.V. RAUT	AGM (OPN)	MPL	9223501513	rautpv@tatapower.com	 RR
22	Gagan Kumar	EE CESC Bihar	SLDC, BSNL	7992486100	gagankumichra@gmail.com	
23	Partha Sharan	DGM	ER-D	943446263	partha.sharan@powersrid.in	
24	TUNESHWAR KUMAR	SM	JUSNL	9431190306	tuneshwar.kumar@gmail.com	
25	Raju Kachhap	Sr. Manager	SLDC, Ranchi JUSNL	7783087568	rajmailme82@gmail.com	
26	S.K. Sharma	Sr. GM & HOD.	DVC, LDC.	9434539423	sanjay.sharma@dvc.gov.in	
27	S.K. Panda	manager.	DVC, LDC.	6370134794	sanjay.panda@dvc.gov.in	
28	Aarshad Jalani	DGM	NTPC	4680997632	aarshadjalani@ntpc.co.in	
29	P P Sena	EE	ERPC	9776198991	ppjena.erpc@gov.in	
30	Manjema M	EC	-	9970223842		

### Participants in 234th OCC Meeting

Venue: ERPC Conference Hall, Kolkata

Time: 10:30 Hrs.

Date: 23.12.2025 (Tuesday)

Sl.	Name	Designation	Organisation	Contact No.	E-mail Id	Signature
31	Agniva Chatterjee	AD-I	ERPC			@chatterjee
32	B S Ray	Dy. DIR	ERPC			B. S. Ray
33	A. Das	"	ERPC			A. Das
34	P. K. De	SE	ERPC			P. K. De
35						
36						
37						
38						
39						
40						
41						
42						
43						
44						
45						

**Participants who joined online**

<b>List of Participants</b>				
<b>Name</b>	<b>First Join</b>	<b>Last Leave</b>	<b>In-Meeting Duration</b>	<b>Email</b>
ERPC Kolkata	12/23/25, 10:22:00 AM	12/23/25, 2:09:14 PM	3h 34m 15s	ERPC@KolkataMST.onmicrosoft.com
Birendra Kumar	12/23/25, 10:32:38 AM	12/23/25, 1:53:18 PM	3h 20m 39s	
Prasanna Kumar Sahoo (External)	12/23/25, 10:32:39 AM	12/23/25, 1:46:09 PM	3h 13m 30s	PRASANNASAHOO@NTPC.CO.IN
THEP (Unverified)	12/23/25, 10:32:39 AM	12/23/25, 10:36:15 AM	3m 35s	
Rahul Srivastava (External)	12/23/25, 10:32:39 AM	12/23/25, 2:09:14 PM	3h 36m 34s	rahul.sr@greenkogroup.com
SLDC ODISHA (Unverified)	12/23/25, 10:32:39 AM	12/23/25, 2:09:14 PM	3h 36m 34s	
DANS ENERGY, SIKKIM (Unverified)	12/23/25, 10:32:39 AM	12/23/25, 11:14:49 AM	42m 9s	
Satyadeep Rai	12/23/25, 10:32:39 AM	12/23/25, 11:48:53 AM	1h 16m 13s	
Surya Pratap Rath, AGM OPTCL (Unverified)	12/23/25, 10:32:40 AM	12/23/25, 2:09:10 PM	3h 36m 30s	
Nishant Kumar Shankwar	12/23/25, 10:32:40 AM	12/23/25, 2:09:14 PM	3h 36m 33s	Nishant.Kumar@energy-sel.com
Shabari Pramanick (External)	12/23/25, 10:32:40 AM	12/23/25, 2:06:10 PM	3h 33m 29s	shabari.pramanick@erldc.onmicrosoft.com
PRATHAM KUMAR (Unverified)	12/23/25, 10:32:40 AM	12/23/25, 2:09:14 PM	3h 36m 33s	
Amit (Unverified)	12/23/25, 10:32:40 AM	12/23/25, 2:09:14 PM	3h 36m 33s	
Sangram Keshari Bhoi (संग्राम केशरी भोई) (Ext	12/23/25, 10:32:40 AM	12/23/25, 1:19:57 PM	2h 35m 57s	sangramkbhoi@powergrid.in
Abhilash Gour (External)	12/23/25, 10:32:41 AM	12/23/25, 2:01:46 PM	3h 29m 5s	abhilash.gour@dansenergy1.onmicrosoft.com
AVINASH SHUKLA (External)	12/23/25, 10:32:54 AM	12/23/25, 2:06:10 PM	3h 30m 56s	AVINASHSHUKLA@NTPC.CO.IN
Bimal (Unverified)	12/23/25, 10:33:18 AM	12/23/25, 2:09:14 PM	3h 35m 55s	

<b>List of Participants</b>				
<b>Name</b>	<b>First Join</b>	<b>Last Leave</b>	<b>In-Meeting Duration</b>	<b>Email</b>
Bans Narain Yadav (External)	12/23/25, 10:33:22 AM	12/23/25, 1:41:15 PM	3h 7m 52s	BNYADAV01@NTPC.CO.IN
Sudhir Kumar Meher {सुधीर कुमार मेहर} (External)	12/23/25, 10:33:24 AM	12/23/25, 12:49:53 PM	2h 16m 28s	sudhirko.meher@powergrid.in
Nisar Husain	12/23/25, 10:38:17 AM	12/23/25, 11:44:14 AM	1h 4m 55s	
Rongnichu HEP (Unverified)	12/23/25, 10:38:18 AM	12/23/25, 2:09:14 PM	3h 30m 55s	
Pintu R Das STPL (Unverified)	12/23/25, 10:40:09 AM	12/23/25, 2:01:41 PM	3h 16m 41s	
RAMESHCHAND YADAV (External)	12/23/25, 10:48:04 AM	12/23/25, 2:09:14 PM	3h 21m 9s	RCYADAV@NTPC.CO.IN
Sudeep Kumar {सुदीप कुमार} (External)	12/23/25, 10:59:06 AM	12/23/25, 2:09:14 PM	3h 10m 7s	sudeepkumar@powergrid.in
Laldhari Kumar (External)	12/23/25, 10:59:59 AM	12/23/25, 1:54:47 PM	2h 54m 48s	laldhari@erldc.onmicrosoft.com
Prabhat Kumar (External)	12/23/25, 11:00:38 AM	12/23/25, 12:51:37 PM	1h 50m 59s	prabhat.k@greenkogroup.com
Shukla Brajesh (External)	12/23/25, 11:00:41 AM	12/23/25, 2:06:46 PM	3h 6m 4s	brajesh.shukla@tatapower.com
RAKESH (External)	12/23/25, 11:10:12 AM	12/23/25, 2:09:14 PM	2h 59m 1s	RAKESHKUMAR07@NTPC.CO.IN
MUKESH KUMAR (External)	12/23/25, 11:12:07 AM	12/23/25, 11:12:56 AM	49s	MUKESHKUMAR51@NTPC.CO.IN
Rahul Anand (External)	12/23/25, 11:12:53 AM	12/23/25, 2:07:21 PM	2h 54m 28s	RAHULANAND@NTPC.CO.IN
Anand Kr. Prajapati (External)	12/23/25, 11:14:10 AM	12/23/25, 12:00:01 PM	44m	AKPRAJAPATI@NTPC.CO.IN
DANS ENERGY, SIKKIM (Unverified)	12/23/25, 11:17:48 AM	12/23/25, 11:49:08 AM	31m 20s	
Ch Eswara Rao {सीएच. ईश्वर राव} (External)	12/23/25, 11:18:35 AM	12/23/25, 1:29:25 PM	2h 10m 50s	eswar@powergrid.in
Kothamasu (External)	12/23/25, 11:28:55 AM	12/23/25, 1:21:08 PM	1h 52m 13s	SURESHKUMARK@NTPC.CO.IN

## List of Participants

Name	First Join	Last Leave	In-Meeting Duration	Email
Prasenjit Halder (External)	12/23/25, 11:30:01 AM	12/23/25, 2:09:14 PM	2h 39m 12s	HALDERPRASENJIT@NTPC.CO.IN
prahlada bhola (Unverified)	12/23/25, 11:36:01 AM	12/23/25, 11:58:34 AM	22m 32s	
K K Prusti {के.के.} (External)	12/23/25, 11:37:04 AM	12/23/25, 12:48:33 PM	1h 11m 29s	kkp@powergrid.in
Pranav Rathore (External)	12/23/25, 11:37:27 AM	12/23/25, 2:09:14 PM	2h 31m 46s	pranav.rathore@indigrid.com
Alok Pratap Singh (External)	12/23/25, 11:41:43 AM	12/23/25, 11:52:00 AM	10m 16s	apsingh@erlhc.onmicrosoft.com
SUMEET NARANG (External)	12/23/25, 11:52:27 AM	12/23/25, 2:00:21 PM	2h 7m 54s	SUMEETNARANG@NTPC.CO.IN
Gaurav Kumar (External)	12/23/25, 1:02:56 PM	12/23/25, 1:38:00 PM	35m 4s	gakumar@erlhc.onmicrosoft.com
Sourav Mandal (Unverified)	12/23/25, 1:02:56 PM	12/23/25, 2:09:14 PM	1h 6m 17s	
Rakesh Kr Pradhan (External)	12/23/25, 1:04:17 PM	12/23/25, 2:09:14 PM	1h 4m 56s	rkpradhan@erlhc.onmicrosoft.com
shabari pramanick	12/23/25, 1:40:47 PM	12/23/25, 1:55:04 PM	14m 17s	
Debadatta Padhy {देवदत्त पाढी} (External)		12/23/25, 2:09:14 PM	3h 36m 33s	debdatta.padhy@powergrid.in
Mahendra Malik		12/23/25, 1:23:32 PM	6s	mahendra.malik@jsw.in