



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति

**Eastern Regional Power Committee**

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008  
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: [www.erpc.gov.in](http://www.erpc.gov.in)

NO: ERPC/COM-II/VARH / 7326-36

Date: 04.01.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

**Sub: Provisional Reactive Energy (VARH) Charges for the week from 10.12.2018-16.12.2018**

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 20.12.2018.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

  
MEMBER SECRETARY

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 10/12/18 to 16/12/18**

***REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL***

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	4449382

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

**MEMBER SECRETARY**

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

for the period 10/12/18 to 16/12/18

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVA/H (Rs)	MVAH_LOW	REACTIVE CHARGE_MVA/H (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-1073.7	150318	0	0	150318
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-3045.3	426342	0	0	426342
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1566.6	219324	0	0	219324
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	81.5	-11410	-2.5	-350	-11760
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	105.3	-14742	-0.6	-84	-14826
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	113.9	-15946	-1.6	-224	-16170
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-2402.7	336378	0	0	336378
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-746.2	104468	0	0	104468
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-782.4	109536	0	0	109536
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG-I)	NP6641A	-1852.5	259350	0	0	259350
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG-II)	NP6060A	-796.2	111468	0	0	111468
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	10.9	-1526	-36.7	-5138	-6664
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARAH 160 MVA ICT-3	ER1313A	1033	-144620	0	0	-144620
	16	132 KV KHALGAON(NTPC)-KHALGAON (BSPHCL)	NP5261A	-1615.1	226114	0	0	226114
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP6665A	-1400.7	196098	0	0	196098
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP6664A	-1389.6	194544	0	0	194544
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	-25	3500	0	0	3500
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	-35.2	4928	0	0	4928
	21	132 KV KHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	302.9	-42406	0	0	-42406
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	891.5	-124810	0	0	-124810
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	908.6	-127204	0	0	-127204
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	997.2	-139608	0	0	-139608
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	939.9	-131586	0	0	-131586
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	105.1	-14714	7.7	1078	-13636
	27	HV side of 400/220 Patna ICT-1	ER1408A	-1012	141680	0	0	141680
	28	HV side of 400/220 Patna ICT-2	ER1407A	0	0	0	0	0
	29	HV side of 400/220 Patna ICT-3	ER1231A	-1889.3	264502	0	0	264502
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	-587.1	82194	0	0	82194
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	-599.1	83874	0	0	83874
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	1798.4	-251776	0	0	-251776
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	1652.2	-231308	0	0	-231308
	34	220 KV PURNEA(PG)-MADEHPURA(BSPHCL) LINE-I	ER1175A	2769.2	-387688	0	0	-387688
	35	220 KV PURNEA(PG)-MADEHPURA(BSPHCL) LINE-II	ER1176A	2768.5	-387590	0	0	-387590
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1574.2	220388	0	0	220388
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-1603.9	224546	0	0	224546
	38	HV side of 400/220 Darbhanga DMTCL ICT-1	ER1274A	0	0	0	0	0
	39	HV side of 400/220 Darbhanga DMTCL ICT-2	ER1275A	0	0	0	0	0
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	-206.1	28854	0	0	28854
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-181.4	25396	0	0	25396
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	0	0	0	0	0
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	0	0	0	0	0
		<b>TOTAL</b>		<b>1368668</b>		<b>-4718</b>	<b>1362150</b>	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-2588.1	362334	0	0	362334
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-2056.5	287910	0	0	287910
	3	HV side meter of 400/220 Jamshedpur ICT-3	ER1297A	-1155.7	161798	0	0	161798
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5879A	858.2	-124348	0	0	-124348
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	663.8	-92932	0	0	-92932
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	3944.4	-552216	0	0	-552216
	7	132 KV KHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1687.4	236236	0	0	236236
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-276.6	39004	0	0	39004
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-251	35140	0	0	35140
	10	HV side meter data of 400/220 Chalbassa ICT-1	NP8637A	153.7	-21518	0	0	-21518
	11	HV side meter data of 400/220 Chalbassa ICT-2	NP8678A	129	-18060	0	0	-18060
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	-119.4	16716	0	0	16716
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	-112.9	15806	0	0	15806
		<b>TOTAL</b>		<b>345870</b>		<b>0</b>	<b>345870</b>	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2338.8	327432	0	0	327432
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-97.2	13608	0	0	13608
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-398.2	55748	0	0	55748
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	247.6	-34664	0	0	-34664
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	388.2	-54348	0	0	-54348
	7	400 KV TATA JAMSHEDPUR (DVC) - BARIPADA(PG)	NP7408A	-2955.6	413784	0	0	413784
	8	400 KV TATA JAMSHEDPUR (DVC) - JAMSHEDPUR (PG)	NP7406A	2342.3	-327922	0	0	-327922
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	1490.5	-208670	0	0	-208670
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-406.2	56868	0	0	56868
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-534.1	74774	0	0	74774
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-5425.1	759514	0	0	759514
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-3902.1	546294	0	0	546294
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	1345.8	-188412	0	0	-188412
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	1338.5	-187390	0	0	-187390
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-HI(MAIN)	NP6524A	-5043.3	706062	0	0	706062
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-HI(MAIN)	NP6522A	-5113.8	715932	0	0	715932
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-4719.6	660744	0	0	660744
19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	3055.6	-427784	0	0	-427784	
20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-3514.5	492030	0	0	492030	
21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	5371.2	-751968	0	0	-751968	
22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	5352.4	-749336	0	0	-749336	
		<b>TOTAL</b>		<b>1892296</b>		<b>0</b>	<b>1892296</b>	

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeyapore ICT-1	ER1550A	0	0	0	0	0
	6	HV side meter of 400/220 Jeyapore ICT-2	ER1571A	0	0	0	0	0
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	-42.6	5964	0	0	5964
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	-48.7	6818	0	0	6818
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-2153.4	301476	0	0	301476
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3057.6	428064	0	0	428064
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-2892.4	404936	0	0	404936
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-2801.8	392252	0	0	392252
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	-190.8	26712	0	0	26712
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA(PG)	NP7916A	-2283.7	319718	0	0	319718
	17	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	5958.1	-834134	0	0	-834134
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	8272.7	-1158178	0	0	-1158178
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)	NP7932A	3049.7	-426958	0	0	-426958
	20	400 KV MENDHASAL (GRIDCO)-PANDIABIL(PG)-I	NP5980A	-403.5	56490	0	0	56490
	21	400 KV MENDHASAL (GRIDCO)-PANDIABIL(PG)-II	NP7498A	-478.9	67046	0	0	67046
	22	400 KV DUBURI (GRIDCO)-PANDIABIL(PG)	NP7915A	-2867.4	401436	0	0	401436
	23	HV side meter of 400/220 Bolangi-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangi-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabil ICT-1	ER1583A	-1207.6	169064	0	0	169064
	26	HV side of 400/220 Pandiabil ICT-2	ER1586A	-463.8	64932	0	0	64932
	27	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	-2991.7	418838	0	0	418838
	28	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	-3111.6	435624	0	0	435624
		<b>TOTAL</b>		<b>1080100</b>		<b>0</b>	<b>1080100</b>	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-51.80	7252	-0.9	-126	7126
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-76.00	10640	-0.6	-84	10556
	3	86 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-3.3	-462	-462
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-1	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	16.00	-2240	0	0	-2240
		<b>TOTAL</b>		<b>15682</b>		<b>-672</b>	<b>14980</b>	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	-1726.6	241724	-261.6	-36624	205100
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1538A	2164.1	-305774	0	0	-305774
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	2125.6	-297584	0	0	-297584
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-490.1	68614	0	0	68614
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-514.1	71974	0	0	71974
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	-62.8	8792	0	0	8792
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-180.1	25214	0	0	25214
	8	132 KV SILIGURI (PG) - NSU (WBSETCL)	NP5889A	594.6	83244	0	0	83244
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-1768.7	247618	0	0	247618
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-429.5	60130	0	0	60130
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	4421.9	-619066	0	0	-619066
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	4921.6	-689024	0	0	-689024
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-33.6	4704	0	0	4704
	14	400 KV DURGAJUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	7898.3	-1105762	0	0	-1105762
	15	400 KV DURGAJUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	9136.3	-1279082	0	0	-1279082
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-1047.7	146678	0	0	146678
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	-3577.8	500892	0	0	500892
	18	132 KV KURSEONG (WBSETCL) - RANGIT (NHPC)	NP7541A	-101.5	14210	0	0	14210
	19	132 KV KURSEONG (WBSETCL) - SILIGURI (NHPC)	NP7542A	52	-7280	0	0	-7280
	20	400 KV KHARAGPUR (WBSETCL) - BARIPADA (PG)	ER1043A	3365.4	-471156	0	0	-471156
	21	400 KV DURGAJUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	3614.2	-505988	0	0	-505988
	22	400 KV DURGAJUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	4696.3	-657482	0	0	-657482
	23	220 KV DALKHOLA (PG) - DALKHOLA (WBSETCL) LINE-I	ER1071A	-305	42700	0	0	42700
	24	220 KV DALKHOLA (PG) - DALKHOLA (WBSETCL) LINE-II	ER1072A	-145.2	20328	-0.1	-14	20314
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP818A	0	0	0	0	0
	28	400 KV SUBHASGRAM (PG) - HALDIA CESC (WB) LINE-I	ER1141A	-2862.2	400708	0	0	400708
	29	400 KV SUBHASGRAM (PG) - HALDIA CESC (WB) LINE-II	NP7937A	-2910.1	407414	0	0	407414
	30	400 KV SAGARDIGHI (WB) - BERHAMPUR (PG) LINE-I	NP8723A	2575.7	-360598	0	0	-360598
	31	400 KV SAGARDIGHI (WB) - BERHAMPUR (PG) LINE-II	NP8724A	2364.7	-331058	0	0	-331058
	32	400 KV KHARAGPUR (WB) - CHAIBASA (PG)-I	NP8731A	-375.5	52570	0	0	52570
	33	400 KV KHARAGPUR (WB) - CHAIBASA (PG)-II	NP8720A	-357.3	50022	0	0	50022
	34	400 KV PPSP NEW (WB) - RANCHI NEW (PG)-I	ER1040A	2937.4	-411236	0	0	-411236
	35	400 KV PPSP NEW (WB) - RANCHI NEW (PG)-II	ER1130A	2933	-410620	0	0	-410620
	36	400 KV GOKARNA (WB) - FARAKKA (NTPC)-I	ER1133A	-1816	254240	0	0	254240
	37	400 KV GOKARNA (WB) - FARAKKA (NTPC)-II	ER1138A	-1654.6	231644	0	0	231644
	38	220 KV ALIPURDUAR (PG) - ALIPURDUAR (WB)-I	ER1044A	100.9	-14126	0	0	-14126
	39	220 KV ALIPURDUAR (PG) - ALIPURDUAR (WB)-II	ER1047A	77.2	-10808	0	0	-10808
	40	400 KV SAGARDIGHI (WB) - FARAKKA (NTPC)-II	ER1131A	-932	130480	0	0	130480
			<b>TOTAL</b>		<b>-4412744</b>		<b>-36638</b>	<b>-4449382</b>

Note: 1) Rate of Reactive Energy Charge has been considered @ 14 paise/KVAH, w.e.f. 01/04/2016

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.