



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/17535-45

Date: 08.01.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week from 17.12.2018-23.12.2018


The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 28.12.2018.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,


(J. Bandyopadhyay)
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 17/12/18 to 23/12/18**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	2733808
SIKKIM	POOL	0
WBSETCL	POOL	4997370

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.


MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 17/12/18 to 23/12/18

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP8063A	-608.8	85232	0	0	85232
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP8069A	-1855.7	259798	0	0	259798
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP8068A	-904.8	126672	0	0	126672
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	144.4	-20216	-0.6	-84	-20300
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	194.5	-27230	0	0	-27230
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	185.8	-26012	-0.1	-14	-26026
	7	220 KV PUSALI (PG) - DEHRI (BSPHCL)	NP8093A	-1887	264160	0	0	264160
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-854.7	119658	0	0	119658
	9	220 KV side of 220/132 Arah ICT-2	NP8059A	-903.3	126462	0	0	126462
	10	220 KV KHAGALI(BSPHCL) - ARAH (PG)-I	NP8641A	-3667.1	513394	0	0	513394
	11	220 KV KHAGALI(BSPHCL) - ARAH (PG)-II	NP8060A	-934.7	130858	0	0	130858
	12	132 KV PUSALI(PG)-MOHANA(BSPHCL)	NP8094A	-46.4	6496	-99	-13860	-7364
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	-3.6	504	0	0	504
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1418A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	1284.7	-179858	0	0	-179858
	16	132 KV KHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5281A	-1179.3	165102	0	0	165102
	17	220KV NEW PUSALI(BSPHCL) - PUSALI(PG)	NP8665A	-2856.1	399854	0	0	399854
	18	220KV NEW PUSALI(BSPHCL) - ARA (PG)	NP8664A	991.3	-138782	0	0	-138782
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	-79.7	11158	0	0	11158
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7869A	-83.2	11648	0	0	11648
	21	132 KV KHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	95.8	-13412	0	0	-13412
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-I	ER1293A	987.1	-138194	0	0	-138194
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-II	ER1296A	993.9	-138146	0	0	-138146
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-III	ER1159A	1082.9	-153006	0	0	-153006
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPHCL)-IV	ER1154A	1035.6	-144984	0	0	-144984
	26	132 KV PUSALI(PG)-KUDRA(BSPHCL)	NP8095A	148.3	-20782	58.3	8162	-12600
	27	HV side of 400/220 Patna ICT-1	ER1408A	-300.6	42084	0	0	42084
	28	HV side of 400/220 Patna ICT-2	ER1407A	0	0	0	0	0
	29	HV side of 400/220 Patna ICT-3	ER1231A	-1223.4	171276	0	0	171276
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1348A	-350.9	49126	0	0	49126
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	-352.4	49336	0	0	49336
	32	220 KV MUJAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1228A	1926.5	-269710	0	0	-269710
	33	220 KV MUJAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	1800.9	-252126	0	0	-252126
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	3059.7	-428358	0	0	-428358
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	3060.4	-428456	0	0	-428456
	36	220 KV KANTI (BSPHCL)-MUJAFFARPUR (PG)-I	NP7398A	-852.5	119350	0	0	119350
	37	220 KV KANTI (BSPHCL)-MUJAFFARPUR (PG)-II	NP7452A	-889.3	124502	0	0	124502
	38	HV side of 400/220 Darhanaga DMTCL ICT-1	ER1274A	0	0	0	0	0
	39	HV side of 400/220 Darhanaga DMTCL ICT-2	ER1275A	0	0	0	0	0
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPHCL)-I	ER1256A	-34.8	4872	0	0	4872
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPHCL)-II	ER1256A	-13.2	1848	0	0	1848
	42	220 KV PURNEA(PG)-BEGUSARA(BSPHCL)-I	ER1348A	1932.1	-270494	0	0	-270494
	43	220 KV PURNEA(PG)-BEGUSARA(BSPHCL)-II	ER1376A	0	0	0	0	0
		TOTAL		132664		-5796	126868	
JVVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP8106A	-2926.5	409710	0	0	409710
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP8105A	-2452.5	343350	0	0	343350
	3	HV side meter of 400/220 Jamshedpur ICT-3	ER1297A	-1249.2	174888	0	0	174888
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	954.5	-133630	0	0	-133630
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5876A	1198.4	-167776	0	0	-167776
	6	220 KV FARAKKA (NTPC)-LALMATIA (JVVNL)	NP5211A	3995	-559300	0	0	-559300
	7	132 KV KHALGAON (NTPC)-LALMATIA (JVVNL)	NP5244A	-1435.1	200914	0	0	200914
	8	220 KV MAITHON(PG) - DUMKA(JVVNL) - I	NP8727A	-41.6	5824	0	0	5824
	9	220 KV MAITHON(PG) - DUMKA(JVVNL) - II	NP8739A	0.2	-28	0	0	-28
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	186.4	-26096	0	0	-26096
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	174.2	-24388	0	0	-24388
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	-31.9	4466	0	0	4466
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	-30.7	4298	0	0	4298
		TOTAL		232232		0	232232	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC)-I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC)-II	NP6458A	-1802.4	252336	0	0	252336
	3	220 KV MAITHON (PG) - DHANBAD (DVC) - I	NP6529A	217.8	-30482	0	0	-30482
	4	220 KV MAITHON (PG) - DHANBAD (DVC) - II	ER1147A	219	-30660	0	0	-30660
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) - I	NP6509A	202.4	-28336	-0.2	-28	-28334
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) - II	NP6510A	267.4	-37436	0	0	-37436
	7	400 KV TATA JAMSHEDPUR (DVC) - BARIPADA(PG)	NP7408A	-4998.9	698046	0	0	698046
	8	400 KV TATA JAMSHEDPUR (DVC) - JAMSHEDPUR (PG)	NP7406A	3489	-488460	0	0	-488460
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	2126.3	-297682	0	0	-297682
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-827.6	129864	0	0	129864
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-1010.8	141484	0	0	141484
	12	400 KV KODERMA(DVC) - BHARSHARIFF(PG)-LINE-I	NP7831A	-3296.4	461496	0	0	461496
	13	400 KV KODERMA(DVC) - BHARSHARIFF(PG)-LINE-II	NP7830A	-2330.5	326270	0	0	326270
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	1837.3	-257222	0	0	-257222
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	1716.8	-240352	0	0	-240352
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-6075.3	850542	0	0	850542
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-III(MAIN)	NP6522A	-8211.2	869568	0	0	869568
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-4666.6	653324	0	0	653324
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	2065.8	-289212	0	0	-289212
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-4382.8	613592	0	0	613592
21	400 KV RANCHI(PG)-RTPS(DVC)-I	NP7871A	5804.7	-812658	0	0	-812658	
22	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7853A	5489.1	-768474	0	0	-768474	
		TOTAL		1717338		-28	1717310	

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	0	0	0	0	0
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	-191.3	26762	0	0	26782
	7	400 KV INDRAVATI (PG) - INDRAVATI PH	NP5968A	786.7	-110138	0	0	-110138
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	-218	30520	0	0	30520
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	-217.8	30492	0	0	30492
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-2737.6	383264	0	0	383264
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2326	325640	0	0	325640
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-2214.6	310044	0	0	310044
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-2158.2	302148	0	0	302148
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	-429	60060	0	0	60060
	15	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-2619.2	366688	0	0	366688
	17	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	18141.5	-2539810	0	0	-2539810
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	17403.5	-2436490	0	0	-2436490
	19	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	14450.6	-2023084	0	0	-2023084
	20	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-500.4	70056	0	0	70056
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-738.1	103334	0	0	103334
	22	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-5041.2	705768	0	0	705768
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabil ICT-1	ER1583A	-3913.8	547932	0	0	547932
	26	HV side of 400/220 Pandiabil ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	-3970.6	555884	0	0	555884
	28	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	-3979.3	557102	0	0	557102
		TOTAL		-2733808	0	0	-2733808	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-29.00	4060	0	0	4060
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-55.50	7770	0	0	7770
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-2	-280	-280
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	15.10	-2114	0	0	-2114
		TOTAL		9716	0	-280	9436	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	-1180.7	165298	-0.7	-98	165200
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	1591.3	-222782	0	0	-222782
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	1557.5	-218050	0	0	-218050
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-278.1	38934	0	0	38934
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-300	42000	0	0	42000
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	7.9	-1106	0	0	-1106
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-335.3	46942	0	0	46942
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-373.3	52262	0	0	52262
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2004.2	280588	0	0	280588
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-353	49420	0	0	49420
	11	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-I	NP5882A	6014.7	-842058	0	0	-842058
	12	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	NP5881A	6499.9	-909986	0	0	-909986
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-12.4	1736	0	0	1736
	14	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	9028.7	-1264018	0	0	-1264018
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	9881	-1353340	0	0	-1353340
	16	400 KV SAGARDIGH(WBSETCL) - FARAKKA (NTPC)	NP6482A	-1115.3	156142	0	0	156142
	17	400 KV SAGARDIGH(WBSETCL) - SUBHASGRAM (PG)	NP6483A	-3516	492240	0	0	492240
	18	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-85.6	13384	0	0	13384
	19	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	58.6	-8204	0	0	-8204
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	3465.2	-485128	0	0	-485128
	21	400 KV DURGAPUR(PG)- SAGARDIGH(WBSETCL)-I	NP6548A	2056.8	-287952	0	0	-287952
	22	400 KV DURGAPUR(PG)- SAGARDIGH(WBSETCL)-II	NP7557A	3896.3	-545482	0	0	-545482
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-165.4	23156	0	0	23156
	24	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-55.7	7798	0	0	7798
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	-2233.9	312746	0	0	312746
	29	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	NP7937A	-2290.6	320684	0	0	320684
	30	400 KV SAGARDIGH(WB)-BERHAMPORE(PG) LINE-I	NP8723A	2976.3	-416682	0	0	-416682
	31	400 KV SAGARDIGH(WB)-BERHAMPORE(PG) LINE-II	NP8724A	2754.5	-385630	0	0	-385630
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-565.5	79170	0	0	79170
	33	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-549.5	76930	0	0	76930
	34	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-I	ER1040A	2300.3	-322042	0	0	-322042
	35	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	ER1130A	2279.6	-319144	0	0	-319144
	36	400 KV GOKARNA(WB)-FARAKKA(NTPC)-I	ER1133A	-1332.7	186578	0	0	186578
	37	400 KV GOKARNA(WB)-FARAKKA(NTPC)-II	ER1138A	-1143.9	160146	0	0	160146
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	181.9	-25466	0	0	-25466
	39	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	149	-20860	0	0	-20860
	40	400 KV SAGARDIGH(WB)-FARAKKA(NTPC)-II	ER1131A	-1103.6	154504	0	0	154504
		TOTAL		-4997272	0	-98	-4997370	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14 paise/KVARH,w.e.f. 01/04/2018

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISGS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.