



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH /7703-13

Date: 11.01.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week from 24.12.2018-30.12.2018

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 04.01.2019.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

A 
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VARH) Charge Statement
for the period 24/12/18 to 30/12/18**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	680666
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	4472370

Note:

- Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.


11/01/19

MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 24/12/18 to 30/12/18

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-580	81200	-0.1	-14	81186
	2	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-1438.9	201446	0	0	201446
	3	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-771.6	108024	0	0	108024
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	130.5	-18270	0	0	-18270
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	146.3	-20482	0	0	-20482
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	167.3	-23422	0	0	-23422
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-1950.6	273084	0	0	273084
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-750.1	105014	0	0	105014
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-786.9	110166	0	0	110166
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-788.9	110446	0	0	110446
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-734.1	102774	0	0	102774
	12	132 KV PUSAULI(PG)-MOHANI(BSPHCL)	NP6094A	1	-140	-232.9	-32806	-32746
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	1111.8	-155652	0	0	-155652
	16	132 KV KHALGAON(NTPC)-KHALGAON (BSPHCL)	NP5261A	-1720.7	240898	0	0	240898
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-2559.3	358302	0	0	358302
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	-958.7	134218	0	0	134218
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	206.5	-28910	0	0	-28910
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	217.7	-30478	0	0	-30478
	21	132 KV KHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	124.2	-17388	0	0	-17388
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1108.4	-155176	0	0	-155176
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1127.3	-157822	0	0	-157822
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1234.7	-172858	0	0	-172858
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1167	-163380	0	0	-163380
	26	132 KV PUSAULI(PG)-KUDRAJ(BSPHCL)	NP6095A	76.1	-10654	157.3	22022	11368
	27	HV side of 400/220 Patna ICT-1	ER1408A	-327.9	45906	0	0	45906
	28	HV side of 400/220 Patna ICT-2	ER1407A	0	0	0	0	0
	29	HV side of 400/220 Patna ICT-3	ER1231A	-1105.8	154812	0	0	154812
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	-54.5	7630	0	0	7630
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	-59.3	8302	0	0	8302
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	1573	-220220	0	0	-220220
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	1455	-203700	0	0	-203700
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2949	-412860	0	0	-412860
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2956.0	-413966	0	0	-413966
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-913.3	127862	0	0	127862
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-969.6	135744	0	0	135744
	38	HV side of 400/220 Darbhanga DMTCL ICT-1	ER1274A	0	0	3.9	546	546
	39	HV side of 400/220 Darbhanga DMTCL ICT-2	ER1275A	0	0	2.5	350	350
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	-30.7	4298	0	0	4298
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-9.3	1302	0	0	1302
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	2229.6	-312144	0	0	-312144
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	3320.5	-464870	0	0	-464870
		TOTAL		-670964	0	-9702	-680666	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-2238.3	313362	0	0	313362
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-1892.6	264964	0	0	264964
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-958.5	134190	0	0	134190
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	878.2	-122948	0	0	-122948
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	588.4	-82376	0	0	-82376
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	3375	-472500	0	0	-472500
	7	132 KV KHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1433.6	200704	0	0	200704
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-59.8	8372	0	0	8372
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-41.4	5796	0	0	5796
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	43.4	-6076	0	0	-6076
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	39.8	-5572	0	0	-5572
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	0	0	0
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	0	0	0
		TOTAL		237916	0	0	237916	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2478.4	346976	0	0	346976
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-19.2	2688	0	0	2688
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-98.2	13748	0	0	13748
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	38.8	-5432	0	0	-5432
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	51.2	-7168	0	0	-7168
	7	400 KV TATA JAMSHEDPUR (DVC)-BARIPADA(PG)	NP7408A	-3673.9	514346	0	0	514346
	8	400 KV TATA JAMSHEDPUR (DVC)-JAMSHEDPUR (PG)	NP7406A	2423.6	-339304	0	0	-339304
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	833.8	-116732	0	0	-116732
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-212.7	29778	0	0	29778
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-288.4	40376	0	0	40376
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-3577.2	500808	0	0	500808
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-2610.4	365456	0	0	365456
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	796	-111440	0	0	-111440
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	790.9	-110726	0	0	-110726
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-5035.9	705026	0	0	705026
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-5237.2	733208	0	0	733208
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-3458.4	484176	0	0	484176
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	2274.4	-318416	0	0	-318416
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-3095.7	433398	0	0	433398
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	4361	-610540	0	0	-610540
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	4223.6	-591304	0	0	-591304
		TOTAL		1958922	0	0	1958922	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	0	0	0	0	0
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	0	0	0	0	0
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	-109.1	15274	0	0	15274
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	-115.4	16156	0	0	16156
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-2636.4	369096	0	0	369096
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2590.8	362712	0	0	362712
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-2278.4	318976	0	0	318976
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-2223.8	311332	0	0	311332
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	-223.6	31304	0	0	31304
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-2093.5	293090	0	0	293090
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	9596	-1343440	0	0	-1343440
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	11810.9	-1653526	0	0	-1653526
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	7424.4	-1039416	0	0	-1039416
	20	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-I	NP5980A	-549.7	76958	0	0	76958
	21	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-II	NP7498A	-666.2	93268	0	0	93268
	22	400 KV DUBURI (GRIDCO)-PANDIABILI (PG)	NP7915A	-3705.5	518770	0	0	518770
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	-2614.9	366086	0	0	366086
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	-343.2	48048	0	0	48048
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-4657.2	652008	0	0	652008
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-4916.7	688338	0	0	688338
		TOTAL		125034		0	125034	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-68.10	9534	0	0	9534
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-104.30	14602	0	0	14602
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-1.7	-238	-238
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	12.90	-1806	0	0	-1806
		TOTAL		22330		-238	22092	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	-377.8	52892	0	0	52892
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	1456	-203840	0	0	-203840
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	1404.9	-196686	0	0	-196686
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-541.2	75768	0	0	75768
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-567	79380	0	0	79380
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	-78.2	10948	0	0	10948
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-1180.1	165214	0	0	165214
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-985.2	137928	0	0	137928
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2255.4	315756	0	0	315756
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-969.6	135744	0	0	135744
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	7091.2	-992768	0	0	-992768
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	7665.6	-1073184	0	0	-1073184
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-55.5	7770	0	0	7770
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	7609	-1065260	0	0	-1065260
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	9617.8	-1346492	0	0	-1346492
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-1027.3	143822	0	0	143822
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	-3497	489580	0	0	489580
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	-118.3	16562	0	0	16562
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	61.4	-8596	0	0	-8596
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	3308.7	-463218	0	0	-463218
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	1006.6	-140924	0	0	-140924
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	2484	-347760	0	0	-347760
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-440.3	61642	0	0	61642
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-140.7	19698	0	0	19698
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	-1635.6	228984	0	0	228984
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	-1678.2	234948	0	0	234948
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	2542.1	-355894	0	0	-355894
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	2249.7	-314958	0	0	-314958
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	-76.2	10668	0	0	10668
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	-66.7	9338	0	0	9338
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1040A	1845.4	-258356	0	0	-258356
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1130A	1850.8	-259112	0	0	-259112
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	-1264.1	176974	0	0	176974
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-1106.9	154966	0	0	154966
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	431.3	-60382	0	0	-60382
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	358	-50120	0	0	-50120
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-975.7	136598	0	0	136598
		TOTAL		-4472370		0	-4472370	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14 paise/KVArh.w.e.f. 01/04/2018

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.