



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/10489-499

Date: 20.03.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comm & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comm), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comm), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week from 04.03.2019-10.03.2019

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 15.03.2019.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

J. Bandyopadhyay 20/3/19

(J. Bandyopadhyay)
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VARH) Charge Statement
for the period 04/03/19 to 10/03/19**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	4127396

Note:

- Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.


MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 04/03/19 to 10/03/19

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-833.4	116676	0	0	116676
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-3091	432740	0	0	432740
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1604.9	224686	0	0	224686
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	190.8	-26712	0	0	-26712
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	275.9	-38626	0	0	-38626
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	255.9	-35826	0	0	-35826
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-1242	173880	0	0	173880
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-1063.3	148862	0	0	148862
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-1101.4	154196	0	0	154196
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-1227.7	171878	0	0	171878
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-1213.4	169876	0	0	169876
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	-39.6	5544	-152.9	-21406	-15862
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	-50.5	7070	0	0	7070
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	1563.8	-218932	0	0	-218932
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1673.6	234304	0	0	234304
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-1838.1	257334	0	0	257334
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	-408.5	57190	0	0	57190
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	-104	14560	0	0	14560
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	-117.3	16422	0	0	16422
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	283.8	-39732	0	0	-39732
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1922.7	-269178	0	0	-269178
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1877.8	-262892	0	0	-262892
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	2025.7	-283598	0	0	-283598
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	2049.3	-286902	0	0	-286902
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	176.9	-24766	47.8	6692	-18074
	27	HV side of 400/220 Palma ICT-1	ER1408A	-1347.6	188664	0	0	188664
	28	HV side of 400/220 Palma ICT-2	ER1407A	-2440.3	341642	0	0	341642
	29	HV side of 400/220 Palma ICT-3	ER1231A	-2154.1	301574	0	0	301574
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	-661.1	92554	0	0	92554
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	-663.8	92932	0	0	92932
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	703.7	-98518	0	0	-98518
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	573.9	-80346	0	0	-80346
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2825.5	-395570	0	0	-395570
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2837.6	-397264	0	0	-397264
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1442	201880	0	0	201880
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-1457.6	204064	0	0	204064
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	301	-42140	0	0	-42140
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	305.8	-42812	0	0	-42812
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	-5.2	728	0	0	728
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	18.7	-2618	0	0	-2618
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	0	0	0	0	0
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	0	0	0	0	0
			TOTAL		1062824		-14714	1048110
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-1423.6	199304	0	0	199304
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-743.2	104048	0	0	104048
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-960.5	134470	0	0	134470
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	586.1	-82054	0	0	-82054
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	810.5	-113470	0	0	-113470
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	2292.8	-320992	0	0	-320992
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1403.5	196490	0	0	196490
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-29.6	4144	0	0	4144
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-25.2	3528	0	0	3528
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	211.1	-29554	0	0	-29554
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	152.8	-21392	0	0	-21392
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	0	0	0
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	0	0	0
			TOTAL		74522		0	74522
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-3210.6	449484	0	0	449484
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-16.8	2352	0	0	2352
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-30.2	4228	0	0	4228
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	21.2	-2968	0	0	-2968
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	22.4	-3136	0	0	-3136
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	-1105.7	154798	0	0	154798
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	1730.4	-242256	0	0	-242256
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	137.4	-19236	0	0	-19236
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	32.5	-4550	0	0	-4550
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-160.7	22498	0	0	22498
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-4811.2	673568	0	0	673568
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-4228	591920	0	0	591920
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	3190.8	-446712	0	0	-446712
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	3000.3	-420042	0	0	-420042
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-3884.7	543858	0	0	543858
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-4020	562800	0	0	562800
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-4953.1	693434	0	0	693434
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	2921.1	-408954	0	0	-408954
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-3084.7	431858	0	0	431858
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	6478.2	-906948	0	0	-906948
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	6389.3	-894502	0	0	-894502
			TOTAL		781494		0	781494

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	0.1	-14	0	0	-14
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	5.2	-728	0	0	-728
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	16.7	-2338	0	0	-2338
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	25.9	-3626	0	0	-3626
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	21.2	-2968	0	0	-2968
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-459.6	92344	0	0	92344
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2731.6	382424	0	0	382424
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-3073.6	430304	0	0	430304
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-2466.4	345296	0	0	345296
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0.3	-42	0	0	-42
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-163.2	22848	0	0	22848
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	0	0	0	0	0
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	0	0	0	0	0
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	0	0	0	0	0
	20	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-I	NP5980A	0	0	0	0	0
	21	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-II	NP7498A	0	0	0	0	0
	22	400 KV DUBURI (GRIDCO)-PANDIABILI (PG)	NP7915A	-251.1	35154	0	0	35154
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabili ICT-1	ER1563A	0	0	0	0	0
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	114.8	-16072	0	0	-16072
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	229	-32060	0	0	-32060
TOTAL				1250522		0	1250522	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-90.40	12656	0	0	12656
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-144.90	20286	0	0	20286
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-1.6	-224	-224
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	15.10	-2114	0	0	-2114
TOTAL				30828		-224	30604	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	-278.9	-39046	-39046
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	533.3	-74662	0	0	-74662
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	511.5	-71610	0	0	-71610
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-2171.8	304052	0	0	304052
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-2221.6	311024	0	0	311024
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	-810.5	113470	0	0	113470
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-1878.5	262990	0	0	262990
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-1343.2	188048	0	0	188048
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-3092.1	432894	0	0	432894
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-1553.4	217476	0	0	217476
	11	220 KV BNAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	6241	-873740	0	0	-873740
	12	220 KV BNAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	7403.6	-1036504	0	0	-1036504
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-101.9	14266	0	0	14266
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	8019.3	-1122702	0	0	-1122702
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	12290.2	-1720628	0	0	-1720628
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-1359	190260	0	0	190260
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	-1408.3	197162	0	0	197162
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	-155.4	21756	0	0	21756
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	70.7	-9898	0	0	-9898
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	3676	-514640	0	0	-514640
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	1146.6	-160524	0	0	-160524
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	1921.8	-269052	0	0	-269052
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-3072.1	430094	0	0	430094
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-1293.9	181146	0	0	181146
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	345.1	-48314	0	0	-48314
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	347.2	-48608	0	0	-48608
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	1625.2	-227528	0	0	-227528
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	1427.2	-199808	0	0	-199808
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	-481.7	67438	0	0	67438
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	-455.7	63798	0	0	63798
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1040A	3141.4	-439796	0	0	-439796
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1130A	3133.9	-438746	0	0	-438746
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	-1120	156800	0	0	156800
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-970.7	135898	0	0	135898
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	955.8	-133812	0	0	-133812
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	926.9	-129766	0	0	-129766
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-1024.4	143416	0	0	143416
TOTAL				-4088350		-39046	-4127396	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14 paise/KVARh, w.e.f. 01/04/2018

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IECG, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.