



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति



**Eastern Regional Power Committee**  
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008  
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: [www.erpc.gov.in](http://www.erpc.gov.in)

NO: ERPC/COM-II/VARH/10,408-10,418

Date: 18.03.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

**Sub: Provisional Reactive Energy (VARH) Charges for the week from 18.02.2019-24.02.2019**

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 18.03.2019.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

(J. Bandyopadhyay)  
MEMBER SECRETARY

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VARH) Charge Statement  
for the period 18/02/19 to 24/02/19**

**REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL**

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	96404
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	3434298

Note:

- Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

  
MEMBER SECRETARY

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

for the period 18/02/19 to 24/02/19

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE (Rs)
<b>BSPHCL</b>	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-891.9	124866	-0.1	-14	124852
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-2656.4	371896	0	0	371896
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1448.6	202804	0	0	202804
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	140.2	-19628	0	0	-19628
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	198.8	-27832	0	0	-27832
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	188.7	-26418	0	0	-26418
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-1843.8	258132	0	0	258132
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-1022	143080	0	0	143080
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-1028.1	143934	0	0	143934
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-830.5	116270	0	0	116270
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-791.7	110838	0	0	110838
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	-45.5	6370	-152.4	-21336	-14966
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	7.9	-1106	0	0	-1106
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0.2	-28	0	0	-28
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	1476.2	-206668	0	0	-206668
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1759.9	246386	0	0	246386
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-3660.1	512414	0	0	512414
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	242.6	-33964	0	0	-33964
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	-33.2	4648	0	0	4648
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	-38.4	5376	0	0	5376
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	287.3	-40222	0	0	-40222
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1427.6	-199864	0	0	-199864
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1456.6	-203924	0	0	-203924
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1595.2	-223328	0	0	-223328
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1510.4	-211456	0	0	-211456
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	231.2	-32368	104.4	14616	-17752
	27	HV side of 400/220 Patna ICT-1	ER1408A	-2861.5	400610	0	0	400610
	28	HV side of 400/220 Patna ICT-2	ER1407A	-4370.9	611926	0	0	611926
	29	HV side of 400/220 Patna ICT-3	ER1231A	-3501.5	490210	0	0	490210
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	-742.6	103964	0	0	103964
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	-779.4	109116	0	0	109116
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	1021.3	-142982	0	0	-142982
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	900	-126000	0	0	-126000
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	3562.7	-498778	0	0	-498778
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	3567.3	-499422	0	0	-499422
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-742.9	104006	0	0	104006
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-756.3	105882	0	0	105882
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	2520	-352800	0	0	-352800
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	5111.7	-715638	0	0	-715638
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	69.3	-9702	0	0	-9702
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	90.6	-12684	0	0	-12684
	42	220 KV PURNEA(PG)-BEGUSARAI(BSPTCL)-I	ER1348A	0	0	0	0	0
	43	220 KV PURNEA(PG)-BEGUSARAI(BSPTCL)-II	ER1376A	0	0	0	0	0
		<b>TOTAL</b>			<b>587916</b>		<b>-6734</b>	<b>581182</b>
<b>JUVNL</b>	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-738.5	103390	0	0	103390
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-347.8	48692	0	0	48692
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-478.3	66962	0	0	66962
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	382.3	-53522	0	0	-53522
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	537.6	-75264	0	0	-75264
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	167.8	-23492	0	0	-23492
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	1146.5	-160510	0	0	-160510
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-54	7560	0	0	7560
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-41	5740	0	0	5740
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	68	-9520	0	0	-9520
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	46	-6440	0	0	-6440
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	0	0	0
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	0	0	0
		<b>TOTAL</b>			<b>-96404</b>		<b>0</b>	<b>-96404</b>
<b>DVC</b>	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2191.4	306796	0	0	306796
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	5.2	-728	0	0	-728
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	7.8	-1092	0	0	-1092
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	-20	2800	0	0	2800
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	-25.2	3528	0	0	3528
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	-933.9	130746	0	0	130746
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	1042.6	-145964	0	0	-145964
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	1017.8	-142492	0	0	-142492
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-441	61740	0	0	61740
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-576.4	80696	0	0	80696
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-5428.6	760004	0	0	760004
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-4670.1	653814	0	0	653814
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	1737.7	-243278	0	0	-243278
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	1684.8	-235872	0	0	-235872
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-2524.7	353458	0	0	353458
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-III(MAIN)	NP6522A	-2641.8	369852	0	0	369852
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-3301.3	462182	0	0	462182
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	1304.4	-182616	0	0	-182616
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-1888.3	264362	0	0	264362
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	3722.5	-521150	0	0	-521150
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	3692	-516880	0	0	-516880
		<b>TOTAL</b>			<b>1459906</b>		<b>0</b>	<b>1459906</b>

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

<b>GRIDCO</b>	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	0	0	0	0	0
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	0	0	0	0	0
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H)	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	24.1	-3374	0	0	-3374
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	18.3	-2562	0	0	-2562
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-2550.2	357028	0	0	357028
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3728	521920	0	0	521920
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-I	NP5112A	-3410.4	477456	0	0	477456
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-II	NP5101A	-3347.8	468692	0	0	468692
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0.3	-42	0	0	-42
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-447.8	62692	0	0	62692
	17	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	1724.6	-241444	0	0	-241444
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	2656.5	-371910	0	0	-371910
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)	NP7932A	30.9	-4326	0	0	-4326
	20	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-44.9	6286	0	0	6286
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-20.2	2828	0	0	2828
	22	400 KV DUBURI (GRIDCO)-PANDIABIL(PG)	NP7915A	-888.1	124334	0	0	124334
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	-21.8	3052	0	0	3052
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	-20.3	2842	0	0	2842
	27	400KV SUNDERGARH(PG)-STERLITE (GRIDCO)-I	ER1059A	1188.7	-166418	0	0	-166418
	28	400KV SUNDERGARH(PG)-STERLITE (GRIDCO)-II	ER1058A	1342.8	-187992	0	0	-187992
		<b>TOTAL</b>		<b>1049062</b>		<b>0</b>	<b>1049062</b>	
<b>SIKKIM</b>	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-63.90	8946	0	0	8946
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-116.60	16324	0	0	16324
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-1.8	-252	-252
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	12.60	-1764	0	0	-1764
		<b>TOTAL</b>		<b>23506</b>		<b>-252</b>	<b>23254</b>	
<b>WBSETCL</b>	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	-1087.6	-152264	-152264
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	304	-42560	0	0	-42560
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	290.3	-40642	0	0	-40642
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1377	192780	0	0	192780
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1434.7	200858	0	0	200858
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	-761	106540	0	0	106540
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-1408.2	197148	0	0	197148
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-1047.7	146678	0	0	146678
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2972.2	416108	0	0	416108
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-1415.5	198170	0	0	198170
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	7381.8	-1033452	0	0	-1033452
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	8594.4	-1203216	0	0	-1203216
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-24.4	3416	0	0	3416
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	4832.3	-676522	0	0	-676522
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	9809.1	-1373274	0	0	-1373274
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-737.3	103222	0	0	103222
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	-785.2	109928	0	0	109928
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	-139.1	19474	0	0	19474
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	77.7	-10878	0	0	-10878
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	1661.3	-232582	0	0	-232582
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	182.3	-25522	0	0	-25522
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	477.1	-66794	0	0	-66794
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-1511.1	211554	0	0	211554
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-747.3	104622	0	0	104622
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	357.3	-50022	0	0	-50022
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	354.7	-49658	0	0	-49658
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	264.5	-37030	0	0	-37030
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	167.8	-23492	0	0	-23492
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	-576.3	80682	0	0	80682
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	-554.5	77630	0	0	77630
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1040A	1889.2	-264488	0	0	-264488
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1130A	1860.7	-260498	0	0	-260498
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	-254.1	35574	0	0	35574
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-242.1	33894	0	0	33894
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	623.2	-87248	0	0	-87248
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	530.7	-74298	0	0	-74298
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-227.6	31864	0	0	31864
		<b>TOTAL</b>		<b>-3282034</b>		<b>-152264</b>	<b>-3434298</b>	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14 paise/KVArH, w.e.f. 01/04/2018

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.