



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति



**Eastern Regional Power Committee**  
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008  
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: [www.erpc.gov.in](http://www.erpc.gov.in)

NO: ERPC/COM-II/VARH/10419-10429

Date: 18.03.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comm & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comm), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comm), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

**Sub: Provisional Reactive Energy (VARH) Charges for the week from 25.02.2019-03.03.2019**


The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 18.03.2019.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

  
(J. Bandyopadhyay)  
MEMBER SECRETARY

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 25/02/19 to 03/03/19**

**REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL**

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	5859924

Note:

- Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

 18/3/19  
MEMBER SECRETARY

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

for the period 25/02/19 to 03/03/19

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE (Rs)
<b>BSPHCL</b>	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-1040.6	145684	0	0	145684
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-2969.7	415758	0	0	415758
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1811.3	253582	0	0	253582
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	262.1	-36694	0	0	-36694
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	345.3	-48342	0	0	-48342
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	324.3	-45402	0	0	-45402
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-1222.6	171164	0	0	171164
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-1020	142800	0	0	142800
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-1050.8	147112	0	0	147112
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-1516.3	212282	0	0	212282
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-1488.9	208446	0	0	208446
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	-50.7	7098	-87.6	-12264	-5166
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	7.3	-1022	0	0	-1022
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	10	-1400	0	0	-1400
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	1500.8	-210112	0	0	-210112
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1646.4	230496	0	0	230496
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-2572.1	360094	0	0	360094
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	331.7	-46438	0	0	-46438
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	-203.5	28490	0	0	28490
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	-227.1	31794	0	0	31794
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	302.5	-42350	0	0	-42350
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1685.3	-235942	0	0	-235942
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1659.9	-232386	0	0	-232386
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1794	-251160	0	0	-251160
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1798.1	-251734	0	0	-251734
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	238	-33320	37	5180	-28140
	27	HV side of 400/220 Patna ICT-1	ER1408A	-2132.9	298606	0	0	298606
	28	HV side of 400/220 Patna ICT-2	ER1407A	-3366.5	471310	0	0	471310
	29	HV side of 400/220 Patna ICT-3	ER1231A	-2908.5	407190	0	0	407190
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	-1338.2	187348	0	0	187348
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	-1349.9	188986	0	0	188986
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	975.2	-136528	0	0	-136528
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	840.1	-117614	0	0	-117614
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	3408.5	-477190	0	0	-477190
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	3547.3	-496622	0	0	-496622
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-611	85540	0	0	85540
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-635.5	88970	0	0	88970
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	565.2	-79128	0	0	-79128
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	606.6	-84924	0	0	-84924
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	31.9	-4466	0	0	-4466
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	55.7	-7798	0	0	-7798
	42	220 KV PURNEA(PG)-BEGUSARAI(BSPTCL)-I	ER1348A	0	0	0	0	0
	43	220 KV PURNEA(PG)-BEGUSARAI(BSPTCL)-II	ER1376A	0	0	0	0	0
		<b>TOTAL</b>			<b>1242178</b>		<b>-7084</b>	<b>1235094</b>
<b>JUVNL</b>	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-2997.5	419650	0	0	419650
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-2290	320600	0	0	320600
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-2151.1	301154	0	0	301154
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	1074	-150360	0	0	-150360
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	1352	-189280	0	0	-189280
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	701.8	-98252	0	0	-98252
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	90	-12600	0	0	-12600
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	38.6	-5404	0	0	-5404
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	50.2	-7028	0	0	-7028
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	1515.4	-212156	0	0	-212156
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	1391.1	-194754	0	0	-194754
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	0	0	0
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	0	0	0
		<b>TOTAL</b>			<b>171570</b>		<b>0</b>	<b>171570</b>
<b>DVC</b>	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2906.2	406868	0	0	406868
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-32.4	4536	0	0	4536
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-35.8	5012	0	0	5012
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	343	-48020	0	0	-48020
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	409.8	-57372	0	0	-57372
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	-2548.3	356762	0	0	356762
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	3765.5	-527170	0	0	-527170
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	992.7	-138978	0	0	-138978
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-1524	213360	0	0	213360
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-1716	240240	0	0	240240
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-6743.7	944118	0	0	944118
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-5920.3	828842	0	0	828842
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	1399.1	-195874	0	0	-195874
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	1635.4	-228956	0	0	-228956
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-5574.7	780458	0	0	780458
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-III(MAIN)	NP6522A	-5686.9	796166	0	0	796166
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-5756	805840	0	0	805840
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	-1683.3	235662	0	0	235662
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-4017.8	562492	0	0	562492
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	6010.5	-841470	0	0	-841470
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	5525.5	-773570	0	0	-773570
		<b>TOTAL</b>			<b>3368946</b>		<b>0</b>	<b>3368946</b>

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

<b>GRIDCO</b>	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	14.5	-2030	0	0	-2030
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	12.6	-1764	0	0	-1764
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	0	0	0	0	0
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	0	0	0	0	0
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H)	NP5966A	0	0	-0.05	-7	-7
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	-21.1	2954	0	0	2954
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	-33.1	4634	0	0	4634
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-2289	320460	0	0	320460
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2519.6	352744	0	0	352744
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-I	NP5112A	-2435	340900	0	0	340900
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-II	NP5101A	-2401.4	336196	0	0	336196
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	-148.4	20776	0	0	20776
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-1335.7	186998	0	0	186998
	17	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	3903	-546420	0	0	-546420
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	4589.6	-642544	0	0	-642544
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)	NP7932A	0	0	0	0	0
	20	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-175.7	24598	-4.3	-602	23996
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-161.6	22624	-9.4	-1316	21308
	22	400 KV DUBURI (GRIDCO)-PANDIABIL(PG)	NP7915A	-1982.6	277564	0	0	277564
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0.2	28	28
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	-263.1	36834	0.7	98	36932
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	-262.4	36736	0	0	36736
	27	400KV SUNDERGARH(PG)-STERLITE (GRIDCO)-I	ER1059A	231.2	-32368	0	0	-32368
	28	400KV SUNDERGARH(PG)-STERLITE (GRIDCO)-II	ER1058A	456	-63840	0	0	-63840
		<b>TOTAL</b>		<b>675052</b>		<b>-1799</b>	<b>673253</b>	
<b>SIKKIM</b>	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-78.00	10920	0	0	10920
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-135.50	18970	0	0	18970
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-1	-140	-140
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	15.50	-2170	0	0	-2170
		<b>TOTAL</b>		<b>27720</b>		<b>-140</b>	<b>27580</b>	
<b>WBSETCL</b>	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	-154.4	21616	0	0	21616
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	1094.1	-153174	0	0	-153174
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	1051.6	-147224	0	0	-147224
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1835.8	257012	0	0	257012
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1866.2	261268	0	0	261268
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	-616.9	86366	0	0	86366
	7	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-1833.9	256746	0	0	256746
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-1305	182700	0	0	182700
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-3365.2	471128	0	0	471128
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-1700.8	238112	0	0	238112
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	6912.7	-967778	0	0	-967778
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	8490.9	-1188726	0	0	-1188726
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-115.7	16198	0	0	16198
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	12137	-1699180	0	0	-1699180
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	13097.1	-1833594	0	0	-1833594
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-3086	432040	0	0	432040
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	-2720.3	380842	0	0	380842
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	-167.5	23450	0	0	23450
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	94.5	-13230	0	0	-13230
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	7124.6	-997444	0	0	-997444
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	2455	-343700	0	0	-343700
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	3143.9	-440146	0	0	-440146
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-2065.9	289226	0	0	289226
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-1006	140840	0	0	140840
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	-602.6	84364	0	0	84364
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	-636.5	89110	0	0	89110
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	2499.3	-349902	0	0	-349902
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	2061.4	-288596	0	0	-288596
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	-477.5	66850	0	0	66850
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	-450.7	63098	0	0	63098
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1040A	4896.7	-685538	0	0	-685538
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1130A	4837.7	-677278	0	0	-677278
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	-1841.1	257754	0	0	257754
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-1653.4	231476	0	0	231476
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	880.1	-123214	0	0	-123214
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	856.6	-119924	0	0	-119924
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-2275.2	318528	0	0	318528
		<b>TOTAL</b>		<b>-5859924</b>		<b>0</b>	<b>-5859924</b>	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14 paise/KVArh, w.e.f. 01/04/2018

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.