



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH /2219 - 2229

Date: 30.05.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week from 06.05.2019-12.05.2019

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 27.05.2019.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

J. Bandyopadhyay 30/5/19

(J. Bandyopadhyay)
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA


**Provisional Reactive Energy (VArH) Charge Statement
for the period 06/05/19 to 12/05/19**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSSETCL	POOL	1621593

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

 30/5/19
MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 06/05/19 to 12/05/19

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-762.6	110577	0	0	110577
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-2594.2	376159	0	0	376159
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1208.6	175247	0	0	175247
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-0.6	87	-206.9	-30000.5	-29914
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-17.9	2596	-54.7	-7931.5	-5336
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	-0.6	87	-142.9	-20720.5	-20634
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-3253.1	471700	0	0	471700
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-485.7	70427	-4.1	-594.5	69832
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-520.9	75531	-2.8	-406	75125
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-689.4	99963	0	0	99963
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-400.6	58087	0	0	58087
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	-18.9	2741	-415.3	-60218.5	-57478
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	-3.2	464	324.4	47038	47502
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	-1	145	213	30885	31030
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	793.4	-115043	2.1	304.5	-114739
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1785.6	258912	0	0	258912
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-1751.1	253910	0	0	253910
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	1116.7	-161922	0	0	-161922
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	-20	2900	0	0	2900
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	-17.2	2494	0	0	2494
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	125.6	-18212	0	0	-18212
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	719.2	-104284	0	0	-104284
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	699.6	-101442	0	0	-101442
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	766.2	-111099	0	0	-111099
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	750.7	-108852	0	0	-108852
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	45.5	-6598	411.5	59667.5	53070
	27	HV side of 400/220 Palma ICT-1	ER1408A	-5899.6	855442	0	0	855442
	28	HV side of 400/220 Palma ICT-2	ER1407A	-6864	995280	0	0	995280
	29	HV side of 400/220 Palma ICT-3	ER1231A	-6364.3	922824	0	0	922824
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	65.1	-9440	0	0	-9440
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	69.4	-10063	0	0	-10063
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-752	109040	0	0	109040
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-733	106285	0	0	106285
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1480.8	-214716	0	0	-214716
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1464.4	-212338	0	0	-212338
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-2842.8	412206	0	0	412206
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-3174.7	460332	0	0	460332
	38	HV side of 400/220 Darbhanga DMTCL ICT-1	ER1274A	153	-22185	0	0	-22185
	39	HV side of 400/220 Darbhanga DMTCL ICT-2	ER1275A	105.2	-15254	0	0	-15254
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	-444.2	64409	0	0	64409
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-443.4	64293	0	0	64293
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	0	0	0	0	0
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	0	0	0	0	0
TOTAL					4740688		18024	4758712
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-285	41325	0	0	41325
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-104.3	15124	0	0	15124
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-216.3	31364	0	0	31364
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	0.8	-116	0	0	-116
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	1.9	-276	0	0	-276
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	208	-30160	0	0	-30160
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-570.2	82679	0	0	82679
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-112.8	16356	0	0	16356
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-188.8	27376	0	0	27376
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	0	0	0	0	0
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	0	0	0	0	0
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	-0.2	-29	-29
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	-0.4	-58	-58
TOTAL					183672		-87	183585
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	228.4	-33118	0	0	-33118
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-1208.6	175247	0	0	175247
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-3	435	0	0	435
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-20.4	2958	0	0	2958
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	-29.8	4321	0	0	4321
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	-68.4	9918	0	0	9918
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	-1.1	160	0	0	159.5
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	846.6	-122757	0	0	-122757
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	4004.2	-580609	0	0	-580609
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-4695.1	680790	0	0	680789.5
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-4681.3	678789	0	0	678788.5
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-3830.8	555466	0	0	555466
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-2345.2	340054	0	0	340054
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-1356.9	196751	0	0	196750.5
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-1591.1	230710	0	0	230709.5
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-1045.5	151598	0	0	151597.5
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-1229.4	178263	0	0	178263
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-4.3	624	0	0	623.5
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	-484.3	70224	0	0	70223.5
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-659.4	95613	0	0	95613
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	396.9	-57551	0	0	-57550.5
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	456.5	-66193	0	0	-66192.5
TOTAL					2511690		0	2511690

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	0	0	0	0	0
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	0	0	0	0	0
	7	400 KV INDRAVATI (PG) - INDRAVATI PH	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	2.9	-420.5	0	0	-420.5
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	0.8	-116	0	0	-116
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1827.6	265002	0	0	265002
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4072.6	590527	0	0	590527
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-4149.8	601721	0	0	601721
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-3046.4	441728	0	0	441728
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0	0	0	0	0
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-148.3	21503.5	0	0	21503.5
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	0	0	0	0	0
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	284.9	-41310.5	0	0	-41310.5
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	0	0	0	0	0
	20	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-I	NP5980A	-64.6	9367	7.9	1145.5	10512.5
	21	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-II	NP7498A	-33.8	4901	8.3	1203.5	6104.5
	22	400 KV DUBURI (GRIDCO)-PANDIABILI (PG)	NP7915A	0	0	0	0	0
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	6.9	1000.5	1000.5
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	6.7	971.5	971.5
	25	HV side of 400/220 Pandiabili ICT-1	ER1563A	19.6	-2842	0	0	-2842
	26	HV side of 400/220 Pandiabili ICT-2	ER1596A	513.5	-74457.5	0	0	-74457.5
	27	400KV SUNDERGARH (PG)-STERILITE (GRIDCO)-I	ER1059A	-4008.4	581218	0	0	581218
	28	400KV SUNDERGARH (PG)-STERILITE (GRIDCO)-II	ER1058A	-4086.8	592586	0	0	592586
TOTAL				2989407		4321	2993728	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-81.70	11847	0	0	11847
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-64.00	9280	0	0	9280
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-0.5	-72.5	-73
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	6.50	-943	0	0	-943
TOTAL				20184		-73	20112	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	20	2900	2900
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	-5.3	769	-1792.8	-259956	-259188
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	0	0	-1936.3	-280764	-280764
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1176.7	170622	0	0	170622
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1261.3	182889	0	0	182889
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	912.6	-132327	0	0	-132327
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-56.2	8149	0	0	8149
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-133.1	19300	0	0	19300
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-1713.4	248443	0	0	248443
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-135.4	19633	0	0	19633
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	478.6	-69397	0	0	-69397
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	1223.5	-177408	0	0	-177408
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	1.1	-160	0	0	-160
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	2055	-297975	0	0	-297975
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	11527.4	-1671473	0	0	-1671473
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-23.9	3466	0	0	3466
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	21.1	-3060	0	0	-3060
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	-56	8120	0	0	8120
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	-36.4	5278	0	0	5278
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	1925.5	-279198	0	0	-279198
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	0	0	0	0	0
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	22.5	-3263	0	0	-3263
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-839.3	121699	0	0	121699
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-159.8	23171	0	0	23171
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	15	-2175	3663.7	531237	529062
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	23.1	-3350	3609.1	523320	519970
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	0	0	0	0	0
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	0	0	0	0	0
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	169.2	-24534	0	0	-24534
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	175.1	-25390	0	0	-25390
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1040A	939	-136155	0	0	-136155
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1130A	885.4	-128383	0	0	-128383
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	-30.4	4408	0	0	4408
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-5.3	769	0	0	769
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	2.7	-392	0	0	-392
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	2.8	-406	0	0	-406
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	0	0	0	0	0
TOTAL				-2138330		516737	-1621593	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVArH, w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an IGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.