



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH 1597-1607

Date: 08.05.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week from 08.04.2019-14.04.2019


The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 18.04.2019.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,


(J. Bandyopadhyay)
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA


**Provisional Reactive Energy (VArH) Charge Statement
for the period 08/04/19 to 14/04/19**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	59059
DVC	POOL	44674.5
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	4005118

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.


MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 08/04/19 to 14/04/19

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-17.8	2581	0	0	2581
	2	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-189.9	27536	0	0	27536
	3	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-71.5	10368	0	0	10368
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	0.6	-87	-36	-5220	-5307
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	30.6	-4437	-23.6	-3422	-7859
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	2.3	-334	-28.7	-4161.5	-4495
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-1651.7	239497	0	0	239497
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-604.3	87624	0	0	87624
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-638.7	92612	0	0	92612
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG-I)	NP8641A	-298.7	43312	0	0	43312
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG-II)	NP6060A	-241.8	35061	0	0	35061
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	-42.8	6206	-61.1	-8899.5	-2654
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	941.2	-136474	0	0	-136474
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1168.6	169447	0	0	169447
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-2029.5	294278	0	0	294278
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	291.4	-42253	0	0	-42253
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	0.2	-29	0	0	-29
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7899A	0	0	0	0	0
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	74.7	-10632	0	0	-10632
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1305.8	-189341	0	0	-189341
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1278.1	-185325	0	0	-185325
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1387.8	-201231	0	0	-201231
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1382.7	-200492	0	0	-200492
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	102.5	-14863	57.5	8337.5	-6525
	27	HV side of 400/220 Patna ICT-1	ER1408A	-3883.3	563079	0	0	563079
	28	HV side of 400/220 Patna ICT-2	ER1407A	-4669.8	677121	0	0	677121
	29	HV side of 400/220 Patna ICT-3	ER1231A	-4356.5	631693	0	0	631693
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	0	0	0	0	0
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	0	0	0	0	0
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-551.8	80011	0	0	80011
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-540.2	78329	0	0	78329
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2611.8	-378711	0	0	-378711
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2556.7	-376377	0	0	-376377
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1157.1	167780	0	0	167780
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-1217.6	176552	0	0	176552
	38	HV side of 400/220 Darbhanga DMTCL ICT-1	ER1274A	13.4	-1943	31.1	4509.5	2567
	39	HV side of 400/220 Darbhanga DMTCL ICT-2	ER1275A	24.3	-3524	27.1	3929.5	406
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	-335.9	48706	0	0	48706
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-321.3	46589	0	0	46589
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	0	0	0	0	0
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	0	0	0	0	0
		TOTAL			1732127		-4887	1727240
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-1.8	261	0	0	261
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	0	0	0	0	0
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-0.4	58	0	0	58
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	241.4	-35003	0	0	-35003
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	290.5	-42123	0	0	-42123
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	67.6	-9802	0	0	-9802
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-253.8	36901	0	0	36901
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	32	-4640	0	0	-4640
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	30.6	-4437	0	0	-4437
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	0	0	0	0	0
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	0	0	0	0	0
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	-0.4	-58	-58
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	-0.8	-116	-116
		TOTAL			-58885	-174	-59059	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-910.2	131979	0	0	131979
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	4	-580	0	0	-580
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	4.6	-667	0	0	-667
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	44	-6380	0	0	-6380
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	47.4	-6873	0	0	-6873
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	-197.2	28594	0	0	28594
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	30.9	-4481	0	0	-4480.5
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	378.7	-54912	0	0	-54911.5
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	8	-1160	0	0	-1160
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-24	3480	0	0	3480
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-127.9	18546	0	0	18545.5
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-54.6	7917	0	0	7917
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	704.5	-102153	0	0	-102152.5
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	589.4	-85463	0	0	-85463
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-777.9	112796	0	0	112795.5
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-I(MAIN)	NP6522A	-828.8	120176	0	0	120176
	18	400 KV RTSPS(DVC)-RANCHI(PG)	NP7973A	-0.7	102	0	0	101.5
	19	400 KV RTSPS(DVC)-MAITHON(PG)	NP7974A	-294.4	42688	0	0	42688
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-158.3	22954	0	0	22953.5
	21	400 KV RANCHI(PG)-RTSPS(DVC)-II	NP7871A	920.4	-133458	0	0	-133458
	22	400 KV RANCHI(PG)-RTSPS(DVC)-III	NP7853A	950.2	-137779	0	0	-137779
		TOTAL			-44675	0	-44675	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	7.4	-1073	0	0	-1073
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	6.5	-942.5	0	0	-942.5
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	18.5	-2682.5	0	0	-2682.5
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	0	0	0	0	0
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	0	0	0	0	0
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1256.8	182236	0	0	182236
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4260	617700	0	0	617700
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-4475.8	648991	0	0	648991
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-2123.4	307893	0	0	307893
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0	0	0	0	0
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	0	0	0	0	0
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	0	0	0	0	0
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	0	0	0	0	0
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	0	0	0	0	0
	20	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-I	NP5980A	0	0	0	0	0
	21	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-II	NP7498A	0	0	0	0	0
	22	400 KV DUBURI (GRIDCO)-PANDIABILI (PG)	NP7915A	0	0	0	0	0
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	0	0	0	0	0
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-95	13775	0	0	13775
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-125	18125	0	0	18125
		TOTAL		1784022		0	1784022	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-10.00	1450	-1.1	-159.5	1291
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-46.20	6699	0.6	87	6786
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-0.2	-29	-29
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	3.60	-522	0	0	-522
		TOTAL		7627		-102	7526	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	-2685.1	-389340	-389340
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	69.2	-10034	-445.9	-64656	-74690
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	79.9	-11586	-678.4	-98368	-109954
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-535.8	77691	0	0	77691
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-642.6	93177	0	0	93177
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	-542.9	78721	0	0	78721
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-24	3480	0	0	3480
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-132.4	19198	0	0	19198
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-1400.2	203029	0	0	203029
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-127.3	18459	0	0	18459
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	4003.5	-580508	0	0	-580508
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	3761.1	-545360	0	0	-545360
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	2394.8	-347246	0	0	-347246
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	11021.5	-1598118	0	0	-1598118
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	21.8	-3161	0	0	-3161
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	-211.5	30668	0	0	30668
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	-28.9	4191	0	0	4191
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	8.4	-1218	0	0	-1218
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	2277.7	-330267	0	0	-330267
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	0	0	0	0	0
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	6	-870	0	0	-870
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-710.4	103008	0	0	103008
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-11.8	1711	-0.3	-44	1668
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	908.4	-131718	972.5	141013	9295
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	967.3	-140259	921.9	133676	-6583
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	62.5	-9063	0	0	-9063
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	3.6	-522	0	0	-522
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	243.4	-35293	0	0	-35293
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	251.4	-36453	0	0	-36453
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1040A	1938.2	-281039	0	0	-281039
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1130A	1901.2	-275674	0	0	-275674
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	0	0	0	0	0
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	0	0	0	0	0
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	78	-11310	0	0	-11310
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	75.5	-10948	-0.6	-87	-11035
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	0	0	0	0	0
		TOTAL		-3727312		-277806	-4005118	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVArH, w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.