



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpcc.gov.in

NO: ERPC/COM-II/VARH /2166-76

Date: 29.05.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week from 29.04.2019-05.05.2019


The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 13.05.2019.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,


(J. Bandyopadhyay)
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 29/04/19 to 05/05/19**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	5529923

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.


MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 29/04/19 to 05/05/19

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-319.6	46342	0	0	46342
	2	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-1152.8	167156	0	0	167156
	3	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-482.6	69977	0	0	69977
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	0	0	-126.6	-18357	-18357
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	0	0	-57.9	-8395.5	-8396
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	0	0	-97.1	-14079.5	-14080
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-2009.4	291363	0	0	291363
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-568.6	82447	0	0	82447
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-613.9	89016	0	0	89016
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-834.3	120974	0	0	120974
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-308.6	44747	0	0	44747
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	-10.4	1508	-135.8	-19691	-18183
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	24.6	-3567	59.6	8642	5075
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	5.8	-841	41.4	6003	5162
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	945.2	-137054	0	0	-137054
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1639.7	237757	0	0	237757
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-2454.3	355874	0	0	355874
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	1151.5	-166968	0	0	-166968
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	11.9	-1726	0	0	-1726
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	12.1	-1755	0	0	-1755
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	183.4	-26593	0	0	-26593
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	290.3	-42094	0	0	-42094
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	283.7	-41137	0	0	-41137
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	314.1	-45545	0	0	-45545
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	295	-42775	0	0	-42775
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	33.1	-4800	138.7	2011.5	15312
	27	HV side of 400/220 Palma ICT-1	ER1408A	-4581.8	664361	0	0	664361
	28	HV side of 400/220 Palma ICT-2	ER1407A	-5389.9	781536	0	0	781536
	29	HV side of 400/220 Palma ICT-3	ER1231A	-5027.2	728944	0	0	728944
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	161.4	-23403	0	0	-23403
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	163.7	-23737	0	0	-23737
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-274.4	39788	0	0	39788
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-309.7	44907	0	0	44907
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1227.2	-177944	0	0	-177944
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1165.2	-168954	0	0	-168954
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-2093.3	303529	0	0	303529
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-2381.8	345361	0	0	345361
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	239.5	-34728	4.7	681.5	-34046
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	202.7	-29392	15.8	2291	-27101
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	-494.1	71645	0	0	71645
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-483.4	70093	0	0	70093
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	0	0	0	0	0
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	0	0	0	0	0
		TOTAL			3584313		-22794	3561519
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-1365	197925	0	0	197925
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-940.3	136344	0	0	136344
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-937.7	135967	0	0	135967
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	225.4	-32683	0	0	-32683
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	306	-44370	0	0	-44370
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	1365.4	-197983	0	0	-197983
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-638.8	92626	0	0	92626
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	317.6	-46052	0	0	-46052
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	321.4	-46603	0	0	-46603
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	636.5	-92293	0	0	-92293
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	608.2	-88189	0	0	-88189
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	0	0	0
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	0	0	0
		TOTAL			14688		0	14688
DVC	1	220 KV DURGA PUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGA PUR (PG) - PARULIA (DVC) -II	NP6458A	-2287.2	331644	0	0	331644
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	71.4	-10353	0	0	-10353
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	88	-12760	0	0	-12760
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	423.2	-61364	0	0	-61364
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	513	-74385	0	0	-74385
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	-214.2	31059	0	0	31059
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	3942.2	-571619	0	0	-571619
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-356.9	51751	0	0	51750.5
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	1037.6	-150452	0	0	-150452
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	884.8	-128296	0	0	-128296
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-925.1	134140	0	0	134139.5
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-797.2	115594	0	0	115594
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	0	0	0	0	0
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	0	0	0	0	0
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-3694	535630	0	0	535630
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-3797.4	550623	0	0	550623
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-1367.1	198230	0	0	198229.5
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	-683.4	99093	0	0	99093
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-2665.2	386454	0	0	386454
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	3279.8	-475571	0	0	-475571
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	3263.7	-473237	0	0	-473236.5
		TOTAL			476180		0	476180

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	3	-435	0	0	-435
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	3.4	-493	0	0	-493
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	342.8	-49706	0	0	-49706
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	-316.9	45950.5	0	0	45950.5
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	-292.7	42441.5	0	0	42441.5
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1977.6	286752	0	0	286752
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3781.2	548274	0	0	548274
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-3926.2	569299	0	0	569299
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-3164.6	458867	0	0	458867
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	-406.8	58986	0	0	58986
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-1392.2	201869	0	0	201869
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	298.9	-43340.5	0	0	-43340.5
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	1500.2	-217529	0	0	-217529
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	125	-18125	0	0	-18125
	20	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-I	NP5980A	0	0	0	0	0
	21	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-II	NP7498A	0	0	0	0	0
	22	400 KV DUBURI (GRIDCO)-PANDIABILI (PG)	NP7915A	0	0	0	0	0
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	41.3	5988.5	5988.5
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	42	6090	6090
	25	HV side of 400/220 Pandiabili ICT-1	ER1563A	-320.7	46501.5	0	0	46501.5
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	-319.2	46284	0	0	46284
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-216.7	31421.5	0	0	31421.5
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-190.7	27651.5	0	0	27651.5
TOTAL				2034669		12079	2046748	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-1.50	218	0	0	218
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-0.80	116	0	0	116
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-0.1	-14.5	-15
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	0.20	-29	0	0	-29
TOTAL				305		-15	290	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	-21.8	-3161	-3161
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	151.5	-21968	-487.3	-70659	-92626
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	171.1	-24810	-543.9	-78866	-103675
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-800.1	116015	0	0	116015
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-898.7	130312	0	0	130312
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	1127	-163415	0	0	-163415
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	0	0	0	0	0
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-1.2	174	0	0	174
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-994.7	144232	0	0	144232
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	0	0	0	0	0
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	24.9	-3611	0	0	-3611
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	102.7	-14892	0	0	-14892
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	7793.1	-1130000	0	0	-1130000
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	14282.6	-2070977	0	0	-2070977
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-507.4	73573	0	0	73573
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	58.5	-8483	0	0	-8483
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	-6.4	928	0	0	928
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	-1.3	189	0	0	189
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	5713.9	-828516	0	0	-828516
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	782.4	-113448	0	0	-113448
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	1257.1	-182280	0	0	-182280
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-226.3	32814	0	0	32814
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	0	0	0	0	0
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	86	-12470	1032.7	149742	137272
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	96.5	-13993	1011.9	146726	132733
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	810.8	-117566	0	0	-117566
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	577.2	-83694	0	0	-83694
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	441.9	-64076	0	0	-64076
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	450	-65250	0	0	-65250
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1040A	4873.8	-706701	0	0	-706701
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1130A	4801.7	-696247	0	0	-696247
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	-457	66265	0	0	66265
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-313	45385	0	0	45385
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	0	0	0	0	0
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	0	0	0	0	0
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-267.6	38902	0	0	38902
TOTAL				-5673705		143782	-5529923	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVArH,w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an IGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.