



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH /2602-12

Date: 07.06.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week from 20.05.2019-26.05.2019

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 31.05.2019.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,


(J. Bandyopadhyay)
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 20/05/19 to 26/05/19**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	3848402

Note:

- Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.


MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 20/05/19 to 26/05/19

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-702.2	101819	0	0	101819
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-2216.7	321422	0	0	321422
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1125	163125	0	0	163125
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	58.7	-8512	-0.6	-87	-8599
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	52.4	-7598	0	0	-7598
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	74.4	-10788	-0.1	-14.5	-10803
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-3950.7	572852	0	0	572852
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-72.1	10455	-192.4	-27898	-17444
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-87.6	12702	-184.6	-26767	-14065
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-237.2	34394	0	0	34394
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-199.9	28986	0	0	28986
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	4.1	-595	-359	-52055	-52650
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	229.6	33292	33292
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	170.8	24766	24766
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	142.9	-20721	264.1	382394.5	17574
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1220.6	176987	0	0	176987
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-2844.6	412467	0	0	412467
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	329.8	-47821	0	0	-47821
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	19.9	-2886	0	0	-2886
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	25.8	-3741	0	0	-3741
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	107.6	-15602	0	0	-15602
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1098.2	-159239	0	0	-159239
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1075.2	-155904	0	0	-155904
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1173.6	-170172	0	0	-170172
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1146.5	-166243	0	0	-166243
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-0.7	102	191.5	27767.5	27869
	27	HV side of 400/220 Palma ICT-1	ER1408A	-5433.4	787843	0	0	787843
	28	HV side of 400/220 Palma ICT-2	ER1407A	-6185.9	896956	0	0	896956
	29	HV side of 400/220 Palma ICT-3	ER1231A	-5710.8	828066	0	0	828066
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	49.4	-7163	0	0	-7163
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	55.3	-8019	0	0	-8019
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1627.6	236002	0	0	236002
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1525.8	221241	0	0	221241
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1241	-179945	0	0	-179945
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	918.7	-133212	0	0	-133212
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-3585.3	519869	0	0	519869
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-3871.8	561411	0	0	561411
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	85.7	-12427	0	0	-12427
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	107.5	-15588	0	0	-15588
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	-349.6	50692	0	0	50692
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-346	50170	0	0	50170
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	450.3	-65294	0	0	450.3
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	0	0	-66.2	-9599	0
TOTAL					4796093		7700	4803792
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-1627.3	235959	0	0	235959
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-1216.6	176407	0	0	176407
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-1217.9	176596	0	0	176596
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	-64.2	9309	0	0	9309
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	-63.3	9179	0	0	9179
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	403.4	-58493	0	0	-58493
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-475.6	68962	0	0	68962
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-212.6	30827	0	0	30827
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-274	39730	0	0	39730
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	297	-43065	0	0	-43065
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	248.8	-36076	0	0	-36076
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	-50.3	7294	0	0	7294
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	-47.1	6830	0	0	6830
TOTAL					623457		0	623457
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	452.4	-65598	0	0	-65598
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2010.8	291566	0	0	291566
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-219.4	31813	0	0	31813
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-303.6	44022	0	0	44022
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	-249.8	36221	0	0	36221
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	-313.4	45443	0	0	45443
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	-2501.5	362718	0	0	362717.5
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	2016.2	-292349	0	0	-292349
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	4177.9	-605796	0	0	-605796.5
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-5733.4	831343	0	0	831343
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-5667.3	821759	0	0	821758.5
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-2137	309865	0	0	309865
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-1575.6	228462	0	0	228462
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-2841.8	412061	0	0	412061
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-3670.3	532194	0	0	532193.5
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-2976.4	431578	0	0	431578
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-3036.8	440336	0	0	440336
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-2515.3	364719	0	0	364718.5
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	1754.7	-254432	0	0	-254431.5
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-1635.3	237119	0	0	237118.5
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	2441.9	-354076	0	0	-354075.5
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	2626	-380770	0	0	-380770
TOTAL					3468197		0	3468197

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	0	0	0	0	0
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	0	0	0	0	0
	7	400 KV INDRAVATI (PG) - INDRAVATI PH	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	567.2	-82244	0	0	-82244
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	536.3	-77763.5	0.4	58	-77705.5
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-432	62640	0	0	62640
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2395.2	347304	0	0	347304
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-3360	487200	0	0	487200
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-1574.2	228259	0	0	228259
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	410.3	-59493.5	25.7	3726.5	-55767
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-17.3	2508.5	0	0	2508.5
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	3.5	-507.5	0	0	-507.5
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	39.5	-5727.5	0	0	-5727.5
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	0	0	0	0	0
	20	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-I	NP5980A	0	0	81.1	11759.5	11759.5
	21	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-II	NP7498A	0	0	127.8	18531	18531
	22	400 KV DUBURI (GRIDCO)-PANDIABILI (PG)	NP7915A	0	0	0	0	0
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	3.2	464	464
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	3.9	565.5	565.5
	25	HV side of 400/220 Pandiabili ICT-1	ER1563A	0	0	258.8	37526	37526
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	233.2	33814	33814
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-3348.8	485576	0	0	485576
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-3667.2	531744	0	0	531744
TOTAL				1919496		106445	2025940	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-83.10	12050	-2.2	-319	11731
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	0.00	0	0	0	0
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	8.40	-1218	0	0	-1218
TOTAL				10832		-319	10513	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	1276.6	185107	185107
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	-59.4	8613	-1906.7	-276472	-267859
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	-47.2	6844	-2373	-344085	-337241
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-2418.3	350654	0	0	350654
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-2517.1	364980	0	0	364980
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	2206.1	-319885	0	0	-319885
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-673.9	97716	0	0	97716
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-508.5	73733	0	0	73733
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2397.4	347623	0	0	347623
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-615.2	89204	0	0	89204
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	2357.2	-341794	0	0	-341794
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	3167.8	-459331	0	0	-459331
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-20.2	2929	0	0	2929
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	6452	-935540	0	0	-935540
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	13961.5	-2024418	0	0	-2024418
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-118.3	17154	0	0	17154
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	-132.3	19184	0	0	19184
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	-49.7	7207	0	0	7207
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	-34	4930	0	0	4930
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	2848.3	-413004	0	0	-413004
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	310	-44950	0	0	-44950
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	626.6	-90857	0	0	-90857
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-624.3	90524	0	0	90524
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-184.6	26767	0	0	26767
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	254.1	-36845	4524	655980	619136
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	258.7	-37512	4501.8	652761	615250
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	432.6	-62727	0	0	-62727
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	234.8	-34046	0	0	-34046
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	842.5	-122163	-5.8	-841	-123004
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	851.2	-123424	-9.4	-1363	-124787
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1040A	3894.3	-564674	0	0	-564674
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1130A	3873.4	-561643	0	0	-561643
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	89.7	-13007	0	0	-13007
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	146.2	-21199	0	0	-21199
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	110	-15850	0	0	-15850
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	85.3	-12369	0	0	-12369
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-53.7	7787	0	0	7787
TOTAL				-4719489		871088	-3848402	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVArh, w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.