



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH /4181-4191

Date: 29.07.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comm & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comm), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comm), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week from 01.07.2019-07.07.2019

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 12.07.2019.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

(J. Bandyopadhyay)
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 01/07/19 to 07/07/19**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	522
WBSETCL	POOL	5049785

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.


MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 01/07/19 to 07/07/19

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-1515.5	219748	0	0	219748
	2	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-4880.2	707629	0	0	707629
	3	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-3253.3	471729	0	0	471729
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-0.3	44	-24.2	-3509	-3466
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-49.8	7221	-13.4	-1943	5278
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	6.1	-885	-19.6	-2842	-3727
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-3841.3	556989	0	0	556989
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-519	75255	-3.1	-449.5	74806
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-552.8	80156	-2.9	-420.5	79736
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-568	82360	0	0	82360
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-513.1	74400	0	0	74400
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	-13	1885	-1002.1	-145304.5	-143420
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	-8.7	1262	0	0	1262
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	-2.3	334	0	0	334
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	858.3	-124454	3.7	536.5	-123917
	16	132 KV KHALGAON(NTPC)-KHALGAON (BSPHCL)	NP5261A	-1471.2	213324	0	0	213324
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-3907.1	566530	0	0	566530
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	1037.7	-150467	0	0	-150467
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	165.7	-24027	0	0	-24027
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	191.1	-27710	0	0	-27710
	21	132 KV KHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	-743.4	107793	0	0	107793
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1172.8	-170056	0	0	-170056
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1159.1	-168070	0	0	-168070
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1290.2	-187079	0	0	-187079
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1206.9	-175001	0	0	-175001
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	49.2	-7134	717.9	104095.5	96962
	27	HV side of 400/220 Palma ICT-1	ER1408A	-5523	800835	0	0	800835
	28	HV side of 400/220 Palma ICT-2	ER1407A	-6561.1	951360	0	0	951360
	29	HV side of 400/220 Palma ICT-3	ER1231A	-6073.4	880643	0	0	880643
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	1048.2	-151989	0	0	-151989
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	1067.7	-154817	0	0	-154817
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1400.4	203058	0	0	203058
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1380.5	200173	0	0	200173
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1182.2	-171419	0	0	-171419
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1180.9	-171231	0	0	-171231
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7368A	-2867	415715	0	0	415715
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-3000.2	435029	0	0	435029
	38	HV side of 400/220 Darbhanga DMTCL ICT-1	ER1274A	535	-77575	4.3	623.5	-76962
	39	HV side of 400/220 Darbhanga DMTCL ICT-2	ER1275A	572	-82940	2.6	377	-82563
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	-432.5	62713	0	0	62713
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-428.8	62176	0	0	62176
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	2428.7	-352162	0	0	2428.7
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	2094.7	-303732	0	0	2094.7
		TOTAL		4677613		-48836	4628777	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-2641.8	383061	0	0	383061
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-1583.9	229666	0	0	229666
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-1826.6	264857	0	0	264857
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	922.9	-133821	0	0	-133821
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	1215.1	-176190	0	0	-176190
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	1778.6	-257897	0	0	-257897
	7	132 KV KHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-634.2	91959	0	0	91959
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-116.8	16936	0	0	16936
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-56.4	8178	0	0	8178
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	88.2	-12789	0	0	-12789
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	76.5	-11093	0	0	-11093
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	-20.3	2944	0	0	2944
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	-17.5	2538	0	0	2538
		TOTAL		408349		0	408349	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-4228.8	613176	0	0	613176
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-69.8	10121	0	0	10121
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-81.8	11861	0	0	11861
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	80.8	-11716	0	0	-11716
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	108	-15660	0	0	-15660
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	-374.4	54288	0	0	54288
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	1999.3	-289899	0	0	-289898.5
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	1367.9	-198346	0	0	-198345.5
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-1629.6	236292	0	0	236292
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-1723.2	249864	0	0	249864
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-5856.4	849178	0	0	849178
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-5322.6	771777	0	0	771777
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	866	-125570	0	0	-125570
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	770	-111650	0	0	-111650
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-3721.1	539560	0	0	539559.5
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-3817.7	553567	0	0	553566.5
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-5999	869855	0	0	869855
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	540.8	-78416	0	0	-78416
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-2310.2	334979	0	0	334979
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	8248.4	-1196018	0	0	-1196018
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	8225.2	-1192654	0	0	-1192654
		TOTAL		1874589		0	1874589	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	-32.8	4756	0	0	4756
	6	HV side meter of 400/220 Baripada ICT-1	ER1571A	-427.4	61973	0	0	61973
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	888.4	-128818	0	0	-128818
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	49.3	-7148.5	0	0	-7148.5
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	43.8	-6351	0	0	-6351
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1435	208075	0	0	208075
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4422.2	641219	0	0	641219
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-4010.8	581566	0	0	581566
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-3990	578550	0	0	578550
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0.7	-101.5	0	0	-101.5
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-713.9	103515.5	0	0	103515.5
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	2675.8	-387991	0	0	-387991
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	5957.5	-863837.5	0	0	-863837.5
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	429.6	-62292	0	0	-62292
	20	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-I	NP5980A	7.9	-1145.5	0	0	-1145.5
	21	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-II	NP7498A	2.5	-362.5	0	0	-362.5
	22	400 KV DUBURI (GRIDCO)-PANDIABILI (PG)	NP7915A	-868.7	125961.5	0	0	125961.5
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	-21.1	3059.5	0	0	3059.5
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	-17.5	2537.5	0	0	2537.5
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	0	0	0	0	0
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	236.4	-34278	0	0	-34278
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-3860	559700	0	0	559700
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-3881.7	562846.5	0	0	562846.5
		TOTAL		1941434	0	0	1941434	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	0.00	0	0	0	0
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	0.00	0	0	0	0
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	3.60	-522	0	0	-522
		TOTAL		-522	0	0	-522	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASHGRAM (PG)	ER1471A	0	0	-1441.1	-208960	-208960
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-1	ER1534A	-95.3	13819	-11.1	-1610	12209
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-2	ER1483A	-54.4	7888	-38.5	-5583	2306
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1614	234030	0	0	234030
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1708.2	247689	0	0	247689
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	1209.5	-175378	0	0	-175378
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	67	-9715	0	0	-9715
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	34.8	-5046	0	0	-5046
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-1395.5	202348	0	0	202348
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	0	0	0	0	0
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	-3310.8	480066	0	0	480066
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	-1814.4	263088	0	0	263088
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	23.9	-3466	0	0	-3466
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	10644	-1543380	0	0	-1543380
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	14835.6	-2151162	0	0	-2151162
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-412.8	59856	0	0	59856
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASHGRAM (PG)	NP6483A	-353.1	51200	0	0	51200
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	194.2	-28159	0	0	-28159
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	-242.3	35134	0	0	35134
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	3714.5	-538603	0	0	-538603
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	600.7	-87102	0	0	-87102
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	1610.9	-233581	0	0	-233581
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-557	80765	-717.3	-104009	-23244
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-198.4	28768	-812.6	-117827	-89059
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	-655.4	95033	0.3	44	95077
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	-340.2	49329	10.1	1465	50794
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	753.9	-109316	0	0	-109316
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	303	-43935	0	0	-43935
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	65.7	-9527	0	0	-9527
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	95.5	-13848	0	0	-13848
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1040A	2601.7	-377247	0	0	-377247
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1130A	8378.9	-1214941	0	0	-1214941
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	-293.2	42514	0	0	42514
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-193.8	28101	0	0	28101
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	0	0	0	0	0
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	0	0	0	0	0
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-79.1	11470	0	0	11470
		TOTAL		-4613306	-436479	-5049785		

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVArH, w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.