



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH 14625-4635

Date: 06.08.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week from 15.07.2019-21.07.2019


The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 29.07.2019.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,


(J. Bandyopadhyay)
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 15/07/19 to 21/07/19**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	218
WBSETCL	POOL	544330

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.


MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 15/07/19 to 21/07/19

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-219	31755	0	0	31755
	2	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-3034.8	440046	0	0	440046
	3	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1177.8	170781	0	0	170781
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-9.2	1334	-105.4	-15283	-13949
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-27.7	4017	-21.3	-3088.5	928
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	-5.9	856	-79.1	-11469.5	-10614
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-4062.3	589034	0	0	589034
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-220.2	31929	-286	-41470	-9541
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-241.7	35047	-282.9	-41020.5	-5974
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-74.1	10745	-21.1	-3059.5	7685
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-156.7	22722	-1.2	-174	22548
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	0.2	-29	-1494.7	-216731.5	-216761
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	1.4	-203	0	0	-203
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	386.4	-56028	433.3	62828.5	6801
	16	132 KV KHALGAON(NTPC)-KHALGAON (BSPHCL)	NP5261A	-1213	175885	0	0	175885
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-5129.1	743720	0	0	743720
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	466.5	-67643	0	0	-67643
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	78.3	-11354	0	0	-11354
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	93.2	-13514	0	0	-13514
	21	132 KV KHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	-222.6	32277	0	0	32277
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	576.6	-83607	0	0	-83607
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	568.3	-82404	0	0	-82404
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	635.3	-92119	0	0	-92119
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	590.1	-85565	0	0	-85565
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP8095A	1.6	-232	1421.5	206117.5	205886
	27	HV side of 400/220 Palma ICT-1	ER1408A	-5801.5	841218	0	0	841218
	28	HV side of 400/220 Palma ICT-2	ER1407A	-6653.5	964758	0	0	964758
	29	HV side of 400/220 Palma ICT-3	ER1231A	-6108.7	885762	0	0	885762
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	109.8	-15921	0	0	-15921
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	118.7	-17212	0	0	-17212
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1558.3	225954	0	0	225954
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1510.2	218979	0	0	218979
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	903.9	-131066	0	0	-131066
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	885.2	-128354	0	0	-128354
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-2589.7	375507	-0.2	-29	375478
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-2819.2	408784	0	0	408784
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	754.2	-109359	-7.2	-1044	-110403
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	570.2	-82679	-10.5	-1522.5	-84202
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	-265.8	38541	0	0	38541
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-514.5	74603	-0.1	-14.5	74588
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	1892.6	-274427	0	0	1892.6
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	1519.4	-220313	0	0	1519.4
		TOTAL		4852222		-65961	4786262	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-2.5	363	0	0	363
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	0	0	0	0	0
	3	HV side meter of 400/220 Jamshedpur ICT-3	ER1297A	-1	145	0	0	145
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	-18.1	2625	0	0	2625
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	8.1	-1175	0	0	-1175
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	603.6	-87522	0	0	-87522
	7	132 KV KHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-503.6	73022	0	0	73022
	8	220 KV MAITHON (PG) - DUMKA (JUVNL) - I	NP8727A	-29.8	4321	0	0	4321
	9	220 KV MAITHON (PG) - DUMKA (JUVNL) - II	NP8739A	-68.2	9889	0	0	9889
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	0	0	0	0	0
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	0	0	0	0	0
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	-10.8	1566	0	0	1566
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	-9.5	1378	0	0	1378
		TOTAL		4611		0	4611	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2159.2	313084	0	0	313084
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	0	0	0	0	0
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	5.8	-841	0	0	-841
	7	400 KV TATA JAMSHEDPUR (DVC)-BARIPADA(PG)	NP7408A	41.9	-6076	0	0	-6076.5
	8	400 KV TATA JAMSHEDPUR (DVC)-JAMSHEDPUR (PG)	NP7406A	120.9	-17531	0	0	-17530.5
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	992.4	-143898	0	0	-143898
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-279.6	40542	0	0	40542
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-303.6	44022	0	0	44022
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-3250.5	471323	0	0	471322.5
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-2238.1	324525	0	0	324524.5
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	386.1	-55985	0	0	-55984.5
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	478.7	-69412	0	0	-69411.5
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-1558.2	225939	0	0	225939
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-I(MAIN)	NP6522A	-1627.2	235944	0	0	235944
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-3161.1	458360	0	0	458359.5
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	2080.3	-301644	0	0	-301643.5
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-790.8	114666	0	0	114666
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	3478.9	-504441	0	0	-504440.5
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	3513	-509385	0	0	-509385
		TOTAL		619194		0	619194	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	0	0	0	0	0
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	-1	145	0	0	145
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	527.2	-76444	0	0	-76444
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	0	0	0	0	0
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	0	0	0	0	0
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1816.2	263349	0	0	263349
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4687.2	679644	0	0	679644
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-4269.6	619092	0	0	619092
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-3948.2	572489	0	0	572489
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0	0	0	0	0
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	0	0	0	0	0
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	632.3	-91683.5	0	0	-91683.5
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	304.7	-44181.5	0	0	-44181.5
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	244.3	-35423.5	0	0	-35423.5
	20	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-I	NP5980A	0	0	0	0	0
	21	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-II	NP7498A	0	0	0	0	0
	22	400 KV DUBURI (GRIDCO)-PANDIABILI (PG)	NP7915A	0	0	0	0	0
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	0	0	1.4	203	203
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-3486.9	505600.5	0	0	505600.5
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-3634.6	527017	0	0	527017
		TOTAL		2919604		203	2919807	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	0.00	0	0	0	0
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	0.00	0	0	0	0
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-0.1	-14.5	-15
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	1.40	-203	0	0	-203
		TOTAL		-203		-15	-218	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASHGRAM (PG)	ER1471A	0	0	-1762	-255490	-255490
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-1	ER1534A	0	0	-2500.2	-362529	-362529
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-2	ER1483A	0	0	-2709.1	-392820	-392820
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-611.2	88624	0	0	88624
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-644.7	93482	0	0	93482
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	995.2	-144304	0	0	-144304
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	8.4	-1218	0	0	-1218
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	11.7	-1697	0	0	-1697
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-694	100630	0	0	100630
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	0	0	0	0	0
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	-619.7	89857	0	0	89857
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	48.5	-7033	0	0	-7033
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	9.4	-1363	0	0	-1363
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	2928.3	-424604	0	0	-424604
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	891.6	-129282	0.3	44	-129239
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-9.4	1363	0	0	1363
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASHGRAM (PG)	NP6483A	144.6	-20967	0	0	-20967
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	50.4	-7308	0	0	-7308
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	-65.9	9556	0	0	9556
	20	400 KV KHARGAPUR (WBSETCL)-BARIPADA (PG)	ER1043A	785.9	-113956	0	0	-113956
	21	400 KV KHARGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	0	0	0	0	0
	22	400 KV KHARGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	64.8	-9396	0	0	-9396
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-470.4	68208	0	0	68208
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-105.3	15289	0	0	15289
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	0.3	-44	4504	653080	653037
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	0	0	4946.4	717228	717228
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	92.9	-13471	0	0	-13471
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	0.7	-102	0	0	-102
	32	400 KV KHARGAPUR (WB)-CHAIBASA (PG)-I	NP8731A	76.3	-11064	0	0	-11064
	33	400 KV KHARGAPUR (WB)-CHAIBASA (PG)-II	NP8720A	82.8	-12006	0	0	-12006
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1040A	1849.9	-268236	0	0	-268236
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1130A	1348.1	-195475	0	0	-195475
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	0	0	0	0	0
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	0	0	-1	-145	-145
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	0	0	-32.3	-4684	-4684
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	0	0	-30.9	-4481	-4481
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	0	0	0	0	0
		TOTAL		-894534		350204	-544330	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVArH, w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.