



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति



**Eastern Regional Power Committee**  
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008  
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: [www.erpc.gov.in](http://www.erpc.gov.in)

NO: ERPC/COM-II/VARH/ 5022-5032

Date: 26.08.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

**Sub: Provisional Reactive Energy (VARH) Charges for the week from 29.07.2019-04.08.2019**


The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 09.08.2019.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

Encl: As above

Yours faithfully,

  
for **MEMBER SECRETARY**

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 29/07/19 to 04/08/19**

**REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL**

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	2613350
SIKKIM	POOL	0
WBSETCL	POOL	2930508

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

  
for MEMBER SECRETARY

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

for the period 29/07/19 to 04/08/19

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-899.8	130471	0	0	130471
	2	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-5332.1	773155	0	0	773155
	3	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-2941.7	426547	0	0	426547
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-2.5	363	-38.9	-5640.5	-5278
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-76.1	11035	-7.9	-1145.5	9889
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	-7.4	1073	-27.3	-3958.5	-2886
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-3376.2	489549	0	0	489549
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-281.4	40803	-308.3	-44703.5	-3901
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-299.4	43413	-305.1	-44239.5	-827
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-10.5	1523	-23	-3335	-1813
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-267	38715	-0.3	-43.5	38672
	12	132 KV PUSAULI(PG)-MOHAN(A)(BSPHCL)	NP6094A	-4.8	696	-788.1	-114274.5	-113579
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	144.1	-20895	0	0	-20895
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	54.8	-7946	0	0	-7946
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	451.7	-65497	463.6	67222	1726
	16	132 KV KHALGAON(NTPC)-KHALGAON (BSPHCL)	NP5261A	-1658.1	240425	0	0	240425
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-3496.3	506964	0	0	506964
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	-1167.1	169230	0	0	169230
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	11	-1595	0	0	-1595
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7899A	14.5	-2103	0	0	-2103
	21	132 KV KHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	-548.1	79475	0	0	79475
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	886.1	-128485	0	0	-128485
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	880.3	-127644	0	0	-127644
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	997.8	-144681	0	0	-144681
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	906.6	-131457	0	0	-131457
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	20.2	-2929	615.8	89291	86362
	27	HV side of 400/220 Patna ICT-1	ER1408A	-5020.7	728002	0	0	728002
	28	HV side of 400/220 Patna ICT-2	ER1407A	-5921.6	858632	0	0	858632
	29	HV side of 400/220 Patna ICT-3	ER1231A	-5487.5	795688	0	0	795688
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	643.1	-93250	0	0	-93250
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	674.3	-97774	0	0	-97774
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1367.3	198259	0	0	198259
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1344.9	195011	0	0	195011
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	907.7	-131617	0	0	-131617
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	906	-131370	0	0	-131370
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-2979.4	432013	0	0	432013
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-3195.5	463348	0	0	463348
	38	HV side of 400/220 Darbhanga DMTCL ICT-1	ER1274A	146.1	-21185	-0.7	-101.5	-21286
	39	HV side of 400/220 Darbhanga DMTCL ICT-2	ER1275A	164.8	-23996	-0.7	-101.5	-23996
	40	132 KV MOTHARI(DMTCL)-MOTHARI(BSPTCL)-I	ER1256A	-570	82650	0	0	82650
	41	132 KV MOTHARI(DMTCL)-MOTHARI(BSPTCL)-II	ER1258A	-560.7	81302	0	0	81302
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	2141.8	-310561	0	0	2141.8
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	1417.4	-205523	0	0	1417.4
		<b>TOTAL</b>		<b>5139931</b>		<b>-61031</b>	<b>5078901</b>	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-2192.5	317913	0	0	317913
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-1141	165445	0	0	165445
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-1399.9	202986	0	0	202986
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	155.1	-22490	0	0	-22490
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	262.9	-38121	0	0	-38121
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	1820.4	-263958	0	0	-263958
	7	132 KV KHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-285.9	41456	0	0	41456
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-389	56405	0	0	56405
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-543.2	78764	0	0	78764
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	44.2	-6409	0	0	-6409
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	48.8	-7076	0	0	-7076
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	-0.2	29	-0.2	-29	0
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	-0.2	29	-0.2	-29	0
		<b>TOTAL</b>		<b>524973</b>		<b>-58</b>	<b>524915</b>	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2411	349595	0	0	349595
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-115.4	16733	0	0	16733
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-163.2	23664	0	0	23664
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	346.4	-50228	0	0	-50228
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	553.6	-80272	0	0	-80272
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	-620.5	89973	0	0	89973.5
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	3023.7	-438437	0	0	-438436.5
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	3846.9	-557801	0	0	-557800.5
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-1898	275210	0	0	275210
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-2009.8	291421	0	0	291421
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-3380.6	490187	0	0	490187
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-3083.3	447079	0	0	447078.5
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-474.8	68846	0	0	68846
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-670.3	97194	0	0	97193.5
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-3881.1	562760	0	0	562759.5
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-I(MAIN)	NP6522A	-3965.4	574983	0	0	574983
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-5900	855500	0	0	855500
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	171.5	-24868	0	0	-24867.5
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-2205.4	319783	0	0	319783
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	6550.2	-949779	0	0	-949779
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	6611.2	-958624	0	0	-958624
		<b>TOTAL</b>		<b>1402919</b>		<b>0</b>	<b>1402919</b>	

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	-197.5	28637.5	0	0	0	28637.5
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	-1025.1	148639.5	0	0	0	148639.5
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	11124.8	-1613096	0	0	0	-1613096
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	106	-15370	0	0	0	-15370
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	80	-11600	0	0	0	-11600
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-2440	353800	0	0	0	353800
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4298.4	623268	0	0	0	623268
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-3907.4	566573	0	0	0	566573
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-3878.6	562397	0	0	0	562397
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	17.7	-2566.5	0	0	0	-2566.5
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-1237.1	179379.5	0	0	0	179379.5
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	11837.7	-1716466.5	0	0	0	-1716466.5
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	12485.5	-1810397.5	0	0	0	-1810397.5
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	3609.5	-523377.5	0	0	0	-523377.5
	20	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-I	NP5980A	-131.5	19067.5	0	0	0	19067.5
	21	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-II	NP7498A	-81.6	11832	0	0	0	11832
	22	400 KV DUBURI (GRIDCO)-PANDIABILI (PG)	NP7915A	-2031.2	294524	0	0	0	294524
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	-4.3	623.5	0	0	0	623.5
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	-2.8	406	0	0	0	406
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	24.6	-3567	0	0	0	-3567
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	13.7	-1986.5	0.7	101.5	0	-1885
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-1010	146450	0	0	0	146450
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-1030.2	149379	0	0	0	149379
		<b>TOTAL</b>		<b>-2613451</b>		<b>102</b>		<b>-2613350</b>	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-67.20	9744	0	0	9744	
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-11.30	1639	0	0	1639	
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0	
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0	
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0	
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	3.70	-537	0	0	-537	
		<b>TOTAL</b>		<b>10846</b>		<b>0</b>		<b>10846</b>	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	1814.2	263059	263059	
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	-8.1	1175	-99.7	-14457	-13282	
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	-0.4	58	-174	-25230	-25172	
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1525.3	221169	0	0	221169	
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1667.7	241817	0	0	241817	
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0	
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	19.6	-2942	0	0	-2942	
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-42.4	6148	0	0	6148	
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-841.1	92960	0	0	92960	
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	0	0	0	0	0	
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	-1382.1	200405	0	0	200405	
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	-357.6	51852	0	0	51852	
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-0.5	73	0	0	73	
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	782.14	-1134103	0	0	-1134103	
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	1651.9	-239526	0	0	-239526	
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-295.7	42877	0	0	42877	
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	663.7	-96237	0	0	-96237	
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	41.2	-5974	0	0	-5974	
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	-91.4	13253	0	0	13253	
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	4167.6	-604302	0	0	-604302	
	21	400 KV KHARAGPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	842.2	-122119	0	0	-122119	
	22	400 KV KHARAGPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	1878.3	-272354	0	0	-272354	
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-1048.9	152091	0	0	152091	
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-437.2	63394	0	0	63394	
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0	
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0	
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	0	0	0	0	0	
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	-50.9	7381	115.5	16748	24128	
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	-54.9	7961	179.5	26028	33988	
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	2132	-309140	0	0	-309140	
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	1360.3	-197244	0	0	-197244	
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	827.2	-119944	0	0	-119944	
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	836.6	-121307	0	0	-121307	
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1040A	4555.2	-660504	0	0	-660504	
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1130A	3264.7	-473382	0	0	-473382	
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	-230.1	33365	0	0	33365	
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-176.6	25607	0	0	25607	
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	0	0	-56.7	-8222	-8222	
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	0	0	-58.1	-8425	-8425	
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-119.9	17386	0	0	17386	
		<b>TOTAL</b>		<b>-3180010</b>		<b>249502</b>	<b>-2930508</b>		

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVArh, w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.