



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/6618-6628

Date: 03.10.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comm & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comm), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comm), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week 26.08.2019-01.09.2019

दिनांक -26.08.2019 से 01.09.2019 तक के सप्ताह के लिए अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क।

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 18.09.2019.*

उपरोक्त अवधि के लिए देय/प्राप्य विवरण सहित अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क का ब्यौरा संलग्न है। दिनांक-18.09.2019 को ईआरएलडीसी(ERLDC) से विषयवार सप्ताह हेतु डाटा की अंतिम किस्त प्राप्त की गई है।

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

संघ के सदस्यों से यह अनुरोध किया जाता है कि बिलिंग तिथि के 10 दिनों के भीतर ईआरएलडीसी(ERLDC) द्वारा संचालित रिएक्टिव पूल खाते में भुगतान करें। इन बिलों के भुगतान में 12 दिनों से अधिक की विलंब के स्थिति में, व्यतिक्रामी घटकों को विलंब के प्रत्येक दिन @ 0.04% का साधारण ब्याज का भुगतान करना होगा।

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat. यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

Encl: As above/ संलग्न यथोपरी

भवदीय/Yours faithfully,

(J. Bandyopadhyay)
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 26/08/19 to 01/09/19**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	1220639

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.


MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 26/08/19 to 01/09/19

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-895.8	129891	0	0	129891
	2	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-5069.2	735034	0	0	735034
	3	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-2871.6	416382	0	0	416382
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-7.6	1102	-10.4	-1508	-406
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-30.9	4481	-0.6	-87	4394
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	-8	1160	-7	-1015	145
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-3579.9	519086	0	0	519086
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-88.7	12862	0	0	12862
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-109.5	15878	0	0	15878
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG-I)	NP8641A	-13.7	1987	-0.1	-14.5	1972
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG-II)	NP6060A	-552	80040	0	0	80040
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	1.4	-203	-489.7	-71006.5	-71210
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	190.9	-27681	0	0	-27681
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1220.2	176929	0	0	176929
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-7017.1	1017480	-0.1	-14.5	1017465
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	1314.3	-190574	0	0	-190574
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	256.6	-37207	0	0	-37207
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	283.2	-41064	0	0	-41064
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	0	0	0	0	0
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	474.3	-68774	0	0	-68774
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	459.9	-66686	0	0	-66686
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	514.8	-74646	0	0	-74646
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	483.6	-70122	0	0	-70122
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP8095A	-3.6	522	384	55680	56202
	27	HV side of 400/220 Patna ICT-1	ER1408A	-4473.4	648643	0	0	648643
	28	HV side of 400/220 Patna ICT-2	ER1407A	-5209.1	755320	0	0	755320
	29	HV side of 400/220 Patna ICT-3	ER1231A	-4864.3	705324	0	0	705324
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	30	-4350	0	0	-4350
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	28.2	-4089	0	0	-4089
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1571.2	227824	0	0	227824
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1419.9	205886	0	0	205886
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	495.2	-71804	0	0	-71804
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	506.4	-73428	0	0	-73428
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-3295.9	477906	-0.1	-14.5	477891
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-3732.3	541184	0	0	541184
	38	HV side of 400/220 Darbhanga DMTCL ICT-1	ER1274A	268.1	-38875	-2.1	-304.5	-39179
	39	HV side of 400/220 Darbhanga DMTCL ICT-2	ER1275A	270.7	-39252	-2.5	-362.5	-39614
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	-161	23345	-1.5	-217.5	23128
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-153.6	22272	-1.4	-203	22069
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	1658.5	-240483	0	0	1658.5
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	1580.6	-229187	0	0	1580.6
		TOTAL		5442111		-19068	5423044	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-1070.7	155252	0	0	155252
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-576.3	83564	0	0	83564
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-647.3	93859	0	0	93859
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	98.5	-14283	0	0	-14283
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	173.2	-25114	0	0	-25114
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	303.4	-43993	0	0	-43993
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	0	0	0	0	0
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	-362	52490	0	0	52490
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	-757	109765	0	0	109765
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	49.9	-7236	0	0	-7236
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	50.1	-7265	0	0	-7265
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	0	0	0
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	0	0	0
		TOTAL		397039		0	397039	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2078.8	301426	0	0	301426
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	2	-290	0	0	-290
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	4	-580	0	0	-580
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	54.6	-7917	0	0	-7917
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	146	-21170	0	0	-21170
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	-84.4	12238	0	0	12238
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	1356.3	-196664	0	0	-196663.5
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	3130.5	-453923	0	0	-453922.5
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-1246.1	180665	0	0	180664.5
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-1262.2	183019	0	0	183019
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-4310.9	625081	0	0	625080.5
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-3545.1	514040	0	0	514039.5
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-718.3	104154	0	0	104153.5
15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-976.3	141564	0	0	141563.5	
16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-2675.3	387919	0	0	387918.5	
17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-2780.6	403187	0	0	403187	
18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-4004	580580	0	0	580580	
19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	4696.3	-680964	0	0	-680963.5	
20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-1940	281300	0	0	281300	
21	400 KV RANCHI(PG)-RTPS(DVC)-I	NP7871A	4860.7	-704802	0	0	-704801.5	
22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	4697.9	-681196	0	0	-681195.5	
		TOTAL		967687		0	967687	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	-248.6	36047	0	0	36047
	6	HV side meter of 400/220 Baripada ICT-1	ER1571A	-216.3	31363.5	0	0	31363.5
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	4302.5	-623862.5	0	0	-623862.5
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	28	-4090	0	0	-4060
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	20	-2900	0	0	-2900
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-2966.4	430128	0	0	430128
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4123.8	597951	0	0	597951
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-4046.6	586757	0	0	586757
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-4007.8	581131	0	0	581131
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	4.3	-623.5	0	0	-623.5
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-249.9	36235.5	0	0	36235.5
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	1156.5	-167692.5	0	0	-167692.5
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	1173.6	-170172	0	0	-170172
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	522.9	-75820.5	0	0	-75820.5
	20	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-I	NP5980A	0	0	0	0	0
	21	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-II	NP7498A	0	0	0	0	0
	22	400 KV DUBURI (GRIDCO)-PANDIABILI (PG)	NP7915A	-165.2	23954	0	0	23954
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	-214.1	-31044.5	-31044.5
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	-215.7	-31276.5	-31276.5
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	0	0	0	0	0
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-3163.4	458693	0	0	458693
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-3262.1	473004.5	0	0	473004.5
		TOTAL		2210134		-62321	2147813	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-21.20	3074	0	0	3074
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-3.00	435	0	0	435
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	-0.30	44	0	0	44
		TOTAL		3553		0	3553	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASHGRAM (PG)	ER1471A	0	0	-2188.9	-317391	-317391
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-1	ER1534A	-35.6	5162	-307.3	-44559	-39397
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-2	ER1483A	-3.2	464	-479.5	-69528	-69064
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-530	76850	0	0	76850
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-582.1	84405	0	0	84405
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	3.1	-450	0	0	-450
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	-32.6	4727	0	0	4727
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-916.6	132907	0	0	132907
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-5.9	856	0	0	856
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	-2200.7	319102	0	0	319102
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	-882.8	99006	0	0	99006
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0.2	-29	0	0	-29
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	3367.6	-488302	0	0	-488302
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	42.5	-6163	0	0	-6163
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	5.6	-812	0	0	-812
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASHGRAM (PG)	NP6483A	-8.5	1233	0	0	1233
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	28.1	-4075	0	0	-4075
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	-59.6	8642	0	0	8642
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	2861.5	-414918	0	0	-414918
	21	400 KV KHARAGPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	30.9	-4481	0	0	-4481
	22	400 KV KHARAGPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	264.2	-38309	0	0	-38309
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-613.9	89016	0	0	89016
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-152	22040	0	0	22040
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	-141.4	20503	420.4	60958	81461
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	-152.7	22142	639.2	92684	114826
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	929.1	-134720	0	0	-134720
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	503.8	-73051	0	0	-73051
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	348.7	-50562	0	0	-50562
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	349.4	-50663	0	0	-50663
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1040A	2248	-325960	0	0	-325960
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1130A	1684	-244180	0	0	-244180
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	0	0	0	0	0
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	0	0	0	0	0
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	0	0	-0.1	-15	-15
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	0	0	-0.1	-15	-15
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-47.2	6844	0	0	6844
		TOTAL		-942776		-277864	-1220639	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVArH, w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.