



सत्यमेव जयते

भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति



**Eastern Regional Power Committee**

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008  
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: [www.erpc.gov.in](http://www.erpc.gov.in)

NO: ERPC/COM-II/VARH/18299-8309

Date: 15.11.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comm & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comm), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comm), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

**Sub: Provisional Reactive Energy (VARH) Charges for the week 28.10.2019-03.11.2019**

दिनांक -03.11.2019 से 28.10.2019 तक के सप्ताह के लिए अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क।

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 08.11.2019.*

उपरोक्त अवधि के लिए देय/प्राप्य विवरण सहित अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क का ब्यौरा संलग्न है। दिनांक- 08.11.2019 को ईआरएलडीसी(ERLDC) से विषयवार सप्ताह हेतु डाटा की अंतिम किस्त प्राप्त की गई है।

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

संघ के सदस्यों से यह अनुरोध किया जाता है कि बिलिंग तिथि के 10 दिनों के भीतर ईआरएलडीसी(ERLDC) द्वारा संचालित रिएक्टिव पूल खाते में भुगतान करें। इन बिलों के भुगतान में 12 दिनों से अधिक की विलंब के स्थिति में, व्यतिक्रामी घटकों को विलंब के प्रत्येक दिन @ 0.04% का साधारण ब्याज का भुगतान करना होगा।

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.  
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

Encl: As above/ संलग्न यथोपरी

भवदीय/Yours faithfully,

  
for MEMBER SECRETARY

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 28/10/19 to 03/11/19**

**REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL**

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	0
WBSETCL	POOL	6567587

Note:

- Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

  
15/11/2019  
for MEMBER SECRETARY

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

for the period 28/10/19 to 03/11/19

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-1078.8	156426	0	0	156426
	2	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-2825.4	409683	0	0	409683
	3	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1410.2	204479	0	0	204479
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	1.2	-174	0	0	-174
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-1.6	232	0	0	232
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	86	-12470	0	0	-12470
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	649.8	-94221	0	0	-94221
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-1023	148335	0	0	148335
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-1062.5	154063	0	0	154063
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-1428	207060	0	0	207060
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-1182.2	171419	0	0	171419
	12	132 KV PUSAULI(PG)-MOHANI(BSPHCL)	NP6094A	-98.4	14268	0	0	14268
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	-0.7	102	0	0	102
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	1538.8	-223126	0	0	-223126
	16	132 KV KHALGAON(NTPC)-KHALGAON (BSPHCL)	NP5261A	0	0	0	0	0
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-1704.9	247211	0	0	247211
	18	220KV NEW PUSAULI(BSPHCL) - ARAH (PG)	NP8664A	193.9	-28116	0	0	-28116
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	447.4	-64873	0	0	-64873
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	492.2	-71369	0	0	-71369
	21	132 KV KHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	0	0	0	0	0
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1864.7	-270382	0	0	-270382
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1838.1	-266525	0	0	-266525
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1994	-289130	0	0	-289130
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1948.9	-282591	0	0	-282591
	26	132 KV PUSAULI(PG)-KUDRAJ(BSPHCL)	NP6095A	332.1	-48155	0	0	-48155
	27	HV side of 400/220 Patna ICT-1	ER1408A	423	-61335	0	0	-61335
	28	HV side of 400/220 Patna ICT-2	ER1407A	-525.7	76227	0	0	76227
	29	HV side of 400/220 Patna ICT-3	ER1231A	-478.7	69412	0	0	69412
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	555.7	-80577	0	0	-80577
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	554.6	-80417	0	0	-80417
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1768.7	256462	0	0	256462
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1813.6	262972	0	0	262972
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2334.9	-338561	0	0	-338561
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2342.7	-339692	0	0	-339692
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1722.2	249719	0	0	249719
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-1679.5	243528	0	0	243528
	38	HV side of 400/220 Darbhanga DMTCL ICT-1	ER1274A	0	0	172.1	24954.5	24955
	39	HV side of 400/220 Darbhanga DMTCL ICT-2	ER1275A	0	0	165.5	23997.5	23998
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	0	0	0	0	0
	42	220 KV PURNEA(PG)-BEGUSARAJ(BSPTCL)-I	ER1348A	0	0	0	0	0
	43	220 KV PURNEA(PG)-BEGUSARAJ(BSPTCL)-II	ER1376A	0	0	0	0	0
		<b>TOTAL</b>			<b>319885</b>		<b>48952</b>	<b>368837</b>
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-4382.5	635463	0	0	635463
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-3378.5	489883	0	0	489883
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-4386.1	635985	0	0	635985
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	1227.3	-177959	0	0	-177959
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	1589.7	-230507	0	0	-230507
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	3036.8	-440336	0	0	-440336
	7	132 KV KHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1829.6	265292	0	0	265292
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	353.6	-51272	0	0	-51272
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	356.4	-51678	0	0	-51678
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	484.7	-70282	0	0	-70282
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	628.6	-91147	0	0	-91147
	12	HV side meter of 400/220 Daltongarj ICT-1	ER1197A	0	0	0	0	0
	13	HV side meter of 400/220 Daltongarj ICT-2	ER1317A	0	0	0	0	0
		<b>TOTAL</b>			<b>913442</b>		<b>0</b>	<b>913442</b>
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2020	292900	0	0	292900
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	-158.2	22939	0	0	22939
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-279.8	40571	0	0	40571
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC)-BARIPADA(PG)	NP7408A	-2256.7	327222	0	0	327221.5
	8	400 KV TATA JAMSHEDPUR (DVC)-JAMSHEDPUR (PG)	NP7406A	3957.4	-573823	0	0	-573823
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	3303.6	-479022	0	0	-479022
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-367.7	533122	0	0	533121.5
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-3761.1	545360	0	0	545359.5
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-4648.4	674018	0	0	674018
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-3476.8	504136	0	0	504136
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-507.5	73588	0	0	73587.5
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-726.8	105386	0	0	105386
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-6105	885225	0	0	885225
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-6148	891460	0	0	891460
	18	400 KV RTSPS(DVC)-RANCHI(PG)	NP7973A	-7292.8	1057456	0	0	1057456
	19	400 KV RTSPS(DVC)-MAITHON(PG)	NP7974A	-603.5	87508	0	0	87507.5
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-4115.2	596704	0	0	596704
	21	400 KV RANCHI(PG)-RTSPS(DVC)-II	NP7871A	9902.9	-1435921	0	0	-1435920.5
	22	400 KV RANCHI(PG)-RTSPS(DVC)-III	NP7853A	9805.5	-1421798	0	0	-1421797.5
		<b>TOTAL</b>			<b>2727030</b>		<b>0</b>	<b>2727030</b>

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	0	0	0	0	0
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	-0.9	130.5	0	0	130.5
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	-650.2	94279	0	0	94279
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	-387.2	56144	0	0	56144
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	-0.2	29	0	0	29
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	0	0	0	0	0
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	371	-53795	0	0	-53795
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-3150.8	456866	0	0	456866
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2767.6	401302	0	0	401302
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-4254.6	616917	0	0	616917
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-4212.4	610798	0	0	610798
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0	0	0	0	0
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-2985.2	432854	0	0	432854
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	4426.2	-641799	0	0	-641799
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	7780.3	-1128143.5	0	0	-1128143.5
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	1013.5	-146957.5	0	0	-146957.5
	20	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-I	NP5980A	31.1	-4509.5	0	0	-4509.5
	21	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-II	NP7498A	11.9	-1725.5	0	0	-1725.5
	22	400 KV DUBURI (GRIDCO)-PANDIABILI (PG)	NP7915A	-2277.5	330237.5	0	0	330237.5
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	0	0	0	0	0
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-4593.1	665999.5	0	0	665999.5
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-4719	684255	0	0	684255
		<b>TOTAL</b>		<b>2372882</b>	<b>0</b>	<b>0</b>	<b>2372882</b>	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-297.60	43152	0	0	43152
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-63.80	9251	0	0	9251
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	-0.10	15	0	0	15
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	12.00	-1740	0	0	-1740
		<b>TOTAL</b>		<b>50678</b>	<b>0</b>	<b>0</b>	<b>50678</b>	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	1191.5	172768	172768
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	742.7	-107692	-65.9	-9556	-117247
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	888.9	-128891	-52.2	-7569	-136460
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-2302.9	333921	0	0	333921
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-2325.5	337198	0	0	337198
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-1759.3	255099	0	0	255099
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-3770.5	546723	0	0	546723
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-2753.7	399287	0	0	399287
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	7166.7	-1039172	0	0	-1039172
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	8050.6	-1167337	0	0	-1167337
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-63.5	9208	0	0	9208
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	13410.6	-1944537	0	0	-1944537
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	4246.5	-615743	0	0	-615743
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-3918.9	568241	0	0	568241
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	-84.2	12209	0	0	12209
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	66.6	-9657	0	0	-9657
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	-174.6	25317	0	0	25317
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	8035.3	-1165119	0	0	-1165119
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	2868.4	-415918	0	0	-415918
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	5144.2	-745909	0	0	-745909
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-412.2	59769	0	0	59769
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-398	57710	0	0	57710
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	-157.7	22867	55.5	8048	30914
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	0	0	0	0	0
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	3271.7	-474397	0	0	-474397
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	2729.1	-395720	0	0	-395720
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	361.9	-52476	0	0	-52476
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	411.3	-59639	0	0	-59639
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1040A	6169.9	-894636	0	0	-894636
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1130A	6084.5	-882253	0	0	-882253
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	-2816.3	408364	0	0	408364
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-2096.4	303978	0	0	303978
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	1331.9	-193126	0	0	-193126
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	1325.4	-192183	0	0	-192183
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-2849.9	413236	0	0	413236
		<b>TOTAL</b>		<b>-6731277</b>	<b>163691</b>	<b>0</b>	<b>-6567587</b>	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVArh, w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.