



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति
Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH /9537-47

Date: 10.12.2019

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comm & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comm), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comm), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week 25.11.2019-01.12.2019

दिनांक -25.11.2019 से 01.12.2019 तक के सप्ताह के लिए अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क।

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 06.12.2019.*

उपरोक्त अवधि के लिए देय/प्राप्य विवरण सहित अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क का ब्यौरा संलग्न है। दिनांक-06.12.2019 को ईआरएलडीसी(ERLDC) से विषयवार सप्ताह हेतु डाटा की अंतिम किस्त प्राप्त की गई है।


The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

संघ के सदस्यों से यह अनुरोध किया जाता है कि बिलिंग तिथि के 10 दिनों के भीतर ईआरएलडीसी(ERLDC) द्वारा संचालित रिएक्टिव पूल खाते में भुगतान करें। इन बिलों के भुगतान में 12 दिनों से अधिक की विलंब के स्थिति में, व्यतिक्रामी घटकों को विलंब के प्रत्येक दिन @ 0.04% का साधारण ब्याज का भुगतान करना होगा।

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat. यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

Encl: As above/ संलग्न यथोपरी

भवदीय/Yours faithfully,


(J. Bandyopadhyay)
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 25/11/19 to 01/12/19**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	1734012
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	2296380
SIKKIM	POOL	0
WBSETCL	POOL	4431374

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.


MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 25/11/19 to 01/12/19

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-553.3	80229	0	0	80229
	2	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-1805.5	261798	0	0	261798
	3	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-793.9	115116	0	0	115116
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	219.5	-31828	0	0	-31828
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	239.1	-34670	0	0	-34670
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	287.1	-41630	0	0	-41630
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	2094.9	-303761	0	0	-303761
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-928.7	134662	0	0	134662
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-916.4	132878	0	0	132878
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-1353.9	196316	0	0	196316
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-1921.3	278589	0	0	278589
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	-154.3	22374	0	0	22374
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	-45.2	6554	0	0	6554
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	-5.8	841	0	0	841
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	1630.3	-236394	0	0	-236394
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	0	0	0	0	0
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	0	0	0	0	0
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	0	0	0	0	0
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	89.6	-12992	0	0	-12992
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	93.9	-13616	0	0	-13616
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	0	0	0	0	0
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	2223.5	-322408	0	0	-322408
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	2180	-316100	0	0	-316100
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	2361.3	-342389	0	0	-342389
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	2320.6	-336487	0	0	-336487
	26	132 KV PUSAULI(PG)-KUDRAJ(BSPHCL)	NP6095A	309.4	-44863	0	0	-44863
	27	HV side of 400/220 Patna ICT-1	ER1408A	577.6	-83752	0	0	-83752
	28	HV side of 400/220 Patna ICT-2	ER1407A	-426.1	61785	0	0	61785
	29	HV side of 400/220 Patna ICT-3	ER1231A	-368.5	53433	0	0	53433
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	297.9	-43196	0	0	-43196
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	303.9	-44066	0	0	-44066
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	830.6	-120437	0	0	-120437
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	652.6	-94627	0	0	-94627
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	3325.3	-482169	0	0	-482169
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	3331.8	-483111	0	0	-483111
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1187.9	172246	0	0	172246
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-1185.7	171927	0	0	171927
	38	HV side of 400/220 Darbhanga DMTCL ICT-1	ER1274A	102	-14790	0	0	-14790
	39	HV side of 400/220 Darbhanga DMTCL ICT-2	ER1275A	134.3	-19474	0	0	-19474
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	0	0	0	0	0
	42	220 KV PURNEA(PG)-BEGUSARAJ(BSPTCL)-I	ER1348A	0	0	0	0	0
	43	220 KV PURNEA(PG)-BEGUSARAJ(BSPTCL)-II	ER1376A	0	0	0	0	0
		TOTAL			-1734012		0	-1734012
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-6901.8	1000761	0	0	1000761
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-6634.8	962046	0	0	962046
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-5020.8	728016	0	0	728016
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	183.1	-26550	0	0	-26550
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	600.4	-87058	0	0	-87058
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	3178	-460810	0	0	-460810
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1767.5	256288	0	0	256288
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	875.5	-126948	0	0	-126948
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	1110.9	-161081	0	0	-161081
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	4303.4	-623993	0	0	-623993
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	4194.8	-608246	0	0	-608246
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	0	0	0
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	0	0	0
		TOTAL			852426		0	852426
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2737.2	396894	0	0	396894
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-514	74530	0	0	74530
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC)-BARIPADA(PG)	NP7408A	-3407.3	494059	0	0	494058.5
	8	400 KV TATA JAMSHEDPUR (DVC)-JAMSHEDPUR (PG)	NP7406A	7228.8	-1048176	0	0	-1048176
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	4464.3	-647324	0	0	-647323.5
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-2044.7	296482	0	0	296481.5
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-2188	317260	0	0	317260
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-4006.9	581001	0	0	581000.5
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-3726.9	540401	0	0	540400.5
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-3341.5	484518	0	0	484517.5
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-4054.9	587961	0	0	587960.5
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-7717.5	1119038	0	0	1119037.5
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-7779.9	1128086	0	0	1128085.5
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-10449.2	1515134	0	0	1515134
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	-64	9280	0	0	9280
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-6276	910020	0	0	910020
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	8201.7	-1189247	0	0	-1189246.5
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	8057.9	-1168396	0	0	-1168395.5
		TOTAL			4401519		0	4401519

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	28.3	-4103.5	0	0	-4103.5
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	12.4	-1798	0	0	-1798
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	-1832.3	265683.5	0	0	265683.5
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	-1945.4	282083	0	0	282083
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	-108.3	15703.5	0	0	15703.5
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	-104.6	15167	0	0	15167
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-3668.2	531889	0	0	531889
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-1673.2	242614	0	0	242614
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-1532.4	222198	0	0	222198
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-1518.2	220139	0	0	220139
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	-56.4	8178	0	0	8178
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-5334.1	773444.5	0	0	773444.5
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	18305.4	-2654283	0	0	-2654283
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	20492	-2971340	0	0	-2971340
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	11825.1	-1714639.5	0	0	-1714639.5
	20	400 KV MENDHASAL (GRIDCO)-PANDIABIL (PG)-I	NP5980A	599.9	-86985.5	0	0	-86985.5
	21	400 KV MENDHASAL (GRIDCO)-PANDIABIL (PG)-II	NP7498A	390.5	-56622.5	0	0	-56622.5
	22	400 KV DUBURI (GRIDCO)-PANDIABIL (PG)	NP7915A	-4978.9	721940.5	0	0	721940.5
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabil ICT-1	ER1583A	-284.1	41194.5	0	0	41194.5
	26	HV side of 400/220 Pandiabil ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-6372	923940	0	0	923940
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-6408.4	929218	0	0	929218
		TOTAL		-2296380		0	-2296380	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-150.10	21765	0	0	21765
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-121.50	17618	0	0	17618
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-0.4	-58	-58
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	17.30	-2509	0	0	-2509
		TOTAL		36874		-58	36816	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	940.8	136416	136416
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	1684.9	-244311	0	0	-244311
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	1424.9	-206611	0	0	-206611
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-2523.8	365951	0	0	365951
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-2557	370765	0	0	370765
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-1496.3	216964	0	0	216964
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-3222.9	467321	0	0	467321
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-1835.4	266133	0	0	266133
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	0	0	0	0	0
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	7654.7	-1109932	0	0	-1109932
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-54.7	7932	0	0	7932
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	13534.2	-1962459	0	0	-1962459
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	6245.5	-905598	0	0	-905598
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-3620	524900	0	0	524900
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	-710.8	103066	0	0	103066
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	-90	13050	0	0	13050
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	14.3	-2074	0	0	-2074
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	6417.8	-930581	0	0	-930581
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	3128.8	-453676	0	0	-453676
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	3635	-527075	0	0	-527075
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	146.9	-21301	0	0	-21301
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	58.6	-8497	0	0	-8497
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	-551.6	79982	0	0	79982
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	0	0	0	0	0
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	3892.7	-564442	0	0	-564442
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	3308.1	-479675	0	0	-479675
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	-1174.9	170361	0	0	170361
33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	-1011.2	146624	0	0	146624	
34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1040A	3290.8	-477166	0	0	-477166	
35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1130A	3317	-480965	0	0	-480965	
36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	1808.5	-262233	0	0	-262233	
37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-8652.6	1254627	0	0	1254627	
38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	1264.6	-183367	0	0	-183367	
39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	1158	-167910	0	0	-167910	
40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-2982.1	432405	0	0	432405	
		TOTAL		-4567790		136416	-4431374	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVArh, w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.