



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH /10544-554

Date: 08.01.2020

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comm & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comm), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comm), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week 16.12.2019-22.12.2019

दिनांक -16.12.2019 से 22.12.2019 तक के सप्ताह के लिए अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क।

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 06.01.2020.*

उपरोक्त अवधि के लिए देय/प्राप्य विवरण सहित अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क का ब्यौरा संलग्न है। दिनांक-06.01.2020 को ईआरएलडीसी(ERLDC) से विषयवार सप्ताह हेतु डाटा की अंतिम किस्त प्राप्त की गई है।

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

संघ के सदस्यों से यह अनुरोध किया जाता है कि बिलिंग तिथि के 10 दिनों के भीतर ईआरएलडीसी(ERLDC) द्वारा संचालित रिएक्टिव पूल खाते में भुगतान करें। इन बिलों के भुगतान में 12 दिनों से अधिक की विलंब के स्थिति में, व्यतिक्रामी घटकों को विलंब के प्रत्येक दिन @ 0.04% का साधारण ब्याज का भुगतान करना होगा।

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

Encl: As above/ संलग्न यथोपरी

भवदीय/Yours faithfully,


(J. Bandyopadhyay)
MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 16/12/19 to 22/12/19**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	1310046
JUVNL	POOL	436305
DVC	POOL	0
GRIDCO	POOL	1308103
SIKKIM	POOL	0
WBSETCL	POOL	1951454

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.


MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 16/12/19 to 22/12/19

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-511.3	74139	0	0	74139
	2	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-1437.9	208496	0	0	208496
	3	400 KV SIDE OF BHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-807.4	117073	0	0	117073
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	118.4	-17168	0	0	-17168
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	110.4	-16008	0	0	-16008
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	176.9	-25651	0	0	-25651
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	1678.7	-243412	0	0	-243412
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-732.6	106227	0	0	106227
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-767.3	111259	0	0	111259
	10	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-I	NP8641A	-1219.7	176857	0	0	176857
	11	220 KV KHAGAIL(BSPHCL) - ARAH (PG)-II	NP6060A	-1919.5	278328	0	0	278328
	12	132 KV PUSAULI(PG)-MOHANI(BSPHCL)	NP6094A	-50.7	7352	0	0	7352
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	-68.9	9991	0	0	9991
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	-10.2	1479	0	0	1479
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	1032.2	-149669	0	0	-149669
	16	132 KV KHALGAON(NTPC)-KHALGAON (BSPHCL)	NP5261A	0	0	0	0	0
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-2160.3	313244	0	0	313244
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	27.1	-3930	0	0	-3930
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	-31.3	4539	0	0	4539
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	-34.7	5032	0	0	5032
	21	132 KV KHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	0	0	0	0	0
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	2432.4	-352698	0	0	-352698
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	2391.9	-346826	0	0	-346826
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	2594.6	-376217	0	0	-376217
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	2546.5	-369243	0	0	-369243
	26	132 KV PUSAULI(PG)-KUDRAJ(BSPHCL)	NP6095A	158.1	-22925	0	0	-22925
	27	HV side of 400/220 Patna ICT-1	ER1408A	934.8	-135546	0	0	-135546
	28	HV side of 400/220 Patna ICT-2	ER1407A	37.4	-5423	0	0	-5423
	29	HV side of 400/220 Patna ICT-3	ER1231A	59.2	-8584	0	0	-8584
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	-73.2	10614	0	0	10614
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	-68.2	9889	0	0	9889
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	543.6	-78822	0	0	-78822
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	460.4	-66758	0	0	-66758
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	3351.5	-485968	0	0	-485968
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	3361.6	-487432	0	0	-487432
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1538.9	223141	0	0	223141
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-1562.7	226592	0	0	226592
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	6.1	-885	0	0	-885
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	7.8	-1131	0	0	-1131
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	0	0	0	0	0
	42	220 KV PURNEA(PG)-BEGUSARAJ(BSPTCL)-I	ER1348A	0	0	0	0	0
	43	220 KV PURNEA(PG)-BEGUSARAJ(BSPTCL)-II	ER1376A	0	0	0	0	0
		TOTAL			-1310046		0	-1310046
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-4347.5	630388	0	0	630388
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-3802.6	551377	0	0	551377
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-2362.4	342548	0	0	342548
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	1739.5	-252228	0	0	-252228
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	2123.5	-307908	0	0	-307908
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	3054.6	-442917	0	0	-442917
	7	132 KV KHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1554.7	225432	0	0	225432
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	1268.8	-183976	0	0	-183976
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	1393.8	-202101	0	0	-202101
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	2762.9	-400621	0	0	-400621
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	2730.9	-395981	0	0	-395981
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	-0.8	-116	-116
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	-1.4	-203	-203
		TOTAL			-435986		-319	-436305
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-2516.4	364878	0	0	364878
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-219.6	31842	0	0	31842
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC)-BARIPADA(PG)	NP7408A	-3052.1	442555	0	0	442554.5
	8	400 KV TATA JAMSHEDPUR (DVC)-JAMSHEDPUR (PG)	NP7406A	4249.1	-616120	0	0	-616119.5
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	2650.5	-413323	0	0	-413322.5
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-1955.2	283504	0	0	283504
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-2057.1	298280	0	0	298279.5
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-3836	556220	0	0	556220
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-3384.3	490724	0	0	490723.5
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-675.3	97919	0	0	97918.5
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-1030.8	149466	0	0	149466
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-5181.3	751289	0	0	751288.5
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-4827.4	699973	0	0	699973
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-6540	948300	0	0	948300
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	-28.3	4104	0	0	4103.5
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-3506.4	508428	0	0	508428
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	5815.5	-843248	0	0	-843247.5
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	5697.1	-826080	0	0	-826079.5
		TOTAL			2928710		0	2928710

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	-78.4	11368	0	0	11368
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	-89.5	12977.5	0	0	12977.5
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	-713.1	103399.5	0	0	103399.5
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	-831.5	120567.5	0	0	120567.5
	7	400 KV INDRAVATI (PG) - INDRAVATI (PH)	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	-125.7	18226.5	0	0	18226.5
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	-85.5	12397.5	0	0	12397.5
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-2583.4	374593	0	0	374593
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-726	105270	0	0	105270
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-1008.6	146247	0	0	146247
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-1004	145580	0	0	145580
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	-172.9	25070.5	0	0	25070.5
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-3664.2	531309	0	0	531309
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	7317.8	-1061081	0	0	-1061081
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	14606.8	-2117986	0	0	-2117986
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	6821.8	-989161	0	0	-989161
	20	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-I	NP5980A	714.5	-103602.5	0	0	-103602.5
	21	400 KV MENDHASAL (GRIDCO)-PANDIABILI (PG)-II	NP7498A	508.8	-73776	0	0	-73776
	22	400 KV DUBURI (GRIDCO)-PANDIABILI (PG)	NP7915A	-4628.1	671074.5	0	0	671074.5
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	-470.2	68179	0	0	68179
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-2378.5	344882.5	0	0	344882.5
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-2388.7	346361.5	0	0	346361.5
		TOTAL		-1308103		0	-1308103	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-62.00	8990	0	0	8990
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-124.30	18024	0	0	18024
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-3	-435	-435
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	14.70	-2132	0	0	-2132
		TOTAL		24882		-435	24447	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	299.4	43413	43413
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	1822.5	-264263	0	0	-264263
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	1733.7	-251387	0	0	-251387
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-2230.1	323365	0	0	323365
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-2279.2	330484	0	0	330484
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-1661.1	240860	0	0	240860
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-3236	469220	0	0	469220
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-1434.3	207974	0	0	207974
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	0	0	0	0	0
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	9671.7	-1402397	0	0	-1402397
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-14.9	2161	0	0	2161
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	8246.8	-1195786	0	0	-1195786
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	3489.5	-505978	0	0	-505978
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-1993.9	289116	0	0	289116
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	-945	137025	0	0	137025
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	-143.1	20750	0	0	20750
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	84.2	-12209	0	0	-12209
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	3769.1	-546520	0	0	-546520
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	3281.9	-475876	0	0	-475876
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	-1957.2	283794	0	0	283794
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	39.3	-5699	0	0	-5699
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	26.9	-3901	0	0	-3901
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	-599.9	86986	0	0	86986
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	0	0	0	0	0
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	2854.1	-413845	0	0	-413845
	31	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	2612	-378740	0	0	-378740
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	-846.9	122801	0	0	122801
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	-815.6	118262	0	0	118262
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1040A	399.4	-57913	0	0	-57913
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1130A	499.4	-72413	0	0	-72413
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	1380.7	-200202	0	0	-200202
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-6725.1	975140	0	0	975140
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	195.1	-28290	0	0	-28290
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	339	-49155	0	0	-49155
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-1805.3	261769	0	0	261769
		TOTAL		-1994867		43413	-1951454	

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVArh, w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.