



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH / 11503 - 513.

Date: 06.02.2020

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the week 13.01.2020-19.01.2020

दिनांक -13.01.2020 से 19.01.2020 तक के सप्ताह के लिए अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क।

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected week has been received from ERLDC on 24.01.2020.*

उपरोक्त अवधि के लिए देय/प्राप्य विवरण सहित अस्थायी प्रतिघाती ऊर्जा (VARH) शुल्क का ब्यौरा संलग्न है। दिनांक-24.01.2020 को ईआरएलडीसी(ERLDC) से विषयवार सप्ताह हेतु डाटा की अंतिम किस्त प्राप्त की गई है।


The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

संघ के सदस्यों से यह अनुरोध किया जाता है कि बिलिंग तिथि के 10 दिनों के भीतर ईआरएलडीसी(ERLDC) द्वारा संचालित रिएक्टिव पूल खाते में भुगतान करें। इन बिलों के भुगतान में 12 दिनों से अधिक की विलंब के स्थिति में, व्यतिक्रामी घटकों को विलंब के प्रत्येक दिन @ 0.04% का साधारण ब्याज का भुगतान करना होगा।

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat. यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

Encl: As above/ संलग्न यथोपरी

भवदीय/Yours faithfully,


for MEMBER SECRETARY

Eastern Regional Power Committee:: KOLKATA


**Provisional Reactive Energy (VArH) Charge Statement
for the period 13/01/20 to 19/01/20**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	69687
JUVNL	POOL	0
DVC	POOL	0
GRIDCO	POOL	2733540
SIKKIM	POOL	0
WBSETCL	POOL	3221523

Note:

- Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.


for MEMBER SECRETARY

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 13/01/20 to 19/01/20

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAH H (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAH L (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-938.7	136112	0	0	136112
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-2359.3	342099	0	0	342099
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1342.8	194706	0	0	194706
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	100.5	-14573	0	0	-14573
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	81	-11745	0	0	-11745
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	166.3	-24114	0	0	-24114
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-17.5	2538	0	0	2538
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-794.1	115145	0	0	115145
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-823.9	119466	0	0	119466
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-1383.3	200579	0	0	200579
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-1848.9	268091	0	0	268091
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	59.1	-8570	-0.9	-130.5	-8700
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	13.5	-1958	0	0	-1958
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	42.4	-6148	0	0	-6148
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	1135	-164575	0	0	-164575
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	0	0	0	0	0
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-1925.4	279183	0	0	279183
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	206.9	-30001	0	0	-30001
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	102.8	-14906	0	0	-14906
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	103.4	-14993	0	0	-14993
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	0	0	0	0	0
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	2410.8	-349566	0	0	-349566
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	2377.9	-344796	0	0	-344796
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	2531.8	-367111	0	0	-367111
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	2478.5	-359383	0	0	-359383
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	2.4	-348	0	0	-348
	27	HV side of 400/220 Patna ICT-1	ER1408A	-406	58870	0	0	58870
	28	HV side of 400/220 Patna ICT-2	ER1407A	-1390.2	201579	0	0	201579
	29	HV side of 400/220 Patna ICT-3	ER1231A	-1270.1	184165	0	0	184165
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	86.7	-12572	0	0	-12572
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	91	-13195	0	0	-13195
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-923.7	133937	0	0	133937
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-969.3	140549	0	0	140549
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2741.9	-397576	0	0	-397576
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2973.8	-431201	0	0	-431201
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1187.7	172217	0	0	172217
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-1200.9	174131	0	0	174131
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	750.3	-108794	0	0	-108794
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	805.5	-116798	0	0	-116798
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	0	0	0	0	0
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	0	0	0	0	0
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	0	0	0	0	0
		TOTAL			-69557		-131	-69687
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-6577.7	953767	0	0	953767
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-5901.7	855747	0	0	855747
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-3885.1	563340	0	0	563340
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	2376.3	-344564	0	0	-344564
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	2892.9	-419471	0	0	-419471
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	3318.4	-481168	0	0	-481168
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	-1849.9	268236	0	0	268236
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	1003.6	-145522	0	0	-145522
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	996.2	-144449	0	0	-144449
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	3382.4	-490448	0	0	-490448
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	3288.3	-476804	0	0	-476804
	12	HV side meter of 400/220 Dallonganj ICT-1	ER1197A	0	0	0	0	0
	13	HV side meter of 400/220 Dallonganj ICT-2	ER1317A	-14.8	2146	0	0	2146
		TOTAL			140810		0	140810
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-3176.2	460549	0	0	460549
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-98	14210	0	0	14210
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	-3784	548680	0	0	548680
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	5638.9	-817641	0	0	-817640.5
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	1644.5	-238453	0	0	-238452.5
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	-2632.3	381684	0	0	381683.5
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	-2851.3	413439	0	0	413438.5
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-2597.4	376623	0	0	376623
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-2672.4	387498	0	0	387498
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	178.1	-25825	0	0	-25824.5
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-184.6	26767	0	0	26767
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-6349.4	920663	0	0	920663
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-6455.6	936062	0	0	936062
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-8113	1176385	0	0	1176385
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	455.9	-66106	0	0	-66105.5
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	-5284.1	766195	0	0	766194.5
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	7608.4	-1103218	0	0	-1103218
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	7480.3	-1084644	0	0	-1084643.5
		TOTAL			3072869		0	3072869

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	143	-20735	0	0	-20735
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	123	-17835	0	0	-17835
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	-1307.3	189558.5	0	0	189558.5
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	-1125.6	163212	0	0	163212
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	-148.9	21590.5	0	0	21590.5
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	-141.5	20517.5	0	0	20517.5
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-2773.2	402114	0	0	402114
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3085.4	447383	0	0	447383
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-1637.6	237452	0	0	237452
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-1613.8	234001	0	0	234001
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	-124.7	18081.5	0	0	18081.5
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-4052	587540	0	0	587540
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	17589.3	-2550448.5	0	0	-2550448.5
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	16708.6	-2422747	0	0	-2422747
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	11556.4	-1675678	0	0	-1675678
	20	400 KV MENDHASAL (GRIDCO)-PANDIABIL (PG)-I	NP5980A	985.7	-142926.5	0	0	-142926.5
	21	400 KV MENDHASAL (GRIDCO)-PANDIABIL (PG)-II	NP7498A	775.6	-112462	0	0	-112462
	22	400 KV DUBURI (GRIDCO)-PANDIABIL (PG)	NP7915A	-5512.7	799341.5	0	0	799341.5
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	25	HV side of 400/220 Pandiabili ICT-1	ER1583A	-571.3	82838.5	0	0	82838.5
	26	HV side of 400/220 Pandiabili ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-3462.7	502091.5	0	0	502091.5
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-3472.9	503570.5	0	0	503570.5
		TOTAL			-2733540		0	-2733540
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-64.70	9382	-21.7	-3146.5	6235
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-130.00	18850	3.7	536.5	19387
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-2.6	-377	-377
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	15.40	-2233	0	0	-2233
		TOTAL			25999		-2987	23012
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	-2855.6	-414062	-414062
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	311.4	-45153	-0.4	-58	-45211
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	383.9	-55666	0	0	-55666
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-2237.3	324409	0	0	324409
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-2266.8	328686	0	0	328686
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-1947.2	282344	0	0	282344
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-3773.7	547187	0	0	547187
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-2054.1	297845	0	0	297845
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	0	0	0	0	0
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	10101.2	-1464674	0	0	-1464674
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-116.7	16922	0	0	16922
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	13849.8	-2008221	0	0	-2008221
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	5772.7	-837042	0	0	-837042
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-4950.3	717794	0	0	717794
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	615.7	-89277	0	0	-89277
	18	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	-154.2	22359	0	0	22359
	19	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	80.4	-11658	0	0	-11658
	20	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	6232.3	-903684	0	0	-903684
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	2036.6	-295307	0	0	-295307
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	0	0	0	0	0
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	27.1	-3930	0	0	-3930
	24	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-285.5	41398	0	0	41398
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	1401.8	-203261	0	0	-203261
	29	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	NP7937A	0	0	0	0	0
	30	400 KV SAGARDIGHI (WB)-BERHAMPORE (PG) LINE-I	NP8723A	466	-67570	0	0	-67570
	31	400 KV SAGARDIGHI (WB)-BERHAMPORE (PG) LINE-II	NP8724A	251.4	-36453	0	0	-36453
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	-699.9	101486	0	0	101486
	33	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	-654.9	94961	0	0	94961
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1040A	3041.1	-440960	0	0	-440960
	35	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1130A	2932	-425140	0	0	-425140
	36	400 KV GOKARNA (WB)-FARAKKA (NTPC)-I	ER1133A	295.4	-42833	0	0	-42833
	37	400 KV GOKARNA (WB)-FARAKKA (NTPC)-II	ER1138A	-8518.6	1235197	0	0	1235197
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	1264.4	-183338	0	0	-183338
	39	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	1480	-214600	0	0	-214600
	40	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-3522.6	510777	0	0	510777
		TOTAL			-2807403		-414120	-3221523

Note: 1) Rate of Reactive Energy Charge has been considered @ 14.5 paise/KVARh, w.e.f. 01/04/2019

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.