



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/13052-055

Date: 05.03.2020

1. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
2. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
3. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
4. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Revised Reactive Energy (VARH) Charges of GRIDCO for the period 24.10.2016 to 12.02.2017, 11.09.2017 to 03.12.2017 & 18.12.2017 to 25.02.2018.

The consolidated statement of Revised Reactive Energy (VARH) charges of GRIDCO with payable / receivable particulars for the above mentioned period is enclosed at Annexure-I. *The above revisions are made due to inadvertent error in accounts of GRIDCO for the subjected period.*

The Constituent is requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

Encl: As above/ संलग्न यथोपरी

भवदीय/Yours faithfully,

(J. Bandyopadhyay)
MEMBER SECRETARY

Consolidated Revised Weekly Reactive Accounts of GRIDCO

SI No.	Week Period	Net Reactive Charges(in Rs.) paid by GRIDCO for the same week period	Revised Net Reactive Charges (in Rs.) payable by GRIDCO for the same week period.	Net Reactive Charges(in Rs.) Receivable/Payable by GRIDCO
1	24th to 30th OCTOBER 2016	-652101	0	652101
2	31st OCTOBER 2016 to 6th NOVEMBER 2016	-3214386	-749268	2465118
3	7th TO 13th NOVEMBER 2016	-2700327	-1116596	1583731
4	14th TO 20th NOVEMBER 2016	-1662925	0	1662925
5	21st TO 27th NOVEMBER 2016	-1060605	0	1060605
6	28th NOVEMBER 2016 to 4th DECEMBER 2016	-2175303	-1939184	236119
7	5th to 11th DECEMBER 2016	-2402621	-2465073	-62452
8	12th to 18th DECEMBER 2016	-4697667	-4105608	592059
9	19th to 25th DECEMBER 2016	-3644498	-3121976	522522
10	26th DECEMBER 2016 to 1st JANUARY 2017	-4152005	-2196740	1955265
11	2nd to 8th JANUARY 2017	-4765605	-3561415	1204190
12	9th to 15th JANUARY 2017	-3682484	-2987920	694564
13	16th to 22nd JANUARY 2017	-2535871	-1244490	1291381
14	23rd to 29th JANUARY 2017	-2099812	-1192997	906815
15	30th JANUARY 2017 to 5th FEBRUARY 2017	-1609140	-1423643	185497
16	6th to 12th FEBRUARY 2017	-2269059	-1974544	294515
17	11th to 17th SEPTEMBER 2017	-60980	-76964	-15984
18	18th to 24th SEPTEMBER 2017	-1290141	-1226610	63531
19	25th SEPTEMBER 2017 to 1st OCTOBER 2017	-2281730	-2175674	106056
20	2nd to 8th OCTOBER 2017	-3970958	-3984944	-13986
21	9th to 15th OCTOBER 2017	-1613088	-1501997	111091
22	16th to 22nd OCTOBER 2017	-2832692	-2776316	56376

Sunder Singh 5/2/2017
Member Secretary

Sl No.	Week Period	Net Reactive Charges(in Rs.) paid by GRIDCO for the same week period	Revised Net Reactive Charges (in Rs.) payable by GRIDCO for the same week period.	Net Reactive Charges(in Rs.) Receivable/Payable by GRIDCO
23	23rd to 29th OCTOBER 2017	-2896506	-2900934	-4428
24	30th OCTOBER 2017 to 05th NOVEMBER 2017	-5226431	-5271197	-44766
25	06th to 12th NOVEMBER 2017	-4986293	-4103163	883130
26	13th to 19th NOVEMBER 2017	-7652165	-6234206	1417959
27	20th to 26th NOVEMBER 2017	-6801503	-5106389	1695114
28	27th NOVEMBER 2017 to 3rd DECEMBER 2017	-6872918	-4778258	2094660
29	18th to 24th DECEMBER 2017	-4114679	-4086140	28539
30	25th to 31st DECEMBER 2017	-2629031	-2644907	-15876
31	1st to 7th JANUARY 2018	-2235749	-2439842	-204093
32	8th to 14th JANUARY 2018	-2088369	-2246724	-158355
33	15th to 21st JANUARY 2018	-2030616	-2256228	-225612
34	22nd to 28th JANUARY 2018	0	-193023	-193023
35	29th JANUARY 2018 to 04th FEBRUARY 2018	-1094688	-1384155	-289467
36	05th to 11th FEBRUARY 2018	-188946	-414126	-225180
37	12th to 18th FEBRUARY 2018	-1537610	-1732415	-194805
38	19th to 25th FEBRUARY 2018	-1577556	-1766232	-188676
39	Total	-107307058	-87379898	19927160

(+) means Receivable by GRIDCO from POOL

(-) means Payable by GRIDCO to POOL

Sandeep Singh 5/3/2020
Member Secretary

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 24/10/16 to 30/10/16

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -1	NP5929A	-506.8	65884	0	0	65884
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -2	NP5933A	-487.8	63414	0	0	63414
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -1	NP5989A	223.4	-29042	0	0	-29042
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -2	NP5990A	320	-41600	0	0	-41600
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -1	NP5957A	-2983.3	387829	0	0	387829
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -2	NP5958A	-3086.4	401232	0	0	401232
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	1913.1	-248703	27.6	3588	-245115
	8	132 KV BARIPADA - BARIPADA (GRIDCO)	NP5916A	-819.6	106548	0	0	106548
	9	132 KV BARIPADA - RAIRANGPUR (GRIDCO)	NP5912A	179.1	-23283	0	0	-23283
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	616.4	-80132	0	0	-80132
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4843	629590	0	0	629590
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-1	NP5112A	-4938.4	641992	0	0	641992
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-2	NP5101A	-4885	635050	0	0	635050
	14	220 KV BARIPADA(PG) - BALASORE(GRIDCO)	NP5915A	-1680	218400	0	0	218400
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)	NP5913A	-1487.3	193349	0	0	193349
	16	400 KV MENDHASAL (GRIDCO)- BARIPADA(PG)	NP5983A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-7417.8	964314	0	0	964314
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-2	NP5976A	11147	-1449110	0	0	-1449110
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-1	NP5977A	23276	-3025880	0	0	-3025880
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	3078.2	-400166	0	0	-400166
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-1	NP5980A	700.3	-91039	0	0	-91039
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-2	NP7498A	238.8	-31044	0	0	-31044
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-3514.2	456846	0	0	456846
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	0	0	0	0	0
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	0	0	0	0	0
	26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	-1653.7	214981	0	0	214981
	27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-8928.7	1160731	0	0	1160731
	28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	-140.9	18317	0	0	18317
	29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	-6368.8	827944	0	0	827944
		Total		-12049.4	1566422	27.6	3588	1570010

Note: 1) Rate of Reactive Energy Charge has been considered @ 13 paise/KVArH,w.e.f. 01/04/2016

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 31/10/16 to 06/11/16

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE	
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -1	NP5929A	-521.2	67756	0	0	67756	
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -2	NP5933A	-467.4	60762	0	0	60762	
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -1	NP5989A	432.8	-56264	0	0	-56264	
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -2	NP5990A	615.1	-79963	0	0	-79963	
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -1	NP5957A	-2445.2	317876	0	0	317876	
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -2	NP5958A	-2563.6	333268	0	0	333268	
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	1093.5	-142155	5.4	702	-141453	
	8	132 KV BARIPADA - BARIPADA (GRIDCO)	NP5916A	-1084.1	140933	0	0	140933	
	9	132 KV BARIPADA - RAIRANGPUR (GRIDCO)	NP5912A	157.4	-20462	0	0	-20462	
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	355.6	-46228	0	0	-46228	
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-5093.2	662116	0	0	662116	
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-1	NP5112A	-4388.2	570466	0	0	570466	
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-2	NP5101A	-4343.2	564616	0	0	564616	
	14	220 KV BARIPADA(PG)- BALASORE(GRIDCO)	NP5915A	-1670.6	217178	0	0	217178	
	15	220 KV BARIPADA (PG)- BALASORE (GRIDCO)	NP5913A	-1526.4	198432	0	0	198432	
	16	400 KV MENDHASAL (GRIDCO)- BARIPADA(PG)	NP5983A	0	0	0	0	0	
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-8896.5	1156545	0	0	1156545	
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-2	NP5976A	19229.5	-2499835	0	0	-2499835	
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-1	NP5977A	31227.7	-4059601	0	0	-4059601	
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	7077.5	-920075	0	0	-920075	
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-1	NP5980A	1048.9	-136357	-0.7	-91	-136448	
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-2	NP7498A	324	-42120	-1	-130	-42250	
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-3832.8	498264	0	0	498264	
		24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	0	0	0	0	0
		25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-20.6	2678	0	0	2678
		26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	-1380.6	179478	0	0	179478
		27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-10430	1355900	0	0	1355900
		28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
		29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	-7131.1	927043	0	0	927043
		Total		5767.3	-749749	3.7	481	-749268	

Note: 1) Rate of Reactive Energy Charge has been considered @ 13 paise/KVArH,w.e.f. 01/04/2016

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 07/11/16 to 13/11/16

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -1	NP5929A	-71.9	9347	0	0	9347
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -2	NP5933A	282.4	-36712	0	0	-36712
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -1	NP5989A	749.2	-97396	0	0	-97396
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -2	NP5990A	879	-114270	0	0	-114270
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -1	NP5957A	-2692.8	350064	0	0	350064
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -2	NP5958A	-2791.9	362947	0	0	362947
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	1817.1	-236223	0	0	-236223
	8	132 KV BARIPADA - BARIPADA (GRIDCO)	NP5916A	-1172.6	152438	0	0	152438
	9	132 KV BARIPADA - RAIRANGPUR (GRIDCO)	NP5912A	179.2	-23296	0	0	-23296
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	461.6	-60008	0	0	-60008
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4127.2	536536	0	0	536536
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-1	NP5112A	-4484.4	582972	0	0	582972
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-2	NP5101A	-4433	576290	0	0	576290
	14	220 KV BARIPADA(PG)- BALASORE(GRIDCO)	NP5915A	-1650	214500	0	0	214500
	15	220 KV BARIPADA (PG)- BALASORE (GRIDCO)	NP5913A	-1577.1	205023	0	0	205023
	16	400 KV MENDHASAL (GRIDCO)- BARIPADA(PG)	NP5983A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-9972.7	1296451	0	0	1296451
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-2	NP5976A	18894.6	-2456298	0	0	-2456298
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-1	NP5977A	28605.9	-3718767	0	0	-3718767
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	4662.1	-606073	0	0	-606073
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-1	NP5980A	1895.2	-246376	-13.8	-1794	-248170
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-2	NP7498A	756.7	-98371	-37	-4810	-103181
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-5486.5	713245	0	0	713245
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	557.9	-72527	0	0	-72527
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-469.5	61035	0	0	61035
	26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	-296	38480	0	0	38480
	27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-7216	938080	0	0	938080
	28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
	29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	-4760.9	618917	0	0	618917
		Total		8538.4	-1109992	-50.8	-6604	-1116596

Note: 1) Rate of Reactive Energy Charge has been considered @ 13 paise/KVArH,w.e.f. 01/04/2016

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 14/11/16 to 20/11/16

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE (Rs)
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -1	NP5929A	530.3	-68939	0	0	-68939
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -2	NP5933A	644.4	-83772	0	0	-83772
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -1	NP5989A	1702	-221260	0	0	-221260
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -2	NP5990A	1761.7	-229021	0	0	-229021
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -1	NP5957A	-2121	275730	0	0	275730
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -2	NP5958A	-2213.4	287742	0	0	287742
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	261.6	-34008	167.1	21723	-12285
	8	132 KV BARIPADA - BARIPADA (GRIDCO)	NP5916A	-1220.9	158717	0	0	158717
	9	132 KV BARIPADA - RAIRANGPUR (GRIDCO)	NP5912A	157.1	-20423	0	0	-20423
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-356.6	46358	0	0	46358
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3490.2	453726	0	0	453726
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-1	NP5112A	-3121.6	405808	0	0	405808
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-2	NP5101A	-3085.8	401154	0	0	401154
	14	220 KV BARIPADA(PG)- BALASORE (GRIDCO)	NP5915A	-1590.7	206791	0	0	206791
	15	220 KV BARIPADA (PG)- BALASORE (GRIDCO)	NP5913A	-1524.7	198211	0	0	198211
	16	400 KV MENDHASAL (GRIDCO)- BARIPADA(PG)	NP5983A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-11297.4	1468662	0	0	1468662
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-2	NP5976A	13572.2	-1764386	0	0	-1764386
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-1	NP5977A	24138.3	-3137979	0	0	-3137979
	20	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)	NP7932A	3560	-462800	0	0	-462800
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-1	NP5980A	1555.3	-202189	0	0	-202189
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-2	NP7498A	493.9	-64207	0	0	-64207
	23	400 KV DUBURI (GRIDCO)-PANDIABIL(PG)	NP7915A	-5402.1	702273	0	0	702273
	24	220 KV BOLANGIR(PG)-KATAPALI (GRIDCO)	NP8790A	254.4	-33072	0	0	-33072
	25	220 KV BOLANGIR(PG)-SADEIPALI (GRIDCO)	NP8789A	-167.4	21762	0	0	21762
	26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	-515.9	67067	0	0	67067
	27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-9215.5	1198015	0	0	1198015
	28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
	29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	-6218.7	808431	0	0	808431
		Total		-2910.7	378391	167.1	21723	400114

Note: 1) Rate of Reactive Energy Charge has been considered @ 13 paise/KVArH,w.e.f. 01/04/2016

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 21/11/16 to 27/11/16

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -1	NP5929A	2611	-339430	0	0	-339430
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -2	NP5933A	2518.2	-327366	0	0	-327366
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -1	NP5989A	2183.4	-283842	0	0	-283842
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -2	NP5990A	2144.7	-278811	0	0	-278811
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -1	NP5957A	-3483.4	452842	0	0	452842
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -2	NP5958A	-3588.4	466492	0	0	466492
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	1824.1	-237133	36.7	4771	-232362
	8	132 KV BARIPADA - BARIPADA (GRIDCO)	NP5916A	-1179.3	153309	0	0	153309
	9	132 KV BARIPADA - RAIRANGPUR (GRIDCO)	NP5912A	167.4	-21762	0	0	-21762
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-372.6	48438	0	0	48438
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2527.8	328614	0	0	328614
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-1	NP5112A	-2901	377130	0	0	377130
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-2	NP5101A	-2883.8	374894	0	0	374894
	14	220 KV BARIPADA(PG)- BALASORE(GRIDCO)	NP5915A	-996	129480	0	0	129480
	15	220 KV BARIPADA (PG)- BALASORE (GRIDCO)	NP5913A	-942	122460	0	0	122460
	16	400 KV MENDHASAL (GRIDCO)- BARIPADA(PG)	NP5983A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-9765.9	1269567	0	0	1269567
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-2	NP5976A	9914.9	-1288937	0	0	-1288937
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-1	NP5977A	14024.8	-1823224	1.4	182	-1823042
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	4553.9	-592007	0	0	-592007
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-1	NP5980A	991.2	-128856	0	0	-128856
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-2	NP7498A	236.3	-30719	0	0	-30719
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-4333.1	563303	0	0	563303
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	86.8	-11284	0	0	-11284
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-263.4	34242	0	0	34242
	26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	-204.2	26546	0	0	26546
	27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-6096.9	792597	0	0	792597
	28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
	29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	-3630.2	471926	0	0	471926
		Total		-1911.3	248469	38.1	4953	253422

Note: 1) Rate of Reactive Energy Charge has been considered @ 13 paise/KVArH,w.e.f. 01/04/2016

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 28/11/16 to 04/12/16

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE	
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -1	NP5929A	3867.8	-502814	0	0	-502814	
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -2	NP5933A	2377	-309010	0	0	-309010	
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -1	NP5989A	1918	-249340	0	0	-249340	
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -2	NP5990A	1844.6	-239798	0	0	-239798	
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -1	NP5957A	-1329.1	172783	0	0	172783	
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -2	NP5958A	-1581.7	205621	0	0	205621	
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	577.5	-75075	86.1	11193	-63882	
	8	132 KV BARIPADA - BARIPADA (GRIDCO)	NP5916A	-978.3	127179	0	0	127179	
	9	132 KV BARIPADA - RAIRANGPUR (GRIDCO)	NP5912A	155.9	-20267	0	0	-20267	
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-346.4	45032	0	0	45032	
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2809.8	365274	0	0	365274	
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-1	NP5112A	-3080.2	400426	0	0	400426	
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-2	NP5101A	-3053.8	396994	0	0	396994	
	14	220 KV BARIPADA(PG)- BALASORE(GRIDCO)	NP5915A	-1059.2	137696	0	0	137696	
	15	220 KV BARIPADA (PG)- BALASORE (GRIDCO)	NP5913A	-995.7	129441	0	0	129441	
	16	400 KV MENDHASAL (GRIDCO)- BARIPADA(PG)	NP5983A	0	0	0	0	0	
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-9445.3	1227889	0	0	1227889	
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-2	NP5976A	9137.4	-1187862	0	0	-1187862	
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-1	NP5977A	18659.6	-2425748	0	0	-2425748	
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	5620.4	-730652	0	0	-730652	
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-1	NP5980A	2490.2	-323726	0	0	-323726	
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-2	NP7498A	1239	-161070	0	0	-161070	
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-6388.7	830531	0	0	830531	
		24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	79.9	-10387	0	0	-10387
		25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-132.2	17186	0	0	17186
		26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	-57.2	7436	0	0	7436
		27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-1066.5	138645	0	0	138645
		28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
		29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	-640.3	83239	0	0	83239
		Total		15002.9	-1950377	86.1	11193	-1939184	

Note: 1) Rate of Reactive Energy Charge has been considered @ 13 paise/KVArH,w.e.f. 01/04/2016

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 05/12/16 to 11/12/16

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE	
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -1	NP5929A	3384	-439920	0	0	-439920	
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -2	NP5933A	2981.2	-387556	0	0	-387556	
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -1	NP5989A	1759	-228670	0	0	-228670	
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -2	NP5990A	2096.2	-272506	0	0	-272506	
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -1	NP5957A	-2319.5	301535	0	0	301535	
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -2	NP5958A	-2463.4	320242	0	0	320242	
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	789.9	-102687	50.1	6513	-96174	
	8	132 KV BARIPADA - BARIPADA (GRIDCO)	NP5916A	-1156.8	150384	0	0	150384	
	9	132 KV BARIPADA - RAIRANGPUR (GRIDCO)	NP5912A	104.2	-13546	0	0	-13546	
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-415	53950	0	0	53950	
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3297.2	428636	0	0	428636	
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-1	NP5112A	-2684.2	348946	0	0	348946	
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-2	NP5101A	-2663.4	346242	0	0	346242	
	14	220 KV BARIPADA(PG)- BALASORE(GRIDCO)	NP5915A	-1039.8	135174	0	0	135174	
	15	220 KV BARIPADA (PG)- BALASORE (GRIDCO)	NP5913A	-979.1	127283	0	0	127283	
	16	400 KV MENDHASAL (GRIDCO)- BARIPADA(PG)	NP5983A	0	0	0	0	0	
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-9915.9	1289067	0	0	1289067	
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-2	NP5976A	11507.8	-1496014	0	0	-1496014	
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-1	NP5977A	18943.4	-2462642	0	0	-2462642	
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	6609	-859170	0	0	-859170	
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-1	NP5980A	3110.9	-404417	0	0	-404417	
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-2	NP7498A	1696.1	-220493	0	0	-220493	
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-7515.6	977028	0	0	977028	
		24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	1515.8	-197054	0	0	-197054
		25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-100.6	13078	0	0	13078
		26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	-10.3	1339	0	0	1339
		27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-808.3	105079	0	0	105079
		28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
		29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	-116.2	15106	0	0	15106
		Total		19012.2	-2471586	50.1	6513	-2465073	

Note: 1) Rate of Reactive Energy Charge has been considered @ 13 paise/KVArH,w.e.f. 01/04/2016

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 12/12/16 to 18/12/16

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE	
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -1	NP5929A	2297	-298610	0	0	-298610	
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -2	NP5933A	2192.2	-284986	0	0	-284986	
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -1	NP5989A	2106	-273780	0	0	-273780	
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -2	NP5990A	2385	-310050	0	0	-310050	
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -1	NP5957A	-1926.9	250497	-3.8	-494	250003	
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -2	NP5958A	-2266.8	294684	0	0	294684	
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	1821.5	-236795	19.2	2496	-234299	
	8	132 KV BARIPADA - BARIPADA (GRIDCO)	NP5916A	-1191.1	154843	0	0	154843	
	9	132 KV BARIPADA - RAIRANGPUR (GRIDCO)	NP5912A	125.1	-16263	0	0	-16263	
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-686.4	89232	0	0	89232	
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2276	295880	0	0	295880	
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-1	NP5112A	-2453	318890	0	0	318890	
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-2	NP5101A	-2426.4	315432	0	0	315432	
	14	220 KV BARIPADA(PG)- BALASORE(GRIDCO)	NP5915A	-1017	132210	0	0	132210	
	15	220 KV BARIPADA (PG)- BALASORE (GRIDCO)	NP5913A	-953.9	124007	0	0	124007	
	16	400 KV MENDHASAL (GRIDCO)- BARIPADA(PG)	NP5983A	0	0	0	0	0	
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-11041.7	1435421	0	0	1435421	
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-2	NP5976A	15969.4	-2076022	0	0	-2076022	
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-1	NP5977A	29930.6	-3890978	0	0	-3890978	
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	8354.1	-1086033	0	0	-1086033	
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-1	NP5980A	3524.6	-458198	0	0	-458198	
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-2	NP7498A	1947.5	-253175	0	0	-253175	
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-8262.5	1074125	0	0	1074125	
		24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	312.4	-40612	0	0	-40612
		25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-434.1	56433	0	0	56433
		26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	-24.4	3172	0	0	3172
		27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-3008.3	391079	0	0	391079
		28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
		29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	-1399.9	181987	0	0	181987
		Total		31597.0	-4107610	15.4	2002	-4105608	

Note: 1) Rate of Reactive Energy Charge has been considered @ 13 paise/KVArH,w.e.f. 01/04/2016

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 19/12/16 to 25/12/16

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE	
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -1	NP5929A	2783	-361790	0	0	-361790	
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -2	NP5933A	2657.4	-345462	0	0	-345462	
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -1	NP5989A	1580.4	-205452	0	0	-205452	
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -2	NP5990A	1967.9	-255827	0	0	-255827	
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -1	NP5957A	-2423.8	315094	0	0	315094	
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -2	NP5958A	-2529.7	328861	0	0	328861	
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	1150.9	-149617	50.4	6552	-143065	
	8	132 KV BARIPADA - BARIPADA (GRIDCO)	NP5916A	-1155.6	150228	0	0	150228	
	9	132 KV BARIPADA - RAIRANGPUR (GRIDCO)	NP5912A	63.8	-8294	0	0	-8294	
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-281.4	36582	0	0	36582	
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2592.6	337038	0	0	337038	
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-1	NP5112A	-2983	387790	0	0	387790	
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-2	NP5101A	-2946.2	383006	0	0	383006	
	14	220 KV BARIPADA(PG)- BALASORE(GRIDCO)	NP5915A	-995.9	129467	0	0	129467	
	15	220 KV BARIPADA (PG)- BALASORE (GRIDCO)	NP5913A	-941.2	122356	0	0	122356	
	16	400 KV MENDHASAL (GRIDCO)- BARIPADA(PG)	NP5983A	0	0	0	0	0	
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-10988.5	1428505	0	0	1428505	
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-2	NP5976A	17069.8	-2219074	0	0	-2219074	
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-1	NP5977A	26530.5	-3448965	0	0	-3448965	
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	5121.3	-665769	0	0	-665769	
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-1	NP5980A	2913.8	-378794	0	0	-378794	
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-2	NP7498A	1574.2	-204646	0	0	-204646	
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-7490.1	973713	0	0	973713	
		24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	381.2	-49556	0	0	-49556
		25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-513.7	66781	0	0	66781
		26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	-3.1	403	0	0	403
		27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-3231.4	420082	0	0	420082
		28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
		29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	-652.4	84812	0	0	84812
		Total		24065.6	-3128528	50.4	6552	-3121976	

Note: 1) Rate of Reactive Energy Charge has been considered @ 13 paise/KVArH,w.e.f. 01/04/2016

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 26/12/16 to 01/01/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE	
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -1	NP5929A	2526.8	-328484	0	0	-328484	
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -2	NP5933A	2412.6	-313638	0	0	-313638	
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -1	NP5989A	1027.7	-133601	0	0	-133601	
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -2	NP5990A	1642.1	-213473	0	0	-213473	
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -1	NP5957A	-2475.1	321763	0	0	321763	
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -2	NP5958A	-2294.2	298246	0	0	298246	
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	479.3	-62309	0	0	-62309	
	8	132 KV BARIPADA - BARIPADA (GRIDCO)	NP5916A	-1346.1	174993	0	0	174993	
	9	132 KV BARIPADA - RAIRANGPUR (GRIDCO)	NP5912A	94.6	-12298	0	0	-12298	
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-512.6	66638	0	0	66638	
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2863.6	372268	0	0	372268	
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-1	NP5112A	-2905.2	377676	0	0	377676	
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-2	NP5101A	-2871.4	373282	0	0	373282	
	14	220 KV BARIPADA(PG)- BALASORE(GRIDCO)	NP5915A	-1151.7	149721	0	0	149721	
	15	220 KV BARIPADA (PG)- BALASORE (GRIDCO)	NP5913A	-1087.8	141414	0	0	141414	
	16	400 KV MENDHASAL (GRIDCO)- BARIPADA(PG)	NP5983A	0	0	0	0	0	
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-10710.2	1392326	0	0	1392326	
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-2	NP5976A	17512.6	-2276638	0	0	-2276638	
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-1	NP5977A	26137.1	-3397823	0	0	-3397823	
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	11233	-1460290	0	0	-1460290	
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-1	NP5980A	2933	-381290	0	0	-381290	
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-2	NP7498A	1422.9	-184977	0	0	-184977	
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-7265.3	944489	0	0	944489	
		24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	637.5	-82875	0	0	-82875
		25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-1331.1	173043	0	0	173043
		26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	-376.8	48984	0	0	48984
		27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-8024.5	1043185	0	0	1043185
		28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
		29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	-5945.6	772928	0	0	772928
		Total		16898.0	-2196740	0.0	0	-2196740	

Note: 1) Rate of Reactive Energy Charge has been considered @ 13 paise/KVArH,w.e.f. 01/04/2016

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 02/01/17 to 08/01/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE	
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -1	NP5929A	2515.4	-327002	0	0	-327002	
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -2	NP5933A	2402.6	-312338	0	0	-312338	
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -1	NP5989A	1391.9	-180947	0	0	-180947	
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -2	NP5990A	1643.9	-213707	0	0	-213707	
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -1	NP5957A	-1966.6	255658	0	0	255658	
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -2	NP5958A	-2015.2	261976	0	0	261976	
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	254.6	-33098	141.6	18408	-14690	
	8	132 KV BARIPADA - BARIPADA (GRIDCO)	NP5916A	-1314.6	170898	0	0	170898	
	9	132 KV BARIPADA - RAIRANGPUR (GRIDCO)	NP5912A	212.3	-27599	0	0	-27599	
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1060.4	137852	0	0	137852	
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2500.4	325052	0	0	325052	
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-1	NP5112A	-2571.8	334334	0	0	334334	
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-2	NP5101A	-2540.6	330278	0	0	330278	
	14	220 KV BARIPADA(PG)- BALASORE(GRIDCO)	NP5915A	-1112.8	144664	0	0	144664	
	15	220 KV BARIPADA (PG)- BALASORE (GRIDCO)	NP5913A	-1056.9	137397	0	0	137397	
	16	400 KV MENDHASAL (GRIDCO)- BARIPADA(PG)	NP5983A	0	0	0	0	0	
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-10984.3	1427959	0	0	1427959	
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-2	NP5976A	18092.7	-2352051	0	0	-2352051	
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-1	NP5977A	27159.6	-3530748	0	0	-3530748	
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	12741.8	-1656434	0	0	-1656434	
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-1	NP5980A	2929.2	-380796	0	0	-380796	
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-2	NP7498A	1275.2	-165776	0	0	-165776	
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-6695.5	870415	0	0	870415	
		24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	922.6	-119938	0	0	-119938
		25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-1578.3	205179	0	0	205179
		26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	-453.3	58929	0	0	58929
		27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-4497.1	584623	0	0	584623
		28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
		29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	-3656.9	475397	0	0	475397
		Total		27537.1	-3579823	141.6	18408	-3561415	

Note: 1) Rate of Reactive Energy Charge has been considered @ 13 paise/KVArH,w.e.f. 01/04/2016

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 09/01/17 to 15/01/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -1	NP5929A	3040.8	-395304	0	0	-395304
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -2	NP5933A	2906.6	-377858	0	0	-377858
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -1	NP5989A	1174.2	-152646	0	0	-152646
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -2	NP5990A	1386.7	-180271	0	0	-180271
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -1	NP5957A	-2153.7	279981	0	0	279981
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -2	NP5958A	-2258.3	293579	0	0	293579
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	558.8	-72644	18	2340	-70304
	8	132 KV BARIPADA - BARIPADA (GRIDCO)	NP5916A	-1092.7	142051	0	0	142051
	9	132 KV BARIPADA - RAIRANGPUR (GRIDCO)	NP5912A	246.5	-32045	0	0	-32045
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-161.8	21034	0	0	21034
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3295.2	428376	0	0	428376
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-1	NP5112A	-3273.2	425516	0	0	425516
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-2	NP5101A	-3226.8	419484	-0.2	-26	419458
	14	220 KV BARIPADA(PG)- BALASORE(GRIDCO)	NP5915A	-1456	189280	0	0	189280
	15	220 KV BARIPADA (PG)- BALASORE (GRIDCO)	NP5913A	-1395	181350	0	0	181350
	16	400 KV MENDHASAL (GRIDCO)- BARIPADA(PG)	NP5983A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-10289.7	1337661	0	0	1337661
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-2	NP5976A	17335.7	-2253641	0	0	-2253641
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-1	NP5977A	27096.3	-3522519	0	0	-3522519
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	6119.2	-795496	0	0	-795496
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-1	NP5980A	2223.3	-289029	0	0	-289029
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-2	NP7498A	1081.9	-140647	0	0	-140647
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-6222.6	808938	0	0	808938
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	619	-80470	-0.6	-78	-80548
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-675.3	87789	-3.5	-455	87334
	26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	-97	12610	0	0	12610
	27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-3385.6	440128	0	0	440128
	28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
	29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	-1808.4	235092	0	0	235092
		Total		22997.7	-2989701	13.7	1781	-2987920

Note: 1) Rate of Reactive Energy Charge has been considered @ 13 paise/KVArH,w.e.f. 01/04/2016

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 16/01/17 to 22/01/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -1	NP5929A	3467.2	-450736	0	0	-450736
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -2	NP5933A	3334.6	-433498	0	0	-433498
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -1	NP5989A	281.5	-36595	0	0	-36595
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -2	NP5990A	391.2	-50856	0	0	-50856
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -1	NP5957A	-3117.7	405301	0	0	405301
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -2	NP5958A	-3249.6	422448	0	0	422448
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	335.1	-43563	45.3	5889	-37674
	8	132 KV BARIPADA - BARIPADA (GRIDCO)	NP5916A	-937.7	121901	0	0	121901
	9	132 KV BARIPADA - RAIRANGPUR (GRIDCO)	NP5912A	317.7	-41301	0	0	-41301
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-117.8	15314	0	0	15314
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3740.4	486252	0	0	486252
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-1	NP5112A	-3676.2	477906	0	0	477906
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-2	NP5101A	-3780	491400	0	0	491400
	14	220 KV BARIPADA(PG)- BALASORE(GRIDCO)	NP5915A	-1450.7	188591	0	0	188591
	15	220 KV BARIPADA (PG)- BALASORE (GRIDCO)	NP5913A	-1170.6	152178	0	0	152178
	16	400 KV MENDHASAL (GRIDCO)- BARIPADA(PG)	NP5983A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-9422.1	1224873	0	0	1224873
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-2	NP5976A	14755.1	-1918163	0	0	-1918163
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-1	NP5977A	25446.3	-3308019	0	0	-3308019
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	4337.4	-563862	0	0	-563862
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-1	NP5980A	2035.6	-264628	0	0	-264628
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-2	NP7498A	1103.6	-143468	0	0	-143468
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-5590.5	726765	0	0	726765
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	688.1	-89453	-0.3	-39	-89492
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-1079.6	140348	-1.2	-156	140192
	26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	-122.2	15886	0	0	15886
	27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-5634.1	732433	0	0	732433
	28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
	29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	-3787.4	492362	0	0	492362
		Total		9616.8	-1250184	43.8	5694	-1244490

Note: 1) Rate of Reactive Energy Charge has been considered @ 13 paise/KVArH,w.e.f. 01/04/2016

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 23/01/17 to 29/01/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -1	NP5929A	2516.4	-327132	0	0	-327132
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -2	NP5933A	2506	-325780	0	0	-325780
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -1	NP5989A	333.9	-43407	0	0	-43407
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -2	NP5990A	299.8	-38974	0	0	-38974
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -1	NP5957A	-3411.5	443495	0	0	443495
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -2	NP5958A	-3561.5	462995	0	0	462995
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	21.6	-2808	15.9	2067	-741
	8	132 KV BARIPADA - BARIPADA (GRIDCO)	NP5916A	-866	112580	0	0	112580
	9	132 KV BARIPADA - RAIRANGPUR (GRIDCO)	NP5912A	266.3	-34619	0	0	-34619
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-88	11440	0	0	11440
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3558	462540	0	0	462540
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-1	NP5112A	-3715.6	483028	0	0	483028
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-2	NP5101A	-3665.4	476502	0	0	476502
	14	220 KV BARIPADA(PG)- BALASORE(GRIDCO)	NP5915A	-1684.2	218946	0	0	218946
	15	220 KV BARIPADA (PG)- BALASORE (GRIDCO)	NP5913A	-1779.6	231348	0	0	231348
	16	400 KV MENDHASAL (GRIDCO)- BARIPADA(PG)	NP5983A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-8974.9	1166737	0	0	1166737
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-2	NP5976A	16428	-2135640	0	0	-2135640
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-1	NP5977A	22785.8	-2962154	0	0	-2962154
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	4233.7	-550381	0	0	-550381
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-1	NP5980A	2433.4	-316342	0	0	-316342
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-2	NP7498A	1241.3	-161369	-2.9	-377	-161746
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-5596.1	727493	0	0	727493
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	175.4	-22802	0	0	-22802
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-431.8	56134	0	0	56134
	26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	-110.1	14313	0	0	14313
	27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-3939.2	512096	0	0	512096
	28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
	29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	-2669.8	347074	0	0	347074
		Total		9189.9	-1194687	13.0	1690	-1192997

Note: 1) Rate of Reactive Energy Charge has been considered @ 13 paise/KVArH,w.e.f. 01/04/2016

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 30/01/17 to 05/02/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE	
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -1	NP5929A	2666.8	-346684	0	0	-346684	
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -2	NP5933A	2542.4	-330512	0	0	-330512	
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -1	NP5989A	152.1	-19773	0	0	-19773	
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -2	NP5990A	189.8	-24674	0	0	-24674	
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -1	NP5957A	-2686.6	349258	0	0	349258	
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -2	NP5958A	-2831.7	368121	0	0	368121	
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	632.8	-82264	0	0	-82264	
	8	132 KV BARIPADA - BARIPADA (GRIDCO)	NP5916A	-965.9	125567	0	0	125567	
	9	132 KV BARIPADA - RAIRANGPUR (GRIDCO)	NP5912A	239.5	-31135	0	0	-31135	
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-387.4	50362	0	0	50362	
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3593.6	467168	0	0	467168	
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-1	NP5112A	-3715.8	483054	0	0	483054	
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-2	NP5101A	-3667	476710	0	0	476710	
	14	220 KV BARIPADA(PG)- BALASORE(GRIDCO)	NP5915A	-1809.3	235209	0	0	235209	
	15	220 KV BARIPADA (PG)- BALASORE (GRIDCO)	NP5913A	-1738.5	226005	0	0	226005	
	16	400 KV MENDHASAL (GRIDCO)- BARIPADA(PG)	NP5983A	0	0	0	0	0	
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-7501	975130	0	0	975130	
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-2	NP5976A	11980.3	-1557439	0	0	-1557439	
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-1	NP5977A	21392.8	-2781064	0	0	-2781064	
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	4085.5	-531115	0	0	-531115	
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-1	NP5980A	2005	-260650	0	0	-260650	
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-2	NP7498A	910	-118300	0	0	-118300	
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-5522.2	717886	0	0	717886	
		24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	10.2	-1326	0	0	-1326
		25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-110.9	14417	0	0	14417
		26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	-0.4	52	0	0	52
		27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-1121.5	145795	0	0	145795
		28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
		29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	-204.3	26559	0	0	26559
		Total		10951.1	-1423643	0.0	0	-1423643	

Note: 1) Rate of Reactive Energy Charge has been considered @ 13 paise/KVArH,w.e.f. 01/04/2016

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 06/02/17 to 12/02/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE	
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -1	NP5929A	2152.2	-279786	0	0	-279786	
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -2	NP5933A	1781.4	-231582	0	0	-231582	
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -1	NP5989A	7.2	-936	0	0	-936	
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -2	NP5990A	49.8	-6474	0	0	-6474	
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -1	NP5957A	-4217.8	548314	0	0	548314	
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -2	NP5958A	-4404.3	572559	0	0	572559	
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	1969	-255970	0	0	-255970	
	8	132 KV BARIPADA - BARIPADA (GRIDCO)	NP5916A	-969.2	125996	0	0	125996	
	9	132 KV BARIPADA - RAIRANGPUR (GRIDCO)	NP5912A	190.4	-24752	0	0	-24752	
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-889	115570	0	0	115570	
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3634.4	472472	0	0	472472	
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-1	NP5112A	-3652.8	474864	0	0	474864	
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-2	NP5101A	-3604.8	468624	0	0	468624	
	14	220 KV BARIPADA(PG)- BALASORE(GRIDCO)	NP5915A	-1898.7	246831	0	0	246831	
	15	220 KV BARIPADA (PG)- BALASORE (GRIDCO)	NP5913A	-1817.4	236262	0	0	236262	
	16	400 KV MENDHASAL (GRIDCO)- BARIPADA(PG)	NP5983A	0	0	0	0	0	
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-8342.9	1084577	0	0	1084577	
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-2	NP5976A	18092.7	-2352051	0	0	-2352051	
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-1	NP5977A	23408.8	-3043144	0	0	-3043144	
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	5847.2	-760136	0	0	-760136	
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-1	NP5980A	1821.5	-236795	0	0	-236795	
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-2	NP7498A	736.4	-95732	0	0	-95732	
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-5171.3	672269	-0.3	-39	672230	
		24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	120.5	-15665	0	0	-15665
		25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	113.8	-14794	0	0	-14794
		26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	-20.4	2652	0	0	2652
		27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-1833.7	238381	0	0	238381
		28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0.0	0	0	0	0
		29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	-645.7	83941	0	0	83941
		Total		15188.5	-1974505	-0.3	-39	-1974544	

Note: 1) Rate of Reactive Energy Charge has been considered @ 13 paise/KVArH,w.e.f. 01/04/2016

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 11/09/17 to 17/09/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	304.2	-41067	0	0	-41067
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	ER1028A	118.4	-15984	0	0	-15984
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	-439	59265	0	0	59265
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	-814.3	109931	0	0	109930.5
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	1903.8	-257013	0	0	-257013
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	1924.8	-259848	0	0	-259848
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	122.5	-16538	0	0	-16537.5
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-487.9	65867	0	0	65866.5
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	76	-10260	0	0	-10260
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1511.8	204093	0	0	204093
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-7394.4	998244	0	0	998244
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-I	NP5112A	-4424.8	597348	0	0	597348
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-II	NP5101A	-4376	590760	0	0	590760
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-2194.8	296298	0	0	296298
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-2485.6	335556	0	0	335556
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-7002.2	945297	0	0	945297
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	NP5976A	12979.7	-1752260	0	0	-1752259.5
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	NP5977A	11357.8	-1533303	0	0	-1533303
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	4673.5	-630923	0	0	-630922.5
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-134.7	18185	0	0	18184.5
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-147.1	19859	0	0	19858.5
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-2184	294840	0	0	294840
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	0	0	0	0	0
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	0	0	0	0	0
	26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	-35.9	4847	0	0	4846.5
	27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-267.6	36126	0	0	36126
	28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	-35.9	4847	0	0	4846.5
	29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	0	0	0	0	0
	30	220 KV PANDIABIL(PG)-ATRII(GRIDCO)-1	ER1018A	570.2	-76977	0	0	-76977
	31	220 KV PANDIABIL(PG)-SAMANGARA(GRIDCO)-1	NP8051A	475.2	-64152	0	0	-64152
		Total		570.1	-76964	0.0	0	-76964

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 18/09/17 to 24/09/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	-485.6	65556	0	0	65556
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	ER1028A	-470.6	63531	0	0	63531
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	-944.1	127454	0	0	127454
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	-680.1	91814	0	0	91814
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	4509.9	-608837	0	0	-608837
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	4500.4	-607554	0	0	-607554
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	65.4	-8829	0.7	94.5	-8735
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-1063.2	143532	0	0	143532
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	142.9	-19292	0	0	-19292
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-2056.6	277641	0	0	277641
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-6491	876285	0	0	876285
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-I	NP5112A	-4495.6	606906	0	0	606906
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-II	NP5101A	-4442	599670	0	0	599670
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-2037.6	275076	0	0	275076
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-1995.2	269352	0	0	269352
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-9707.6	1310526	0	0	1310526
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	NP5976A	17179.6	-2319246	0	0	-2319246
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	NP5977A	16065	-2168775	0	0	-2168775
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	4224.8	-570348	0	0	-570348
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-791	106785	0	0	106785
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-837.5	113063	0	0	113063
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-3033.8	409563	0	0	409563
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	134.9	-18212	0	0	-18212
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-24.6	3321	-8	-1080	2241
	26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	0	0	0	0	0
	27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	0	0	0	0	0
	28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	-550.1	74264	0	0	74264
	29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	0	0	0	0	0
	30	220 KV PANDIABIL(PG)-ATRI(GRIDCO)-1	ER1018A	1209.1	-163229	0	0	-163229
	31	220 KV PANDIABIL(PG)-SAMANGARA(GRIDCO)-1	NP8051A	1167.7	-157640	0	0	-157640
	32	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	-14.8	1998	0	0	1998
		Total		9078.7	-1225625	-7.3	-986	-1226610

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 25/09/17 to 01/10/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	-939.6	126846	0	0	126846
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	ER1028A	-926.4	125064	0	0	125064
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	-785.5	106043	0	0	106043
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	-547	73845	0	0	73845
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	4677.3	-631436	0	0	-631436
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	4691.4	-633339	0	0	-633339
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	-43.6	5886	0	0	5886
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-1461.6	197316	0	0	197316
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	106.1	-14324	0	0	-14324
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-2190.6	295731	0	0	295731
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-5828.2	786807	0	0	786807
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-I	NP5112A	-4552.6	614601	0	0	614601
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-II	NP5101A	-4501.8	607743	0	0	607743
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-2360.3	318641	0	0	318641
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-2252.2	304047	0	0	304047
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-11330.7	1529645	0	0	1529645
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	NP5976A	21926.5	-2960078	0	0	-2960078
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	NP5977A	18211.1	-2458499	0	0	-2458499
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	7397.1	-998609	0	0	-998609
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-1224.4	165294	0	0	165294
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-1419.3	191606	0	0	191606
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-3902.1	526784	0	0	526784
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	49.1	-6629	0	0	-6629
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-19.5	2633	0	0	2633
	26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	0	0	0	0	0
	27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	0	0	0	0	0
	28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
	29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	0	0	0	0	0
	30	220 KV PANDIABIL(PG)-ATR(I)(GRIDCO)-1	ER1018A	1827.1	-246659	0	0	-246659
	31	220 KV PANDIABIL(PG)-SAMANGARA(GRIDCO)-1	NP8051A	1554.8	-209898	0	0	-209898
	32	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	-179.8	24273	0	0	24273
	33	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	140.8	-19008	0	0	-19008
		Total		16116.1	-2175674	0.0	0	-2175674

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 02/10/17 to 08/10/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE (Rs)
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	3.8	-513	0	0	-513
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	ER1028A	-8.2	1107	0	0	1107
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	-565.7	76370	0	0	76370
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	-473.4	63909	0	0	63909
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	4275.1	-577139	0	0	-577139
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	4308.2	-581607	0	0	-581607
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	7.9	-1067	0	0	-1067
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-1631.9	220307	0	0	220307
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	236.1	-31874	0	0	-31874
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-2259	304965	0	0	304965
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-5817	785295	0	0	785295
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-I	NP5112A	-4396.2	593487	0	0	593487
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-II	NP5101A	-4351.8	587493	0	0	587493
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-1568.9	211802	0	0	211802
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-1514.8	204498	0	0	204498
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-11114.2	1500417	0	0	1500417
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	NP5976A	25951.2	-3503412	0	0	-3503412
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	NP5977A	21324.2	-2878767	0	0	-2878767
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	11505.8	-1553283	0	0	-1553283
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-1752.7	236615	0	0	236615
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-1912.3	258161	0	0	258161
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-4736.3	639401	0	0	639401
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	317.6	-42876	0	0	-42876
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-24.2	3267	0	0	3267
	26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	0	0	0	0	0
	27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-206.7	27905	0	0	27905
	28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
	29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	-2.2	297	19.9	2686.5	2984
	30	220 KV PANDIABIL(PG)-ATRI(GRIDCO)-1	ER1018A	2160.2	-291627	0	0	-291627
	31	220 KV PANDIABIL(PG)-SAMANGARA(GRIDCO)-1	NP8051A	1959.7	-264560	0	0	-264560
	32	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	-288.1	38894	0	0	38894
	33	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	111.8	-15093	0	0	-15093
		Total		29538.0	-3987630	19.9	2687	-3984944

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 09/10/17 to 15/10/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE (Rs)
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	-1031.2	139212	0	0	139212
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	ER1028A	-1012.4	136674	0	0	136674
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	-1091.4	147339	0	0	147339
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	-1167.9	157667	0	0	157667
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	4037.8	-545103	0	0	-545103
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	4040.8	-545508	0	0	-545508
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	-2.1	284	0	0	284
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-1519.2	205092	0	0	205092
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	27.7	-3740	0	0	-3740
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-2408.6	325161	0	0	325161
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-7021.6	947916	0	0	947916
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-4550.4	614304	0	0	614304
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-4503.4	607959	0	0	607959
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-2389.7	322610	0	0	322610
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-2120.7	286295	0	0	286295
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-11059.5	1493033	0	0	1493033
	18	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-II	NP5976A	21662.8	-2924478	0	0	-2924478
	19	400 KV MMUNDALI (GRIDCO)-ANGUL(PG)-I	NP5977A	16354.6	-2207871	0	0	-2207871
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	6901.6	-931716	0	0	-931716
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-688.7	92975	0	0	92975
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-814.3	109931	0	0	109931
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-2981.4	402489	0	0	402489
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	0.3	-41	0	0	-41
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	0	0	0	0	0
	26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	0	0	0	0	0
	27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	0	0	0	0	0
	28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
	29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	0	0	0	0	0
	30	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-1	ER1018A	1123.5	-151673	0	0	-151673
	31	220 KV PANDIABILI(PG)-SAMANGARA(GRIDCO)-1	NP8051A	1226.2	-165537	0	0	-165537
	32	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	-76.4	10314	0	0	10314
	33	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	189.5	-25583	0	0	-25583
		Total		11125.9	-1501997	0.0	0	-1501997

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 16/10/17 to 22/10/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE (Rs)
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	-417.4	56349	0	0	56349
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	ER1028A	-417.6	56376	0	0	56376
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	-1193	161055	0	0	161055
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	-1186.8	160218	0	0	160218
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	2157.3	-291236	0	0	-291236
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	2081.8	-281043	0	0	-281043
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	111.4	-15039	0	0	-15039
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-1261.8	170343	0	0	170343
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	403.9	-54527	0	0	-54527
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1723.8	232713	0	0	232713
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-7965.6	1075356	0	0	1075356
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-3743.4	505359	0	0	505359
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-3705.2	500202	0	0	500202
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-1410.3	190391	0	0	190391
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-1354.3	182831	0	0	182831
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-10308.9	1391702	0	0	1391702
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	NP5976A	27270.2	-3681477	0	0	-3681477
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	NP5977A	18345.1	-2476589	0	0	-2476589
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	7971.6	-1076166	0	0	-1076166
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-1392.1	187934	0	0	187934
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-1598.8	215838	0	0	215838
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-3331.3	449726	0	0	449726
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	0.3	-41	0	0	-41
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	0	0	0	0	0
	26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	0	0	0	0	0
	27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-11.8	1593	0	0	1593
	28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
	29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	0	0	0	0	0
	30	220 KV PANDIABIL(PG)-ATRI(GRIDCO)-1	ER1018A	1214.2	-163917	0	0	-163917
	31	220 KV PANDIABIL(PG)-SAMANGARA(GRIDCO)-1	NP8051A	1565.9	-211397	0	0	-211397
	32	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	122.8	-16578	0	0	-16578
	33	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	342.9	-46292	0	0	-46292
		Total		20565.3	-2776316	0.0	0	-2776316

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 23/10/17 to 29/10/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	58.4	-7884	0	0	-7884
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	ER1028A	32.8	-4428	0	0	-4428
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	-70.1	9464	0	0	9464
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	-34.3	4631	0	0	4631
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	759.6	-102546	0	0	-102546
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	593.5	-80123	0	0	-80123
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	4902.8	-661878	0	0	-661878
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-1479.3	199706	0	0	199706
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	175.1	-23639	0	0	-23639
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1581	213435	0	0	213435
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-6659.4	899019	0	0	899019
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-I	NP5112A	-4041.6	545616	0	0	545616
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-II	NP5101A	-4007.8	541053	0	0	541053
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-1649.4	222669	0	0	222669
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-1582.6	213651	0	0	213651
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-12254.5	1654358	0	0	1654358
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	NP5976A	22324.4	-3013794	0	0	-3013794
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	NP5977A	19247.9	-2598467	0	0	-2598467
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	10206	-1377810	0	0	-1377810
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-863.6	116586	0	0	116586
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-1007.2	135972	0	0	135972
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-3202.7	432365	0	0	432365
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	0	0	0	0	0
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	0	0	0	0	0
	26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	-2.2	297	0	0	297
	27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-1391.7	187880	0	0	187880
	28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	-25.3	3416	0	0	3416
	29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	0	0	0	0	0
	30	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-1	ER1018A	1299.3	-175406	0	0	-175406
	31	220 KV PANDIABILI(PG)-SAMANGARA(GRIDCO)-1	NP8051A	1646.8	-222318	0	0	-222318
	32	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	-130.3	17591	0	0	17591
	33	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	224.8	-30348	0	0	-30348
		Total		21488.4	-2900934	0.0	0	-2900934

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 30/10/17 to 05/11/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	385	-51975	0	0	-51975
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	ER1028A	331.6	-44766	0	0	-44766
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	620.4	-83754	0	0	-83754
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	718.4	-96984	0	0	-96984
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	2858.8	-385938	0	0	-385938
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	2860.3	-386141	0	0	-386141
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	686.8	-92718	0	0	-92718
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-1511.3	204026	0	0	204026
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	260.5	-35168	0	0	-35168
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1077.2	145422	0	0	145422
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-5373	725355	0	0	725355
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-I	NP5112A	-4314.6	582471	0	0	582471
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-II	NP5101A	-4268.2	576207	0	0	576207
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-1329.4	179469	0	0	179469
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-637.1	86009	0	0	86009
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-12605	1701675	0	0	1701675
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	28755.7	-3882020	0	0	-3882020
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	27734.2	-3744117	0	0	-3744117
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	10494.9	-1416812	0	0	-1416812
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-1518.9	205052	0	0	205052
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-1899.2	256392	0	0	256392
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-4273	576855	0	0	576855
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	34.8	-4698	0.3	40.5	-4658
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-5.1	689	0	0	689
	26	400 KV STERLITE - RAIGARH(WR)-I	NP6539A	0	0	0	0	0
	27	400 KV STERLITE - RAIGARH(WR)-II	NP7572A	-2406.9	324932	0	0	324932
	28	400 KV STERLITE - ROURKELLA(PG)-I	NP6538A	0	0	0	0	0
	29	400 KV STERLITE - ROURKELLA(PG)-II	NP7372A	0	0	0	0	0
	30	220 KV PANDIABIL(PG)-ATRII(GRIDCO)-1	ER1018A	1980.7	-267395	0	0	-267395
	31	220 KV PANDIABIL(PG)-SAMANGARA(GRIDCO)-1	NP8051A	2177.6	-293976	0	0	-293976
	32	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	6.8	-918	0	0	-918
	33	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	358.6	-48411	0	0	-48411
		Total		39046.2	-5271237	0.3	41	-5271197

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 06/11/17 to 12/11/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	617.2	-83322	0	0	-83322
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	ER1028A	565.6	-76356	0	0	-76356
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	785	-105975	0	0	-105975
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	852.7	-115115	0	0	-115115
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	4868.3	-657221	0	0	-657221
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	4905.9	-662297	0	0	-662297
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	-3.2	432	4.2	567	999
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-1447	195345	0	0	195345
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	217.3	-29336	0	0	-29336
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1080	145800	0	0	145800
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4862.4	656424	0	0	656424
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-I	NP5112A	-4142.8	559278	0	0	559278
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-II	NP5101A	-4097.6	553176	0	0	553176
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-958.4	129384	0	0	129384
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-900.6	121581	0	0	121581
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-11967.6	1615626	0	0	1615626
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	29574.1	-3992504	0	0	-3992504
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	19232.3	-2596361	0	0	-2596361
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	7444	-1004940	0	0	-1004940
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-1221.1	164849	0	0	164849
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-1500.1	202514	0	0	202514
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-4495.3	606866	0	0	606866
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	54.7	-7385	0	0	-7385
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-0.3	41	0	0	41
	26	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-1	ER1018A	2291.2	-309312	-0.1	-13.5	-309326
	27	220 KV PANDIABILI(PG)-SAMANGARA(GRIDCO)-1	NP8051A	2284.3	-308381	0	0	-308381
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	32	-4320	0	0	-4320
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	371.7	-50180	0	0	-50180
	30	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-I	ER1059A	-2974.3	401531	0	0	401531
	31	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-II	ER1058A	-4047.7	546440	0	0	546440
		Total		37419.9	-5051687	4.1	554	-4103163

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 13/11/17 to 19/11/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE (Rs)	
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	198.6	-26811	0	0	-26811	
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	ER1028A	135.8	-18333	0	0	-18333	
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	803.7	-108500	0	0	-108500	
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	972.2	-131247	0	0	-131247	
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	3959.2	-534492	0	0	-534492	
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	3963.7	-535100	0	0	-535100	
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H)	NP5966A	66.7	-9005	0	0	-9005	
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-1454.3	196331	0	0	196331	
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	257.5	-34763	0	0	-34763	
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1157.8	156303	0	0	156303	
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4947.2	667872	0	0	667872	
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-3479.8	469773	0	0	469773	
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-3767.8	508653	0	0	508653	
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-394	53190	0	0	53190	
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-343.1	46319	0	0	46319	
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0	
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-12753.1	1721669	0	0	1721669	
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	37198.4	-5021784	0	0	-5021784	
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	29439.3	-3974306	0	0	-3974306	
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	10873.1	-1467869	0	0	-1467869	
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-2054.6	277371	0	0	277371	
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-2434.2	328617	0	0	328617	
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-5734.4	774144	0	0	774144	
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	711.7	-96080	0	0	-96080	
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	2.8	-378	0	0	-378	
	26	220 KV PANDIABIL(PG)-ATRI(GRIDCO)-1	ER1018A	3102.7	-418865	0	0	-418865	
	27	220 KV PANDIABIL(PG)-SAMANGARA(GRIDCO)-1	NP8051A	2964.6	-400221	0	0	-400221	
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	138.8	-18738	0	0	-18738	
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	464.7	-62735	0	0	-62735	
		30	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-I	ER1059A	-4983.5	672773	0	0	672773
		31	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-II	ER1058A	-5570.4	752004	0	0	752004
		Total		56733.2	-7658982	0.0	0	-6234206	

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 20/11/17 to 26/11/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	1461.4	-197289	0	0	-197289
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	ER1028A	1344	-181440	0	0	-181440
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	614.4	-82944	0	0	-82944
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	689	-93015	0	0	-93015
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	900.7	-121595	0	0	-121595
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	820.6	-110781	0	0	-110781
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	442.7	-59765	0	0	-59765
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-1464.5	197708	0	0	197708
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	377.7	-50990	0	0	-50990
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-595.6	80406	0	0	80406
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-557.7	752895	0	0	752895
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-I	NP5112A	-3662.8	494478	0	0	494478
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-II	NP5101A	-3310	446850	0	0	446850
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-279.3	37706	0	0	37706
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-231	31185	0	0	31185
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-11365.6	1534356	0	0	1534356
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	36187.6	-4885326	0	0	-4885326
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	28785.4	-3886029	0	0	-3886029
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	11261.1	-1520249	0	0	-1520249
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-1822.6	246051	0	0	246051
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-2333.7	315050	0	0	315050
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-5002.5	675338	0	0	675338
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	644.6	-87021	0	0	-87021
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-25.7	3470	0	0	3470
	26	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-1	ER1018A	0	0	0	0	0
	27	220 KV PANDIABILI(PG)-SAMANGARA(GRIDCO)-1	NP8051A	2830.6	-382131	0	0	-382131
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	140.3	-18941	0	0	-18941
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	471.6	-63666	0	0	-63666
	30	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-I	ER1059A	-6526.9	881132	0	0	881132
	31	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-II	ER1058A	-6949.4	938169	0	0	938169
		Total		51301.4	-6925689	0.0	0	-5106389

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

- 2) For reactive energy, (+) means injection and (-) means drawal with respect to utility
- 3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.
- 4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.
- 5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 27/11/17 to 03/12/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	1061	-143235	0	0	-143235
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	ER1028A	989.8	-133623	0	0	-133623
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	385.8	-52083	0	0	-52083
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	453.1	-61169	0	0	-61169
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	-62.4	8424	-120	-16200	-7776
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	909	-122715	0	0	-122715
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	741.9	-100157	0	0	-100157
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-1384.5	186908	0	0	186908
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	354.9	-47912	0	0	-47912
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-572.8	77328	0	0	77328
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-5993.2	809082	0	0	809082
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-I	NP5112A	-3468	468180	0	0	468180
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-II	NP5101A	-3424	462240	0	0	462240
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-127.5	17213	0	0	17213
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-193.5	26123	0	0	26123
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-11301.1	1525649	0	0	1525649
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	35669.5	-4815383	0	0	-4815383
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	28248.1	-3813494	0	0	-3813494
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	11447	-1545345	0	0	-1545345
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-1922.6	259551	0	0	259551
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-2377.7	320990	0	0	320990
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-5440.3	734441	0	0	734441
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	548.9	-74102	0	0	-74102
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-56.2	7587	0	0	7587
	26	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-1	ER1018A	3425	-462375	0	0	-462375
	27	220 KV PANDIABILI(PG)-SAMANGARA(GRIDCO)-1	NP8051A	2924.6	-394821	0	0	-394821
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	185.6	-25056	0	0	-25056
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	465.1	-62789	0	0	-62789
	30	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-I	ER1059A	-7864.3	1061681	0	0	1061681
	31	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-II	ER1058A	-8346.7	1126805	0	0	1126805
		Total		51485.5	-6950543	-120.0	-16200	-4778258

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTs.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 18/12/17 to 24/12/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	-152	20520	0	0	20520
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	ER1028A	-211.4	28539	0	0	28539
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	487.9	-65867	0	0	-65867
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	429.1	-57929	0	0	-57929
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	396.6	-53541	0	0	-53541
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	335.4	-45279	0	0	-45279
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	3764.7	-508235	31.9	4306.5	-503928
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-1195.5	161393	0	0	161393
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	83	-11205	0	0	-11205
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1036.2	139887	0	0	139887
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4368.4	589734	0	0	589734
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-I	NP5112A	-4317.4	582849	0	0	582849
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-II	NP5101A	-4270.6	576531	0	0	576531
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-197.7	26690	0	0	26690
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	64.1	-8654	0	0	-8654
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-9607.9	1297067	0	0	1297067
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	33751.2	-4556412	0	0	-4556412
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	24010.4	-3241404	0	0	-3241404
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	10963.6	-1480086	0	0	-1480086
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-1561.5	210803	0	0	210803
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-1961.3	264776	0	0	264776
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-5501.5	742703	0	0	742703
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	225.1	-30389	0	0	-30389
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-17.6	2376	0	0	2376
	26	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-1	ER1018A	2048	-276480	0	0	-276480
	27	220 KV PANDIABILI(PG)-SAMANGARA(GRIDCO)-1	NP8051A	2653.1	-358169	0	0	-358169
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	113.3	-15296	0	0	-15296
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	356.8	-48168	0	0	-48168
	30	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-I	ER1059A	-7670.2	1035477	0	0	1035477
	31	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-II	ER1058A	-7919.6	1069146	0	0	1069146
	32	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-2	ER1099A	606.1	-81824	0	0	-81824
		Total		30299.6	-4090446	31.9	4307	-4086140

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 25/12/17 to 31/12/17

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	203.8	-27513	0	0	-27513
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	ER1028A	117.6	-15876	0	0	-15876
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	597	-80595	0	0	-80595
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	564.4	-76194	0	0	-76194
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	582.2	-78597	0	0	-78597
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	410.9	-55472	0	0	-55472
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	1710.9	-230972	58	7830	-223142
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-1334.2	180117	0	0	180117
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	256	-34560	0	0	-34560
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1021.8	137943	0	0	137943
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3859.8	521073	0	0	521073
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-I	NP5112A	-4002.2	540297	0	0	540297
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-II	NP5101A	-3960.6	534681	0	0	534681
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	49.4	-6669	0	0	-6669
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	91.6	-12366	0	0	-12366
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-8965.4	1210329	0	0	1210329
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	27769.5	-3748883	0	0	-3748883
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	18079.4	-2440719	0	0	-2440719
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	8194.9	-1106312	0	0	-1106312
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-1492	201420	0	0	201420
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-1824.4	246294	0	0	246294
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-5300.6	715581	0	0	715581
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	3.5	-473	0.6	81	-392
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	0	0	-65.6	-8856	-8856
	26	220 KV PANDIABIL(PG)-ATRI(GRIDCO)-1	ER1018A	1343.2	-181332	0	0	-181332
	27	220 KV PANDIABIL(PG)-SAMANGARA(GRIDCO)-1	NP8051A	2390.3	-322691	0	0	-322691
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	86.7	-11705	0	0	-11705
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	310.7	-41945	0	0	-41945
	30	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-I	ER1059A	-6246.8	843318	0	0	843318
	31	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-II	ER1058A	-6476.7	874355	0	0	874355
	32	220 KV PANDIABIL(PG)-ATRI(GRIDCO)-2	ER1099A	1307.4	-176499	0	0	-176499
		Total		19584.9	-2643962	-7.0	-945	-2644907

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 01/01/18 to 07/01/18

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	1623.6	-219186	0	0	-219186
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	ER1028A	1511.8	-204093	0	0	-204093
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	973.8	-131463	0	0	-131463
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	902.8	-121878	0	0	-121878
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	-524.1	70754	0	0	70754
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	-545.4	73629	0	0	73629
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	2062.6	-278451	0	0	-278451
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-1000	135000	0	0	135000
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	207.3	-27986	0	0	-27986
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1018.4	137484	0	0	137484
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3947.2	532872	0	0	532872
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-I	NP5112A	-4109	554715	0	0	554715
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-II	NP5101A	-4072.8	549828	0	0	549828
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-139.3	18806	0	0	18806
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-97	13095	0	0	13095
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-9465	1277775	0	0	1277775
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	27918.3	-3768971	0	0	-3768971
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	17886.5	-2414678	0	0	-2414678
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	10460.1	-1412114	0	0	-1412114
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-1731.2	233712	0	0	233712
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-1976.8	266868	0	0	266868
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-5663.6	764586	0	0	764586
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	787.8	-106353	11.4	1539	-104814
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-559.2	75492	-204.7	-27634.5	47858
	26	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-1	ER1018A	1453.4	-196209	0	0	-196209
	27	220 KV PANDIABILI(PG)-SAMANGARA(GRIDCO)-1	NP8051A	2307.2	-311472	0	0	-311472
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	-10.9	1472	0	0	1472
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	210.3	-28391	0	0	-28391
	30	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-I	ER1059A	-8268.7	1116275	0	0	1116275
	31	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-II	ER1058A	-8718.8	1177038	0	0	1177038
	32	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-2	ER1099A	1421.5	-191903	0	0	-191903
		Total		17879.6	-2413746	-193.3	-26096	-2439842

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 08/01/18 to 14/01/18

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	1249	-168615	0	0	-168615
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	ER1028A	1173	-158355	0	0	-158355
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	124.4	-16794	0	0	-16794
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	13.5	-1823	0	0	-1823
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	-483.3	65246	-46.1	-6223.5	59022
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	-470.1	63464	0	0	63464
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	2424.8	-327348	31.9	4306.5	-323042
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-1241.6	167616	0	0	167616
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	242.2	-32697	0	0	-32697
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1234.4	166644	0	0	166644
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4368.6	589761	0	0	589761
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-I	NP5112A	-4372.4	590274	0	0	590274
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-II	NP5101A	-4321.2	583362	0	0	583362
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-197.6	26676	0	0	26676
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-154.5	20858	0	0	20858
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-9315.2	1257552	0	0	1257552
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	30035.6	-4054806	0	0	-4054806
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	19211.2	-2593512	0	0	-2593512
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	10991.6	-1483866	0	0	-1483866
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-1503.3	202946	0	0	202946
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-1712	231120	0	0	231120
	23	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	NP7915A	-5532.4	746874	0	0	746874
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	530.9	-71672	-27.2	-3672	-75344
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-820.2	110727	-496.8	-67068	43659
	26	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-1	ER1018A	1189.3	-160556	0	0	-160556
	27	220 KV PANDIABILI(PG)-SAMANGARA(GRIDCO)-1	NP8051A	2268.8	-306288	0	0	-306288
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	0	0	0	0	0
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	161.4	-21789	0	0	-21789
	30	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-I	ER1059A	-9324.7	1258835	0	0	1258835
	31	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-II	ER1058A	-9628.8	1299888	0	0	1299888
	32	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-2	ER1099A	1168.8	-157788	0	0	-157788
		Total		16104.2	-2174067	-538.2	-72657	-2246724

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 15/01/18 to 21/01/18

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	1535.8	-207333	0	0	-207333
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	ER1028A	1671.2	-225612	0	0	-225612
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	455.9	-61547	0	0	-61547
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	321.8	-43443	0	0	-43443
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	368.5	-49748	0.1	13.5	-49734
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	159.5	-21533	0	0	-21533
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	2800.8	-378108	23.2	3132	-374976
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-783.5	105773	0	0	105773
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	317.1	-42809	0	0	-42809
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-778.8	105138	0	0	105138
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4595.4	620379	0	0	620379
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-I	NP5112A	-4529	611415	0	0	611415
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-II	NP5101A	-4472.2	603747	0	0	603747
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	14.2	-1917	0	0	-1917
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	51.7	-6980	0	0	-6980
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-7912	1068120	0	0	1068120
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	26155.4	-3530979	0	0	-3530979
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	16145.1	-2179589	0	0	-2179589
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	8446.8	-1140318	0	0	-1140318
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-1301.4	175689	0	0	175689
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-1502.9	202892	0	0	202892
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-4808.8	649188	0	0	649188
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	405.8	-54783	-77	-10395	-65178
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-291.4	39339	-361.8	-48843	-9504
	26	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-1	ER1018A	1183.5	-159773	0	0	-159773
	27	220 KV PANDIABILI(PG)-SAMANGARA(GRIDCO)-1	NP8051A	1953.4	-263709	0	0	-263709
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	-251.7	33980	0	0	33980
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	106.6	-14391	0	0	-14391
	30	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-I	ER1059A	-7697.7	1039190	0	0	1039190
	31	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-II	ER1058A	-8027.3	1083686	0	0	1083686
	32	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-2	ER1099A	1156.3	-156101	0	0	-156101
		Total		16297.3	-2200136	-415.5	-56093	-2256228

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 22/01/18 to 28/01/18

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	3210.2	-433377	0	0	-433377
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	ER1028A	3121.6	-421416	0	0	-421416
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	917.9	-123917	0	0	-123917
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	854.8	-115398	0	0	-115398
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	0	0	-150.8	-20358	-20358
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	-198.5	26798	0	0	26798
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	2746.4	-370764	0	0	-370764
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-767.2	103572	0	0	103572
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	235.7	-31820	0	0	-31820
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-966.6	130491	0	0	130491
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4770.8	644058	0	0	644058
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-I	NP5112A	-3818.2	515457	0	0	515457
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-II	NP5101A	-3769.6	508896	0	0	508896
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	16.6	-2241	0	0	-2241
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	56	-7560	0	0	-7560
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-6690.6	903231	0	0	903231
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	16485.9	-2225597	0	0	-2225597
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	8312	-1122120	0	0	-1122120
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	5721.7	-772430	0	0	-772430
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-1265	170775	0	0	170775
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-1466.6	197991	0	0	197991
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-4426.5	597578	0	0	597578
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	115.1	-15539	-103.4	-13959	-29498
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-0.6	81	-612.2	-82647	-82566
	26	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-1	ER1018A	1533.3	-206996	0	0	-206996
	27	220 KV PANDIABILI(PG)-SAMANGARA(GRIDCO)-1	NP8051A	1772.1	-239234	0	0	-239234
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	-266.2	35937	0	0	35937
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	71.6	-9666	0	0	-9666
	30	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-I	ER1059A	-8579.2	1158192	0	0	1158192
	31	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-II	ER1058A	-9110.1	1229864	0	0	1229864
	32	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-2	ER1099A	1488.2	-200907	0	0	-200907
		Total		563.4	-76059	-866.4	-116964	-193023

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 29/01/18 to 04/02/18

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	2199.6	-296946	0	0	-296946
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	ER1028A	2144.2	-289467	0	0	-289467
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	390.6	-52731	0	0	-52731
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	385.9	-52097	0	0	-52097
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	0	0	-193.7	-26149.5	-26150
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	-419.2	56592	0	0	56592
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	2842.1	-383684	5.7	769.5	-382914
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-626	84510	0	0	84510
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	229.6	-30996	0	0	-30996
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-696	93960	0	0	93960
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3589.6	484596	0	0	484596
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-I	NP5112A	-3608.6	487161	0	0	487161
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-II	NP5101A	-3569.8	481923	0	0	481923
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-26.4	3564	0	0	3564
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	14.4	-1944	0	0	-1944
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-6208.3	838121	0	0	838121
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	20203.2	-2727432	0	0	-2727432
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	9711.4	-1311039	0	0	-1311039
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	5708.8	-770688	0	0	-770688
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-956.4	129114	0	0	129114
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-1167.9	157667	0	0	157667
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-4228.7	570875	0	0	570875
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	12.4	-1674	-799.3	-107905.5	-109580
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	0	0	-1656.9	-223681.5	-223682
	26	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-1	ER1018A	1234.7	-166685	0	0	-166685
	27	220 KV PANDIABILI(PG)-SAMANGARA(GRIDCO)-1	NP8051A	1655.9	-223547	0	0	-223547
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	-401	54135	0	0	54135
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	10.5	-1418	0	0	-1418
	30	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-I	ER1059A	-7201.9	972257	0	0	972257
	31	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-II	ER1058A	-7639.6	1031346	0	0	1031346
	32	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-2	ER1099A	1204.9	-162662	0	0	-162662
		Total		7608.8	-1027188	-2644.2	-356967	-1384155

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 05/02/18 to 11/02/18

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE (Rs)
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	1728	-233280	0	0	-233280
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	ER1028A	1668	-225180	0	0	-225180
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	281.6	-38016	0	0	-38016
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	301.7	-40730	0	0	-40730
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	585.5	-79043	-26	-3510	-82553
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	142.5	-19238	0	0	-19238
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	911	-122985	3.9	526.5	-122459
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-502.8	67878	0	0	67878
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	218.2	-29457	0	0	-29457
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1003.4	135459	0	0	135459
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-3585.2	484002	0	0	484002
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-3893.2	525582	0	0	525582
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-3846.6	519291	0	0	519291
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-166.6	22491	0	0	22491
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-119.7	16160	0	0	16160
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-5881.4	793989	0	0	793989
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	16869	-2277315	0	0	-2277315
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	7698.5	-1039298	0	0	-1039298
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	4723.9	-637727	0	0	-637727
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-745.4	100629	0	0	100629
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-942.3	127211	0	0	127211
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-4150.5	560318	0	0	560318
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	157.7	-21290	21.1	2848.5	-18441
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-127.7	17240	-246.7	-33304.5	-16065
	26	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-1	ER1018A	1347.2	-181872	0	0	-181872
	27	220 KV PANDIABILI(PG)-SAMANGARA(GRIDCO)-1	NP8051A	1626.2	-219537	0	0	-219537
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	-534.5	72158	0	0	72158
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	-77	10395	0	0	10395
	30	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-I	ER1059A	-5349.4	722169	0	0	722169
	31	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-II	ER1058A	-5782.1	780584	0	0	780584
	32	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-2	ER1099A	1268.7	-171275	0	0	-171275
		Total		2819.9	-380687	-247.7	-33440	-414126

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 12/02/18 to 18/02/18

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	1504.4	-203094	0	0	-203094
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	ER1028A	1443	-194805	0	0	-194805
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	623.9	-84227	0	0	-84227
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	732.4	-98874	0	0	-98874
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	955.9	-129047	0	0	-129047
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	738.1	-99644	0	0	-99644
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	50.8	-6858	0	0	-6858
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-505.7	68270	0	0	68270
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	178.1	-24044	0	0	-24044
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-1643	221805	0	0	221805
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4618.4	623484	0	0	623484
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-I	NP5112A	-2346	316710	0	0	316710
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-II	NP5101A	-4894	660690	0	0	660690
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-59.7	8060	0	0	8060
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-11.6	1566	0	0	1566
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-6311.6	852066	0	0	852066
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	23376.8	-3155868	0	0	-3155868
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	11278.9	-1522652	0	0	-1522652
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	7138.8	-963738	0	0	-963738
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-753.1	101669	0	0	101669
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-1013	136755	0	0	136755
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-4898.5	661298	0	0	661298
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	210.5	-28418	0	0	-28418
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-62.3	8411	0	0	8411
	26	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-1	ER1018A	1659.2	-223992	0	0	-223992
	27	220 KV PANDIABILI(PG)-SAMANGARA(GRIDCO)-1	NP8051A	1997.7	-269690	0	0	-269690
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	-562.7	75965	0	0	75965
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	-86.9	11732	0	0	11732
	30	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-I	ER1059A	-6180	834300	0	0	834300
	31	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-II	ER1058A	-6617.2	893322	0	0	893322
	32	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-2	ER1099A	1507.9	-203567	0	0	-203567
		Total		12832.7	-1732415	0.0	0	-1732415

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF GRIDCO WITH THE POOL

for the period 19/02/18 to 25/02/18

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVArH_HIGH	REACTIVE CHARGE_MVArH (Rs)	MVArH_LOW	REACTIVE CHARGE_MVArL (Rs)	NET REACTIVE CHARGE
GRIDCO	1	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -I	NP5929A	1378.4	-186084	0	0	-186084
	2	220 KV ROURKELA (PG) - TARKERA (GRIDCO) -II	ER1028A	1397.6	-188676	0	0	-188676
	3	220 KV RENGALI (PG) - RENGALI (GRIDCO) -I	NP5989A	126.5	-17078	0	0	-17078
	4	220 KV RENGALI (PG) - RENGALI (GRIDCO) -II	NP5990A	122.4	-16524	0	0	-16524
	5	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -I	ER1096A	604	-81540	0	0	-81540
	6	220 KV JEYPORE (PG) - JEYNAGAR (GRIDCO) -II	ER1013A	459.3	-62006	0	0	-62006
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	1138.6	-153711	0	0	-153711
	8	132 KV BARIPADA(PG) - BARIPADA (GRIDCO)	NP5916A	-453.2	61182	0	0	61182
	9	132 KV BARIPADA(PG) - BANGRIPOSHI (GRIDCO)	NP5912A	61	-8235	0	0	-8235
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-384.8	51948	0	0	51948
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-4605.6	621756	0	0	621756
	12	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-I	NP5112A	-4838.6	653211	0	0	653211
	13	220 KV TSTPP (NTPC) - M'MUNDALI (GRIDCO)-II	NP5101A	-4777.2	644922	0	0	644922
	14	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-I	NP5915A	-809.9	109337	0	0	109337
	15	220 KV BARIPADA (PG) - BALASORE (GRIDCO)-II	NP5913A	-607.4	81999	0	0	81999
	16	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	17	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	NP7916A	-5723.3	772646	0	0	772646
	18	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-I	ER1054A	21087.6	-2846826	0	0	-2846826
	19	400 KV M'MUNDALI (GRIDCO)-ANGUL(PG)-II	ER1055A	11009.6	-1486296	0	0	-1486296
	20	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	NP7932A	7141.7	-964130	0	0	-964130
	21	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	-510.2	68877	0	0	68877
	22	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	-694.8	93798	0	0	93798
	23	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	NP7915A	-4211.3	568526	0	0	568526
	24	220 KV BOLANGIR(PG)-KATAPALI(GRIDCO)	NP8790A	78	-10530	0	0	-10530
	25	220 KV BOLANGIR(PG)-SADEIPALI(GRIDCO)	NP8789A	-37.1	5009	-0.6	-81	4928
	26	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-1	ER1018A	1415.8	-191133	0	0	-191133
	27	220 KV PANDIABILI(PG)-SAMANGARA(GRIDCO)-1	NP8051A	1450.4	-195804	0	0	-195804
	28	132 KV BARIPADA(PG)-JALESWAR(GRIDCO)	NP5914A	-362.2	48897	0	0	48897
	29	132 KV BARIPADA(PG)-BHOGRAI(GRIDCO)	ER1115A	9.8	-1323	0	0	-1323
	30	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-I	ER1059A	-3761.8	507843	0	0	507843
	31	400 KV STERLITE(GRIDCO) - SUNDERGARH(PG)-II	ER1058A	-3940.9	532022	0	0	532022
	32	220 KV PANDIABILI(PG)-ATRI(GRIDCO)-2	ER1099A	1320.2	-178227	0	0	-178227
		Total		13082.6	-1766151	-0.6	-81	-1766232

Note: 1) Rate of Reactive Energy Charge has been considered @ 13.5 paise/KVArH,w.e.f. 01/04/2017

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.