



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/8076-8086

Date: 28.01.2021

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 11.01.2021-17.01.2021

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 23.01.2021.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This is issued with the approval of Member Secretary.

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)
SUPERINTENDING ENGINEER

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 11/01/20 to 17/01/21**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)
BSPHCL	POOL	0
JUVNL	POOL	1288380
DVC	POOL	0
GRIDCO	POOL	0
SIKKIM	POOL	34245
WBSETCL	POOL	1087785

Note:

- a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC
- b) Receivables from the Reactive Pool are reduced to zero as per decision taken in the meeting of the " Group" held on 15.09.06 at ERPC, Kolkata.

SUPERINTENDING ENGINEER

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 11/01/20 to 17/01/21

BENEFICIARY	SL. NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVA/H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVA/H (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-2267.7	340155	0	0	340155
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-3583.7	537555	0	0	537555
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-2834.2	425130	0	0	425130
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	125.1	-18765	0	0	-18765
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	115.6	-17340	0	0	-17340
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	199.3	-29895	0	0	-29895
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-1006	150900	0	0	150900
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-526	78900	0	0	78900
	9	220 KV side of 220/132 Arah ICT-2	NP6059A	-548.8	82320	0	0	82320
	10	220 KV KHAGALGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-866.1	129915	0	0	129915
	11	220 KV KHAGALGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-1161.7	174255	0	0	174255
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	-19.9	2985	-82.3	-12345	-9360
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	-130.8	19620	0	0	19620
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	-15.2	2280	0	0	2280
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	755.5	-113325	0	0	-113325
	16	132 KV KAHALGAON(NTPC)-KAHALGAON (BSPHCL)	NP5261A	-1090.9	163635	0	0	163635
	17	220KV NEW PUSAULI(BSPHCL) - PUSAULI(PG)	NP8665A	-1217.6	182640	0	0	182640
	18	220KV NEW PUSAULI(BSPHCL) - ARA (PG)	NP8664A	0	0	0	0	0
	19	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	NP7429A	239.4	-35910	0	0	-35910
	20	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	NP7889A	264.7	-39705	0	0	-39705
	21	132 KV KAHALGAON (NTPC)-SABOUR (BSPHCL)	NP5239A	-898.1	134715	0	0	134715
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1525.5	-228825	0	0	-228825
	23	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1512.1	-226815	0	0	-226815
	24	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1638.7	-245805	0	0	-245805
	25	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1611.8	-241770	0	0	-241770
	26	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	147.4	-22110	19.9	2985	-19125
	27	HV side of 400/220 Patna ICT-1	ER1408A	1982.6	-297390	0	0	-297390
	28	HV side of 400/220 Patna ICT-2	ER1407A	1315.6	-197340	0	0	-197340
	29	HV side of 400/220 Patna ICT-3	ER1231A	1223.9	-183585	0	0	-183585
	30	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	632	-94800	0	0	-94800
	31	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	633.4	-95010	0	0	-95010
	32	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-2177.3	326595	0	0	326595
	33	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-2169.8	325470	0	0	325470
	34	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	850.8	-127620	0	0	-127620
	35	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2218.1	-332715	0	0	-332715
	36	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-I	NP7398A	-1159.1	173865	0	0	173865
	37	220 KV KANTI (BSPHCL)-MUZAFFARPUR (PG)-II	NP7452A	-1172.5	175875	0	0	175875
	38	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	1415.6	-212340	0	0	-212340
	39	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	1560	-234000	0	0	-234000
	40	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-I	ER1256A	0	0	0	0	0
	41	132 KV MOTIHARI(DMTCL)-MOTIHARI(BSPTCL)-II	ER1258A	-183.2	27480	0	0	27480
	42	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	3192	-478800	0	0	-478800
	43	220 KV PURNEA(PG)-BEGUSARA(BSPTCL)-II	ER1376A	3642.5	-546375	0	0	-546375
	44	220 KV NADHOKHAR(BSPHCL)- ARA(PG) LINE-1	ER1305A	-1452.6	217890	0	0	217890
	45	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	1535.4	-230310	0	0	-230310
	46	HV side of 400/220 KV Biharshariff(PG) ICT-4	ER1386A	-5686.5	852975	0	0	852975
		TOTAL		274605		-9360	265245	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-3304.9	495735	0	0	495735
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-3594.9	539235	0	0	539235
	3	HV side meter of 400/220 Jamshedpur ICT-3	ER1297A	-6812.3	1021845	0	0	1021845
	4	HV side meter data of 400/220 Ranchi ICT-1	NP5873A	2668.3	-400245	0	0	-400245
	5	HV side meter data of 400/220 Ranchi ICT-2	NP5878A	3122.4	-468360	0	0	-468360
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	2860.6	-429090	0	0	-429090
	7	132 KV KAHALGAON (NTPC)-LALMATIA (JUVNL)	NP5244A	328	-49200	0	0	-49200
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	3275.4	-491310	0	0	-491310
	9	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	3433.4	-515010	0	0	-515010
	10	HV side meter data of 400/220 Chaibasa ICT-1	NP8637A	3201.1	-480165	0	0	-480165
	11	HV side meter data of 400/220 Chaibasa ICT-2	NP8678A	3184.7	-477705	0	0	-477705
	12	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	116.4	-17460	0	0	-17460
	13	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	111	-16650	0	0	-16650
		TOTAL		-1288380		0	-1288380	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-5505.8	825870	0	0	825870
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	NP6529A	0	0	0	0	0
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	84	-12600	0	0	-12600
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	NP6509A	0	0	0	0	0
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	NP6510A	0	0	0	0	0
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	NP7408A	0	0	0	0	0
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	NP7406A	0	0	0	0	0
	9	400 KV MEJIA(DVC)-MAITHON(PG)	NP6557A	-1728.4	259260	0	0	259260
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1008A	0	0	0	0	0
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1031A	0	0	0	0	0
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	0	0	0	0	0
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	0	0	0	0	0
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	0	0	0	0	0
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	0	0	0	0	0
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-III(MAIN)	NP6524A	-5807.7	871155	0	0	871155
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-5766.9	865035	0	0	865035
	18	400 KV RTPS(DVC)-RANCHI(PG)	NP7973A	-6253.4	938010	0	0	938010
	19	400 KV RTPS(DVC)-MAITHON(PG)	NP7974A	-1942.9	291435	0	0	291435
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	NP6508A	0	0	0	0	0
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	7323.9	-1098585	0	0	-1098585
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	7161.7	-1074255	0	0	-1074255
		TOTAL		1865325		0	1865325	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	HV side meter of 400/220 Rourkela ICT-1	ER1563A	198.6	-29790	0	0	-29790
	2	HV side meter of 400/220 Rourkela ICT-2	ER1565A	-720	108000	0	0	108000
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	54.5	-8175	0	0	-8175
	5	HV side meter of 400/220 Jeypore ICT-1	ER1550A	0	0	0	0	0
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	-639.6	95940	0	0	95940
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	NP5966A	0	0	0	0	0
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	-205.7	30855	0	0	30855
	9	HV side meter of 400/220 Baripada ICT-2	ER1594A	0	0	0	0	0
	10	220 KV TSTPP (NTPC) - RENGALI HPS (GRIDCO)	NP5102A	-3523.4	528510	0	0	528510
	11	220 KV TSTPP (NTPC) - TTPS (GRIDCO)	NP5103A	-2616.8	392520	0	0	392520
	12	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-I	NP5112A	-2141.8	321270	0	0	321270
	13	220 KV TSTPP (NTPC) - MMUNDALI (GRIDCO)-II	NP5101A	-2174.6	326190	0	0	326190
	14	HV side meter of 400/220 Baripada ICT-3	ER1564A	0	0	0	0	0
	15	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	16	400 KV DUBURI (GRIDCO)-BARIPADA (PG)	NP7916A	-1665.8	249870	0	0	249870
	17	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-I	ER1054A	12087.6	-1813140	0.3	45	-1813095
	18	400 KV MMUNDALI (GRIDCO)-ANGUL (PG)-II	ER1055A	13867.3	-2080095	0	0	-2080095
	19	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	NP7932A	0	0	0	0	0
	20	400 KV MENDHASAL (GRIDCO)-PANDIABIL (PG)-I	NP5980A	-1738.6	260790	0	0	260790
	21	400 KV MENDHASAL (GRIDCO)-PANDIABIL (PG)-II	NP7498A	-1590.8	238620	0	0	238620
	22	400 KV DUBURI (GRIDCO)-PANDIABIL (PG)	NP7915A	-6752.3	1012845	0	0	1012845
	23	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	1	150	150
	24	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	1.3	195	195
	25	HV side of 400/220 Pandiabil ICT-1	ER1583A	-5135.6	770340	0	0	770340
	26	HV side of 400/220 Pandiabil ICT-2	ER1586A	0	0	0	0	0
	27	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-404.8	60720	0	0	60720
	28	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-481.1	72165	0	0	72165
	29	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	30	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	31	400 KV SUNDERGARH (PG)-OPGC-1	ER1117A	-1270.2	190530	0	0	190530
	32	400 KV SUNDERGARH (PG)-OPGC-2	ER1119A	-1257.1	188565	0	0	188565
		TOTAL		916530		390	916920	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-56.90	8535	-300.2	-45030	-36495
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-45.80	6870	-32.3	-4845	2025
	3	66 KV RAVANGLA (SIKKIM) - RANGIT (NHPC)	NP6481A	0.00	0	-0.7	-105	-105
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	NP6029A	0.00	0	0	0	0
	5	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	NP6028A	0.00	0	0	0	0
	6	132 KV RANGIT (NHPC) - SAGBARI (SIKKIM)	NP5925A	-2.20	330	0	0	330
		TOTAL		15735		-49980	-34245	
WBSETCL	1	400 KV JEERAT (WBSETCL) - SUBHASGRAM (PG)	ER1471A	0	0	18.2	2730	2730
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	1310.8	-196620	0	0	-196620
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	1237.6	-185640	0	0	-185640
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-2096	314400	0	0	314400
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-2122.6	318390	0	0	318390
	6	220 KV SIDE OF 220/132 MALDA 50 MVA ICT-3	ER1511A	0	0	0	0	0
	7	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-2064.1	309615	0	0	309615
	8	132 KV SILIGURI (PG) - NBU (WBSETCL)	NP5889A	0	0	0	0	0
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-3383.9	507585	0	0	507585
	10	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-1796.1	269415	0	0	269415
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	NP5882A	0	0	0	0	0
	12	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	9683.5	-1452525	0	0	-1452525
	13	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	-188	28200	0	0	28200
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	6935.5	-1040325	0	0	-1040325
	15	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	2803.6	-420540	0	0	-420540
	16	400 KV SAGARDIGHI (WBSETCL) - FARAKKA (NTPC)	NP6482A	-3451.2	517680	0	0	517680
	17	400 KV SAGARDIGHI (WBSETCL) - SUBHASGRAM (PG)	NP6483A	34.1	-5115	0	0	-5115
	18	132 KV KURSEONG (WBSETCL) - RANGIT (NHPC)	NP7541A	-157.4	23610	0	0	23610
	19	132 KV KURSEONG (WBSETCL) - SILIGURI (NHPC)	NP7542A	73.2	-10980	0	0	-10980
	20	400 KV KHARAGPUR (WBSETCL) - BARIPADA (PG)	ER1043A	1599.6	-239940	0	0	-239940
	21	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-I	NP6548A	3928.3	-589245	0	0	-589245
	22	400 KV DURGAPUR (PG) - SAGARDIGHI (WBSETCL)-II	NP7557A	0	0	0	0	0
	23	220 KV DALKHOLA (PG) - DALKHOLA (WBSETCL) LINE-I	ER1071A	96.1	-14415	0	0	-14415
	24	220 KV DALKHOLA (PG) - DALKHOLA (WBSETCL) LINE-II	ER1072A	42.2	-6330	0	0	-6330
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	NP7545A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	NP7939A	0	0	0	0	0
	27	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	NP8718A	0	0	0	0	0
	28	400 KV SUBHASHGRAM (PG) - HALDIA CESC (WB) LINE-I	ER1141A	1746.1	-261915	0	0	-261915
	29	400 KV SUBHASHGRAM (PG) - HALDIA CESC (WB) LINE-II	NP7937A	0	0	0	0	0
	30	400 KV SAGARDIGHI (WB) - BERHAMPUR (PG) LINE-I	NP8723A	434.6	-65190	0	0	-65190
	31	400 KV SAGARDIGHI (WB) - BERHAMPUR (PG) LINE-II	NP8724A	264.6	-39690	0	0	-39690
	32	400 KV KHARAGPUR (WB) - CHAIBASA (PG)-I	NP8731A	-1221.5	183225	0	0	183225
	33	400 KV KHARAGPUR (WB) - CHAIBASA (PG)-II	NP8720A	-1190.2	178530	0	0	178530
	34	400 KV PPSF NEW (WB) - RANCHI NEW (PG)-II	ER1040A	2618.8	-392820	0	0	-392820
	35	400 KV PPSF NEW (WB) - RANCHI NEW (PG)-I	ER1130A	2585.1	-387765	0	0	-387765
	36	400 KV GOKARNA (WB) - FARAKKA (NTPC)-I	ER1133A	-4141.9	621285	0	0	621285
	37	400 KV GOKARNA (WB) - FARAKKA (NTPC)-II	ER1138A	-7208.3	1081245	0	0	1081245
	38	220 KV ALIPURDUAR (PG) - ALIPURDUAR (WB)-I	ER1044A	0	0	0	0	0
	39	220 KV ALIPURDUAR (PG) - ALIPURDUAR (WB)-II	ER1047A	1717	-257550	0	0	-257550
	40	400 KV SAGARDIGHI (WB) - FARAKKA (NTPC)-II	ER1131A	-2628	394200	0	0	394200
	41	HV side of 400/220 KV RAJARHAT (PG) ICT-1	ER1526A	2066.8	-310020	0	0	-310020
	42	220 KV GAZOLE (WB) - MALDA (PG)-1	ER1693A	-2907.8	436170	0	0	436170
	43	220 KV GAZOLE (WB) - MALDA (PG)-2	ER1696A	-2910.6	436590	0	0	436590
	44	220 KV GAZOLE (WB) - DALKHOLA (PG)-1	ER1698A	2596.7	-389505	0	0	-389505
	45	220 KV GAZOLE (WB) - DALKHOLA (PG)-2	ER1699A	2963.5	-444525	0	0	-444525
		TOTAL		-1090515		2730	-1087785	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15 paise/KVArH,w.e.f. 01/04/2020

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.