

Sl	Element	Requestor	Element Name	Daily(D)/Continous(C)	Comment	Information Required	Consent	Day	Reason	From Date (DD-MMM-YYYY)	From Time (HH:MM)	To Date (DD-MMM-YYYY)	To Time	Requestor Remarks	NLDC Remarks	Reliability Remarks
1	BUS	WBSETCL	400KV MAIN BUS - 1 AT JEERAT	D				1	Maintenance of Pantograph Isolator i.r.t Main Bus I Isolator of 315 MVA 400/220 Tr-3 and BKTPP for which said feeder & Transformer will be diverted through B/T one after another	07 April 2021	07:00 hrs	07 April 2021	16:00 hrs			Other Bus Should be available
2	BUS	WBSETCL	400KV MAIN BUS - 2 AT JEERAT	D				2	Maintenance of Pantograph Isolator i.r.t Main Bus II Isolator of 315 MVA 400/220 Tr-3 and BKTPP for which said feeder & Transformer will be diverted through B/T one after another	20 April 2021	07:00 hrs	21 April 2021	16:00 hrs			Other Bus Should be available
3	BUS	WBSETCL	400 KV TRANSFER BUS AT BAKRESWAR	C				2	RETROFITTING OF TRIPPING RELAY(86),BUS BAR TRIPPING RELAY (96),UNDER PSDF	07 April 2021	08:00	08 April 2021	17:00			Other Bus Should be available
4	BUS	WBSETCL	400KV MAIN BUS - 2 AT KHARAGPUR	D				1	DCRM TEST	07 April 2021	10:00	07 April 2021	16:00	ALL FEEDERS & TR. ON 400KV MAIN BUS-I		Other Bus Should be available
5	BUS	WBSETCL	400KV MAIN BUS - 1 AT KOLAGHAT	D				3	Replacement of Breaker & 29A of IBT#1 Bay (PSDF)	14 April 2021	08:00	16 April 2021	17:00	All other feeders shifted to MB#2		Other Bus Should be available
6	BUS	WBSETCL	400KV MAIN BUS - 2 AT KOLAGHAT	D				4	Replacement of Breaker & 29B of IBT#1 Bay (PSDF)	17 April 2021	08:00	20 April 2021	17:00	All other feeders shifted to MB#1		Other Bus Should be available
7	BUS	WBSETCL	400KV MAIN BUS - 1 AT KOLAGHAT	D				3	Replacement of Breaker & 29A of IBT#2 Bay (PSDF)	24 April 2021	08:00	26 April 2021	17:00	All other feeders shifted to MB#2		Other Bus Should be available
8	BUS	WBSETCL	400KV MAIN BUS - 2 AT KOLAGHAT	D				4	Replacement of Breaker & 29B of IBT#2 Bay (PSDF)	27 April 2021	08:00	30 April 2021	17:00	All other feeders shifted to MB#1		Other Bus Should be available
9	ICT	WBSETCL	400KV/220KV 315 MVA ICT 1 AT JEERAT	D				1	Condition monitoring of CT of both 400 KV and 220 KV side	04 April 2021	08:00 hrs	04 April 2021	15:00 hrs			Other ICT(s) should be available
10	ICT	WBSETCL	400KV/220KV 315 MVA ICT 2 AT JEERAT	D				1	Condition monitoring of CT of both 400 KV and 220 KV side	12 April 2021	08:00 hrs	12 April 2021	15:00 hrs			Other ICT(s) should be available
11	ICT	WBSETCL	400KV/220KV 315 MVA ICT 3 AT JEERAT	D				1	Condition monitoring of CT of both 400 KV and 220 KV side	19 April 2021	08:00 hrs	19 April 2021	15:00 hrs			Other ICT(s) should be available
12	ICT	WBSETCL	400KV/220KV 315 MVA ICT 4 AT JEERAT	D				1	Condition monitoring of CT of both 400 KV and 220 KV side	27 April 2021	08:00 hrs	27 April 2021	15:00 hrs			Other ICT(s) should be available
13	ICT	WBSETCL	400KV/220KV 315 MVA ICT 4 AT ARAMBAGH	D				1	CT Tan -Delta	07 April 2021	07:00	07 April 2021	15:00			Other ICT(s) should be available
14	ICT	WBSETCL	400KV/220KV 315 MVA ICT 1 AT KOLAGHAT TPS	C				5	Replacement of 29C, 29D & Relays (PSDF)	11 April 2021	08:00	15 April 2021	17:00	Transformer & Transfer Bus shutdown		Other ICT(s) should be available
15	ICT	WBSETCL	400KV/220KV 315 MVA ICT 1 AT KOLAGHAT TPS	D				1	Testing of retrofitted relays (PSDF)	20 April 2021	08:00	20 April 2021	17:00	Transformer shutdown required		Other ICT(s) should be available
16	ICT	WBSETCL	400KV/220KV 315 MVA ICT 2 AT KOLAGHAT TPS	C				5	Replacement of 29C, 29D & Relays (PSDF)	21 April 2021	08:00	25 April 2021	17:00	Transformer & Transfer Bus shutdown		Other ICT(s) should be available
17	ICT	WBSETCL	400KV/220KV 315 MVA ICT 2 AT KOLAGHAT TPS	D				1	Testing of retrofitted relays (PSDF)	30 April 2021	08:00	30 April 2021	17:00	Transformer shutdown required		Other ICT(s) should be available
18	LINE	WBSETCL	400KV-JEERAT-NEW CHANDITALA-1	D				1	Trimming of Trees	08 April 2021	07:00 hrs	08 April 2021	15:00 hrs			Other Paralle line should be available
19	LINE	WBSETCL	400KV-JEERAT-BAKRESWAR-1	D				1	Trimming of Trees	15 April 2021	07:00 hrs	15 April 2021	15:00 hrs			Other Paralle line should be available
20	LINE	WBSETCL	400KV-JEERAT-SAGARDIGHI-1	D	REPEATED SHUTDOWN			1	Testing of Protection Relay	23 April 2021	07:00 hrs	23 April 2021	15:00 hrs			Other Paralle line should be available
21	LINE	WBSETCL	400KV-RAJARHAT-JEERAT-1	D	REPEATED SHUTDOWN			1	Testing of Protection Relay	30 April 2021	07:00 hrs	30 April 2021	15:00 hrs			Other Paralle line should be available
22	LINE	WBSETCL	220KV-DALKHOLA (WB)-DALKHOLA (PG)-2	D				1	Line & Bay element and line side CTs Maintenance work.	07 April 2021	09:00	07 April 2021	15:00			Other Paralle line should be available
23	LINE	WBSETCL	132KV-BAISI-DALKHOLA(WB)-1	D			BSEB	1	Line & Bay element and line side CTs Maintenance work.	08 April 2021	09:00	08 April 2021	15:00			Other Paralle line should be available
24	LINE	WBSETCL	400KV-NEW PPSP-ARAMBAGH-1	D				1	Tree trimming	12 April 2021	07:00	12 April 2021	15:00			Other Paralle line should be available
25	LINE	WBSETCL	400KV-NEW PPSP-ARAMBAGH-2	D				1	Tree trimming	13 April 2021	07:00	13 April 2021	15:00			Other Paralle line should be available
26	LINE	WBSETCL	400KV-ARAMBAGH-NEW CHANDITALA-1	D				1	Bay Maintenance and Tree trimming	19 April 2021	07:00	19 April 2021	15:00			Other Paralle line should be available
27	LINE	WBSETCL	400KV-KOLAGHAT-ARAMBAGH-1	D				1	Bay Maintenance and Tree trimming	20 April 2021	07:00	20 April 2021	15:00			Other Paralle line should be available
28	LINE	WBSETCL	400KV-ARAMBAGH-BAKRESWAR-1	D				1	Bay Maintenance and Tree trimming	04 April 2021	07:00	04 April 2021	15:00			Other Paralle line should be available
29	LINE	WBSETCL	220KV-SUBHASGRAM(PG)-KLC-1					1	Line & Bay element and line side CTs Maintenance work.	20 April 2021	07:00	20 April 2021	15:00			Other Paralle line should be available
30	LINE	WBSETCL	220KV-SUBHASGRAM(PG)-NEW TOWN-1		REPEATED SHUTDOWN			1	Annual Maintenance & testing works	01 April 2021	07:00	01 April 2021	15:00			Other Paralle line should be available
31	LINE	WBSETCL	220KV-CHANDIL-STPS(WBPDCL)-1	C			JSEB	3	SAS work under PSDF scheme	05 April 2021	08:00 hrs	07 April 2021	17:00 hrs	All associated isolator opens and earth		Other Paralle line should be available
32	LINE	WBSETCL	400KV-BARIPADA-KHARAGPUR-1	D				1	TREE TRIMMING	27 April 2021	07:00	27 April 2021	16:00			Other Paralle line should be available
33	LINE	WBSETCL	400KV-BARIPADA-KHARAGPUR-1	D				1	TREE TRIMMING	28 April 2021	07:00	28 April 2021	16:00			Other Paralle line should be available
34	LINE	WBSETCL	400KV-KHARAGPUR-KOLAGHAT-1	D				1	TREE TRIMMING	19 April 2021	07:00	19 April 2021	16:00			Other Paralle line should be available
35	LINE	WBSETCL	400KV-KHARAGPUR-KOLAGHAT-1	D				1	TREE TRIMMING	20 April 2021	07:00	20 April 2021	16:00			Other Paralle line should be available
36	LINE	WBSETCL	400KV-KOLAGHAT-KHARAGPUR-2	D				1	TREE TRIMMING	21 April 2021	07:00	21 April 2021	16:00			Other Paralle line should be available

37	LINE	WBSETCL	400KV-KOLAGHAT-KHARAGPUR-2	D			1	TREE TRIMMING	22 April 2021	07:00	22 April 2021	16:00			Other Parillel line should be available
38	LINE	WBSETCL	400kv Kharagpur #1	C	Name of element to be confirmed		5	Replacement of Relays (PSDF)	15 April 2021	08:00	19 April 2021	17:00	Feeder shutdown required		Other Parillel line should be available
39	BR	WBSETCL	80MVAR 400KV B/R-1 AT KHARAGPUR	D			1	TAN-DELTA	05 April 2021	10:00	05 April 2021	16:00			Other Shunt Element should be in Service
40	BAY	WBSETCL	400KV MAIN BAY OF ICT I AT KOLAGHAT(WB)	C			6	Replacement of Circuit Breaker (PSDF)	15 April 2021	17:00	20 April 2021	08:00	Feeder diverted through Bus Tie		Element should remain in service
41	BAY	WBSETCL	400KV MAIN BAY OF ICT II AT KOLAGHAT(WB)	C			6	Replacement of Circuit Breaker (PSDF)	25 April 2021	17:00	30 April 2021	08:00	Feeder diverted through Bus Tie		Element should remain in service
42	LINE	MPL	400KV-RANCHI-MAITHON RB-1	D	Reason may be clarified		2	For reliability of Unit#1	01 April 2021	09:00	02 April 2021	18:00			Other Parillel line should be available
43	BUS	MPL	400KV MAIN BUS - 1 AT MAITHON RB	D			2	New tower erection job for FGD Project	01 April 2021	09:00	02 April 2021	18:00			Other Bus Should be available
44	LINE	TPTL	400KV-RANGPO-DIKCHU-1	D	The Shutdown will be reviewed based on hydro situation in April. It may be planned preferably after high hydro. To be clubbed with shutdown for LILO work of Teesta III-Kishanganj	DIKCHU	1	For removing trees and bamboos in the transmission corridor between Tower no 75-76,81-82 & 85-86.	26 April 2021	10:00	26 April 2021	16:00	Regular Maintenance		Other Parillel line should be available
45	LINE	TPTL	400KV-TEESTA-III-DIKCHU-1	D	The Shutdown will be reviewed based on hydro situation in April. It may be planned preferably after high hydro. To be clubbed with shutdown for LILO work of Teesta III-Kishanganj	TEESTA III/ DIKCHU	1	For removing trees and bamboos in the transmission corridor between Tower no 28-29, 30-31,34-35-36-37.	20 April 2021	10:00	20 April 2021	16:00	Regular Maintenance		Other Parillel line should be available
46	ICT	DVC	400KV/220KV 315 MVA ICT 2 AT BOKARO-A TPS	D			1	PMS and Connector tightness	05 April 2021	08:00	05 April 2021	18:00	CTPS-B both units to be on bar		Other ICT(s) should be available
47	ICT	DVC	400KV/220KV 315 MVA ICT 1 AT BOKARO-A TPS	C			11	Oil filtration Purpose	10 April 2021	09:00	20 April 2021	18:00			Other ICT(s) should be available
48	LINE	DVC	132KV-BARHI-RAJGIR-1	D		BSEB	3	Annual maintenance work	15 April 2021	09:00	17 April 2021	15:00			Other Parillel line should be available
49	LINE	DVC	132KV-NALANDA-BARHI(DVC)-1	D		BSEB	2	Annual maintenance work	12 April 2021	09:00	13 April 2021	15:00			Other Parillel line should be available
50	LINE	DVC	400KV-RANCHI-RAGHUNATHPUR-2	D	REPEATED SHUTDOWN		1	Preventive Maintenance Work, Hardware checking, jumper tightening if required and checking of earthings in Loc-339-346	27 April 2021	09:00	27 April 2021	18:00			Other Parillel line should be available
51	LINE	DVC	400KV-RANCHI-RAGHUNATHPUR-3	D	REPEATED SHUTDOWN		1	Preventive Maintenance Work, Hardware checking, jumper tightening if required and checking of earthings in Loc-326-336	28 April 2021	09:00	28 April 2021	18:00			Other Parillel line should be available
52	ICT	DVC	400KV/220KV 315 MVA ICT 1 AT KODARMA	D	alternate ICT may be availed		1	Annual maintenance work	16 April 2021	09:30	16 April 2021	13:00			Other ICT(s) should be available
53	ICT	DVC	400KV/220KV 315 MVA ICT 2 AT KODARMA	D	alternate ICT may be availed		1	Annual maintenance work	16 April 2021	14:00	16 April 2021	17:30			Other ICT(s) should be available
54	LINE	DVC	400KV-DSTPS(ANDAL)-RAGHUNATHPUR-1	D			4	1. Jumper Point tightness Checking work, 2. Hardware Inspection and Insulator Cleaning work, 3. Tower Top Inspection of the Line.	09 April 2021	08:00	12 April 2021	17:00			Other Parillel line should be available
55	LINE	DVC	220KV-BIDHANNAGAR-WARIA-1	D		WB	2	1. Jumper Point tightness Checking work, 2. Hardware Inspection and Insulator Cleaning work, 3. Tower Top Inspection of the Line.	16 April 2021	08:00	17 April 2021	17:00			Other Parillel line should be available
56	LINE	DVC	220KV-BIDHANNAGAR-WARIA-2	D		WB	2	1. Jumper Point tightness Checking work, 2. Hardware Inspection and Insulator Cleaning work, 3. Tower Top Inspection of the Line.	18 April 2021	08:00	19 April 2021	17:00			Other Parillel line should be available
57	LINE	DVC	400KV-RANCHI-RAGHUNATHPUR-1	D	REPEATED SHUTDOWN		2	For Bay Equipment maintenance/ Tightness checking at RTPS	15 April 2021	07:00	16 April 2021	16:00			Other Parillel line should be available
58	LINE	DVC	400KV-RANCHI-RAGHUNATHPUR-2	D	REPEATED SHUTDOWN		1	For Bay Equipment maintenance/ Tightness checking at RTPS	26 April 2021	07:00	26 April 2021	16:00			Other Parillel line should be available
59	LINE	DVC	400KV-RANCHI-RAGHUNATHPUR-3	D	REPEATED SHUTDOWN		1	For Bay Equipment maintenance/ Tightness checking at RTPS	29 April 2021	07:00	29 April 2021	16:00			Other Parillel line should be available
60	BUS	DVC	400KV MAIN BUS - 1 AT MEJIA-B	C			3	For establishment of connectivity on 400 KV MB#1 by fixing fix contact on Bus.	05 April 2021	09:00	07 April 2021	18:00			Other Bus Should be available
61	BUS	DVC	400KV MAIN BUS - 2 AT MEJIA-B	C	Reason may be clarified		3	For establishment of connectivity on 400 KV MB#2 by fixing fix contact on Bus	08 April 2021	09:00	10 April 2021	18:00			Other Bus Should be available
62	LINE	DVC	400KV TRANSFER BUS AT MEJIA-B	C	Reason may be clarified		3	For establishment of connectivity on 400 KV MB#2 by fixing fix contact on Bus	12 April 2021	09:00	14 April 2021	18:00			Other Parillel line should be available
63	LINE	DVC	220KV-MAITHON-DHANBAD-1	D	REPEATED SHUTDOWN		2	1. Jumper Point tightness Checking & Repairing work, 2. Hardware Inspection and Insulator Cleaning/Replacement work.	07 April 2021	08:00	08 April 2021	17:00			Other Parillel line should be available
64	LINE	DVC	220KV-MAITHON-DHANBAD-2	D	REPEATED SHUTDOWN		2	1. Jumper Point tightness Checking & Repairing work, 2. Hardware Inspection and Insulator Cleaning/Replacement work.	15 April 2021	08:00	16 April 2021	17:00			Other Parillel line should be available
65	LINE	DVC	220KV-JINDAL-JAMSHEDPUR-1	D		GRIDCO	1	Replacement of Line side Isolator under the PSDF work	05 April 2021	08:00	05 April 2021	18:00			Other Parillel line should be available
66	BAY	DVC	400KV MAIN BAY OF MEJIA-MAITHON-1 AT MEJIA	C			5	Hydraulic overhauling of 400KV Circuit breaker by OEM	05 April 2021	09:00	09 April 2021	18:00			Element should remain in service

67	BAY	DVC	400KV MAIN BAY OF MEJIA-MAITHON-2 AT MEJIA	C				5	Hydraulic overhauling of 400KV Circuit breaker by OEM	10 April 2021	09:00	14 April 2021	18:00			Element should remain in service
68	BAY	DVC	400KV MAIN BAY OF MEJIA-MAITHON-3 AT MEJIA	C				5	Hydraulic overhauling of 400KV Circuit breaker by OEM	15 April 2021	09:00	19 April 2021	18:00			Element should remain in service
69	BAY	DVC	400KV MAIN BAY OF MEJIA-JAMSHEDPUR AT MEJIA	C				5	Hydraulic overhauling of 400KV Circuit breaker by OEM	20 April 2021	09:00	24 April 2021	18:00			Element should remain in service
70	BAY	DVC	ST#1 BAY AT MEJIA	C				5	Hydraulic overhauling of 400KV Circuit breaker by OEM	25 April 2021	09:00	29 April 2021	18:00			Element should remain in service
71	LINE	ER-II/Odisha	400KV-BARIPADA(PG)-NEW DUBURI-1	D			GRIDCO	1	Line isolator rectification work	01 April 2021	09:00	01 April 2021	17:00			Other Parllel line should be available
72	LINE	ER-II/Odisha	400KV-JAMSHEDPUR-BARIPADA-1	D				1	Line isolator rectification work	03 April 2021	09:00	03 April 2021	17:00			Other Parllel line should be available
74	LINE	ER-II/Odisha	400KV-JEYPORE-BOLANGIR-1	D	May not be allowed with Rengali Indravati		NLDC	1	For attending shutdown nature defects	25 April 2021	08:00	25 April 2021	18:00		ATC-TTC of SR Import to be reduced by 350 MW	Other Parllel line should be available
75	LINE	ER-II/Odisha	400KV-JEYPORE-GAJUWAKA-1	D			NLDC	2	For replacement of porcelain insulator by polymer insulator at major crossing & replacement of PID defect insulator	27 April 2021	08:00	28 April 2021	18:00		ATC-TTC of SR Import to be reduced by 350 MW	Other Parllel line should be available
76	LINE	ER-II/Odisha	400KV-JEYPORE-GAJUWAKA-2	D			NLDC	2	For replacement of porcelain insulator by polymer insulator at major crossing & replacement of PID defect insulator	29 April 2021	08:00	30 April 2021	18:00		ATC-TTC of SR Import to be reduced by 350 MW	Other Parllel line should be available
77	LINE	ER-II/Odisha	400KV-JEYPORE-INDRAVATI-1	D			NLDC	1	For attending shutdown nature defects	26 April 2021	08:00	26 April 2021	18:00		ATC-TTC of SR Import to be reduced by 350 MW	Other Parllel line should be available
78	LINE	ER-II/Odisha	400KV-JHARSUGUDA-RAIGARH-1	D			NLDC	6	Replacement of old defective Porcelain Insulator by CLR	01 April 2021	08:00	06 April 2021	18:00			Other Parllel line should be available
79	LINE	ER-II/Odisha	400KV-JHARSUGUDA-RAIGARH-3	D			NLDC	6	Replacement of old defective Porcelain Insulator by CLR + Line Bay AMP	07 April 2021	08:00	12 April 2021	18:00			Other Parllel line should be available
80	LINE	ER-II/Odisha	400KV-MEERAMUNDALI-TSTPP-2	C	DETAILED STUDY TO BE DONE	DETAILS OF WORK ALONG WITH SKETCH TO BE PROVIDED	NLDC/GRIDCO	10	Line diversion work for construction of Railway track by RVNL & East cost Railway.	01 April 2021	08:00	10 April 2021	17:00			Talcher-Kolar HVDC and other Lines from Talcher Should be available
81	LINE	ER-II/Odisha	400KV-RENGALI-INDRAVATI-1	C	Sr 81 and 127 may not be allowed toghether	DETAILS OF WORK ALONG WITH SKETCH TO BE PROVIDED	NLDC	16	Dismantling of 3 nos. existing towers, installation of 4 nos. New towers under existing line and stringing of 5 nos. span for line diversion work due to construction of new Balangir-Khurda Rail Line under East Cost Railway, Balangir	10 April 2021	09:00	25 April 2021	18:00			Other Parllel line should be available
82	LINE	ER-II/Odisha	400KV-ROURKELA-JHARSUGUDA-1	D				6	Replacement of old defective Porcelain Insulator by CLR	13 April 2021	08:00	18 April 2021	18:00			Other Parllel line should be available
83	LINE	ER-II/Odisha	400KV-TSTPP-MEERAMUNDALI-1	C	DETAILED STUDY TO BE DONE	DETAILS OF WORK ALONG WITH SKETCH TO BE PROVIDED	NLDC/GRIDCO	10	Line diversion work for construction of Railway track by RVNL & East cost Railway.	01 April 2021	08:00	10 April 2021	17:00			Talcher-Kolar HVDC and other Lines from Talcher Should be available
84	LINE	ER-II/Odisha	765KV-ANGUL-JHARSUGUDA-1	D			NLDC	1	Guy Arrangement work	09 April 2021	09:00	09 April 2021	15:00			Other Parllel line should be available
85	LINE	ER-II/Odisha	765KV-DHARAMJAIGARH-JHARSUGUDA-1	D			NLDC	1	Guy Arrangement work	12 April 2021	08:00	12 April 2021	14:00			Other Parllel line should be available
86	LINE	ER-II/Odisha	765KV-JHARSUGUDA-ANGUL-4	D			NLDC	1	Guy Arrangement work	05 April 2021	09:00	05 April 2021	15:00			Other Parllel line should be available
87	LINE	ER-II/Odisha	765KV-JHARSUGUDA-DARLIPALI-2	D			NLDC/NTPC DARLIPALLI	1	Guy Arrangement work	06 April 2021	09:00	06 April 2021	14:00			Other Parllel line should be available
88	LINE	ER-II/Odisha	765KV-JHARSUGUDA-DHARAMJAIGARH-3	D			NLDC	1	Guy Arrangement work	07 April 2021	09:00	07 April 2021	14:00			Other Parllel line should be available
89	LINE	ER-II/Odisha	765KV-JHARSUGUDA-DHARAMJAIGARH-4	D			NLDC	1	Guy Arrangement work	08 April 2021	09:00	08 April 2021	14:00			Other Parllel line should be available
90	AR	ER-II/Odisha	A/R OF 400KV-ANGUL-JITPL-1	D			JITPL	27	Line Auto-reclose switch is to be kept in Non-auto mode For stringing of OPGW under "EASTERN REGION FIBRE OPTIC EXPANSION PROJECT (Reliable Requirement)	04 April 2021	07:00	30 April 2021	17:00			Line Should Remain in service, Line will trip for transient SLG Fault as well

91	AR	ER-II/Odisha	A/R OF 400KV-ANGUL-JITPL-2	D		JITPL	27	Line Auto-reclose switch is to be kept in Non-auto mode For stringing of OPGW under "EASTERN REGION FIBRE OPTIC EXPANSION PROJECT (Reliable Requirement)	04 April 2021	07:00	30 April 2021	17:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
92	AR	ER-II/Odisha	A/R OF 400KV-GMR-ANGUL-1	D		GMR	27	Line Auto-reclose switch is to be kept in Non-auto mode For stringing of OPGW under "EASTERN REGION FIBRE OPTIC EXPANSION PROJECT (Reliable Requirement)	04 April 2021	07:00	30 April 2021	17:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
93	AR	ER-II/Odisha	A/R OF 400KV-GMR-ANGUL-2	D		GMR	27	Line Auto-reclose switch is to be kept in Non-auto mode For stringing of OPGW under "EASTERN REGION FIBRE OPTIC EXPANSION PROJECT (Reliable Requirement)	04 April 2021	07:00	30 April 2021	17:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
94	AR	ER-II/Odisha	A/R OF 765KV-ANGUL-SRIKAKULAM-1	D		NLDC	27	Line Auto-reclose switch is to be kept in Non-auto mode For stringing of OPGW under "EASTERN REGION FIBRE OPTIC EXPANSION PROJECT (Reliable Requirement)	04 April 2021	07:00	30 April 2021	17:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
95	LR	ER-II/Odisha	63MVAR SWITCHABLE L/R OF 400KV-BARIPADA(PG)-NEW DUBURI-1 AT BARIPADA(PG)	C	MAY BE ALLOWED WHEN LINE SD IS PLANNED		1	AMP WORKS	08 April 2021	09:00	08 April 2021	17:00		Other Shunt Element should be in Service
96	LR	ER-II/Odisha	240MVAR SWITCHABLE L/R OF 765KV-ANGUL-SRIKAKULAM-2 AT ANGUL	D	MAY BE ALLOWED WHEN LINE SD IS PLANNED	NLDC	1	Spare rotaion for attending leakages in B-phase	16 April 2021	09:00	16 April 2021	14:00		Other Shunt Element should be in Service
97	LR	ER-II/Odisha	80MVAR SWITCHABLE L/R OF 765KV-ANGUL-SRIKAKULAM-1 AT ANGUL	D	MAY BE ALLOWED WHEN LINE SD IS PLANNED	NLDC	1	Spare rotaion for attending leakages in B-phase	08 April 2021	09:00	08 April 2021	14:00		Other Shunt Element should be in Service
98	LR	ER-II/Odisha	80MVAR SWITCHABLE L/R OF 765KV-ANGUL-SRIKAKULAM-1 AT ANGUL	D	MAY BE ALLOWED WHEN LINE SD IS PLANNED	NLDC	1	Spare rotaion for taking spare unit out of service	12 April 2021	09:00	12 April 2021	14:00		Other Shunt Element should be in Service
99	LR	ER-II/Odisha	50MVAR NON-SWITCHABLE L/R OF 400KV-RENGALI-INDRAVATI-SC AT RENGALI	C		NLDC	13	For Overhauling of NGR & Calibration of OTI & WTI (power interruption to 400 KV Rengali indravati line will be interrupted during switching of the Reactor)	03 April 2021	08:00	15 April 2021	18:00		Other Shunt Element should be in Service
100	LR	ER-II/Odisha	240MVAR SWITCHABLE L/R OF 400KV-ANGUL-JHARSUGUDA-4 AT ANGUL	D	MAY BE ALLOWED WHEN LINE SD IS PLANNED		1	Spare rotaion for taking R ph in service and taking spare unit out of service	06 April 2021	09:00	06 April 2021	14:00		Other Shunt Element should be in Service
101	LR	ER-II/Odisha	240MVAR SWITCHABLE L/R OF 765KV-JHARSUGUDA-ANGUL-4 AT JHARSUGUDA	D	MAY BE ALLOWED WHEN LINE SD IS PLANNED	NLDC	1	Guy Arrangement work	05 April 2021	09:00	05 April 2021	15:00		Other Shunt Element should be in Service
102	LR	ER-II/Odisha	63MVAR SWITCHABLE L/R OF 400KV-PANDIABILI-BARIPADA-1 AT PANDIABILI	D	MAY BE ALLOWED WHEN LINE SD IS PLANNED		1	AMP work(Cap and tan delta test of bushing)	07 April 2021	09:00	07 April 2021	18:00:00		Other Shunt Element should be in Service
103	LR	ER-II/Odisha	240MVAR SWITCHABLE L/R OF 765KV-JHARSUGUDA-ANGUL-1 AT JHARSUGUDA	D	MAY BE ALLOWED WHEN LINE SD IS PLANNED	NLDC	1	Guy Arrangement work	09 April 2021	09:00	09 April 2021	15:00		Other Shunt Element should be in Service
104	LR	ER-II/Odisha	50MVAR SWITCHABLE L/R OF 400KV-BOLANGIR-JEYPORE-1 AT BOLANGIR	D	MAY BE ALLOWED WHEN LINE SD IS PLANNED		1	AMP for 50MVAR Jeypore Line Reactor and AMP for 403R 52CB .	09 April 2021	09:00	09 April 2021	17:00		Other Shunt Element should be in Service
105	LR	ER-II/Odisha	80MVAR L/R OF 400KV-JEYPORE-BOLANGIR AT JEYPORE	D	MAY BE ALLOWED WHEN LINE SD IS PLANNED		1	For AMP works of 80 MVAR L/R	25 April 2021	09:00	25 April 2021	18:00		Other Shunt Element should be in Service
106	BR	ER-II/Odisha	80MVAR 400KV B/R-1 AT NEW DUBURI	D			1	AMP works	14 April 2021	09:00	14 April 2021	17:00		Other Shunt Element should be in Service
107	BR	ER-II/Odisha	80MVAR 400KV B/R-1 AT PANDIABILI	D			1	AMP work(Cap and tan delta test of bushing)	08 April 2021	09:00	08 April 2021	18:00:00		Other Shunt Element should be in Service
108	BR	ER-II/Odisha	125MVAR 400KV B/R-1 AT RENGALI	D			1	For AMP & Calibartion of OTI & WTI	05 April 2021	09:00	05 April 2021	17:00		Other Shunt Element should be in Service
109	BR	ER-II/Odisha	125MVAR 400KV B/R-2 AT RENGALI	D			1	For AMP Work	08 April 2021	09:00	08 April 2021	17:00		Other Shunt Element should be in Service
110	BR	ER-II/Odisha	240MVAR 765KV B/R-1 AT JHARSUGUDA	D		NLDC	1	Guy Arrangement work	02 April 2021	09:00	02 April 2021	17:00		Other Shunt Element should be in Service
111	BR	ER-II/Odisha	125MVAR 400KV B/R-2 AT BARIPADA	D			1	AMP works	05 April 2021	09:00	05 April 2021	17:00		Other Shunt Element should be in Service
112	BR	ER-II/Odisha	125MVAR 400KV B/R-1 AT BARIPADA	D			1	AMP works	07 April 2021	09:00	07 April 2021	17:00		Other Shunt Element should be in Service
113	BUS	ER-II/Odisha	220KV MAIN BUS - 1 AT BARIPADA	D		GRIDCO	1	AMP WORKS	11 April 2021	09:00	11 April 2021	17:00		Other Bus Should be available
114	BUS	ER-II/Odisha	220KV MAIN BUS - 2 AT ROURKELA	D		GRIDCO	1	AMP	01 April 2021	09:00	01 April 2021	18:00		Other Bus Should be available
115	BUS	ER-II/Odisha	400KV MAIN BUS - 2 AT ROURKELA	D		GRIDCO	1	AMP	02 April 2021	09:00	02 April 2021	18:00		Other Bus Should be available
116	BUS	ER-II/Odisha	220KV MAIN BUS - 1 AT JEYPORE	D	May not be allowed with Rengali Indravati	GRIDCO	1	Termination of new constructed Jaynagar 3 & 4 bays by OPTCL with existing 220 kV bus at Jeypore S/s (Outage to be booked under Construction Head)	16 April 2021	09:00	16 April 2021	18:00		Other Bus Should be available
117	BUS	ER-II/Odisha	220KV MAIN BUS - 2 AT JEYPORE	D	May not be allowed with Rengali Indravati	GRIDCO	1	Termination of new constructed Jaynagar 3 & 4 bays by OPTCL with existing 220 kV bus at Jeypore S/s (Outage to be booked under Construction Head)	17 April 2021	09:00	17 April 2021	18:00		Other Bus Should be available
118	FSC	ER-II/Odisha	FSC OF 400KV-RENGALI-INDRAVATI-1 AT RENGALI	C			30	Refurbishment of FSC	01 April 2021	09:00	30 April 2021	17:00	0	
119	STATCOM	ER-II/Odisha	STATCOM AT ROURKELA	D			1	Rotation of Coupling Transformer	05 April 2021	10:00	05 April 2021	11:00		Other Shunt Element should be in Service

120	HVDC	ER-II/Odisha	HVDC 500KV TALCHER POLE 1	D	Shutdown of Rourkela Bus and Talcher Kolar Pole may not be allowed together		NLDC	1	Replacement of L1 Smoothing Reactor from spare (towards Valve side) a flashover i sbeing observed intermittently indicating probable failure of same in future and Replacement of SPART Microcontroller in Valve Cooling System of Pole-1 so as to enable fine control of Valve Cooling Water Inlet Temperature. Remarks: Pole-2 shall run in MR Mode with Powerflow 1250MW.	02 April 2021	07:00	02 April 2021	17:00		Cannot be allowed with Talcher-Meramandali Shutdown
121	ICT	ER-II/Odisha	400KV/220KV 315 MVA ICT 2 AT BOLANGIR	C			GRIDCO	9	Internal inspection and Bushings lead connection checking due to rise in fault gases	01 April 2021	09:00	09 April 2021	18:00		Other ICT(s) should be available
122	ICT	ER-II/Odisha	400KV/220KV 315 MVA ICT 2 AT INDRAVATI.	D			GRIDCO	2	Retrofitting of Numerical Over flux, Directional Over current, REF relay and Checking the healthyness of Aircell of MainTank conservator. During this shutdown Power flow from ICT#2 will be Interrupted.	09 April 2021	08:00	10 April 2021	18:00		Other ICT(s) should be available
123	ICT	ER-II/Odisha	400KV/220KV 315 MVA ICT 1 AT BARIPADA(PG)	D			GRIDCO	1	CT oil leakage arrest WORKS	13 April 2021	08:00	13 April 2021	16:00		Other ICT(s) should be available
124	ICT	ER-II/Odisha	765KV/400KV 1500 MVA ICT 2 AT JHARSUGUDA	D			NLDC	1	Guy Arrangement work	01 April 2021	09:00	01 April 2021	15:00		Other ICT(s) should be available
125	ICT	ER-II/Odisha	765KV/400KV 1500 MVA ICT 1 AT ANGUL	D			NLDC	1	Spare Rotation: Taking ICT I Bph out of service for attending oil leakages	30 April 2021	09:00	30 April 2021	14:00		Other ICT(s) should be available
126	ICT	ER-II/Odisha	765KV/400KV 1500 MVA ICT 2 AT ANGUL	D			NLDC	1	Spare Rotation: Taking spare unit out of service.	15 April 2021	09:00	15 April 2021	14:00		Other ICT(s) should be available
127	ICT	ER-II/Odisha	400KV/220KV 315 MVA ICT 1 AT JEYPORE	C	Sr 81 and 127 may not be allowed together	DETAILS OF WORK ALONG WITH SKETCH TO BE PROVIDED/DAY WISE WORK SCHEDULE TO BE SHARED	GRIDCO/NLDC	13	For 220kV Cable termination and Jumper connection from existing ICT-1 to ICT-3 Transformer Bay. (Outage to be booked under Construction Head)	10 April 2021	09:00	22 April 2021	17:00	ATC-TTC of SR Import to be reduced by 350 MW	Cannot be allowed with Rengali-Indravati
128	ICT	ER-II/Odisha	400KV/220KV 315 MVA ICT 1 AT JEYPORE	D	May not be allowed with Rengali Indravati		GRIDCO/NLDC	1	If the above is not availed in this month, For CSD Commissioning (During this, CB will open and close 2-3 times) and changing ICT-I combination form Unit-I,III, IV to Unit- II, III & IV for charging Unit-II	23 April 2021	10:00	23 April 2021	12:00	ATC-TTC of SR Import to be reduced by 350 MW	Other ICT(s) should be available
129	ICT	ER-II/Odisha	400KV/220KV 315 MVA ICT 2 AT JEYPORE	D			GRIDCO/NLDC	1	For top up oil in conservator of ICT-2 for rectification of low oil level	05 April 2021	10:00	05 April 2021	13:00	ATC-TTC of SR Import to be reduced by 350 MW	Other ICT(s) should be available
130	ICT	ER-II/Odisha	400KV/220KV 315 MVA ICT 1 AT RENGALI	C		Day wise work schedule needs to be provided	GRIDCO	14	Calibration of OTI & WTI. Replacement of damaged gasket	02 April 2021	08:00	15 April 2021	18:00		Other ICT(s) should be available
131	ICT	ER-II/Odisha	400KV/220KV 315 MVA ICT 2 AT RENGALI	D			GRIDCO	2	Calibration of OTI & WTI	01 April 2021	08:00	02 April 2021	18:00		Other ICT(s) should be available
132	ICT	ER-II/Odisha	400KV/220KV 315 MVA ICT 1 AT ROURKELA	D	Parallel ICT will be in service or not		GRIDCO	1	CSD Final Tuning (Multiple times switching On and Switching Off may be required to be done for fine tuning of CSD relay)	06 April 2021	09:00	06 April 2021	13:00		Other ICT(s) should be available
133	ICT	ER-II/Odisha	400KV/220KV 315 MVA ICT 2 AT ROURKELA	D			GRIDCO	1	Connection on Tertiary Bushings of ICT 2 for Subsequent Loading and CSD Final Tuning (Multiple times switching On and Switching Off may be required to be done for fine tuning of CSD relay)	07 April 2021	09:00	07 April 2021	13:00		Other ICT(s) should be available
134	ICT	ER-II/Odisha	765KV/400KV 1500 MVA ICT 4 AT JHARSUGUDA(GIS)	D			NLDC	1	Six Monthly Hot Spare changeover work	03 April 2021	09:00	03 April 2021	13:00		Other ICT(s) should be available
135	ICT	ER-II/Odisha	400KV/220KV 315 MVA ICT 4 AT ROURKELA	D			GRIDCO	1	Connection on Tertiary Bushings of ICT 2 for Subsequent Loading and CSD Final Tuning (Multiple times switching On and Switching Off may be required to be done for fine tuning of CSD relay)	07 April 2021	09:00	07 April 2021	13:00		Other ICT(s) should be available
136	ICT	ER-II/Odisha	220KV/132KV 160 MVA ICT 1 AT BARIPADA.	D			JSEB	1	CT oil leakage arrest WORKS	14 April 2021	08:00	14 April 2021	16:00		Other ICT(s) should be available
137	ICT	ER-II/Odisha	400KV/220KV 500 MVA ICT 1 AT PANDIABILI	D			GRIDCO	1	AMP work(Cap and tan delta test of bushing)	09 April 2021	09:00	09 April 2021	18:00:00		Other ICT(s) should be available
138	ICT	ER-II/Odisha	400KV/220KV 500 MVA ICT 2 AT PANDIABILI	D			GRIDCO	1	AMP work(Cap and tan delta test of bushing)	10 April 2021	09:00	10 April 2021	18:00:00		Other ICT(s) should be available
139	ICT	ER-II/Odisha	400KV/28KV 500 MVA COUPLING TRANSFORMER AT JEYPORE	D				1	For changing Coupling Transformer combination form Unit-R, Y, B to Unit- R,Y,S for charging Unit-S	26 April 2021	10:00	26 April 2021	13:00		Other ICT(s) should be available
140	BAY	ER-II/Odisha	220KV MAIN BAY OF SADEIPALI-2 AT BOLANGIR(PG)	D	Element shall remain in service through Tr bus			1	AMP for 207 52CB and 207 CT	12 April 2021	09:00	12 April 2021	18:00		Element should remain in service
141	BAY	ER-II/Odisha	220KV MAIN BAY OF BOLANGIR(GRIDCO)-4 (FUTURE) AT BOLANGIR(PG)	D	Element shall remain in service through Tr bus			1	AMP for 209 52CB and 209 CT	13 April 2021	09:00	13 April 2021	18:00		Element should remain in service
142	BAY	ER-II/Odisha	400KV TIE BAY OF TSTPP-1 AND FUTURE AT RENGALI	D				1	Replacement of CB Aux Contact	21 April 2021	09:00	21 April 2021	17:00		Element should remain in service
143	BAY	ER-II/Odisha	400KV MAIN BAY OF 765KV/400KV 1500 MVA ICT 4 AT JHARSUGUDA(GIS)	D			NLDC	1	CSD wiring & Tuning work (435 Main Bay of ICT-4)	13 April 2021	09:00	13 April 2021	17:00		Element should remain in service
144	BAY	ER-II/Odisha	400KV TIE BAY OF (765KV/400KV 1500 MVA ICT 3 AND 400KV-OPGC-2) AT JHARSUGUDA(GIS)	D			NLDC	1	CSD Wiring & Tuning work (437 Tie Bay (GIS)	14 April 2021	09:00	14 April 2021	17:00		Element should remain in service
145	BAY	ER-II/Odisha	400KV MAIN BAY OF 765KV/400KV 1500 MVA ICT 3 AT JHARSUGUDA(GIS)	D			NLDC	1	CSD Wiring & Tuning work -436 Main Bay of ICT-3 (GIS)	15 April 2021	09:00	15 April 2021	17:00		Element should remain in service
146	BAY	ER-II/Odisha	220KV BUS COUPLER BAY AT BARIPADA	D				1	AMP WORKS	06 April 2021	09:00	06 April 2021	17:00		Element should remain in service

147	BAY	ER-II/Odisha	220KV MAIN BAY OF 315MVA ICT-II AT BARIPADA(PG)	D	Element shall remain in service through Tr bus		1	AMP WORKS	07 April 2021	09:00	07 April 2021	17:00		Element should remain in service
148	BAY	ER-II/Odisha	400KV MAIN BAY OF 315MVA ICT-II AT RENGALI(PG)	D			1	Replacement of Faulty Compressor	20 April 2021	09:00	20 April 2021	17:00		Element should remain in service
149	BAY	ER-II/Odisha	400KV MAIN BAY OF 315MVA ICT-II AT BARIPADA(PG)	C			6	CB replacement work	01 April 2021	07:00	06 April 2021	21:00		Element should remain in service
150	BAY	ER-II/Odisha	400KV MAIN BAY OF 63MVAR BR AT JEYPORE	C	May not be allowed with Rengali Indravati		3	ABB CB Drive overhauling work	14 April 2021	09:00	16 April 2021	18:00		Element should remain in service
151	BAY	ER-II/Odisha	400KV MAIN BAY OF GAZUWAKA-I AT JEYPORE	C			3	ABB CB Drive overhauling work	01 April 2021	09:00	03 April 2021	18:00		Element should remain in service
152	BAY	ER-II/Odisha	400KV MAIN BAY OF GAZUWAKA-II AT JEYPORE	C			3	ABB CB Drive overhauling work	05 April 2021	09:00	07 April 2021	18:00		Element should remain in service
153	BAY	ER-II/Odisha	400KV MAIN BAY OF INDRAVATI(GR) AT INDRAVATI(PG)	D	May not be allowed with Rengali Indravati		1	AMP works of UIHEP Main Bay (412) . During this shutdown Power flow will not be Interrupted.	24 April 2021	09:00	24 April 2021	18:00		Element should remain in service
154	BAY	ER-II/Odisha	400KV MAIN BAY OF JEYPORE AT INDRAVATI(PG)	D	May not be allowed with Rengali Indravati		1	AMP works of Jeypore Main Bay (401) . During this shutdown Power flow will not be Interrupted.	22 April 2021	09:00	22 April 2021	18:00		Element should remain in service
155	BAY	ER-II/Odisha	400KV MAIN BAY OF KEONJHOR AT BARIPADA(PG)	C			3	BHEL CB Mechanism overhauling work	01 April 2021	07:00	03 April 2021	17:00 HRS		Element should remain in service
156	BAY	ER-II/Odisha	400KV MAIN BAY OF KEONJHOR AT RENGALI	D			1	To attend hotspot at Isolator contact	16 April 2021	09:00	16 April 2021	17:00		Element should remain in service
157	BAY	ER-II/Odisha	400KV MAIN BAY OF TALCHER I AT RENGALI(PG)	D			1	Replacement of CB Aux Contact	22 April 2021	09:00	22 April 2021	17:00		Element should remain in service
158	BAY	ER-II/Odisha	400KV TIE BAY OF (315MVA ICT-II AND 63MVAR BR) AT JEYPORE	C			3	ABB CB Drive overhauling work	08 April 2021	09:00	10 April 2021	18:00		Element should remain in service
159	BAY	ER-II/Odisha	400KV TIE BAY OF (BOLANGIR AND GAJUWAKA-II) AT JEYPORE	C	May not be allowed with Rengali Indravati		3	ABB CB Drive overhauling work	11 April 2021	09:00	13 April 2021	18:00		Element should remain in service
160	BAY	ER-II/Odisha	400KV TIE BAY OF (INDRAVATI(GR) AND 125MVAR BR-I) AT INDRAVATI(PG)	D			1	AMP works of UHIEP-BR TIE Bay (411). During this shutdown Power flow will not be Interrupted.	16 April 2021	09:00	16 April 2021	18:00		Element should remain in service
161	BAY	ER-II/Odisha	400KV TIE BAY OF (INDRAVATI(PG) AND 125MVAR BR-1) AT RENGALI	D			1	To arrest oil leakage from CT	15 April 2021	09:00	15 April 2021	17:00		Element should remain in service
162	BAY	ER-II/Odisha	400KV TIE BAY OF (KEONJHOR AND 315MVA ICT-I) AT BARIPADA	C			3	BHEL CB Mechanism overhauling work	04 April 2021	07:00	06 April 2021	17:00		Element should remain in service
163	BAY	ER-II/Odisha	400KV TIE BAY OF (KHARAGPUR AND 315MVA ICT-II) AT BARIPADA(PG)	C			3	BHEL CB Mechanism overhauling work	07 April 2021	07:00	09 April 2021	17:00		Element should remain in service
164	BAY	ER-II/Odisha	765KV MAIN BAY OF 1500MVA ICT-I AT JHARSUGUDA	C		NLDC	4	SIEMENS Guide Valve Modification work by OEM Engineer	01 April 2021	09:00	04 April 2021	17:00		Element should remain in service
165	BAY	ER-II/Odisha	765KV MAIN BAY OF 1500MVA ICT-II AT JHARSUGUDA	C		NLDC	4	SIEMENS Guide Valve Modification work by OEM Engineer	05 April 2021	09:00	08 April 2021	17:00		Element should remain in service
166	BAY	ER-II/Odisha	765KV MAIN BAY OF 1500MVA ICT-III AT ANGUL	C		NLDC	5	Modified Guide Valve replacement work	03 April 2021	09:00	07 April 2021	17:00		Element should remain in service
167	BAY	ER-II/Odisha	765KV MAIN BAY OF ANGUL-I AT JHARSUGUDA	C		NLDC	4	SIEMENS Guide Valve Modification work by OEM Engineer	09 April 2021	09:00	12 April 2021	17:00		Element should remain in service
168	BAY	ER-II/Odisha	765KV MAIN BAY OF ANGUL-II AT JHARSUGUDA	C		NLDC	4	SIEMENS Guide Valve Modification work by OEM Engineer	13 April 2021	09:00	16 April 2021	17:00		Element should remain in service
169	BAY	ER-II/Odisha	765KV MAIN BAY OF ANGUL-III AT JHARSUGUDA	C		NLDC	4	SIEMENS Guide Valve Modification work by OEM Engineer	17 April 2021	09:00	20 April 2021	17:00		Element should remain in service
170	BAY	ER-II/Odisha	765KV MAIN BAY OF DHARAMJAIGARH-I AT JHARSUGUDA	C		NLDC	4	SIEMENS Guide Valve Modification work by OEM Engineer	22 April 2021	09:00	25 April 2021	17:00		Element should remain in service
171	BAY	ER-II/Odisha	765KV MAIN BAY OF SRIKAKULAM-I AT ANGUL	C		NLDC	5	Modified Guide Valve replacement work	08 April 2021	09:00	12 April 2021	17:00		Element should remain in service
172	BAY	ER-II/Odisha	765KV MAIN BAY OF SRIKAKULAM-II AT ANGUL	C		NLDC	5	Modified Guide Valve replacement work	13 April 2021	09:00	17 April 2021	17:00		Element should remain in service
173	BAY	ER-II/Odisha	765KV TIE BAY OF (DHARAMJAIGARH-I AND DARLIPALI-II) AT JHARSUGUDA	C		NLDC	4	SIEMENS Guide Valve Modification work by OEM Engineer	26 April 2021	09:00	29 April 2021	17:00		Element should remain in service
174	BAY	ER-II/Odisha	765KV TIE BAY OF (DHARAMJAIGARH-II AND DARLIPALI-I) AT JHARSUGUDA	C		NLDC	4	SIEMENS Guide Valve Modification work by OEM Engineer	11 April 2021	09:00	14 April 2021	17:00		Element should remain in service
175	BAY	ER-II/Odisha	765KV TIE BAY OF (FUTURE AND JHARSUGUDA-III) AT ANGUL	C		NLDC	3	Modified Guide Valve replacement work	28 April 2021	09:00	30 April 2021	17:00		Element should remain in service
176	BAY	ER-II/Odisha	765KV TIE BAY OF (SRIKAKULAM-I AND FUTURE) AT ANGUL	C		NLDC	4	Modified Guide Valve replacement work	19 April 2021	09:00	22 April 2021	17:00		Element should remain in service
177	BAY	ER-II/Odisha	765KV TIE BAY OF (SRIKAKULAM-II AND FUTURE) AT ANGUL	C		NLDC	5	Modified Guide Valve replacement work	23 April 2021	09:00	27 April 2021	17:00		Element should remain in service
178	BAY	ER-II/Odisha	220KV TRANSFER BUS AT BOLANGIR(PG)	D			1	AMP for 210 52CB and 210 CT	14 April 2021	09:00	14 April 2021	18:00		Element should remain in service
179	BAY	ER-II/Odisha	400KV MAIN BAY OF JEYPORE LINE REACTOR AT BOLANGIR	D			1	AMP FOR 403R 52CB	09 April 2021	09:00	09 April 2021	18:00		Element should remain in service
180	BAY	ER-II/Odisha	220KV BUS COUPLER BAY AT ROURKELA	D			1	Overhauling of Isolator Moving Blade	08 April 2021	07:00	08 April 2021	17:00		Element should remain in service
181	BAY	ER-II/Odisha	220KV MAIN BAY OF 315 MVA ICT 2 & ICT 4 AT ROURKELA	D	Element shall remain in service through Tr bus		1	Overhauling of Isolator Moving Blade	09 April 2021	07:00	09 April 2021	17:00		Element should remain in service
182	BAY	ER-II/Odisha	220KV MAIN BAY OF 315MVA ICT-I & ICT 3 AT ROURKELA	D	Element shall remain in service through Tr bus		1	Overhauling of Isolator Moving Blade	10 April 2021	07:00	10 April 2021	17:00		Element should remain in service
183	BAY	ER-II/Odisha	220KV MAIN BAY OF TARKERA-I AT ROURKELA	D	Element shall remain in service through Tr bus		1	Overhauling of Isolator Moving Blade	12 April 2021	07:00	12 April 2021	17:00		Element should remain in service
184	BAY	ER-II/Odisha	220KV MAIN BAY OF TARKERA-II AT ROURKELA	D	Element shall remain in service through Tr bus		1	Overhauling of Isolator Moving Blade	13 April 2021	07:00	13 April 2021	17:00		Element should remain in service
185	BAY	ER-II/Odisha	765KV MAIN BAY OF DHARAMJAIGARH-II AT JHARSUGUDA	C		NLDC	5	SIEMENS Guide Valve Modification work by OEM Engineer	15 April 2021	09:00	19 April 2021	17:00		Element should remain in service
186	LINE	FS TPP	400KV-FSTPP-KHSTPP-1	C	REPEATED SHUTDOWN		3	Annual testing of CB,CT, relay and retrofitting of LBB relay	01 April 2021	09:00	03 April 2021	17:00		Other Partile line should be available

187	LINE	FSTPP	400KV-FSTPP-BAHARAMPUR-2	C	REPEATED SHUTDOWN			3	Annual testing of CB,CT, relay and retrofitting of LBB relay	05 April 2021	09:00	07 April 2021	17:00		Other Parille line should be available
188	LINE	FSTPP	400KV-SAGARDIGHI-FSTPP-1	C	REPEATED SHUTDOWN		WB	3	Annual testing of CB,CT, relay and retrofitting of LBB relay	08 April 2021	09:00	10 April 2021	17:00		Other Parille line should be available
189	LR	BARH	63MVAR SWITCHABLE L/R OF 400KV-BARH-MOTIHARI-1 AT BARH	C	MAY BE ALLOWED WHEN LINE SD IS PLANNED			3	Annual maintenance & testing of line reactor# 2	01 April 2021	09:00	03 April 2021	18:00		Other Shunt Element should be in Service
190	LR	BARH	63MVAR SWITCHABLE L/R OF 400KV-MOTIHARI-BARH-2 AT BARH	C	MAY BE ALLOWED WHEN LINE SD IS PLANNED			3	Annual maintenance & testing of line reactor# 1	07 April 2021	09:00	09 April 2021	18:00		Other Shunt Element should be in Service
191	ICT	BARH	400KV/132KV 200 MVA ICT 1 AT BARH	C				5	Annual maint & testing of ICT-1	12 April 2021	09:00	16 April 2021	18:00		Other ICT(s) should be available
192	LINE	BARH	400KV-BARH-GORAKHPUR-1	C			NLDC	2	For Auto Reclose relay testing, Annual maintenance & testing of bay equipments	22 April 2021	09:00	23 April 2021	18:00		Other Parille line should be available
193	LINE	TSTPP	400KV-TSTPP-ROURKELA-1	C	May not be allowed with Rengali Indravati			10	Replacement of Rourkela-1 line side isolator with earth switch provision. Replacement of Tie CB 552, between Rourkela-1 and ICT-2	12 April 2021	08:00	21 April 2021	17:00		Other Parille line should be available
194	ICT	TSTPP	400KV/220KV 315 MVA ICT 2 AT TSTPP	C	May not be allowed with Rengali Indravati		GRIDCO	2	For replacemnt of ICT-2 CT R phase and Y phase	12 April 2021	08:00	13 April 2021	17:00		Other ICT(s) should be available
195	ICT	TSTPP	400KV/220KV 315 MVA ICT 2 AT TSTPP	D			GRIDCO	1	Connecting IPS of CB.	21 April 2021	08:00	21 April 2021	17:00		Other ICT(s) should be available
196	LINE	TSTPP	400KV-TSTPP-RENGALI-2	C	May not be allowed with Rengali Indravati			9	Replacement of Rengali-2 line side isolator with earth switch provision. Replacement of Main bay CB 1652	23 April 2021	08:00	01 May 2021	17:00		Other Parille line should be available
197	LINE	OPTCL	220KV-TSTPP-MERAMUNDALI-1	D				1	Replacement of wavetrap at Meramundali end	06 April 2021	07:00	06 April 2021	16:00	220kv Meramundali-Kaniha ckt-II will remain in service	Other Parille line should be available
198	LINE	OPTCL	400KV-MERAMUNDALI-LAPANGA-1	D				1	Trimming of tree branches along the corridor of the line	07 April 2021	07:00	07 April 2021	16:00	400kv Meramundali-Lapanga-II will remain in service	Other Parille line should be available
199	LINE	OPTCL	220KV-JODA-RAMCHANDRAPUR-1	D			JSEB	1	Commissioning of Apex-100 energy meter at Joda end	07 April 2021	10:00	07 April 2021	13:00	All other 220kv feeders from Joda shall remain in service	Other Parille line should be available
200	LINE	OPTCL	132KV-JODA-KENDPOSI-1	D			JSEB	1	Commissioning of Apex-100 energy meter at Joda end	07 April 2021	14:00	07 April 2021	17:00	All other 132kv feeders from Joda shall remain in service	Other Parille line should be available
201	LINE	OPTCL	220KV-KEONJHAR(PG)-KEONJHAR(OPTCL)-1	D				1	Commissioning of Apex-100 energy meter at Keonjhar end	08 April 2021	10:00	08 April 2021	13:00	220kv Keonjhar-Keonjhar PG ckt-II will remain in service	Other Parille line should be available
202	LINE	OPTCL	220KV-KEONJHAR(PG)-KEONJHAR(OPTCL)-2	D				1	Commissioning of Apex-100 energy meter at Keonjhar end	08 April 2021	14:00	08 April 2021	17:00	220kv Keonjhar-Keonjhar PG ckt-I will remain in service	Other Parille line should be available
203	LINE	OPTCL	400KV-MERAMUNDALI-MENDHASAL-1	D				1	Trimming of tree branches along the corridor of the line	08 April 2021	08:00	08 April 2021	17:00	400kv Mendhasal-Meramundali Ckt- II & 400kv Pandiabilli ckt-I & II will be in service	Other Parille line should be available
204	LINE	OPTCL	400KV-MERAMUNDALI-LAPANGA-2	D				1	Trimming of branches of trees between loc. Nos. 270-271, 271-272, 272-273, 273-274, 274-275	09 April 2021	08:00	09 April 2021	17:00	400kv Lapanga-Meramundali Ckt- I will remain in service	Other Parille line should be available
205	LINE	OPTCL	220KV-RENGALI(PH)-TSTPP-1	D				1	Installation & testing of Apex-100 energy meter at Rengali PH end	19 April 2021	08:00	19 April 2021	17:00	220kv Rengali PH-TTPS & Kaniha-TTPS will remain in service	Other Parille line should be available
206	LINE	OPTCL	400KV-LAPANGA-OPGC (IB THERMAL)-1	D				1	Trimming of branches of trees between loc. Nos. 70-71, 78-79, 79-80, 80-81, 53-54, 54-55, 63-64	27 April 2021	08:00	27 April 2021	17:00	400kv OPGC- Lapanga Ckt-II will remain in service	Other Parille line should be available
207	LINE	OPTCL	400KV-LAPANGA-OPGC (IB THERMAL)-2	D				1	Trimming of branches of trees between loc. Nos. 70-71, 78-79, 79-80, 80-81, 53-54, 54-55, 63-64	28 April 2021	08:00	28 April 2021	17:00	400kv OPGC- Lapanga Ckt-I will remain in service	Other Parille line should be available
208	AR	OPTCL	A/R OF 400KV-NEW DUBURI-MERAMUNDALI-1	D				61	HOTLINE STRINGING OF OPGW WORK	21 March 2021	07:00	20 May 2021	16:00	400kv Meramundali-New Duburi ckt-I & II will remain in service	Line Should Remain in service, Line will trip for transient SLG Fault as well
209	AR	OPTCL	A/R OF 400KV-NEW DUBURI-MERAMUNDALI-2					61	HOTLINE STRINGING OF OPGW WORK	21 March 2021	07:00	20 May 2021	16:00	400kv Meramundali-New Duburi ckt-I & II will remain in service	Line Should Remain in service, Line will trip for transient SLG Fault as well
210	ICT	OPTCL	400KV/220KV 315 MVA ICT 2 AT MENDHASAL	D				1	Condition monitoring of TRF	06 April 2021	10:00Hrs	06 April 2021	17:00Hrs	315MVA ICT-I & III remain in service	Other ICT(s) should be available
211	LINE	ER-I	765KV-NEW RANCHI-MEDINIPUR-2	D			NLDC/WB	1	SWITCHING OF SPARE REACTOR	26 April 2021	09:00	26 April 2021	17:00		Other Parille line should be available
212	LINE	ER-I	400KV-NEW PURNEA-GOKARNA-1	C	REPEATED SHUTDOWN	DETAILS OF WORK ALONG WITH SKETCH TO BE PROVIDED	WB	15	FOR RESTORATION WORK NEAR GANGA RIVER	01 April 2021	09:00	15 April 2021	17:00		Other Parille line should be available
213	LINE	ER-I	400KV-NEW PURNEA-FSTPP-1	C	REPEATED SHUTDOWN	DETAILS OF WORK ALONG WITH SKETCH TO BE PROVIDED		15	FOR RESTORATION WORK NEAR GANGA RIVER	01 April 2021	09:00	15 April 2021	17:00		Other Parille line should be available
214	LINE	ER-I	132KV-ARRAH (PG)-ARRAH (BSPHCL)-1	D			BSEB	1	Rectification of bellow level in Rph CT AT ARA PG	08 April 2021	09:00	08 April 2021	17:30		Other Parille line should be available
215	LINE	ER-I	220KV-ARRAH (PG)-KHAGAUL-1	D			BSEB	1	Main-I Relay retrofitting	19 April 2021	09:00	19 April 2021	17:00		Other Parille line should be available
216	LINE	ER-I	220KV-ARRAH (PG)-KHAGAUL-2	D	Sr 216 and 217 may be clubbed		BSEB	1	Main-I Relay retrofitting	20 April 2021	09:00	20 April 2021	17:00		Other Parille line should be available

217	LINE	ER-I	220KV-ARRAH-KHAGAU-2	D	Sr 216 and 217 may be clubbed		BSEB	1	Energy Meter Replacement in 220 kV Side due to time drift of 13 minutes as mentioned vide email from ERLDC dated 2nd March 2021	20 April 2021	09:00	20 April 2021	11:00			Other Parllel line should be available
218	LINE	ER-I	220KV-DALKHOLA-PURNEA-1	D	MAY BE ALLOWED AFTER 500MVA ICT-3 AT MALDA COMES INTO SERVICE			2	220 KV BUS #2 CONDUCTOR REPLACEMENT WORK	05 April 2021	09:00	06 April 2021	18:00			Other Parllel line should be available
219	LINE	ER-I	220KV-DALKHOLA-PURNEA-2	D	MAY BE ALLOWED AFTER 500MVA ICT-3 AT MALDA COMES INTO SERVICE			1	220 KV BUS #2 CONDUCTOR REPLACEMENT WORK	05 April 2021	09:00	05 April 2021	18:00			Other Parllel line should be available
220	LINE	ER-I	220KV-NEW PURNEA-PURNEA-1	D	MAY BE ALLOWED AFTER 500MVA ICT-3 AT MALDA COMES INTO SERVICE			1	LINE BAY AMP WORK AT NEW PURNEA	02 April 2021	9:30 AM	02 April 2021	5:30 PM			Other Parllel line should be available
221	LINE	ER-I	220KV-NEW PURNEA-PURNEA-2	D	MAY BE ALLOWED AFTER 500MVA ICT-3 AT MALDA COMES INTO SERVICE			1	LINE BAY AMP WORK AT NEW PURNEA	03 April 2021	9:30 AM	03 April 2021	5:30 PM			Other Parllel line should be available
222	LINE	ER-I	400KV-BARIPADA-TISCO-1	D			DVC	1	REPLACEMENT OF INSULATORS DAMGED BY MISCREANTS	19 April 2021	09:30	19 April 2021	17:30			Other Parllel line should be available
223	LINE	ER-I	400KV-BIHARSARIFF(PG)-BANKA(PG)-1	D				2	Auto reclose Relay retrofitment work	10 April 2021	10:00	11 April 2021	18:00			Other Parllel line should be available
224	LINE	ER-I	400KV-BIHARSARIFF(PG)-BANKA(PG)-2	D				2	Autoreclose Relay retrofitment work	12 April 2021	10:00	13 April 2021	18:00			Other Parllel line should be available
225	LINE	ER-I	400KV-BIHARSARIFF(PG)-LAKHISARAI(PG)-2	D				2	Relay retrofitment work	08 April 2021	10:00	09 April 2021	18:00			Other Parllel line should be available
226	LINE	ER-I	400KV-BIHARSARIFF(PG)-MUZAFFARPUR(PG)-1	D	REPEATED SHUTDOWN			1	Distance relay, Auto recloser Relay retrofitment work	04 April 2021	10:00	04 April 2021	20:00			Other Parllel line should be available
227	LINE	ER-I	400KV-BIHARSARIFF(PG)-MUZAFFARPUR(PG)-2	D	REPEATED SHUTDOWN			1	Auto recloser Relay retrofitment work	05 April 2021	10:00	05 April 2021	20:00			Other Parllel line should be available
228	LINE	ER-I	400KV-BIHARSARIFF(PG)-PUSAULI-1	D		Why line SD required when they can be on AC bypass mode	NLDC	1	TO FACILITATE THE S/D OF HVDC PUSAULI	29 March 2021	08:00	29 March 2021	18:00			Othe Line elements at Pusauli should be available
229	LINE	ER-I	400KV-BIHARSARIFF(PG)-PUSAULI-2	D		Why line SD required when they can be on AC bypass mode	NLDC	1	TO FACILITATE THE S/D OF HVDC PUSAULI	29 March 2021	08:00	29 March 2021	18:00			Othe Line elements at Pusauli should be available
230	LINE	ER-I	400KV-DARBHANGA (DMTCL)-KISHANGANJ(PG)-1	D				1	1) AMP of bay equipments of Main bays ,tie bays & line equipments.2) AMP of reactor	15 April 2021	08:30	15 April 2021	17:30	Tie bay & reactor bay CB required off.		Other Parllel line should be available
231	LINE	ER-I	400KV-GAYA-CHANDWA-1	D				1	FOR REPLACEMENT OF INSULATOR DAMGED BY MISCREANTS	16 April 2021	09:00	16 April 2021	17:00			Other Parllel line should be available
232	LINE	ER-I	400KV-GAYA-CHANDWA-2	D				1	FOR REPLACEMENT OF INSULATOR DAMGED BY MISCREANTS	17 April 2021	09:00	17 April 2021	17:00			Other Parllel line should be available
233	LINE	ER-I	400KV-KHSTPP-BANKA (PG)-2	D		DETAILS OF WORK ALONG WITH SKETCH TO BE PROVIDED		15	OPGW INSTALLATION UNDER KAHALGAON SPLIT BUS SCHEME	01 April 2021	08:00	15 April 2021	18:00			Other Parllel line should be available
234	LINE	ER-I	400KV-KHSTPP-BARH-1	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLY MER INSULATOR	17 April 2021	08:00	17 April 2021	18:00			Other Parllel line should be available
235	LINE	ER-I	400KV-KHSTPP-BARH-2	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLY MER INSULATOR	18 April 2021	08:00	18 April 2021	18:00			Other Parllel line should be available
236	LINE	ER-I	400KV-KISHANGANJ-RANGPO-1	D	The Shutdown will be reviewed based on hydro situation in April. It may be planned preferably after high hydro.			1	1)AMP of bay equipments of Main bays ,tie bays & line equipments 2)Out door Gas density monitor (GDM) cable connector replacement of Line side	01 April 2021	08:30	01 April 2021	17:30	Tie bay CB required off.		Other Parllel line should be available
237	LINE	ER-I	400KV-KISHANGANJ-TEESTA-III-1	D	The Shutdown will be reviewed based on hydro situation in April. It may be planned preferably after high hydro.			1	Out door Gas density monitor (GDM) cable connector replacement of Line side by new one.	05 April 2021	11:00	05 April 2021	16:00	Tie bay CB required off.		After Return of Rangpo-Binaguri DC
238	LINE	ER-I	400KV-KODERMA-BIHARSARIFF(PG)-1	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLYMER INSULATOR	27 April 2021	08:00	27 April 2021	18:00			Other Parllel line should be available
239	LINE	ER-I	400KV-KODERMA-BIHARSARIFF(PG)-2	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLYMER INSULATOR	28 April 2021	08:00	28 April 2021	18:00			Other Parllel line should be available
240	LINE	ER-I	400KV-MAITHON-KHSTPP-1	C		DETAILS OF DIVERSION ALONG WITH SKETCH TO BE PROVIDED		5	Diversion work of 400 kv KHG-FRKK 3&4 TL and 400 kv KHG-MTN 1&2, intermediate reservoir and railway corridor for M/s Adani Power (2x800 MW) Station	12 April 2021	08:00	16 April 2021	17:00			Other Parllel line should be available
241	LINE	ER-I	400KV-MAITHON-KHSTPP-2	C		DETAILS OF DIVERSION ALONG WITH SKETCH TO BE PROVIDED		5	Diversion work of 400 kv KHG-FRKK 3&4 TL and 400 kv KHG-MTN 1&2, intermediate reservoir and railway corridor for M/s Adani Power (2x800 MW) Station	12 April 2021	08:00	16 April 2021	17:00			Other Parllel line should be available
242	LINE	ER-I	400KV-MAITHON-RANCHI-1	C	May not be allowed with 400kV KHSTPP-Maithon D/C	DETAILS OF DIVERSION ALONG WITH SKETCH TO BE PROVIDED		5	DIVERSION WORK OF 400 KV RANCHI-MAITHON & RANCHI-RAGHUNATHPUR FOR NHAI RING ROAD CONSTRUCTION	12 April 2021	08:00	16 April 2021	18:00			Other Parllel line should be available
243	LINE	ER-I	400KV-NABINAGAR(NPGC)-PATNA-1	D			NPGC	1	REPLACEMENT OF FLASHOVER INSULATOR	26 April 2021	08:00	26 April 2021	18:00			Other Parllel line should be available
244	LINE	ER-I	400KV-NEW PURNEA-MUZAFFARPUR-1	D		DETAILS OF WORK ALONG WITH SKETCH TO BE PROVIDED	NLDC	2	For stringing work of LOOP IN Line of LILO of 400KV D/C Kishanganj – Patna Line [Section 28/0 to 29/0] between Loc. No. 301 to 302 of POWERLINK Line	12 April 2021	08:00	13 April 2021	18:00			Other Parllel line should be available
245	LINE	ER-I	400KV-NEW PURNEA-MUZAFFARPUR-2	D		DETAILS OF WORK ALONG WITH SKETCH TO BE PROVIDED	NLDC	2	For stringing work of LOOP OUT Line of LILO of 400KV D/C Kishanganj – Patna Line [Section 11/0 to 12/0] between Loc. No. 302 to 303 of POWERLINK Line.	12 April 2021	08:00	13 April 2021	18:00			Other Parllel line should be available
246	LINE	ER-I	400KV-PATNA-BALIA-1	D			NLDC	1	Flashover insulator replacement	13 April 2021	09:00	13 April 2021	17:00			Other Parllel line should be available

247	LINE	ER-I	400KV-PATNA-BALIA-2	D			NLDC	1	Flashover Insulator replacement	14 April 2021	09:00	14 April 2021	17:00			Other Parilel line should be available
248	LINE	ER-I	400KV-PATNA-BARH-1	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLY MER INSULATOR	07 April 2021	09:00	07 April 2021	17:00			Other Parilel line should be available
249	LINE	ER-I	400KV-PATNA-BARH-2	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLY MER INSULATOR	08 April 2021	09:00	08 April 2021	17:00			Other Parilel line should be available
250	LINE	ER-I	400KV-PATNA-NABINAGAR(NPGC)-2	D			NPGC	1	INSULATOR WASHING WORK AT DIFFERENT LOACATIONS IN HIGHLY POLLUTED AREA	27 April 2021	08:00	27 April 2021	18:00			Other Parilel line should be available
251	LINE	ER-I	400KV-PUSAULI(PG)-ALLAHABAD-1	D		Why line SD required when they can be on AC bypass mode	NLDC	1	TO FACILITATE THE S/D OF HVDC PUSAULI	29 March 2021	08:00	29 March 2021	18:00			Othe Line elements at Pusauli Should be available
252	LINE	ER-I	400KV-PUSAULI(PG)-VARANASI-1	D		Why line SD required when they can be on AC bypass mode	NLDC	1	TO FACILITATE THE S/D OF HVDC PUSAULI	29 March 2021	08:00	29 March 2021	18:00			Othe Line elements at Pusauli Should be available
253	LINE	ER-I	400KV-PUSAULI-PUSAULI-AC BYPASS	D		Why AC bypass SD required ?	NLDC	1	TO FACILITATE THE S/D OF HVDC PUSAULI	29 March 2021	08:00	29 March 2021	18:00			Othe Line elements at Pusauli Should be available
254	LINE	ER-I	400KV-RANCHI-RAGHUNATHPUR-1	C	REPEATED SHUTDOWN	DETAILS OF DIVERSION ALONG WITH SKETCH TO BE PROVIDED		5	DIVERSION WORK OF 400 KV RANCHI-MAITHON & RANCHI-RAGHUNATHPUR FOR NHAI RING ROAD CONSTRUCTION	12 April 2021	08:00	16 April 2021	18:00			Other Parilel line should be available
255	LINE	ER-I	400KV-RANCHI-ROURKELA-1	D				1	Replacement of bent Peak of tower for OPGW at Loc-76. REPLACEMENT OF INSULATOR DAMGED BY MISCREANTS	06 April 2021	08:00	06 April 2021	17:30	Replacement of bent Peak of tower for OPGW at Loc-76.		Other Parilel line should be available
256	LINE	ER-I	400KV-RANCHI-ROURKELA-2	D				1	REPLACEMENT OF INSULATOR DAMGED BY MISCREANTS	08 April 2021	09:30	08 April 2021	17:30			Other Parilel line should be available
257	LINE	ER-I	765KV-FATEHPUR-PUSAULI-1	D			NLDC	2	For Tower rectification work at Loc.no. 326	08 April 2021	08:00	09 April 2021	18:00			Other Parilel line should be available
258	LINE	ER-I	765KV-GAYA-VARANASI-1	D			NLDC	1	Replacement of flashover insulator	06 April 2021	09:00	06 April 2021	17:00			Other Parilel line should be available
259	LINE	ER-I	765KV-GAYA-VARANASI-2	D			NLDC	2	Replacement of flashover insulator	07 April 2021	09:00	08 April 2021	17:00			Other Parilel line should be available
260	LINE	ER-I	765KV-NEW RANCHI-DHARAMJAIGARH-1	D			NLDC	1	For replacement of insulator damaged by miscreants	07 April 2021	09:00	07 April 2021	17:00			Other Parilel line should be available
261	LINE	ER-I	765KV-NEW RANCHI-DHARAMJAIGARH-2	D			NLDC	2	Stability and trip validation with spare reactor and rectification of broken glass insulator	12 April 2021	09:00	13 April 2021	17:00			Other Parilel line should be available
262	LINE	ER-I	400 KV BIHARSHARIF NEW PURNEA-1	D				2	AMP work of line Bay	17 April 2021	11:00	18 April 2021	19:00			Other Parilel line should be available
263	LINE	ER-I	400KV-BIHARSARIF(PG)-MUZAFFARPUR(PG)-1	D	REPEATED SHUTDOWN			5	Porcelain insulator replacement with Polymer	18 April 2021	08:00	22 April 2021	18:00			Other Parilel line should be available
264	LINE	ER-I	400KV-BIHARSARIF(PG)-MUZAFFARPUR(PG)-2	D	REPEATED SHUTDOWN			4	Porcelain insulator replacement with Polymer	22 April 2021	08:00	25 April 2021	18:00			Other Parilel line should be available
265	LINE	ER-I	400KV BARH -PATNA CKT -I	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLYMER INSULATOR	07 April 2021	08:00	07 April 2021	18:00			Other Parilel line should be available
266	LINE	ER-I	400KV BARH- PATNA CKT-II	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLYMER INSULATOR	08 April 2021	08:00	08 April 2021	18:00			Other Parilel line should be available
267	LINE	ER-I	400KV BARH -PATNA CKT -I	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLYMER INSULATOR	09 April 2021	08:00	09 April 2021	18:00			Other Parilel line should be available
268	LINE	ER-I	400KV BARH- PATNA CKT-II	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLYMER INSULATOR	10 April 2021	08:00	10 April 2021	18:00			Other Parilel line should be available
269	LINE	ER-I	400KV BARH -PATNA CKT -I	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLYMER INSULATOR	11 April 2021	08:00	11 April 2021	18:00			Other Parilel line should be available
270	LINE	ER-I	400KV BARH- PATNA CKT-II	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLYMER INSULATOR	12 April 2021	08:00	12 April 2021	18:00			Other Parilel line should be available
271	LINE	ER-I	400KV BARH -PATNA CKT -I	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLYMER INSULATOR	13 April 2021	08:00	13 April 2021	18:00			Other Parilel line should be available
272	LINE	ER-I	400KV BARH- PATNA CKT-II	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLYMER INSULATOR	14 April 2021	08:00	14 April 2021	18:00			Other Parilel line should be available
273	LINE	ER-I	400KV BARH -PATNA CKT -I	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLYMER INSULATOR	15 April 2021	08:00	15 April 2021	18:00			Other Parilel line should be available
274	LINE	ER-I	400KV BARH- PATNA CKT-II	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLYMER INSULATOR	16 April 2021	08:00	16 April 2021	18:00			Other Parilel line should be available
275	LINE	ER-I	400KV BARH- KAHALGAON CKT -I	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLYMER INSULATOR	19 April 2021	08:00	19 April 2021	18:00			Other Parilel line should be available
276	LINE	ER-I	400KV BARH- KAHALGAON CKT -II	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLYMER INSULATOR	20 April 2021	08:00	20 April 2021	18:00			Other Parilel line should be available
277	LINE	ER-I	400KV BARH- KAHALGAON CKT -I	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLYMER INSULATOR	21 April 2021	08:00	21 April 2021	18:00			Other Parilel line should be available
278	LINE	ER-I	400KV BARH- KAHALGAON CKT -II	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLYMER INSULATOR	22 April 2021	08:00	22 April 2021	18:00			Other Parilel line should be available
279	LINE	ER-I	400KV BARH- KAHALGAON CKT -I	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLYMER INSULATOR	23 April 2021	08:00	23 April 2021	18:00			Other Parilel line should be available
280	LINE	ER-I	400KV BARH- KAHALGAON CKT -II	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLYMER INSULATOR	24 April 2021	08:00	24 April 2021	18:00			Other Parilel line should be available
281	LINE	ER-I	400KV BARH- KAHALGAON CKT -I	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLYMER INSULATOR	25 April 2021	08:00	25 April 2021	18:00			Other Parilel line should be available
282	LINE	ER-I	400KV BARH- KAHALGAON CKT -II	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLYMER INSULATOR	26 April 2021	08:00	26 April 2021	18:00			Other Parilel line should be available
283	LINE	ER-I	400KV BIHARSHARIF- KODERMA CKT -I	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLYMER INSULATOR	29 April 2021	08:00	29 April 2021	18:00			Other Parilel line should be available
284	LINE	ER-I	400KV BIHARSHARIF- KODERMA CKT -II	D				1	REPLACEMENT OF PORCELENE INSULATOR WITH POLYMER INSULATOR	30 April 2021	08:00	30 April 2021	18:00			Other Parilel line should be available

285	LINE	ER-I	400KV-NEW PURNEA-MUZAFFARPUR-1	D		DETAILS OF WORK ALONG WITH SKETCH TO BE PROVIDED	NLDC	2	For stringing work of LOOP IN Line of LILO of 400KV D/C Kishanganj – Patna Line (Section 28/0 to 29/0) between Loc. No. 301 to 302 of POWERLINK Line	19 April 2021	08:00	20 April 2021	18:00		Other Parllel line should be available
286	LINE	ER-I	400KV-NEW PURNEA-MUZAFFARPUR-2	D		DETAILS OF WORK ALONG WITH SKETCH TO BE PROVIDED	NLDC	2	For stringing work of LOOP OUT Line of LILO of 400KV D/C Kishanganj – Patna Line (Section 11/0 to 12/0) between Loc. No. 302 to 303 of POWERLINK Line.	19 April 2021	08:00	20 April 2021	18:00		Other Parllel line should be available
287	LINE	ER-I	400KV-FSTPP-KHSTPP-3	C		DETAILS OF DIVERSION ALONG WITH SKETCH TO BE PROVIDED		5	Diversion work of 400 kv KHG-FRKK 3&4 TL and 400 kv KHG-MTN 1&2, intermediate reservoirier and railway corridor for M/s Adani Power (2x800 MW) Station	19 April 2021	08:00	23 April 2021	17:00		Other Parllel line should be available
288	LINE	ER-I	400KV-FSTPP-KHSTPP-4	C		DETAILS OF DIVERSION ALONG WITH SKETCH TO BE PROVIDED		5	Diversion work of 400 kv KHG-FRKK 3&4 TL and 400 kv KHG-MTN 1&2, intermediate reservoirier and railway corridor for M/s Adani Power (2x800 MW) Station	19 April 2021	08:00	23 April 2021	17:00		Other Parllel line should be available
289	LINE	ER-I	220KV-ARRAH (PG)-KHGAUL-1	D			BSEB	1	Energy Meter Replacement in 220 kV Side due to time drift of 11 minutes as mentioned vide email from ERLDC dated 2nd March 2021	19 April 2021	09:00	19 April 2021	11:00		Other Parllel line should be available
290	LINE	ER-I	220KV-ARRAH (PG)-KHGAUL-2	D			BSEB	1	Energy Meter Replacement in 220 kV Side due to time drift of 13 minutes as mentioned vide email from ERLDC dated 2nd March 2021	20 April 2021	09:00	20 April 2021	11:00		Other Parllel line should be available
291	AR	ER-I	A/R OF 220KV-ARRAH (PG)-KHGAUL-1	D				1	TO FACILIATATE THE S/D OF OTHER CKT	20 April 2021	09:00	20 April 2021	17:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
292	AR	ER-I	A/R OF 220KV-ARRAH (PG)-KHGAUL-2	D				1	TO FACILIATATE THE S/D OF OTHER CKT	19 April 2021	09:00	19 April 2021	17:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
293	AR	ER-I	A/R OF 400KV-BIHARSARIFF(PG)- BANKA(PG)-1	D				2	TO FACILITATE THE S/D OF CKT-2	12 April 2021	10:00	13 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
294	AR	ER-I	A/R OF 400KV-BIHARSARIFF(PG)- BANKA(PG)-2	D				2	TO FACILITATE THE S/D OF CKT-1	10 April 2021	10:00	11 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
295	AR	ER-I	A/R OF 400KV-BIHARSARIFF(PG)- LAKHISARA(PG)-1	D				2	TO FACILITATE THE S/D OF CKT-2	08 April 2021	10:00	09 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
296	AR	ER-I	A/R OF 400KV-BIHARSARIFF(PG)- MUZAFFARPUR(PG)-1	D	Please clarify reason for requirement of shutdown			1	TO FACILITATE THE S/D OF CKT-2	05 April 2021	10:00	05 April 2021	20:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
297	AR	ER-I	A/R OF 400KV-BIHARSARIFF(PG)- MUZAFFARPUR(PG)-2	D	Please clarify reason for requirement of shutdown			1	TO FACILITATE THE S/D OF CKT-1	04 April 2021	10:00	04 April 2021	20:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
298	AR	ER-I	A/R OF 400KV-BIHARSARIFF(PG)-PUSAULI-1	D				1	TO FACILITATE THE S/D OF CKT-2	06 April 2021	10:00	06 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
299	AR	ER-I	A/R OF 400KV-GAYA-CHANDWA-1	D				1	TO FACILITATE THE S/D OF OTHER CKT	17 April 2021	09:00	17 April 2021	17:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
300	AR	ER-I	A/R OF 400KV-GAYA-CHANDWA-2	D				1	TO FACILITATE THE S/D OF OTHER CKT	16 April 2021	09:00	16 April 2021	17:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
301	AR	ER-I	A/R OF 400KV-JAMSHEDPUR-BARIPADA-1	D				1	TO FACILITATE THE S/D OF 400 KV BARIPADA- TISCO	19 April 2021	09:30	19 April 2021	17:30		Line Should Remain in service, Line will trip for transient SLG Fault as well
302	AR	ER-I	A/R OF 400KV-KHSTPP-BARH-1	D				1	TO FACILITATE THE S/D OF OTHER CKT	17 April 2021	08:00	17 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
303	AR	ER-I	A/R OF 400KV-KHSTPP-BARH-2	D				1	TO FACILITATE THE S/D OF OTHER CKT	18 April 2021	08:00	18 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
304	AR	ER-I	A/R OF 400KV-KODERMA-BIHARSARIFF(PG)- 1	D				1	TO FACILITATE THE S/D OF OTHER CKT	28 April 2021	08:00	28 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
305	AR	ER-I	A/R OF 400KV-KODERMA-BIHARSARIFF(PG)- 2	D				1	TO FACILITATE THE S/D OF OTHER CKT	27 April 2021	08:00	27 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
306	AR	ER-I	A/R OF 400KV-MOTIHARI-BARH-2	D				30	FOR OPGW INSTALLATION WORK	01 April 2021	08:00	30 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
307	AR	ER-I	A/R OF 400KV-MOTIHARI-GORAKHPUR-A/R MOTIHARI GORAKHPUR II	D			NLDC	30	FOR OPGW INSTALLATION WORK	01 April 2021	08:00	30 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
308	AR	ER-I	A/R OF 400KV-NABINAGAR(NPGC)-PATNA-1	D				1	TO FACILITATE THE S/D OF OTHER CKT	27 April 2021	08:00	27 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
309	AR	ER-I	A/R OF 400KV-PATNA-BALIA-1	D			NLDC	1	TO FACILITATE THE S/D OF OTHER CKT	14 April 2021	09:00	14 April 2021	17:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
310	AR	ER-I	A/R OF 400KV-PATNA-BALIA-2	D			NLDC	1	TO FACILITATE THE S/D OF OTHER CKT	13 April 2021	09:00	13 April 2021	17:00		Line Should Remain in service, Line will trip for transient SLG Fault as well

311	AR	ER-I	A/R OF 400KV-PATNA-BARH-1	D				1	TO FACILITATE THE S/D OF OTHER CKT	08 April 2021	09:00	08 April 2021	17:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
312	AR	ER-I	A/R OF 400KV-PATNA-BARH-2	D				1	TO FACILITATE THE S/D OF OTHER CKT	07 April 2021	09:00	07 April 2021	17:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
313	AR	ER-I	A/R OF 400KV-PATNA-KISHANGANJ-2	D				1	TO FACILITATE THE S/D OF OTHER CKT	08 April 2021	08:30	08 April 2021	17:30		Line Should Remain in service, Line will trip for transient SLG Fault as well
314	AR	ER-I	A/R OF 400KV-PATNA-NABINAGAR(NPGC)-2	D				1	TO FACILITATE THE S/D OF OTHER CKT	26 April 2021	08:00	26 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
315	AR	ER-I	A/R OF 400KV-RANCHI-ROURKELA-1	D				1	TO FACILITATE THE S/D OF OTHER CKT	08 April 2021	08:00	08 April 2021	17:30		Line Should Remain in service, Line will trip for transient SLG Fault as well
316	AR	ER-I	A/R OF 400KV-RANCHI-ROURKELA-2	D				1	TO FACILITATE THE S/D OF OTHER CKT	06 April 2021	08:00	06 April 2021	17:30		Line Should Remain in service, Line will trip for transient SLG Fault as well
317	AR	ER-I	A/R OF 765KV-NEW RANCHI-DHARAMJAIGARH-1	D		NLDC		2	TO FACILITATE THE S/D OF OTHER CKT	12 April 2021	09:00	13 April 2021	17:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
318	AR	ER-I	A/R OF 400 KV BIHARSHARIF NEW PURNEA-2	D				2	TO FACILITATE THE S/D OF CKT-1	17 April 2021	11:00	18 April 2021	19:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
319	AR	ER-I	A/R OF 400KV-BIHARSARIFF(PG)-MUZAFFARPUR(PG)-2	D				4	TO FACILITATE THE S/D OF CKT-1	22 April 2021	10:00	25 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
320	AR	ER-I	A/R OF 400KV-BIHARSARIFF(PG)-MUZAFFARPUR(PG)-1	D				4	TO FACILITATE THE S/D OF CKT-2	18 April 2021	10:00	21 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
321	AR	ER-I	A/R OF 400KV BARH -PATNA CKT -II	D				1	TO FACILITATE THE S/D OF OTHER CKT	07 April 2021	08:00	07 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
322	AR	ER-I	A/R OF 400KV BARH- PATNA CKT-I	D				1	TO FACILITATE THE S/D OF OTHER CKT	08 April 2021	08:00	08 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
323	AR	ER-I	A/R OF 400KV BARH -PATNA CKT -II	D				1	TO FACILITATE THE S/D OF OTHER CKT	09 April 2021	08:00	09 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
324	AR	ER-I	A/R OF 400KV BARH- PATNA CKT-I	D				1	TO FACILITATE THE S/D OF OTHER CKT	10 April 2021	08:00	10 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
325	AR	ER-I	A/R OF 400KV BARH -PATNA CKT -II	D				1	TO FACILITATE THE S/D OF OTHER CKT	11 April 2021	08:00	11 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
326	AR	ER-I	A/R OF 400KV BARH- PATNA CKT-I	D				1	TO FACILITATE THE S/D OF OTHER CKT	12 April 2021	08:00	12 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
327	AR	ER-I	A/R OF 400KV BARH -PATNA CKT -II	D				1	TO FACILITATE THE S/D OF OTHER CKT	13 April 2021	08:00	13 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
328	AR	ER-I	A/R OF 400KV BARH- PATNA CKT-I	D				1	TO FACILITATE THE S/D OF OTHER CKT	14 April 2021	08:00	14 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
329	AR	ER-I	A/R OF 400KV BARH -PATNA CKT -II	D				1	TO FACILITATE THE S/D OF OTHER CKT	15 April 2021	08:00	15 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
330	AR	ER-I	A/R OF 400KV BARH- PATNA CKT-I	D				1	TO FACILITATE THE S/D OF OTHER CKT	16 April 2021	08:00	16 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
331	AR	ER-I	A/R OF 400KV BARH- KAHALGAON CKT -II	D				1	TO FACILITATE THE S/D OF OTHER CKT	19 April 2021	08:00	19 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
332	AR	ER-I	A/R OF 400KV BARH- KAHALGAON CKT -I	D				1	TO FACILITATE THE S/D OF OTHER CKT	20 April 2021	08:00	20 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
333	AR	ER-I	A/R OF 400KV BARH- KAHALGAON CKT -II	D				1	TO FACILITATE THE S/D OF OTHER CKT	21 April 2021	08:00	21 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
334	AR	ER-I	A/R OF 400KV BARH- KAHALGAON CKT -I	D				1	TO FACILITATE THE S/D OF OTHER CKT	22 April 2021	08:00	22 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
335	AR	ER-I	A/R OF 400KV BARH- KAHALGAON CKT -II	D				1	TO FACILITATE THE S/D OF OTHER CKT	23 April 2021	08:00	23 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
336	AR	ER-I	A/R OF 400KV BARH- KAHALGAON CKT -I	D				1	TO FACILITATE THE S/D OF OTHER CKT	24 April 2021	08:00	24 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well
337	AR	ER-I	A/R OF 400KV BARH- KAHALGAON CKT -II	D				1	TO FACILITATE THE S/D OF OTHER CKT	25 April 2021	08:00	25 April 2021	18:00		Line Should Remain in service, Line will trip for transient SLG Fault as well

338	AR	ER-I	A/R OF 400KV BARH- KAHALGAON CKT -I	D				1	TO FACILITATE THE S/D OF OTHER CKT	26 April 2021	08:00	26 April 2021	18:00			Line Should Remain in service, Line will trip for transient SLG Fault as well
339	AR	ER-I	A/R OF 400KV-KODERMA-BIHARSARIFF(PG)-2	D				1	TO FACILITATE THE S/D OF OTHER CKT	29 April 2021	08:00	29 April 2021	18:00			Line Should Remain in service, Line will trip for transient SLG Fault as well
340	AR	ER-I	A/R OF 400KV-KODERMA-BIHARSARIFF(PG)-1	D				1	TO FACILITATE THE S/D OF OTHER CKT	30 April 2021	08:00	30 April 2021	18:00			Line Should Remain in service, Line will trip for transient SLG Fault as well
341	AR	ER-I	A/R OF 400KV-BIHARSARIFF(PG)-BANKA(PG)-2	D				30	FOR OPGW INSTALLATION WORK	01 April 2021	10:00	30 April 2021	18:00			Line Should Remain in service, Line will trip for transient SLG Fault as well
342	AR	ER-I	A/R OF 400KV-PATNA-KISHANGANJ-2	D				30	FOR OPGW INSTALLATION WORK	01 April 2021	08:00	30 April 2021	17:30			Line Should Remain in service, Line will trip for transient SLG Fault as well
343	LR	ER-I	63MVAR SWITCHABLE L/R OF 400KV-BIHARSARIFF(PG)-PUSAULI-1 AT PUSAULI	D	MAY BE ALLOWED WHEN LINE SD IS PLANNED			1	AMP WORK	09 April 2021	10:00	09 April 2021	18:00			Other Shunt Element should be in Service
344	LR	ER-I	240MVAR SWITCHABLE L/R OF 765KV-NEW RANCHI-DHARMAJAYAGARH-2 AT NEW RANCHI	D	MAY BE ALLOWED WHEN LINE SD IS PLANNED		NLDC	1	REACTOR BAY AMP	12 April 2021	09:00	12 April 2021	17:00			Other Shunt Element should be in Service
345	LR	ER-I	240MVAR SWITCHABLE L/R OF 765KV-NEW RANCHI-DHARMAJAYAGARH-1 AT NEW RANCHI	D	MAY BE ALLOWED WHEN LINE SD IS PLANNED		NLDC	1	REACTOR BAY AMP	07 April 2021	09:00	07 April 2021	17:00			Other Shunt Element should be in Service
346	BR	ER-I	80MVAR 400KV B/R-1 AT PATNA	D				1	AMP	12 April 2021	09:00	12 April 2021	17:00			Other Shunt Element should be in Service
347	BR	ER-I	80MVAR 400KV B/R-1 AT LAKHISARAI	D				1	FOR AMP WORK	09 April 2021	09:30	09 April 2021	17:30			Other Shunt Element should be in Service
348	BR	ER-I	125MVAR 400KV B/R-2 AT LAKHISARAI	D				1	FOR AMP WORK	11 April 2021	10:00	11 April 2021	14:00			Other Shunt Element should be in Service
349	BR	ER-I	240MVAR 765KV B/R-1 AT NEW RANCHI	D			NLDC	1	AMP	09 April 2021	09:00	09 April 2021	17:00			Other Shunt Element should be in Service
350	BR	ER-I	125MVAR 400KV B/R-2 AT KISHANGANJ	D				1	FOR AMP WORK	19 April 2021	08:30	19 April 2021	17:30	Tie bay CB required off.		Other Shunt Element should be in Service
351	BR	ER-I	125MVAR 400KV B/R-3 AT BIHARSARIFF	D				1	AMP WORK	04 April 2021	09:00	04 April 2021	18:00			Other Shunt Element should be in Service
352	BR	ER-I	125MVAR 400KV B/R-2 AT PUSAULI	D				1	FOR AMP WORK	05 April 2021	09:00	05 April 2021	18:00			Other Shunt Element should be in Service
353	BUS	ER-I	765KV MAIN BUS - 1 AT NEW RANCHI	D			NLDC	1	Rectification of burnt connector(bus side) of 70489A isolator	05 April 2021	09:00	05 April 2021	17:00			Other Bus Should be available
354	BUS	ER-I	220KV MAIN BUS - 1 AT MUZAFFARPUR	D			BSEB	2	For extension of ICT-IV work (Construction work)	19 April 2021	09:00	20 April 2021	18:00			Other Bus Should be available
355	BUS	ER-I	220KV MAIN BUS - 2 AT MUZAFFARPUR	D			BSEB	1	For extension of ICT-IV work (Construction work)	23 April 2021	09:00	23 April 2021	18:00			Other Bus Should be available
356	BUS	ER-I	220KV MAIN BUS - 1 AT NEW PURNEA	D	MAY BE ALLOWED AFTER 500MVA ICT-3 AT MALDA COMES INTO SERVICE.220KV Bus 1 and Bus 2 at New Purnea may not be allowed together		BSEB	2	FOR AMP WORK	05 April 2021	09:00	06 April 2021	18:00			Both Busses cannot be allowed together
357	BUS	ER-I	220KV MAIN BUS - 2 AT NEW PURNEA	D	MAY BE ALLOWED AFTER 500MVA ICT-3 AT MALDA COMES INTO SERVICE.220KV Bus 1 and Bus 2 at New Purnea may not be allowed together		BSEB	2	FOR AMP WORK	05 April 2021	09:00	06 April 2021	18:00			Both Busses cannot be allowed together
358	BUS	ER-I	400KV MAIN BUS - 1 AT NEW PURNEA	D	MAY BE ALLOWED AFTER 500MVA ICT-3 AT MALDA COMES INTO SERVICE		BSEB	1	FOR AMP WORK	01 April 2021	09:00	01 April 2021	18:00			Other Bus Should be available
359	BUS	ER-I	220KV MAIN BUS - 1 AT KISHANGANJ	D	MAY BE ALLOWED AFTER RESTORATION OF ICT-III AT MALDA		BSEB	1	Bus coupler CB AMP(CRM,DCRM,Dew point measurement)	22 April 2021	09:00	22 April 2021	16:00			Other Bus Should be available
360	BUS	ER-I	220KV MAIN BUS - 1 AT PURNEA(OLD)	D	MAY BE ALLOWED AFTER 500MVA ICT-3 AT MALDA COMES INTO SERVICE		BSEB	2	220 KV BUS #1 CONDUCTOR REPLACEMENT WORK	01 April 2021	09:00	02 April 2021	18:00			Other Bus Should be available
361	BUS	ER-I	220KV MAIN BUS - 2 AT PURNEA(OLD)	D	MAY BE ALLOWED AFTER 500MVA ICT-3 AT MALDA COMES INTO SERVICE.220KV Bus 1 and Bus 2 at New Purnea may not be allowed together		BSEB	5	220 KV BUS #2 CONDUCTOR REPLACEMENT WORK & 220 KV BUS COUPLER BAY CONDUCTOR REPLACEMENT WORK	05 April 2021	09:00	09 April 2021	18:00			May be allowed when both buses at New Purnea Reamain in service
362	BUS	ER-I	400KV MAIN BUS - 1 AT DARBHANGA (DMTCL)	D			BSEB	1	HV Testing of newly installed 400 kV GIS Bays	06 April 2021	08:00	06 April 2021	20:00			Other Bus Should be available
363	BUS	ER-I	400KV MAIN BUS - 2 AT DARBHANGA (DMTCL)	D			BSEB	1	HV Testing of newly installed 400 kV GIS Bays	07 April 2021	08:00	07 April 2021	20:00			Other Bus Should be available
364	BUS	ER-I	400KV MAIN BUS - 1 AT BIHARSARIFF (PG)	D	Shutdown of Biharshariff Bus and New Purnea Bus may not be allowed together		BSEB	1	Isolator AMP work	01 April 2021	10:00	01 April 2021	18:00			Other Bus Should be available
365	BUS	ER-I	400KV MAIN BUS - 2 AT BIHARSARIFF (PG)	D			BSEB	1	Isolator alignment AMP work	02 April 2021	10:00	02 April 2021	18:00			Other Bus Should be available
366	BUS	ER-I	400KV MAIN BUS - 1 AT DARBHANGA (DMTCL)	C	Day wise work schedule needs to shared		BSEB	3	Bus bar protection& final conductor connection	08 April 2021	08:00	10 April 2021	20:00			Other Bus Should be available
367	BUS	ER-I	400KV MAIN BUS - 2 AT DARBHANGA (DMTCL)	C	Why 6 days SD required		BSEB	6	Stability testing of Extensioun bus	10 April 2021	08:00	15 April 2021	20:00			Other Bus Should be available
368	BUS	ER-I	132KV MAIN BUS - 1 AT LAKHISARAI	D			BSEB	1	FOR AMP WORK	23 April 2021	09:30	23 April 2021	17:30	ALL 132 KV LINES WILL BE OUT OF SERVICE		Other Bus Should be available

369	BUS	ER-I	132KV TRANSFER BUS - 1 AT DALTONGANJ	D			BSEB	1	FOR AMP	20 April 2021	09:30	20 April 2021	17:30		Other Bus Should be available
370	BUS	ER-I	132KV MAIN BUS - 1 AT MOTIHARI (DMTCL)	C			BSEB/NLDC	1	HV Testing of newly installed 132 kV GIS Bays	26 April 2021	08:00	26 April 2021	20:00		Other Bus Should be available
371	BUS	ER-I	PUSAULI(PG) - 220KV - BUS 2	D			BSEB	1	FOR AMP WORK	07 April 2021	09:00	07 April 2021	18:00		Other Bus Should be available
372	BUS	ER-I	BIHARSARIFF(PG) - 400KV - BUS 3	D			BSEB	1	AMP work	03 April 2021	10:00	03 April 2021	18:00		Other Bus Should be available
373	BUS	ER-I	BIHARSARIFF(PG) - 400KV - BUS 4	D	Shutdown of Biharhariff Bus and ICT at Patna may not be allowed together		BSEB	1	AMP work	05 April 2021	10:00	05 April 2021	18:00		Other Bus Should be available
374	BUS	ER-I	220KV MAIN BUS - 1 AT PURNEA(OLD)	D			BSEB	1	220 KV BUS COUPLER BAY CONDUCTOR REPLACEMENT WORK	09 April 2021	09:00	09 April 2021	18:00		Other Bus Should be available
375	BUS	ER-I	400KV MAIN BUS - 1 AT DARBHANGA (DMTCL)	D	Day wise work schedule needs to be shared. Both Buses sd may not be allowed together.		BSEB	3	Bus bar protection& final conductor connection	17 April 2021	08:00	19 April 2021	20:00		Other Bus Should be available
376	BUS	ER-I	400KV MAIN BUS - 2 AT DARBHANGA (DMTCL)	D	Day wise work schedule needs to be shared. Both Buses sd may not be allowed together.		BSEB	3	Bus bar protection& final conductor connection	17 April 2021	08:00	19 April 2021	20:00		Other Bus Should be available
377	BUS	ER-I	132 KV Bus 2 AT DMTCL(MOTIHARI)	D			BSEB/NLDC	1	HV Testing of newly installed 132 kV GIS Bays	26 March 2021	08:00	26 March 2021	20:00		Other Bus Should be available
378	BUS	ER-I	132 KV Bus 1 AT DMTCL(MOTIHARI)	D			BSEB/NLDC	1	Bus bar protection argumentation work of newly installed 132 kV GIS Bays	03 April 2021	08:00	03 April 2021	20:00		Other Bus Should be available
379	BUS	ER-I	132 KV Bus 1 AT DMTCL(MOTIHARI)	C			BSEB/NLDC	2	Bus bar protection argumentation work of newly installed 132 kV GIS Bays	04 April 2021	08:00	05 April 2021	20:00		Other Bus Should be available
380	BUS	ER-I	132 kv Bus 2 AT DMTCL(MOTIHARI)	C			BSEB/NLDC	2	Bus bar protection & stability testing and conductor connection	03 April 2021	08:00	04 April 2021	20:00		Other Bus Should be available
381	HVDC	ER-I	800 KV BNC-AGRA POLE I	D			NLDC	1	Earthwire clearance issue at 2515-2516	15 April 2021	10:00	15 April 2021	17:00		0
382	HVDC	ER-I	800KV HVDC BNC-AGRA-POLE-II	D	HVDC Line should remain in service. May be reviewed after high hydro.		NLDC	1	to attend broken jumper from jumper pad T-2235	13 April 2021	10:00	13 April 2021	17:00		0
383	HVDC	ER-I	800KV HVDC BNC - AGRA-POLE 1	D	HVDC Line should remain in service. May be reviewed after high hydro.		NLDC	1	FOR TIGHTENING/INSTALLATION OF JUMPER BOLTS	06 April 2021	09:00	06 April 2021	17:00		0
384	HVDC	ER-I	HVDC 400KV PUSAULI POLE 1				NLDC	1	For Operation Checking of CB,Iso etc. from Mimic Panel	29 March 2021	09:00	29 March 2021	18:00		0
385	ICT	ER-I	400KV/220KV 315 MVA ICT 2 AT BIHARSARIFF	C			BSEB	4	Bushing replacement work	15 April 2021	10:00	18 April 2021	18:00		Other ICT(s) should be available
386	ICT	ER-I	400KV/220KV 315 MVA ICT 3 AT BIHARSARIFF	C			BSEB	4	OLTC Overhauling work	22 April 2021	10:00	25 April 2021	18:00		Other ICT(s) should be available
387	ICT	ER-I	765KV/400KV 1500 MVA ICT 3 AT GAYA	D			NLDC/GAYA	1	FOR AMP WORK	08 April 2021	09:00	08 April 2021	17:00		Other ICT(s) should be available
388	ICT	ER-I	400KV/220KV 315 MVA ICT 3 AT JAMSHEDPUR	D			JSEB	1	Installtion of rain hood on OSR relay. Note : If ICT 3 outage provided with 220kv bay at JUSNL approved on 09.03.2021, 176th OCC serial no. 363 then this outage shall not required.	16 April 2021	09:30	16 April 2021	17:30		Other ICT(s) should be available
389	ICT	ER-I	400KV/220KV 500 MVA ICT 2 AT KISHANGANJ	D	MAY BE ALLOWED AFTER 500MVA ICT-3 AT MALDA COMES INTO SERVICE		BSEB	1	AMP work of ICT & Main Bay	26 April 2021	09:00	26 April 2021	18:00		Other ICT(s) should be available
390	ICT	ER-I	400KV/220KV 500 MVA ICT 1 AT NEW PURNEA	D	MAY BE ALLOWED AFTER 500MVA ICT-3 AT MALDA COMES INTO SERVICE		BSEB	1	Bus-2 Isolator alignment at ICT-1 220 KV Bay(Bay 209).	07 April 2021	09:00	07 April 2021	18:00		Other ICT(s) should be available
391	ICT	ER-I	400KV/220KV 500 MVA ICT 3 AT PATNA	C	Shutdown of Biharhariff Bus and ICT at Patna may not be allowed together		BSEB	2	Oil leakage attend	05 April 2021	09:00	06 April 2021	17:00		Other ICT(s) should be available
392	ICT	ER-I	400KV/132KV 200 MVA ICT 1 AT LAKHISARAI	D			BSEB	1	FOR AMP WORK	01 April 2021	09:30	01 April 2021	17:30		Other ICT(s) should be available
393	ICT	ER-I	400KV/132KV 200 MVA ICT 2 AT LAKHISARAI	D			BSEB	1	FOR AMP WORK	02 April 2021	09:30	02 April 2021	17:30		Other ICT(s) should be available
394	ICT	ER-I	400KV/220KV 315 MVA ICT 2 AT JAMSHEDPUR	D			JSEB	1	Painting of Fire fighting ring pipes. Note : Outage required for compliance of SIR observation point.	22 April 2021	10:00	22 April 2021	13:00		Other ICT(s) should be available
395	ICT	ER-I	220KV/132KV 160 MVA ICT 1 AT PURNEA	D	Sr 396 and 395 may not be allowed together		BSEB	1	220 KV BUS #2 CONDUCTOR REPLACEMENT WORK	06 April 2021	09:00	06 April 2021	18:00		Both ICTs cannot be allowed together
396	ICT	ER-I	220KV/132KV 160 MVA ICT 2 AT PURNEA	D	Sr 396 and 395 may not be allowed together		BSEB	1	220 KV BUS #2 CONDUCTOR REPLACEMENT WORK	06 April 2021	09:00	06 April 2021	18:00		Both ICTs cannot be allowed together
397	ICT	ER-I	220KV/132KV 160 MVA ICT 3 AT PURNEA	D	Sr 397 and 405 may not be allowed together		BSEB	1	220 KV BUS #2 CONDUCTOR REPLACEMENT WORK	08 April 2021	09:00	08 April 2021	18:00		Other ICT(s) should be available
398	ICT	ER-I	400KV/220KV 315 MVA ICT 1 AT RANCHI	D			JSEB	1	AMP	13 April 2021	09:00	13 April 2021	17:30		Other ICT(s) should be available
400	ICT	ER-I	220KV/132KV 100 MVA ICT 2 AT ARRAHA	D			BSEB	1	1. Energy Meter Replacement in 220 kV Side due to time drift of 10 minutes as mentioned vide email from ERLDC dated 2nd March 2021. and 2. Retrofitting of P643 differential relay	05 April 2021	09:00	05 April 2021	17:30		Other ICT(s) should be available
401	ICT	ER-I	400KV/132KV 315 MVA ICT 3 AT LAKHISARAI	D			BSEB	1	FOR AMP WORK	04 April 2021	09:30	04 April 2021	17:30		Other ICT(s) should be available
402	ICT	ER-I	400KV/132KV 315 MVA ICT 3 AT LAKHISARAI	D	Shutdown of Two ICTs at a Time may be explored		BSEB	1	Final commissioning of AVR panel/ Parallel operation of ICT	18 April 2021	09:30	18 April 2021	17:30		Other ICT(s) should be available
403	ICT	ER-I	400KV/132KV 200 MVA ICT 1 AT LAKHISARAI	D	Shutdown of Two ICTs at a Time may be explored		BSEB	1	Commissioning of AVR panel/ Parallel operation of ICT	18 April 2021	09:30	18 April 2021	17:30		Other ICT(s) should be available

404	ICT	ER-I	400KV/132KV 200 MVA ICT 2 AT LAKHISARAI	D	Shutdown of Two ICTs at a Time may be explored		BSEB	1	Commissioning of AVR panel/Parallel operation of ICT	18 April 2021	09:30	18 April 2021	17:30		Other ICT(s) should be available
405	ICT	ER-I	220KV/132KV 160 MVA ICT 1 AT PURNEA	D	Sr 397 and 405 may not be allowed together		BSEB	1	220 KV BUS #2 CONDUCTOR REPLACEMENT WORK	08 April 2021	09:00	08 April 2021	18:00		Other ICT(s) should be available
406	ICT	ER-I	100 MVA 220/132 KV ICT 1 AT ARA (PG)	D			BSEB	1	Rectification of below level in 132 KV Side Bph CT of ICT 1	07 April 2021	09:00	07 April 2021	17:30		Other ICT(s) should be available
407	BAY	ER-I	220KV MAIN BAY OF SAHUPURI-1 AT PUSAULI	D	Element shall remain in service through Tr bus			1	AMP WORK	15 April 2021	09:00	15 April 2021	18:00		Element should remain in service
408	BAY	ER-I	220KV MAIN BAY OF NADHOKAR-2 AT PUSAULI	D	Element shall remain in service through Tr bus			1	AMP WORK	09 April 2021	09:00	09 April 2021	18:00		Element should remain in service
409	BAY	ER-I	400KV MAIN BAY OF (50+125)MVAR B/R-1&4 AT BIHARSARIFF(PG)	D				1	AMP WORK WORK	26 April 2021	09:00	26 April 2021	18:00		Element should remain in service
410	BAY	ER-I	400KV BUS SECTIONALIZER BAY OF (MAIN BUS - 1 AND MAIN BUS - 3) AT BIHARSARIFF	D				1	AMP WORK WORK	23 April 2021	09:00	23 April 2021	18:00		Element should remain in service
411	BAY	ER-I	400KV BUS SECTIONALIZER BAY OF (MAIN BUS - 2 AND MAIN BUS - 4) AT BIHARSARIFF	D				1	AMP WORK WORK	24 April 2021	09:00	24 April 2021	18:00		Element should remain in service
412	BAY	ER-I	220KV MAIN BAY OF NADHOKAR-1 AT PUSAULI	D	Element shall remain in service through Tr bus			1	AMP WORK	13 April 2021	09:00	13 April 2021	18:00		Element should remain in service
413	BAY	ER-I	220KV MAIN BAY OF FATUHA-1 AT PATNA	D	Element shall remain in service through Tr bus			1	AMP WORK	08 April 2021	09:00	08 April 2021	17:00		Element should remain in service
414	BAY	ER-I	220KV MAIN BAY OF 400KV/220KV 500 MVA ICT- 2 AT PATNA	D	Element shall remain in service through Tr bus			1	AMP WORK	10 April 2021	09:00	10 April 2021	17:00		Element should remain in service
415	BAY	ER-I	220KV TRANSFER BUS COUPLER BAY AT PURNEA(OLD)	D				1	220 KV BUS #2 CONDUCTOR REPLACEMENT WORK	06 April 2021	09:00	06 April 2021	18:00		Element should remain in service
416	BAY	ER-I	400KV TIE BAY OF MAITHON-1 AND ICT-1 AT RANCHI	C				2	REPLACEMENT OF SF6 GAS IN Yph	01 April 2021	09:00	02 April 2021	17:30		Element should remain in service
417	BAY	ER-I	400KV TIE BAY OF BALIA-4 AND BARH-4 AT PATNA	D				1	AMP WORK	17 April 2021	09:00	17 April 2021	17:00		Element should remain in service
418	BAY	ER-I	132KV MAIN BAY OF CHHATARPUR I AT DALTONGANJ (PG)	D				1	AMP WORK WORK	09 April 2021	09:00	09 April 2021	17:00		Element should remain in service
419	BAY	ER-I	132KV MAIN BAY OF CHHATARPUR II AT DALTONGANJ (PG)	D				1	AMP WORK WORK	23 April 2021	09:00	23 April 2021	17:00		Element should remain in service
420	BAY	ER-I	220KV BUS COUPLER BAY AT NEW PURNEA	D				1	FOR AMP WORK WORK	19 April 2021	09:00	19 April 2021	18:00		Element should remain in service
421	BAY	ER-I	220KV BUS COUPLER BAY AT PURNEA (PG)	D				1	220 KV BUS #2 CONDUCTOR REPLACEMENT WORK	08 April 2021	09:00	08 April 2021	18:00		Element should remain in service
422	BAY	ER-I	220KV MAIN BAY OF 160MVA ICT-II AT PURNEA (PG)	D	Element shall remain in service through Tr bus			1	220 KV BUS #2 CONDUCTOR REPLACEMENT WORK(BUS JUMPER OPEN/CLOSED)	05 April 2021	09:00	05 April 2021	18:00		Element should remain in service
423	BAY	ER-I	400KV MAIN BAY OF RANCHI-I AT NEW RANCHI	D				1	AMP	19 April 2021	09:00	19 April 2021	17:00		Element should remain in service
424	BAY	ER-I	400KV MAIN BAY OF 125MVAR BR-I AT NEW PURNEA	D				3	MECHANISM OVERHAULING WORK	15 April 2021	09:00	17 April 2021	18:00		Element should remain in service
425	BAY	ER-I	400KV MAIN BAY OF 315MVA ICT-I AT RANCHI	C				2	REPLACEMENT OF SF6 GAS IN Rph	05 April 2021	09:00	06 April 2021	17:30		Element should remain in service
426	BAY	ER-I	400KV MAIN BAY OF 315MVA ICT-II AT RANCHI	C				2	REPLACEMENT OF SF6 GAS IN Yph	07 April 2021	09:00	08 April 2021	17:30		Element should remain in service
427	BAY	ER-I	400KV MAIN BAY OF BALIA-II AT BIHARSARIFF(PG)	D				1	AMP WORK WORK	22 April 2021	10:00	22 April 2021	18:00		Element should remain in service
428	BAY	ER-I	400KV MAIN BAY OF BANKA(PG)-I AT BIHARSARIFF(PG)	D				1	RELAY RETROFITTING WORK	11 April 2021	10:00	11 April 2021	18:00		Element should remain in service
429	BAY	ER-I	400KV MAIN BAY OF BANKA(PG)-II AT BIHARSARIFF(PG)	D				1	RELAY RETROFITTING WORK	12 April 2021	10:00	12 April 2021	18:00		Element should remain in service
430	BAY	ER-I	400KV MAIN BAY OF KHARAGPUR-I AT CHAIBASA	D				1	AMP WORK	06 April 2021	09:30	06 April 2021	17:30		Element should remain in service
431	BAY	ER-I	400KV MAIN BAY OF KHARAGPUR-II AT CHAIBASA(PG)	D				1	AMP WORK	08 April 2021	09:30	08 April 2021	17:30		Element should remain in service
432	BAY	ER-I	400KV MAIN BAY OF LAKHISARAI(PG)-II AT BIHARSARIFF(PG)	D				1	AMP WORK WORK	05 April 2021	10:00	05 April 2021	18:00		Element should remain in service
433	BAY	ER-I	400KV MAIN BAY OF MUZAFFARPUR(PG)-I AT BIHARSARIFF(PG)	D				1	RELAY RETROFITTING WORK	06 April 2021	10:00	06 April 2021	10:00		Element should remain in service
434	BAY	ER-I	400KV MAIN BAY OF MUZAFFARPUR(PG)-II AT BIHARSARIFF(PG)	D				1	RELAY RETROFITTING WORK	07 April 2021	10:00	07 April 2021	10:00		Element should remain in service
435	BAY	ER-I	400KV MAIN BAY OF TENUGHAT-I AT BIHARSARIFF(PG)	D				1	RELAY RETROFITTING WORK	02 April 2021	10:00	02 April 2021	18:00		Element should remain in service
436	BAY	ER-I	400KV MAIN BAY OF TISCO-1 AT JAMSHEDPUR	D				1	Half yearly CB catch gear maintenance of 419 Main bay.	07 April 2021	09:30	07 April 2021	17:30		Element should remain in service
437	BAY	ER-I	400KV TIE BAY OF ((50+125)MVAR 400KV B/R-1 AND PUSAULI-1) AT BIHARSARIFF(PG)	D				1	AMP WORK Work	10 April 2021	10:00	10 April 2021	18:00		Element should remain in service
438	BAY	ER-I	400KV TIE BAY OF (TISCO-1 AND FUTURE) AT JAMSHEDPUR	D				1	Half yearly CB catch gear maintenance of 420 Main bay.	09 April 2021	09:30	09 April 2021	17:30		Element should remain in service
439	BAY	ER-I	400KV TIE BAY OF (BANKA(PG)-I AND BANKA(PG)-II) AT BIHARSARIFF(PG)	D				1	RELAY RETROFITTING WORK	27 April 2021	09:00	27 April 2021	18:00		Element should remain in service
440	BAY	ER-I	400KV TIE BAY OF (BINAGURI-I AND 500MVA ICT-II) AT NEW PURNEA	D				3	MECHANISM OVERHAULING WORK	20 April 2021	09:00	22 April 2021	18:00		Element should remain in service
441	BAY	ER-I	400KV TIE BAY OF (KHARAGPUR-I AND 125MVAR BR-II) AT CHAIBASA(PG)	D				1	AMP WORK	07 April 2021	09:30	07 April 2021	17:30		Element should remain in service
442	BAY	ER-I	400KV TIE BAY OF (KISHANGANJ-I AND MUZAFFARPUR-II) AT NEW PURNEA	D				3	MECHANISM OVERHAULING WORK	12 April 2021	09:00	14 April 2021	18:00		Element should remain in service

443	BAY	ER-I	400KV TIE BAY OF (KODERMA-I AND FUTURE) AT BIHARSARIFF(PG)	D			1	AMP Work	14 April 2021	10:00	14 April 2021	18:00			Element should remain in service
444	BAY	ER-I	400KV TIE BAY OF (MUZAFFARPUR(PG)-I AND MUZAFFARPUR(PG)-II) AT BIHARSARIFF(PG)	D			1	RELAY RETROFITTING WORK	03 April 2021	10:00	03 April 2021	18:00			Element should remain in service
445	BAY	ER-I	400KV TIE BAY OF (MUZAFFARPUR-I AND KISHANGANJ(PG)-II) AT NEW PURNEA	D			1	FOR AMP WORK	09 April 2021	09:00	09 April 2021	18:00			Element should remain in service
446	BAY	ER-I	400KV TIE BAY OF (ROURKELA-II AND BUS REACTOR-I) AT CHAIBASA(PG)	D			1	AMP WORK	09 April 2021	09:30	09 April 2021	17:30			Element should remain in service
447	BAY	ER-I	400KV TIE BAY OF (TENUGHAT AND LAKHISARAI(PG)II) AT BIHARSARIFF	D			1	RELAY RETROFITTING WORK	28 April 2021	10:00	28 April 2021	18:00			Element should remain in service
448	BAY	ER-I	765KV TIE BAY OF (DHARAMJAIGARH-II AND FUTURE) AT NEW RANCHI	D		NLDC	2	Rectification work in future bay side Earth switch	20 April 2021	09:00	21 April 2021	17:00			Element should remain in service
449	BAY	ER-I	220 kV main bay (213) of 400/220 kV 500 MVA ICT-3 at Gaya	D	Element shall remain in service through Tr bus		1	FOR AMP WORK	09 April 2021	09:00	09 April 2021	17:00			Element should remain in service
450	BAY	ER-I	220KV TRANSFER BUS COUPLER BAY AT PURNEA(OLD)	D			1	220 KV BUS #2 CONDUCTOR REPLACEMENT WORK	12 April 2021	09:00	12 April 2021	18:00			Element should remain in service
451	BAY	ER-I	220KV BUS COUPLER BAY AT PURNEA (PG)	D			1	220 KV BUS #2 CONDUCTOR REPLACEMENT WORK	13 April 2021	09:00	13 April 2021	18:00			Element should remain in service
452	BAY	ER-I	220KV TRANSFER BUS COUPLER BAY AT PURNEA(OLD)	D			1	220 KV BUS #2 CONDUCTOR REPLACEMENT WORK(BUS JUMPER OPEN/CLOSED)	08 April 2021	09:00	08 April 2021	18:00			Element should remain in service
453	BAY	ER-I	400KV MAIN BAY OF FARAKKA- 3 AT NTPC KAHALGAON	D		Details & nature of work may be clarified	30	400KV Kahalgaon S/S (NTPC) extension under ERTS-XXIII	05 April 2021	08:00	04 May 2021	17:00			Element should remain in service
454	BAY	ER-I	400KV MAIN BAY OF FARAKKA- 4 AT NTPC KAHALGAON	D		Details & nature of work may be clarified	30	400KV Kahalgaon S/S (NTPC) extension under ERTS-XXIII	06 April 2021	08:00	05 May 2021	17:00			Element should remain in service
455	LINE	JUSNL	220KV-RAMCHANDRAPUR-JAMSHEDPUR-1	D	ICT-1 at Jamshedpur will be out		1	For connection of RTU panel and for checking metering connection at GSS Ramchandrapur.	06 April 2021	11:30	06 April 2021	17:30			Other Parllel line should be available
456	LINE	JUSNL	220KV-RAMCHANDRAPUR-JAMSHEDPUR-2	D			1	For connection of RTU panel at GSS Ramchandrapur.	07 April 2021	11:30	07 April 2021	14:30			Other Parllel line should be available
457	LINE	JUSNL	220KV-RAMCHANDRAPUR-JAMSHEDPUR-3	D	ICT-3 at Jamshedpur will be out		1	For connection of RTU panel at GSS Ramchandrapur.	08 April 2021	11:30	08 April 2021	14:30			Other Parllel line should be available
458	LINE	KHSTPP	400KV-FSTPP-KHSTPP-1	C	REPEATED SHUTDOWN		2	Bay maintenance & relay testing	01 April 2021	09:00	02 April 2021	18:00			Other Parllel line should be available
459	LINE	KHSTPP	400KV-FSTPP-KHSTPP-2	C			2	Bay maintenance & relay testing	08 April 2021	09:00	09 April 2021	18:00			Other Parllel line should be available
460	LINE	BSPTCL	132KV-BANKA (PG)-SABOUR-1	D			1	Line maintenance work	04 April 2021	10:00	04 April 2021	16:00	Sabour will avail power from Goradiah		Other Parllel line should be available
461	LINE	BSPTCL	132KV-BANKA (PG)-SABOUR-2	D			1	Line maintenance work	04 April 2021	10:00	04 April 2021	16:00	Sabour will avail power from Goradiah		Other Parllel line should be available
462	LINE	BSPTCL	132KV-BANKA (PG)-SULTANGANJ-1	D			2	Line maintenance work	11 April 2021	10:00	12 April 2021	16:00	Sultanganj will avail power from Havelikharapur		Other Parllel line should be available
463	LINE	BSPTCL	132KV-BANKA (PG)-SULTANGANJ-2	D			2	Line maintenance work	11 April 2021	10:00	12 April 2021	16:00	Sultanganj will avail power from Havelikharapur		Other Parllel line should be available
464	LINE	BSPTCL	132KV-KAHALGAON(BSEB)-LALMATIA-1	D		JSEB	1	Line maintenance work	09 April 2021	10:00	09 April 2021	16:00	lalmatia may avail power from alternate sources		Other Parllel line should be available
465	LINE	BSPTCL	132KV-KHSTPP-KAHALGAON(BSEB)-1	D			1	Line maintenance work	12 April 2021	10:00	12 April 2021	16:00	lalmatia may avail power from alternate sources		Other Parllel line should be available
467	LINE	BSPTCL	132KV-KHSTPP-SABOUR-1	D			1	Line maintenance work	06 April 2021	10:00	06 April 2021	16:00	Sabour will avail power from Banka(PG)		Other Parllel line should be available
468	LINE	BSPTCL	132KV-LAKHISARAI(PG)-LAKHISARAI(BSEB)-1	D			1	Line maintenance work	05 April 2021	10:00	05 April 2021	16:00	Lakhisarai will avail power from alternate source.		Other Parllel line should be available
469	LINE	BSPTCL	132KV-LAKHISARAI(PG)-LAKHISARAI(BSEB)-2	D			1	Line maintenance work	06 April 2021	10:00	06 April 2021	16:00	Lakhisarai will avail power from alternate source.		Other Parllel line should be available
470	LINE	BSPTCL	132KV-SULTANGANJ-DEOGHAR-1	D		JSEB	2	Line maintenance work	07 April 2021	10:00	08 April 2021	16:00	Deoghar will avail power from alternate source.		Other Parllel line should be available
471	LINE	BSPTCL	220KV-BEGUSARAI-NEW PURNEA-1	D			1	Testing work by Tn C team	10 April 2021	10:00	10 April 2021	16:00	Begusarai will avail power from alternate ckt		Other Parllel line should be available
472	LINE	BSPTCL	220KV-KHAGARIA(NEW)-NEW PURNEA-2	D			1	Testing work by Tn C team	11 April 2021	10:00	11 April 2021	16:00	Begusarai will avail power from alternate ckt		Other Parllel line should be available
473	LINE	BSPTCL	220KV-BODHGAYA-GAYA(PG)-1	D	alternate ckt may be availed		1	Line maintenance work	08 April 2021	10:00	08 April 2021	16:00	Bodhgaya will avail power from Khizersarai		Other Parllel line should be available
474	LINE	BSPTCL	220KV-BODHGAYA-GAYA(PG)-2	D	alternate ckt may be availed		1	Line maintenance work	08 April 2021	10:00	08 April 2021	16:00	Bodhgaya will avail power from Khizersarai		Other Parllel line should be available
475	LINE	BSPTCL	220KV-DEHRI-GAYA-1	D			1	Line maintenance work	12 April 2021	10:00	12 April 2021	16:00	Dehri will avail power from Pusaui		Other Parllel line should be available
476	LINE	BSPTCL	220KV-DEHRI-GAYA-2	D			1	Line maintenance work	12 April 2021	10:00	12 April 2021	16:00	Dehri will avail power from alternate ckt		Other Parllel line should be available

477	LINE	BSPTCL	220KV-PATNA-KHAGAU-2	D				1	Line maintenance work/Safety purpose	01 April 2021	10:00	01 April 2021	16:00	Khagaul will avail power from available 220 KV CKT o Patna(PG).		Other Parllel line should be available
478	LINE	BSPTCL	220KV-PATNA-KHAGAU-3	D				1	Line maintenance work/Safety purpose	01 April 2021	10:00	01 April 2021	16:00	Khagaul will avail power from available 220 KV CKT o Patna(PG).		Other Parllel line should be available
479	LINE	BSPTCL	220KV-PATNA-SIPARA-3	D				1	Line maintenance work	01 April 2021	10:00	01 April 2021	16:00	Sipara will avail power from available 220 KV CKT o Patna(PG).		Other Parllel line should be available
480	LINE	BSPTCL	220KV-PUSAULI-DEHRI-1	D				1	Line maintenance work	01 April 2021	10:00	01 April 2021	16:00	Dehri will avail power from alternate ckt		Other Parllel line should be available
481	LINE	BSPTCL	220KV-PUSAULI-NADHOKAR-1	D	alternate ckt may be availed			1	Line maintenance work	02 April 2021	10:00	02 April 2021	16:00	Nadokhar will avail power from alternate ckt		Other Parllel line should be available
482	LINE	BSPTCL	220KV-PUSAULI-NADHOKAR-2	D	alternate ckt may be availed			1	Line maintenance work	02 April 2021	10:00	02 April 2021	16:00	Nadokhar will avail power from alternate ckt		Other Parllel line should be available
483	LINE	BSPTCL	220KV-PUSAULI-SAHUPURI-1	C	FTC CLEARNCE REQUIRED	DETAILS OF WORK ALONG WITH SKETCH TO BE PROVIDED	NLDC	9	For inline tower erection work for LILO at Karamnasa(New)	20 March 2021	10:00	28 March 2021	16:00			Other Parllel line should be available
484	LINE	BSPTCL	400KV-BIHARSARIFF(PG)-MUZAFFARPUR(PG)-1	D	Shutdown of Biharshariff Bus and Muzaffarpur-Biharshariff line may not be allowed together	DETAILS OF WORK ALONG WITH SKETCH TO BE PROVIDED	NLDC	4	For stringing work of 400 KV D/C Barh-Patna(PG) LILO at Bakhtiyarpur(BSPTCL)	01 April 2021	09:00	04 April 2021	16:00			Other Parllel line should be available
485	LINE	BSPTCL	400KV-BIHARSARIFF(PG)-MUZAFFARPUR(PG)-2	D	Shutdown of Biharshariff Bus and Muzaffarpur-Biharshariff line may not be allowed together	DETAILS OF WORK ALONG WITH SKETCH TO BE PROVIDED	NLDC	4	For stringing work of 400 KV D/C Barh-Patna(PG) LILO at Bakhtiyarpur(BSPTCL)	01 April 2021	09:00	04 April 2021	16:00			Other Parllel line should be available
486	AR	BSPTCL	A/R OF 220KV-PUSAULI(PG)-SAHUPURI(UP) T/L	D			NLDC	14	OPGW work	20 March 2021	10:00	02 April 2021	16:00	Live line OPGW commissioning work		Line Should Remain in service, Line will trip for transient SLG Fault as well
487	LINE	ER-II	220KV-MALDA(PG)-GAZOLE-1	D			WB	1	AMP Work	01 April 2021	08:00	01 April 2021	17:00			Other Parllel line should be available
488	LINE	ER-II	220KV-MALDA(PG)-GAZOLE-2	D			WB	1	Auto-reclose relay retrofitting & checking	20 April 2021	08:00	20 April 2021	17:00			Other Parllel line should be available
489	LINE	ER-II	400KV-NEW PURNEA-GOKARNA-1	D	May be reviewed after WB Election		WB	4	Replacement of Porcelain Insulators by CLR at major crossings	02 April 2021	08:00	05 April 2021	17:00			Other Parllel line should be available
490	LINE	ER-II	400KV-NEW PURNEA-FSTPP-1	D	REPEATED SHUTDOWN			3	Replacement of Porcelain Insulators by CLR at major crossings	10 April 2021	08:00	12 April 2021	17:00			Other Parllel line should be available
491	LINE	ER-II	132KV-CHUZACHEN-RANGPO-1	D	Line shall remain in service		Chuzachen, Sikkim	30	Permission For OPGW installation Work under Fiber Optic Expansion Project (Addl. Requirement)	01 April 2021	07:00 hrs	30 April 2021	18:00 hrs			May be allowed when Chujachen Generation is zero
492	LINE	ER-II	132KV-CHUZACHEN-RANGPO-2	D	Line shall remain in service		Chuzachen, Sikkim	30	Permission For OPGW installation Work under Fiber Optic Expansion Project (Addl. Requirement)	01 April 2021	07:00 hrs	30 April 2021	18:00 hrs			May be allowed when Chujachen Generation is zero
493	LINE	ER-II	132KV-MAITHON-JAMTARA-1	D		DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	JSEB/DVC	3	PL Crossing during Re-conductoring work of Maithon - Right Bank # I Line	24 April 2021	08:00	26 April 2021	18:00			Other Parllel line should be available
494	LINE	ER-II	132KV-RAMKANALI-CTPS-1	D		DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	DVC	1	PL Crossing with 400KV Maithon - Mejia Line for Rectification of Earth Wire Clearance Violation	10 April 2021	08:00	10 April 2021	17:00			Other Parllel line should be available
495	LINE	ER-II	132KV-RAMKANALI-CTPS-2	D		DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	DVC	1	PL Crossing with 400KV Maithon - Mejia Line for Rectification of Earth Wire Clearance Violation	10 April 2021	08:00	10 April 2021	17:00			Other Parllel line should be available
496	LINE	ER-II	132KV-RANGIT-KURSEONG-1	D	REPEATED SHUTDOWN		RANGIT/WB	10	FIXING OF LINE LA ON ALTERNATE DAY BASIS	01 April 2021	08:00	10 April 2021	18:00			496 and 497 to be combined
497	LINE	ER-II	132KV-RANGIT-KURSEONG-1	C	REPEATED simultaneous SHUTDOWN	DETAILS OF WORK ALONG WITH SKETCH TO BE PROVIDED	RANGIT/WB	1	Re-routing of Loc24 due to Hill sinkng	01 April 2021	08:00	01 April 2021	18:00			496 and 497 to be combined
498	LINE	ER-II	132KV-RANGIT-RAMMAM-1	D				2	Sag Correction work at Loc30-31 &73-74 due to hill sinking	16 April 2021	08:00	17 April 2021	18:00			Other Parllel line should be available
499	LINE	ER-II	132KV-RANGIT-RANGPO-1	C	REPEATED simultaneous SHUTDOWN	DETAILS OF WORK ALONG WITH SKETCH TO BE PROVIDED	SIKKIM	12	Re-routing of Loc24 & Tower strenghtening work at Loc3 of LILO	01 April 2021	08:00	12 April 2021	18:00			Rangit will be hanging on Single Synchronized source
500	LINE	ER-II	132KV-RANGPO-GANGTOK-1	D			SIKKIM	1	FOR ANNUAL AMP WORKS	20 April 2021	09:00	20 April 2021	17:00			Other Parllel line should be available
501	LINE	ER-II	132KV-SILIGURI-MELLI-CKT-1	D	Shutdown of Rangit- Rangpo and Siliguri- Melli line may not be allowed together		SIKKIM	10	FIXING OF LINE LA ON ALTERNATE DAY BASIS	01 April 2021	08:00	10 April 2021	18:00			Melli will be on Rangpo
502	LINE	ER-II	132KV-SILIGURI-MELLI-CKT-1	C	REPEATED SHUTDOWN			4	Tower strenghtening work at Loc3 of LILO	09 April 2021	08:00	12 April 2021	18:00			Other Parllel line should be available
503	LINE	ER-II	220KV-ALIPURDUAR (PG)-BIRPARA-1	D	Exact work may be mentioned			3	Shutdown nature defects rectification work	19 April 2021	07:00 Hrs	21 April 2021	17:00 Hrs			Other Parllel line should be available
504	LINE	ER-II	220KV-ALIPURDUAR (PG)-BIRPARA-2	D	Exact work may be mentioned			3	Shutdown nature defects rectification work	22 April 2021	07:00 Hrs	24 April 2021	17:00 Hrs			Other Parllel line should be available
505	LINE	ER-II	220KV-ALIPURDUAR (PG)-SALAKATI-1	D			NLDC	1	to facilitate the replacement / upgradation of 220kV Transfer Bus at Salakati SS under Bay upgradation construction project.	01 April 2021	09:00	01 April 2021	17:00			Other Parllel line should be available

506	LINE	ER-II	220KV-ALIPURDUAR (PG)-SALAKATI-2	D			NLDC	1	to facilitate the replacement / upgradation of 220kV Transfer Bus at Salakati S5 under Bay upgradation construction project.	01 April 2021	09:00	01 April 2021	17:00		Other Parllel line should be available
507	LINE	ER-II	220KV-BINAGURI-BIRPARA-1	C	May be reviewed considering Hydro situation. Shutdown to be requested by MS Railway	DETAILS OF WORK ALONG WITH SKETCH TO BE PROVIDED		30	Railway Diversion work at by 145-146 , Excution by MS Railway	01 April 2021	08:00	30 April 2021	18:00		Other Parllel line should be available
508	LINE	ER-II	220KV-BINAGURI-BIRPARA-1	D	May be clubbed with Sr. 507			1	Shutdown nature defects rectification work	11 April 2021	07:00 Hrs	11 April 2021	17:00 Hrs		Other Parllel line should be available
509	LINE	ER-II	220KV-BINAGURI-BIRPARA-2	C	May be reviewed considering Hydro situation. Shutdown to be requested by MS Railway	DETAILS OF WORK ALONG WITH SKETCH TO BE PROVIDED		30	Railway Diversion work at by 145-146 , Excution by MS Railway	01 April 2021	08:00	30 April 2021	18:00		Other Parllel line should be available
510	LINE	ER-II	220KV-BINAGURI-BIRPARA-2	D	May be clubbed with Sr. 509			1	Shutdown nature defects rectification work	12 April 2021	07:00 Hrs	12 April 2021	17:00 Hrs		Other Parllel line should be available
511	LINE	ER-II	400KV-NEW PURNEA-FSTPP-1	C	REPEATED SHUTDOWN	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED		2	For stringing of powerline crossing AP 5/0 to AP 6/0 for the work of "Bypassing of Kahalgaon-Farakka and Durgapur-Farakka 400 KV lines so as to form Kahalgaon-Durgapur 400 kV D/C Transmission line" under ERSS-XXIII scheme.	27 April 2021	08:00	28 April 2021	17:00		Other Parllel line should be available
512	LINE	ER-II	220KV-JEERAT-SATGACHIA-1	D		DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	WB	2	Stringing b/w AP 4/0 to AP 5/0 of 400 KV D/C Jeerat (New) - Subhasgram TL Over existing 220 KV D/C Satgachia - Jeerat TL (WBSETCL)	27 April 2021	08:00	28 April 2021	17:00		Other Parllel line should be available
513	LINE	ER-II	220KV-JEERAT-SATGACHIA-2	D		DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	WB	2	Stringing b/w AP 4/0 to AP 5/0 of 400 KV D/C Jeerat (New) - Subhasgram TL Over existing 220 KV D/C Satgachia - Jeerat TL (WBSETCL)	27 April 2021	08:00	28 April 2021	17:00		Other Parllel line should be available
514	LINE	ER-II	220KV-JORETHANG-NEW MELLI-2	D			JORETHANG	1	AMP works	15 April 2021	09:00	15 April 2021	18:00		Other Parllel line should be available
515	LINE	ER-II	220KV-MAITHON-DHANBAD-1	C	REPEATED SHUTDOWN	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	DVC	3	PL Crossing during Re-conductoring work of Maithon - Right Bank # I Line	01 April 2021	08:00	03 April 2021	18:00		Other Parllel line should be available
516	LINE	ER-II	220KV-MAITHON-DHANBAD-1	C	REPEATED SHUTDOWN	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	DVC	3	PL Crossing during Re-conductoring work of Maithon - Right Bank # II Line	05 April 2021	08:00	07 April 2021	18:00		Other Parllel line should be available
517	LINE	ER-II	220KV-MAITHON-DHANBAD-1	D	REPEATED SHUTDOWN		DVC	1	Retrofitting work of Bus Bar protection	23 April 2021	08:00	23 April 2021	16:00		Other Parllel line should be available
518	LINE	ER-II	220KV-MAITHON-DHANBAD-2	C	REPEATED SHUTDOWN	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	DVC	3	PL Crossing during Re-conductoring work of Maithon - Right Bank # I Line	01 April 2021	08:00	03 April 2021	18:00		Other Parllel line should be available
519	LINE	ER-II	220KV-MAITHON-DHANBAD-2	C	REPEATED SHUTDOWN	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	DVC	3	PL Crossing during Re-conductoring work of Maithon - Right Bank # II Line	05 April 2021	08:00	07 April 2021	18:00		Other Parllel line should be available
520	LINE	ER-II	220KV-MAITHON-DHANBAD-2	D	REPEATED SHUTDOWN		DVC	1	Retrofitting work of Bus Bar protection	24 April 2021	08:00	24 April 2021	16:00		Other Parllel line should be available
521	LINE	ER-II	220KV-MAITHON-DUMKA-1	D	REPEATED SHUTDOWN	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	JSEB	5	PL Crossing during Re-conductoring work of Maithon - Right Bank # I Line	08 April 2021	08:00	12 April 2021	18:00		Other Parllel line should be available
522	LINE	ER-II	220KV-MAITHON-DUMKA-1	D	REPEATED SHUTDOWN	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	JSEB	5	PL Crossing during Re-conductoring work of Maithon - Right Bank # I Line	19 April 2021	08:00	23 April 2021	18:00		Other Parllel line should be available
523	LINE	ER-II	220KV-MAITHON-DUMKA-1	D	REPEATED SHUTDOWN		JSEB	1	Retrofitting work of Bus Bar protection	27 April 2021	08:00	27 April 2021	16:00		Other Parllel line should be available
524	LINE	ER-II	220KV-MAITHON-DUMKA-2	D	REPEATED SHUTDOWN	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	JSEB	5	PL Crossing during Re-conductoring work of Maithon - Right Bank # II Line	08 April 2021	08:00	12 April 2021	18:00		Other Parllel line should be available
525	LINE	ER-II	220KV-MAITHON-DUMKA-2	D	REPEATED SHUTDOWN	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	JSEB	5	PL Crossing during Re-conductoring work of Maithon - Right Bank # I Line	19 April 2021	08:00	23 April 2021	18:00		Other Parllel line should be available
526	LINE	ER-II	220KV-MAITHON-DUMKA-2	D	REPEATED SHUTDOWN		JSEB	1	Retrofitting work of Bus Bar protection	28 April 2021	08:00	28 April 2021	16:00		Other Parllel line should be available
527	LINE	ER-II	220KV-MAITHON-KALYANESHWARI-1	D			DVC	1	Retrofitting work of Bus Bar protection	25 April 2021	08:00	25 April 2021	16:00		Other Parllel line should be available
528	LINE	ER-II	220KV-MAITHON-KALYANESHWARI-2	D			DVC	1	Retrofitting work of Bus Bar protection	26 April 2021	08:00	26 April 2021	16:00		Other Parllel line should be available
529	LINE	ER-II	220KV-NEW MELLI-JORETHANG-1	D			JORETHANG	1	AMP works	14 April 2021	09:00	14 April 2021	18:00		Other Parllel line should be available
530	LINE	ER-II	220KV-NEW MELLI-TASHIDING-1	D			TASHIDING/JORETHANG	1	AMP works	08 April 2021	09:00	08 April 2021	18:00		Other Parllel line should be available
531	LINE	ER-II	220KV-NEW TOWN(AAA-III)-RAJARHAT-2	D	May be reviewed after WB Election		WB	1	AMP OF GIS BAY.	13 April 2021	07:00:00	13 April 2021	17:00:00		Other Parllel line should be available
532	LINE	ER-II	220KV-NEW TOWN(AA-III)-RAJARHAT-1	D	May be reviewed after WB Election		WB	1	AMP OF GIS BAY.	12 April 2021	07:00:00	12 April 2021	17:00:00		Other Parllel line should be available
533	LINE	ER-II	220KV-RANGPO-NEW MELLI-1	D			TASHIDING/JORETHANG	1	AMP works	07 April 2021	09:00	07 April 2021	18:00		Other Parllel line should be available
534	LINE	ER-II	220KV-SUBHASGRAM(PG)-NEW TOWN-1	D	May be reviewed after WB Election		WB	1	AMP of 205 Bay	06 April 2021	09:00	06 April 2021	17:00		Other Parllel line should be available
535	LINE	ER-II	400KV-ALIPURDUAR (PG)-PUNASANGCHUN-1	D			NLDC	2	Replacement of insulator at major crossing	05 April 2021	0600 hrs:	06 April 2021	1800 hrs.		Other Parllel line should be available
536	LINE	ER-II	400KV-ALIPURDUAR (PG)-PUNASANGCHUN-2	D			NLDC	2	Replacement of insulator at major crossing	07 April 2021	0600 hrs:	08 April 2021	1800 hrs.		Other Parllel line should be available
537	LINE	ER-II	400KV-BAHARAMPUR-BHERAMARA-1	D			NLDC	3	Replacement of insulator at major crossing	12 April 2021	07:00	14 April 2021	16:00		Other Parllel line should be available

538	LINE	ER-II	400KV-BAHARAMPUR-BHERAMARA-2	D			NLDC	3	Replacement of insulator at major crossing	15 April 2021	07:00	17 April 2021	16:00			Other Parillel line should be available
539	LINE	ER-II	400KV-BAHARAMPUR-SAGARDIGHI-1	D			WB	1	Relay and PLCC Testing	21 April 2021	09:00	21 April 2021	17:00			Other Parillel line should be available
540	LINE	ER-II	400KV-BAHARAMPUR-SAGARDIGHI-2	D			WB	1	Relay and PLCC Testing	19 April 2021	09:00	19 April 2021	17:00			Other Parillel line should be available
541	LINE	ER-II	400KV-BINAGURI-BONGAIGAON-1	D	REPEATED SHUTDOWN		NLDC	2	Replacement of insulator at major crossing	11 April 2021	0600 hrs:	12 April 2021	1800 hrs.			Other Parillel line should be available
542	LINE	ER-II	400KV-BINAGURI-BONGAIGAON-2	D	REPEATED SHUTDOWN		NLDC	1	For AMP of Line Reactor at Bongaigaon SS, Both Line and its Reactor will be under shutdown due to clearance issue.	26 April 2021	09:00	26 April 2021	17:00			Other Parillel line should be available
543	LINE	ER-II	400KV-BINAGURI-BONGAIGAON-1	D	REPEATED SHUTDOWN		NLDC	2	Dismantling of Span Marker installed during visit of Honourable Chief Minister, West Bengal and Replacement of insulator at major crossing	13 April 2021	0600 hrs:	14 April 2021	1800 hrs.		May be clubbed with S.No. 541	Other Parillel line should be available
544	LINE	ER-II	400KV-BINAGURI-BONGAIGAON-2	D	REPEATED SHUTDOWN		NLDC	2	For numerical A/R relay retrofitting at Bongaigaon substation.	02 April 2021	09:00	03 April 2021	17:00		May be clubbed with S.No. 542	Other Parillel line should be available
545	LINE	ER-II	400KV-BINAGURI-KISHANGANJ-1	D	The Shutdown will be reviewed based on hydro situation in April. It may be planned preferably after high hydro.			1	Replacement of auto reclosure relay	02 April 2021	08:00	02 April 2021	16:00			Other Parillel line should be available
546	LINE	ER-II	400KV-BINAGURI-KISHANGANJ-2	D	The Shutdown will be reviewed based on hydro situation in April. It may be planned preferably after high hydro.			1	Replacement of auto reclosure relay	03 April 2021	08:00	03 April 2021	16:00			Other Parillel line should be available
547	LINE	ER-II	400KV-BINAGURI-MALBASE-3	D			NLDC	1	Replacement of auto reclosure relay	01 April 2021	08:00	01 April 2021	16:00			Other Parillel line should be available
548	LINE	ER-II	400KV-BINAGURI-NEW PURNEA-1	C	MAY BE ALLOWED WITH AT LEAST ONE CKT RETURNED ON ERS	DAY WISE WORK PLAN/SCHEDULE TO BE PROVIDED	NLDC	16	NHAI Diversion Work	05 April 2021	08:00	20 April 2021	17:00			Other Parillel line should be available
549	LINE	ER-II	400KV-BINAGURI-NEW PURNEA-2	C	MAY BE ALLOWED WITH AT LEAST ONE CKT RETURNED ON ERS	DAY WISE WORK PLAN/SCHEDULE TO BE PROVIDED	NLDC	16	NHAI Diversion Work	05 April 2021	08:00	20 April 2021	17:00			Other Parillel line should be available
550	LINE	ER-II	400KV-BINAGURI-RANGPO-1	C	Can't be allowed due to increasing Hydro generation at Sikkim Complex	STATUS OF WORK DONE NEEDS TO BE SUBMITTED		30	Dismantalling of ACSR Conductor & re-stringing with HTLS Conductor	01 April 2021	08:00	30 April 2021	17:00			Other Parillel line should be available
551	LINE	ER-II	400KV-BINAGURI-RANGPO-2	C	Can't be allowed due to increasing Hydro generation at Sikkim Complex	STATUS OF WORK DONE NEEDS TO BE SUBMITTED		30	Dismantalling of ACSR Conductor & re-stringing with HTLS Conductor	01 April 2021	08:00	30 April 2021	17:00			Other Parillel line should be available
552	LINE	ER-II	400KV-DURGAPUR-FSTPP-1	D				4	Replacement of porcelien with CLR at major crossing (NH, Railway etc.)	10 April 2021	09:00 hrs	13 April 2021	17.00 hrs			Other Parillel line should be available
553	LINE	ER-II	400KV-DURGAPUR-JAMSHEDPUR-1	D				6	Replacement of defective porceline insulator string as per PID result with CLR	12 April 2021	08:00 hrs	17 April 2021	17.00 hrs			Other Parillel line should be available
554	LINE	ER-II	400KV-DURGAPUR-SAGARDIGHI-2	D	Detail shutdown activity may be mentioned		WB	3	Shutdown nature defects rectification work	07 April 2021	09:00	09 April 2021	17:00			Other Parillel line should be available
555	LINE	ER-II	400KV-FSTPP-BAHARAMPUR-1	C	Line and Bus shutdown at Bahrapur may not be allowed together	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	NLDC	2	For stringing of powerline crossing AP 3/0 to AP 4/0 for the work of "Bypassing of Kahalgaoon-Farakka and Durgapur-Farakka 400 KV lines so as to form Kahalgaoon-Durgapur 400 kV D/C Transmission line" under ERSS-XXIII scheme.	20 April 2021	08:00	21 April 2021	17:00			Other Parillel line should be available
556	LINE	ER-II	400KV-FSTPP-BAHARAMPUR-2	C	Line and Bus shutdown at Bahrapur may not be allowed together	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	NLDC	2	For stringing of powerline crossing AP 3/0 to AP 4/0 for the work of "Bypassing of Kahalgaoon-Farakka and Durgapur-Farakka 400 KV lines so as to form Kahalgaoon-Durgapur 400 kV D/C Transmission line" under ERSS-XXIII scheme.	20 April 2021	08:00	21 April 2021	17:00			Other Parillel line should be available
557	LINE	ER-II	400KV-FSTPP-DURGAPUR-1	D				2	Rectification of shutdown nature defects at various locations of TL	16 April 2021	08:00	17 April 2021	17:00			Other Parillel line should be available
558	LINE	ER-II	400KV-FSTPP-MALDA(PG)-1	C	Farakka Malda and Malda Purnea may not be allowed together			2	Distance relay retrofitting	09 April 2021	08:00	10 April 2021	17:00			Other Parillel line should be available
559	LINE	ER-II	400KV-FSTPP-MALDA(PG)-1	D	REPEATED SHUTDOWN			4	Replacement of Porcelain Insulators with CLR Insulators at Major Crossings	15 April 2021	08:00	18 April 2021	17:00			Other Parillel line should be available
560	LINE	ER-II	400KV-FSTPP-MALDA(PG)-2	D				4	Replacement of Porcelain Insulators with CLR Insulators at Major Crossings	19 April 2021	08:00	22 April 2021	17:00			Other Parillel line should be available
561	LINE	ER-II	400KV-JAMSHEDPUR-ANDAL-1	D				2	Replacement of porcelien with CLR at major crossing (NH, Railway etc.)	15 March 2021	09:00 hrs	16 March 2021	17.00 hrs			Other Parillel line should be available
562	LINE	ER-II	400KV-JAMSHEDPUR-ANDAL-2	D				2	Replacement of porcelien with CLR at major crossing (NH, Railway etc.)	17 March 2021	09:00 hrs	18 March 2021	17.00 hrs			Other Parillel line should be available
563	LINE	ER-II	400KV-JAMSHEDPUR-MAITHON-1	D	Sr 563,572 and 584 may not be allowed together	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED		1	PL Crossing with 400KV Maithon - Durgapur Line for Rectification of Earth Wire Clearance Violation	02 April 2021	08:00	02 April 2021	17:00			Other Parillel line should be available
564	LINE	ER-II	400KV-JAMSHEDPUR-MAITHON-1	D	Sr 564,575 and 585 may not be allowed together	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED		1	PL Crossing with 400KV Maithon - Durgapur Line for Rectification of Earth Wire Clearance Violation	03 April 2021	08:00	03 April 2021	17:00			Other Parillel line should be available
565	LINE	ER-II	400KV-JAMSHEDPUR-MAITHON-1	D	REPEATED SHUTDOWN			5	Insulator Replacement work	18 April 2021	08:00	22 April 2021	17:00			Other Parillel line should be available
567	LINE	ER-II	400KV-JAMSHEDPUR-MEJIA-1	D				5	Insulator Replacement work	08 April 2021	08:00	12 April 2021	17:00			Other Parillel line should be available

568	LINE	ER-II	400KV-JEERAT-SAGARDIGHI-1	D	May be reviewed after WB Election		WB	2	Shutdown nature defects rectification work	12 April 2021	09:00	13 April 2021	17:00			Other Parille line should be available
569	LINE	ER-II	400KV-JEERAT-SAGARDIGHI-1	D	May be reviewed after WB Election	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	WB	2	Stringing b/w AP 8/0 to AP 9/0 of 400 KV D/C Jeerat (New) - Subhasgram TL Over existing 400 KV S/C Sagardighi - Jeerat TL (PGCIL)	15 April 2021	08:00	16 April 2021	17:00			Other Parille line should be available
570	LINE	ER-II	400KV-KISHANGANJ(PG)-RANGPO-1	D	The Shutdown will be reviewed based on hydro situation in April. It may be planned preferably after high hydro.			1	AMP & line maintenance Works	16 April 2021	09:00	16 April 2021	17:00			Other Parille line should be available
571	LINE	ER-II	400KV-KISHANGANJ-RANGPO-1	D	The Shutdown will be reviewed based on hydro situation in April. It may be planned preferably after high hydro.	DETAILS OF WORK ALONG WITH SKETCH TO BE PROVIDED		15	For stringing work of 400KV LOOP OUT in Multi Ckt portion in Top Phase of Ckt -1. (Subjected to restoration of 400KV DC Rangpo-Binaguri line)	16 April 2021	08:00	30 April 2021	17:00			Other Parille line should be available
572	LINE	ER-II	400KV-MAITHON-DURGAPUR-1	D	Sr 563,572 and 584 may not be allowed together	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED		1	PL Crossing with 400KV Maithon - Durgapur Line for Rectification of Earth Wire Clearance Violation	02 April 2021	08:00	02 April 2021	17:00			Other Parille line should be available
573	LINE	ER-II	400KV-MAITHON-DURGAPUR-1	D	Sr 573,586 and 589 may not be allowed together	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED		1	PL Crossing with 400KV Maithon - Durgapur Line for Rectification of Earth Wire Clearance Violation	06 April 2021	08:00	06 April 2021	17:00			Other Parille line should be available
574	LINE	ER-II	400KV-MAITHON-DURGAPUR-1	D		DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED		1	PL Crossing with 400KV Maithon - Durgapur Line for Rectification of Earth Wire Clearance Violation	08 April 2021	08:00	08 April 2021	17:00			Other Parille line should be available
575	LINE	ER-II	400KV-MAITHON-DURGAPUR-2	D	Sr 564,575 and 585 may not be allowed together	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED		1	PL Crossing with 400KV Maithon - Durgapur Line for Rectification of Earth Wire Clearance Violation	03 April 2021	08:00	03 April 2021	17:00			Other Parille line should be available
576	LINE	ER-II	400KV-MAITHON-DURGAPUR-2	D	Sr 576,587 and 596 may not be allowed together	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED		1	PL Crossing with 400KV Maithon - Durgapur Line for Rectification of Earth Wire Clearance Violation	07 April 2021	08:00	07 April 2021	17:00			Other Parille line should be available
577	LINE	ER-II	400KV-MAITHON-DURGAPUR-2	D		DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED		1	PL Crossing with 400KV Maithon - Durgapur Line for Rectification of Earth Wire Clearance Violation	09 April 2021	08:00	09 April 2021	17:00			Other Parille line should be available
578	LINE	ER-II	400KV-MAITHON-MAITHON RB-1	C				3	Re conducting work	01 April 2021	08:00	03 April 2021	18:00			MPL generation to be restricted to 850
579	LINE	ER-II	400KV-MAITHON-MAITHON RB-1	C	STATUS OF WORK DONE NEEDS TO BE SUBMITTED.		MPL	15	Re conducting work	19 April 2021	08:00	03 May 2021	18:00			Other Parille line should be available
580	LINE	ER-II	400KV-MAITHON-MAITHON RB-2	C	STATUS OF WORK DONE NEEDS TO BE SUBMITTED.	why simultanueos sd	MPL	15	Re conducting work	04 April 2021	08:00	18 April 2021	18:00			Generation Restriction to MPL will be required
581	LINE	ER-II	400KV-MAITHON-MEJIA-1	D				5	Insulator Replacement work at major crossings	01 April 2021	08:00	05 April 2021	17:00			Other Parille line should be available
582	LINE	ER-II	400KV-MAITHON-MEJIA-2	D		DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED		1	PL Crossing with 400KV Maithon - Durgapur Line for Rectification of Earth Wire Clearance Violation	10 April 2021	08:00	10 April 2021	17:00			Other Parille line should be available
583	LINE	ER-II	400KV-MAITHON-MEJIA-3	D	REPEATED SHUTDOWN			5	Insulator Replacement work	13 April 2021	08:00	17 April 2021	17:00			Other Parille line should be available
584	LINE	ER-II	400KV-MAITHON-MEJIA-3	D	Sr 563,572 and 584 may not be allowed together	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED		1	PL Crossing with 400KV Maithon - Durgapur Line for Rectification of Earth Wire Clearance Violation	02 April 2021	08:00	02 April 2021	17:00			Other Parille line should be available
585	LINE	ER-II	400KV-MAITHON-MEJIA-3	D	Sr 564,575 and 585 may not be allowed together	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED		1	PL Crossing with 400KV Maithon - Durgapur Line for Rectification of Earth Wire Clearance Violation	03 April 2021	08:00	03 April 2021	17:00			Other Parille line should be available
586	LINE	ER-II	400KV-MAITHON-RAGHUNATHPUR-1	D	Sr 573,586 and 589 may not be allowed together	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	MPL	1	PL Crossing with 400KV Maithon - Durgapur Line for Rectification of Earth Wire Clearance Violation	06 April 2021	08:00	06 April 2021	17:00			Other Parille line should be available
587	LINE	ER-II	400KV-MAITHON-RAGHUNATHPUR-1	D	Sr 576,587 and 596 may not be allowed together	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	MPL	1	PL Crossing with 400KV Maithon - Durgapur Line for Rectification of Earth Wire Clearance Violation	07 April 2021	08:00	07 April 2021	17:00			Other Parille line should be available
588	LINE	ER-II	400KV-MAITHON-RAGHUNATHPUR-1	D	May not be allowed with 400KV KHSTPP-Maithon D/C			1	Replacment of isolator work	12 April 2021	08:00	12 April 2021	18:00			Other Parille line should be available
589	LINE	ER-II	400KV-MAITHON-RANCHI-1	D	Sr 573,586 and 589 may not be allowed together	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	MPL	1	PL Crossing with 400KV Maithon - Durgapur Line for Rectification of Earth Wire Clearance Violation	06 April 2021	08:00	06 April 2021	17:00			Other Parille line should be available
590	LINE	ER-II	400KV-MALDA(PG)-NEW PURNEA-1	D	Sr 549 and 590 may not be allowed together			1	Porecelin insulator replacement work in Major Crossing	05 April 2021	08:00	05 April 2021	17:00			Other Parille line should be available
591	LINE	ER-II	400KV-MALDA(PG)-NEW PURNEA-1	D				1	Porecelin insulator replacement work in Major Crossing	07 April 2021	08:00	07 April 2021	17:00			Other Parille line should be available
592	LINE	ER-II	400KV-MALDA(PG)-NEW PURNEA-1	D	Farakka Malda and Malda Purnea may not be allowed together			1	Porecelin insulator replacement work in Major Crossing	09 April 2021	08:00	09 April 2021	17:00			Other Parille line should be available
593	LINE	ER-II	400KV-MALDA(PG)-NEW PURNEA-1	D	REPEATED SHUTDOWN			1	Porecelin insulator replacement work in Major Crossing	11 April 2021	08:00	11 April 2021	17:00			Other Parille line should be available
594	LINE	ER-II	400KV-MALDA(PG)-NEW PURNEA-1	D	REPEATED SHUTDOWN			1	Busbar Stability Test	17 April 2021	08:00	17 April 2021	17:00			Other Parille line should be available
595	LINE	ER-II	400KV-MALDA(PG)-NEW PURNEA-2	D				1	Porecelin insulator replacement work in Major Crossing	06 April 2021	08:00	06 April 2021	17:00			Other Parille line should be available
596	LINE	ER-II	400KV-MAITHON-RANCHI-1	D	Sr 576,587 and 596 may not be allowed together	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	MPL	1	PL Crossing with 400KV Maithon - Durgapur Line for Rectification of Earth Wire Clearance Violation	07 April 2021	08:00	07 April 2021	17:00			Other Parille line should be available
599	LINE	ER-II	400KV-RAJARHAT-FSTPP-1	D	May be reviewed after WB Election		WB	4	Replacement of Porcelain Insulators by CLR at major crossings	06 April 2021	08:00	09 April 2021	17:00			Other Parille line should be available
600	LINE	ER-II	400KV-RAJARHAT-FSTPP-1	D	May be reviewed after WB Election			1	Modification in PD sensors/GO system of 400KV TIE BAY-406	05 April 2021	07:00:00	05 April 2021	17:00:00			Other Parille line should be available

601	LINE	ER-II	400KV-RAJARHAT-FSTPP-1	D	May be reviewed after WB Election	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	WB	2	Stringing b/w AP 47/0 to AP 48/0 of 400 KV D/C Jeerat (New) - Subhasgram TL Over existing 400 KV Rajarahat - Farakka TL (PGCIL) & 400 KV Jarahat - Gokarna TL (PGCIL) (Crossing tower No - RAI-PRN 106 & RAI-PRN 107)	06 April 2021	08:00	07 April 2021	17:00		Other Parllel line should be availble
602	LINE	ER-II	400KV-RAJARHAT-FSTPP-1	C	May be reviewed after WB Election	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	WB	2	For stringing of powerline crossing AP 5/0 to AP 6/0 for the work of "Bypassing of Kahalgaoon-Farakka and Durgapur-Farakka 400 KV lines so as to form Kahalgaoon-Durgapur 400 kv D/C Transmission line" under ERS5-XXIII scheme.	27 April 2021	08:00	28 April 2021	17:00		Other Parllel line should be availble
603	LINE	ER-II	400KV-RAJARHAT-FSTPP-1	D	May be reviewed after WB Election		WB	3	Replacement of Porcelain Insulators with CLR Insulators at Major Crossings	23 April 2021	07:00	25 April 2021	16:00		Other Parllel line should be availble
604	LINE	ER-II	400KV-RAJARHAT-GOKARNA-1	D	May be reviewed after WB Election		WB	1	Modification in PD sensors/GD system of 400KV TIE BAY-413	08 April 2021	07:00	08 April 2021	17:00		Other Parllel line should be availble
605	LINE	ER-II	400KV-RAJARHAT-GOKARNA-1	D	May be reviewed after WB Election		WB	3	Replacement of Porcelain Insulators with CLR Insulators at Major Crossings	26 April 2021	07:00	28 April 2021	16:00		Other Parllel line should be availble
606	LINE	ER-II	400KV-RAJARHAT-JEERAT-1	D	May be reviewed after WB Election		WB	1	Modification in PD sensors/GD system of 400KV TIE BAY-409	06 April 2021	07:00	06 April 2021	17:00		Other Parllel line should be availble
607	LINE	ER-II	400KV-RAJARHAT-JEERAT-1	D	May be reviewed after WB Election	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	WB	1	OPGW Stringing b/w AP 40/0 to AP 41/0 of 400 KV D/C Jeerat (New) - Jeerat TL Over existing 400 KV Rajarahat - Jeerat TL (Previously Jeerat - Subhasgram TL)	02 April 2021	08:00	02 April 2021	17:00		Other Parllel line should be availble
610	LINE	ER-II	400KV-RANGPO-DIKCHU-1	D	The Shutdown will be reviewed based on hydro situation in April. It may be planned preferably after high hydro.	DETAILS OF WORK ALONG WITH SKETCH TO BE PROVIDED	DIKCHU	15	For stringing work of 400KV LOOP OUT in Multi Ckt portion in Top Phase of Ckt -2. (Subjected to restoration of 400KV DC Rangpo-Binaguri line)	01 April 2021	08:00	15 April 2021	17:00		Other Parllel line should be availble
611	LINE	ER-II	400KV-RANGPO-TEESTA-V-2	C	The Shutdown will be reviewed based on hydro situation in April. It may be planned preferably after high hydro.	PGCIL will share a presentation to explain the root cause of so many SF6 leakage and their action plan.	TEESTA V	10	For rectification of SF6 gas leakage repair work,	21 April 2021	08:00	30 April 2021	17:00		Other Parllel line should be availble
613	LINE	ER-II	400KV-SAGARDIGHI-FSTPP-1	D	REPEATED SHUTDOWN		WB	3	Replacement of broken disc insulators damaged by miscreants at various locations of TL	13 April 2021	08:00	15 April 2021	17:00		Other Parllel line should be availble
614	LINE	ER-II	400KV-SAGARDIGHI-FSTPP-1	D	May be reviewed after WB Election		WB	3	Shutdown nature defects rectification work	24 April 2021	09:00	26 April 2021	17:00		Other Parllel line should be availble
615	LINE	ER-II	400KV-SUBHASGRAM(PG)-RAJARHAT-1	D	May be reviewed after WB Election		WB	1	Modification in PD sensors/GD system.	01 April 2021	07:00:00	01 April 2021	17:00:00		Other Parllel line should be availble
616	LINE	ER-II	400KV-SUBHASGRAM(PG)-RAJARHAT-1	D	May be reviewed after WB Election		WB	1	Modification in PD sensors/GD system of 400KV TIE BAY-402	03 April 2021	07:00:00	03 April 2021	17:00:00		Other Parllel line should be availble
617	LINE	ER-II	400KV-SUBHASGRAM-SAGARDIGHI-1	D	May be reviewed after WB Election		WB	2	Shutdown nature defects rectification work	16 April 2021	09:00	17 April 2021	17:00		Other Parllel line should be availble
618	LINE	ER-II	66KV-GANGTOK-SHERATHANG-1	D			SIKKIM	1	FOR ANNUAL AMP WORKS	10 April 2021	09:00	10 April 2021	17:00		Other Parllel line should be availble
619	LINE	ER-II	400KV-SUBHASGRAM-SAGARDIGHI-1	D	May be reviewed after WB Election		WB	1	Pre-Mansoon Line Maintenance Work	09 April 2021	07:00	09 April 2021	17:00		Other Parllel line should be availble
620	LINE	ER-II	400KV-SUBHASGRAM-SAGARDIGHI-1	D	May be reviewed after WB Election	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	WB	2	Stringing b/w AP 9/0 to AP 10/0 of 400 KV D/C Jeerat (New) - Subhasgram TL Over existing 400 KV S/C Sagardighi - Subhasgram TL (PGCIL)	20 April 2021	08:00	21 April 2021	17:00		Other Parllel line should be availble
621	LINE	ER-II	400KV-MALDA(PG)-NEW PURNEA-2	D				1	Porecelin insulator replacement work in Major Crossing	08 April 2021	08:00	08 April 2021	17:00		Other Parllel line should be availble
622	LINE	ER-II	400KV-MALDA(PG)-NEW PURNEA-2	D				1	Porecelin insulator replacement work in Major Crossing	10 April 2021	08:00	10 April 2021	17:00		Other Parllel line should be availble
623	LINE	ER-II	400KV-MALDA(PG)-NEW PURNEA-2	D				1	Porecelin insulator replacement work in Major Crossing	12 April 2021	08:00	12 April 2021	17:00		Other Parllel line should be availble
624	LINE	ER-II	400KV-RAJARHAT-GOKARNA-1	D	May be reviewed after WB Election	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	WB	2	Stringing b/w AP 47/0 to AP 48/0 of 400 KV D/C Jeerat (New) - Subhasgram TL Over existing 400 KV Rajarahat - Farakka TL (PGCIL) & 400 KV ajarahat - Gokarna TL (PGCIL) (Crossing tower No - RAI-PRN 106 & RAI-PRN 107)	06 April 2021	08:00	07 April 2021	17:00		Other Parllel line should be availble
625	LINE	ER-II	400KV-SUBHASGRAM(PG)-RAJARHAT-1	D	May be reviewed after WB Election		WB	1	Pre-Mansoon Line Maintenance Work	09 April 2021	07:00	09 April 2021	17:00		Other Parllel line should be availble
626	LINE	ER-II	400KV-SUBHASGRAM(PG)-RAJARHAT-1	D	May be reviewed after WB Election		WB	1	Pre-Mansoon Line Maintenance Work	10 April 2021	07:00	10 April 2021	17:00		Other Parllel line should be availble
627	LINE	ER-II	400KV-SUBHASGRAM(PG)-RAJARHAT-1	D	May be reviewed after WB Election	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	WB	2	Stringing b/w AP 9/0 to AP 10/0 of 400 KV D/C Jeerat (New) - Subhasgram TL Over existing 400 KV S/C Sagardighi - Subhasgram TL (PGCIL)	20 April 2021	08:00	21 April 2021	17:00		Other Parllel line should be availble
628	LINE	ER-II	220KV-MAITHON-DHANBAD-2	C	REPEATED SHUTDOWN	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	DVC	3	PL Crossing during Re-conductoring work of Maithon - Right Bank # II Line	05 April 2021	08:00	07 April 2021	18:00		Other Parllel line should be availble
629	LINE	ER-II	132kv D/C JEERAT - BONGA TL (WBSETCL)	D	May be reviewed after WB Election	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	WB	2	Stringing b/w AP 24/0 to AP 25/0 of 400 KV D/C Jeerat (New) - Subhasgram TL Over existing 132 KV D/C Jeerat - Bonga TL (WBSETCL)	09 April 2021	08:00	10 April 2021	17:00		Other Parllel line should be availble
630	LINE	ER-II	132kv SARISATALI(CPL) - ASANSOL(WBSETCL)- I	D		DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	WB	1	PL Crossing with 400KV Maithon - Durgapur Line for Rectification of Earth Wire Clearance Violation	08 April 2021	08:00	08 April 2021	17:00		Other Parllel line should be availble

631	LINE	ER-II	132kV SARISATALI(CPL) - ASANSOL(WBSETCL) - II	D		DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	WB	1	PL Crossing with 400KV Maithon - Durgapur Line for Rectification of Earth Wire Clearance Violation	08 April 2021	08:00	08 April 2021	17:00			Other Parllel line should be available
632	LINE	ER-II	132KV Ramkanali - Jamuria TL (DVC)	D		DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	DVC	1	PL Crossing with 400KV Maithon - Mejia Line for Rectification of Earth Wire Clearance Violation	10 April 2021	08:00	10 April 2021	17:00			Other Parllel line should be available
633	LINE	ER-II	132kV CTPS - DTPS TL (DVC)	D		DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	DVC	1	PL Crossing with 400KV Maithon - Mejia Line for Rectification of Earth Wire Clearance Violation	10 April 2021	08:00	10 April 2021	17:00			Other Parllel line should be available
634	AR	ER-II	A/R OF 400KV-KISHANGANJ-TEESTA-III-1	D		How much work remains pending? May not be allowed if hydro in Sikkim Complex peaks & Rangpo-Binaguri remains under outage		30	For OPGW installation Work under Fiber Optic Expansion Project (Addl. Requirement)	01 April 2021	07:00 hrs	30 April 2021	18:00 hrs			Line Should Remain in service, Line will trip for transient SLG Fault as well
635	AR	ER-II	A/R OF 400KV-MAITHON-MAITHON RB-1	D				15	To be kept in Non-Auto Mode during reconductoring of 400KV Maithon- RB# II line for safety measure	04 April 2021	08:00	18 April 2021	18:00			Line Should Remain in service, Line will trip for transient SLG Fault as well
636	AR	ER-II	A/R OF 400KV-MAITHON-MAITHON RB-2	D				3	To be kept in Non-Auto Mode during reconductoring of 400KV Maithon- RB# I line for safety measure	01 April 2021	08:00	03 April 2021	18:00			Line Should Remain in service, Line will trip for transient SLG Fault as well
637	AR	ER-II	A/R OF 400KV-MAITHON-MAITHON RB-2	D				15	To be kept in Non-Auto Mode during reconductoring of 400KV Maithon- RB# I line for safety measure	19 April 2021	08:00	03 May 2021	18:00			Line Should Remain in service, Line will trip for transient SLG Fault as well
638	BR	ER-II	125MVAR 400KV B/R-2 AT RAJARHAT	D				1	Modification in PD sensors/GD system of 400KV TIE BAY-413	08 April 2021	07:00:00 Hrs	08 April 2021	17:00:00 Hrs			Other Shunt Element should be in Service
639	BR	ER-II	125MVAR 400KV B/R-2 AT RAJARHAT	D				1	Modification in PD sensors/GD system.	14 April 2021	07:00:00 Hrs	14 April 2021	17:00:00 Hrs			Other Shunt Element should be in Service
640	BR	ER-II	125MVAR 400KV B/R-1 AT ALIPURDUAR	C				6	To attend Oil Leakages in Drain Valve, Thermometer Pockets and Buckholz Pipe Line etc in 125 MVAR BHEL Reactor	12 April 2021	09:00	17 April 2021	18:00			Other Shunt Element should be in Service
641	BR	ER-II	125MVAR 400KV B/R-3 AT DURGAPUR	D				1	CSD fine tuning & Rectification works	09 April 2021	9:30hrs	09 April 2021	17.30 hrs			Other Shunt Element should be in Service
642	BR	ER-II	125MVAR 400KV B/R-4 AT DURGAPUR	D				1	CSD fine tuning & Rectification works	07 April 2021	9:30hrs	07 April 2021	17.30 hrs			Other Shunt Element should be in Service
643	BR	ER-II	125MVAR 400KV B/R-1 AT SUBHASGRAM	D				2	onload testing of 417 and 418 Bay CSD	07 April 2021	09:00	08 April 2021	17:00			Other Shunt Element should be in Service
644	BR	ER-II	125MVAR 400KV B/R-1 AT RAJARHAT	D				1	Modification in PD sensors/GD system of 400KV TIE BAY-409	06 April 2021	07:00:00 Hrs	06 April 2021	17:00:00 Hrs			Other Shunt Element should be in Service
645	BR	ER-II	125MVAR 400KV B/R-1 AT RAJARHAT	D				1	Modification in PD sensors/GD system.	10 April 2021	07:00:00 Hrs	10 April 2021	17:00:00Hrs			Other Shunt Element should be in Service
646	BUS	ER-II	400KV MAIN BUS - 1 AT RANGPO	D	The Shutdown will be reviewed based on hydro situation in April. It may be planned preferably after high hydro.	PGCIL will share a presentation to explain the root cause of so many SF6 leakage and their action plan.		2	For Gas logic modification work	05 April 2021	11:00	06 April 2021	17:00			Cannot be allowed together
647	BUS	ER-II	400KV MAIN BUS - 2 AT RANGPO	D	The Shutdown will be reviewed based on hydro situation in April. It may be planned preferably after high hydro.	PGCIL will share a presentation to explain the root cause of so many SF6 leakage and their action plan.		2	For Gas logic modification work	05 April 2021	11:00	06 April 2021	17:00			Cannot be allowed together
648	BUS	ER-II	400KV MAIN BUS - 2 AT DURGAPUR	D			WB	1	BUS-II tightness works	19 April 2021	09:00	19 April 2021	17:00			Other Bus Should be available
649	BUS	ER-II	220KV MAIN BUS - 1 AT BINAGURI	D				1	Bus Stability & Jumper connection for ICT#3	18 April 2021	09:00	18 April 2021	17:00			Other Bus Should be available
650	BUS	ER-II	220KV MAIN BUS - 2 AT BINAGURI	D				1	Bus Stability & Jumper connection for ICT#3	25 April 2021	09:00	25 April 2021	17:00			Other Bus Should be available
651	BUS	ER-II	400KV MAIN BUS - 1 AT BINAGURI	D	Why HV testing is required. Bay name may be mentioned if newly commissioned.The Shutdown will be reviewed based on hydro situation in April. It may be planned preferably after high hydro.			1	HV testing and Jumper connection	17 April 2021	09:00	17 April 2021	17:00			Other Bus Should be available
652	BUS	ER-II	400KV MAIN BUS - 1 AT BINAGURI	D	Why Bus stability testing is required. Bay name may be mentioned if newly commissioned.Shutdown will be reviewed based on hydro situation in April. It may be planned preferably after high hydro.			1	Bus Stability	27 April 2021	09:00	27 April 2021	17:00			Other Bus Should be available
653	BUS	ER-II	400KV MAIN BUS - 2 AT BINAGURI	D	Why HV testing is required. Bay name may be mentioned if newly commissioned.The Shutdown will be reviewed based on hydro situation in April. It may be planned preferably after high hydro.			1	HV testing and Jumper connection	05 April 2021	10:00	05 April 2021	17:00			Other Bus Should be available

654	BUS	ER-II	400KV MAIN BUS - 2 AT BINAGURI	D	Why Bus stability testing is required. Bay name may be mentioned if newly commissioned.Shutdown will be reviewed based on hydro situation in April. It may be planned preferably after high hydro.		1	Bus Stability	15 April 2021	09:00	15 April 2021	17:00		Other Bus Should be available
655	BUS	ER-II	400KV MAIN BUS - 1 AT MALDA	D	Sd related to ICT-III must be returned before commencement of WB election	Tentative date of restoration of ICT-III to be informed	WB	1	ERSS-XVII-B Constructional work (ICT-III Jumper Connection & Isolator Alignment)	13 April 2021	08:00	13 April 2021	17:00	Other Bus Should be available
656	BUS	ER-II	400KV MAIN BUS - 2 AT MALDA	D	Sd related to ICT-III must be returned before commencement of WB election	Tentative date of restoration of ICT-III to be informed	WB	1	ERSS-XVII-B Constructional work (ICT-III Jumper Connection & Isolator Alignment)	15 April 2021	08:00	15 April 2021	17:00	Other Bus Should be available
657	BUS	ER-II	220KV MAIN BUS - 1 AT MALDA(PG)	D	Sd related to ICT-III must be returned before commencement of WB election	Tentative date of restoration of ICT-III to be informed	WB	1	ERSS-XVII-B Constructional work(ICT-III Jumper Connection & Isolator Alignment)	12 April 2021	08:00	12 April 2021	17:00	Other Bus Should be available
658	BUS	ER-II	220KV MAIN BUS - 2 AT MALDA(PG)	D	Sd related to ICT-III must be returned before commencement of WB election	Tentative date of restoration of ICT-III to be informed	WB	1	ERSS-XVII-B Constructional work(ICT-III Jumper Connection & Isolator Alignment)	10 April 2021	08:00	10 April 2021	17:00	Other Bus Should be available
659	BUS	ER-II	400KV MAIN BUS - 2 AT BAHARAMPUR	D			NLDC	1	Busbar AMP	22 April 2021	09:00	22 April 2021	17:00	Other Bus Should be available
660	BUS	ER-II	220KV MAIN BUS - 1 AT DALKHOLA(PG)	D	MAY BE ALLOWED AFTER RESTORATION OF ICT-III AT MALDA		WB	1	Bus side Dropper replacement on DLK-KNE-I , DLK-PRN-I and Isolator alignment	12 April 2021	08:00	12 April 2021	17:00	Other Bus Should be available
661	BUS	ER-II	400KV MAIN BUS - 2 AT RAJARHAT	D	May be reviewed after WB Election		WB	1	Modification in PD sensors/GD system.	10 April 2021	07:00:00 Hrs	10 April 2021	17:00:00Hrs	Other Bus Should be available
662	BUS	ER-II	400KV MAIN BUS - 1 AT BAHARAMPUR	D	Line and Bus shutdown at Bahrapur may not be allowed together		NLDC	1	Busbar AMP	20 April 2021	09:00	20 April 2021	17:00	Other Bus Should be available
663	BUS	ER-II	400KV MAIN BUS - 2 AT RAJARHAT	D	May be reviewed after WB Election		WB	1	Modification in PD sensors/GD system.	14 April 2021	07:00:00 Hrs	14 April 2021	17:00:00 Hrs	Other Bus Should be available
664	BUS	ER-II	400KV MAIN BUS - 1 AT RAJARHAT	D	May be reviewed after WB Election		WB	1	Modification in PD sensors/GD system.	01 April 2021	07:00:00	01 April 2021	17:00:00	Other Bus Should be available
665	BUS	ER-II	220KV MAIN BUS - 1 AT NEW MELLI	D			JORETHANG / TASHIDING	1	AMP works	10 April 2021	09:00	10 April 2021	17:00	Other Bus Should be available
666	BUS	ER-II	400KV MAIN BUS - 3 AT MAITHON	D			JSEB/ DVC	2	Augmentation of Bus Bar protection for Bus#3 & 4	12 April 2021	08:00	13 April 2021	18:00	Other Bus Should be available
667	BUS	ER-II	400KV MAIN BUS - 4 AT MAITHON	D			JSEB/ DVC	2	Augmentation of Bus Bar protection for Bus#3 & 4	14 April 2021	08:00	15 April 2021	18:00	Other Bus Should be available
668	BUS	ER-II	220KV MAIN BUS - 1 AT SUBHASGRAM(PG)	D	May be reviewed after WB Election		WB	1	AMP & Hotspot Rectification	03 April 2021	09:00	03 April 2021	17:00	Other Bus Should be available
669	BUS	ER-II	220KV MAIN BUS - 2 AT NEW MELLI	D			JORETHANG / TASHIDING	1	AMP works	12 April 2021	09:00	12 April 2021	17:00	Other Bus Should be available
670	BUS	ER-II	220KV MAIN BUS - 2 AT SUBHASGRAM(PG)	D	May be reviewed after WB Election		WB	1	AMP & Hotspot Rectification	05 April 2021	09:00	05 April 2021	17:00	Other Bus Should be available
671	HVDC	ER-II	800KV HVDC ALIPURDUAR-AGRA-POLE-I	D			NLDC	2	Fixing of span marker & AMP	01 March 2021	08:00	02 March 2021	17:00	0
672	HVDC	ER-II	800KV HVDC ALIPURDUAR-AGRA-POLE-II	D			NLDC	2	Fixing of span marker & AMP	03 March 2021	08:00	04 March 2021	17:00	0
673	ICT	ER-II	400KV/220KV 500 MVA ICT 1 AT RAJARHAT	D	May be reviewed after WB Election		WB	1	Modification in PD sensors/GD system of 400KV TIE BAY-402	03 April 2021	07:00:00	03 April 2021	17:00:00	Other ICT(s) should be available
674	ICT	ER-II	400KV/220KV 315 MVA ICT 1 AT RANGPO	C		PGCIL will share a presentation to explain the root cause of so many SF6 leakage and their action plan.		20	For rectification of SF6 gas leakage repair work,	01 April 2021	08:00	20 April 2021	17:00	Other ICT(s) should be available
675	ICT	ER-II	400KV/220KV 500 MVA ICT 3 AT MAITHON(PG)	D	Sr. 675 and 688 may not be allowed together		JSEB/DVC	1	Retrofitting work of Bus Bar protection	22 April 2021	08:00	22 April 2021	16:00	Other ICT(s) should be available
676	ICT	ER-II	220KV/132KV 160 MVA ICT 4 AT MALDA	D			WB	1	220KV Side BCU Rectification (209 bay),NIPPS commissioning,Aircell replacement	07 April 2021	09:00	07 April 2021	17:00	Other ICT(s) should be available
677	ICT	ER-II	400KV/220KV 500 MVA ICT 2 AT RAJARHAT	D	May be reviewed after WB Election		WB	1	Modification in PD sensors/GD system of 400KV TIE BAY-406	05 April 2021	07:00:00	05 April 2021	17:00:00	Other ICT(s) should be available
678	ICT	ER-II	400KV/220KV 500 MVA ICT 1 AT MAITHON(PG)	D			JSEB/DVC	1	Retrofitting work of Bus Bar protection	20 April 2021	08:00	20 April 2021	16:00	Other ICT(s) should be available
679	ICT	ER-II	400KV/220KV 500 MVA ICT 2 AT MAITHON(PG)	D			JSEB/DVC	1	Retrofitting work of Bus Bar protection	21 April 2021	08:00	21 April 2021	16:00	Other ICT(s) should be available
680	ICT	ER-II	400KV/220KV 315 MVA ICT 3 AT SUBHASGRAM(WB)	D	May be reviewed after WB Election		WB	1	ERSS-XVIII Bay Upgradation Work . Bus Pipe Connection between 409-89B & 407-89B	01 April 2021	08:00	01 April 2021	17:00	Other ICT(s) should be available
681	ICT	ER-II	400KV/220KV 315 MVA ICT 4 AT SUBHASGRAM(WB)	D	May be reviewed after WB Election		WB	1	ERSS-XVIII Bay Upgradation Work . Bus Pipe Cconnection between 412-89B & 411-89B	02 April 2021	08:00	02 April 2021	17:00	Other ICT(s) should be available
682	ICT	ER-II	400KV/220KV 500 MVA ICT 5 AT SUBHASGRAM(PG)	D	May be reviewed after WB Election		WB	1	Onload testing of Tie Bay (414 Bay) CSD	11 April 2021	09:00	11 April 2021	17:00	Other ICT(s) should be available
683	ICT	ER-II	220KV/132KV 160 MVA ICT 1 AT MALDA	C			WB	3	220KV R-ph Bushing replacement owing to high Variable frequency Tan-delta Value	19 April 2021	08:00	21 April 2021	17:00	Other ICT(s) should be available
684	BAY	ER-II	220KV BUS COUPLER BAY AT MAITHON(PG)	D				1	Retrofitting work of Bus Bar protection	29 April 2021	08:00	29 April 2021	16:00	Element should remain in service

685	BAY	ER-II	400KV MAIN BAY OF DURGAPUR II AT FSTPP	D				1	AMP WORKS	12 April 2021	09:00	12 April 2021	17:00		Element should remain in service
686	BAY	ER-II	400KV MAIN BAY OF MAITHON-I AT MAITHON RB	C				14	Upgradation of Bay equipmenets under ER55-XVII Project work. Shut down of Bays proposed in respect of line shut down for reconductoring work.	20 April 2021	08:00	03 May 2021	18:00		Element should remain in service
687	BAY	ER-II	400KV MAIN BAY OF MAITHON-II AT MAITHON RB	C				19	Upgradation of Bay equipmenets under ER55-XVII Project work. Shut down of Bays proposed in respect of line shut down for reconductoring work.	01 April 2021	08:00	19 April 2021	18:00		Element should remain in service
688	BAY	ER-II	400KV TIE BAY OF (500MVA ICT-I AND MEJIA-II) AT MAITHON	D	Sr. 675 and 688 may not be allowed together			1	AMP WORKS	22 April 2021	09:00:00	22 April 2021	17:00		Element should remain in service
689	BAY	ER-II	400KV TIE BAY OF (MAITHON-II AND FUTURE) AT DURGAPUR	D				1	AMP WORKS	16 April 2021	09:00	16 April 2021	17:00		Element should remain in service
690	BAY	ER-II	220KV MAIN BAY OF 315MVA ICT-III AT DURGAPUR	D	Element shall remain in service through Tr bus			1	AMP WORKS	13 April 2021	09:00	13 April 2021	17:00		Element should remain in service
691	LINE	PMJTL	765 KV Ranchi- Medinipur Ckt-1 alongwith LR (Bay no- 702,703, 703R)	D			WB/NLDC	1	Final tuning of CSD of 765 KV LR-1 under constructional punch point	07 April 2021	10:00 Hrs	07 April 2021	18:00 Hrs		Other Parllel line should be available
692	LINE	PMJTL	765 KV Ranchi- Medinipur Ckt-2 alongwith LR (Bay no- 705, 706, 706R)	D			WB/NLDC	1	Final tuning of CSD of 765 KV LR-2 under constructional punch point	08 April 2021	10:00 Hrs	08 April 2021	18:00 Hrs		Other Parllel line should be available
693	LINE	PMJTL	400 kV D/C Medinipur - Kharagpur TL (Line I & II)	D	Newly Commissioned Element		WB	5	Checking & tightening of Jumpers, Checking of Insulators and rectification of punch list	20 April 2021	8:00 Hrs	24 April 2021	18:00 Hrs		Other Parllel line should be available
694	LINE	PMJTL	400 kV D/C Medinipur - Chanditala TL (Line I & II)	D	Newly Commissioned Element		WB	5	Checking & tightening of Jumpers, Checking of Insulators and rectification of punch list	27 April 2021	8:00 Hrs	01 May 2021	18:00 Hrs		Other Parllel line should be available
695	LINE	PMJTL	765 kV D/C Ranchi - Medinipur TL (Line I & II)	D	Newly Commissioned Element.		WB/NLDC	5	Checking & tightening of Jumpers, Checking of Insulators and rectification of punch list	06 April 2021	8:00 Hrs	10 April 2021	18:00 Hrs		Other Parllel line should be available
696	LR	PMJTL	765 KV Ranchi- Medinipur LR -I (Bay no- 702,703, 703R) alongwith Ckt-1	D	MAY BE ALLOWED WHEN LINE SD IS PLANNED		NLDC	1	Final tuning of CSD of 765 KV LR-1 under constructional punch point	07 April 2021	10:00 Hrs	07 April 2021	18:00 Hrs		Other Shunt Element should be in Service
697	LR	PMJTL	765 KV Ranchi- Medinipur LR-II (Bay no- 705, 706, 706R) alongwith Ckt-2	D	MAY BE ALLOWED WHEN LINE SD IS PLANNED		NLDC	1	Final tuning of CSD of 765 KV LR-2 under constructional punch point	08 April 2021	10:00 Hrs	08 April 2021	18:00 Hrs		Other Shunt Element should be in Service
698	BR	PMJTL	765 KV BR-1 (Bay no- 701 & 702) at TBCB,Medinipore	D			NLDC	1	Final tuning of CSD of 765 KV BR-1 under constructional punch point	05 April 2021	10:00 Hrs	05 April 2021	18:00 Hrs		Other Shunt Element should be in Service
699	BR	PMJTL	765 KV BR-2 (Bay no- 704 & 705) at TBCB,Medinipore	D			NLDC	1	Final tuning of CSD of 765 KV BR-2 under constructional punch point	06 April 2021	10:00 Hrs	06 April 2021	18:00 Hrs		Other Shunt Element should be in Service
700	BR	PMJTL	400 KV BR-1 (Bay no- 410 & 411) at TBCB,Medinipore	D				1	Final tuning of CSD of 400 KV BR-1 under constructional punch point	15 April 2021	10:00 Hrs	15 April 2021	18:00 Hrs		Other Shunt Element should be in Service
701	BR	PMJTL	400 KV BR-2 (Bay no- 404 & 405) at TBCB,Medinipore	D				1	Final tuning of CSD of 400 KV BR-2 under constructional punch point	16 April 2021	10:00 Hrs	16 April 2021	18:00 Hrs		Other Shunt Element should be in Service
702	ICT	PMJTL	765 KV ICT-1 (Bay no- 708, 709, 401,402) at TBCB,Medinipore	D			NLDC/WB	2	Final Tuning of CSD of ICT-1 of 765 KV side & 400 KV side	09 April 2021	10:00 Hrs	10 April 2021	18:00 Hrs		Other ICT(s) should be available
703	ICT	PMJTL	765 KV ICT-2 (Bay no- 711, 712, 407,408) at TBCB,Medinipore	D			NLDC/WB	2	Final Tuning of CSD of ICT-2 of 765 KV side & 400 KV side	12 April 2021	10:00 Hrs	13 April 2021	18:00 Hrs		Other ICT(s) should be available
704	ICT	PMJTL	765 KV ICT-2 (Bay no- 711, 712, 407,408)	D	Newly Commissioned Element		NLDC/WB	1	For rectification of air cell leakage of Rph ICT of bank-2	20 April 2021	10:00 Hrs	20 April 2021	18:00 Hrs		Other ICT(s) should be available
705	BAY	OPTCL	220KV MAIN BAY OF JAYNAGAR-2 AT JEYPORE	D	Element shall remain in service through Tr bus			1	Charging of new 220KV Jayanagar-Jeypore PG ckt- III & IV	26 March 2021	07:00	26 March 2021	16:00		Element should remain in service
706	BAY	OPTCL	220KV MAIN BAY OF JAYNAGAR -1 AT JEYPORE	D	Element shall remain in service through Tr bus			1	Charging of new 220KV Jayanagar-Jeypore PG ckt- III & IV	26 March 2021	07:00	26 March 2021	16:00		Element should remain in service
707	BAY	OPTCL	220KV MAIN BAY OF KESINGA AT BOLANGIR PG	D	Element shall remain in service through Tr bus			1	Charging of new 220KV Bolangir PG-Kesinga line	15 April 2021	07:00	15 April 2021	16:00		Element should remain in service
708	BAY	OPTCL	220KV MAIN BAY OF PRATAPSASAN-1 & 2 AT PANDIABILI	D	Element shall remain in service through Tr bus			1	Charging of new 220KV Pandiabili-Pratapsasan line	25 April 2021	07:00	25 April 2021	16:00		Element should remain in service
709	LINE	ADANI POWER (JHARKHA ND) LTD	400KV-FSTPP-BAHARAMPUR-1	D	REPEATED SHUTDOWN	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	NLDC	1	OVER HEAD CROSSING	14 April 2021	07:00	14 April 2021	17:00		Other Parllel line should be available
710	LINE	ADANI POWER (JHARKHA ND) LTD	400KV-FSTPP-BAHARAMPUR-2	D	REPEATED SHUTDOWN	DETAILS OF CROSSING ALONG WITH SKETCH TO BE PROVIDED	NLDC	1	OVER HEAD CROSSING	14 April 2021	07:00	14 April 2021	17:00		Other Parllel line should be available
711	LINE	POWERGR ID WRTS	765KV-DHARAMJAYGARH-JHARSUGUDA-1	D					For Tamnar Bay Contruction Works	15 April 2021	07:00	15 April 2021	18:00		
712	LINE	POWERGR ID WRTS	765KV-DHARIJAYGARH-JHARSUGUDA-1 L/R@ DHARAMJAYGARH - 765KV	D					For Tamnar Bay Contruction Works	15 April 2021	07:00	15 April 2021	18:00		
713	LINE	POWERGR ID WRTS	765KV-DHARAMJAYGARH-JHARSUGUDA-2	D					Line A/R to be keep in non auto mode in view of Jharsuguda #1 Line outage.	15 April 2021	07:00	15 April 2021	18:00		
714	LINE	OPTCL	400KV-MEERAMUNDALI-JSPL-1	D					R PH WAVE TRAP DROP REPLACEMENT AT MERAMUNDALI END	12 April 2021	07:00	12 April 2021	16:00	400KV-MEERAMUNDALI-JSPL-2 will remain in service	