



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति



Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टालीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

Tel No.:033-24239659/9651 FAX No.:033-24239652/53 Web: www.erpc.gov.in

सं./No. ERPC/COM-I/REA/2019-20/1352

दिनांक / Date: 12.03.2021

To: As per list enclosed / सेवा में: (संलग्न सूची के अनुसार)

Sub.: Revised DC statement of FSTPP-III due to 95% allocation of capacity during specific months of F.Y 2019-20

Sir,

Please find enclosed a revised DC figures of FSTPPP-III for corresponding Regional Energy Accounts for the months from Oct,19 to March,20 due to 95% allocation of capacity of FSTPPP-III. The same has been considered and necessary changes have been reflected in the statement.

Constituents are requested to intimate any discrepancy / error within **60 days** from the date of issue of this provisional REA. In case of any discrepancy / error, the provisional REA would be revised based on re-examination, final decision and confirmation. In case no communication is received from any of the constituents indicating mistakes / discrepancy, the provisional REA as issued, would be treated as final.

कृपया March,20 के ABT आधारित अस्थायी उर्जा लेखा की एक प्रति संलग्न करें।

संघ के सदस्यों से यह अनुरोध किया जाता है के अस्थायी क्षेत्रीय उर्जा लेखा के प्रकाशित होने की तिथि से 60 दिनों के भीतर किसी भी असंगति / त्रुटि की सूचना दे। असंगति / त्रुटि की परिस्थिति में अस्थायी क्षेत्रीय उर्जा लेखा को पुनः परीक्षण अंतिम निर्णय एवं संपुष्टि के आधार पर परिशोधित किया जाएगा। यदि संघ के सदस्यों से किसी तरह की दोष / असंगति का सूचना प्राप्त नहीं होता है, तो जारी किये गए अस्थायी क्षेत्रीय उर्जा लेखा को ही अंतिम माना जाएगा।

Encl.: As above

संलग्नक: योथोपरी

Yours faithfully, / भवदीय

Member Secretary / सदस्य सचिव

DISTRIBUTION LIST

- 1) Chief Engineer, (Commercial), Bihar State Power Holding Company Ltd., Vidyut Bhavan, Bailey Road, Patna-800021 (FAX:0612 2227557).
- 2) Chief Engineer (Commercial), Damodar Valley Corporation, DVC Tower, VIP Road, Kolkata-700054 (FAX: 033 23552129)
- 3) Chief Engineer (COMML. & REVENUE), Jharkhand Urja Vikas Nigam Ltd, HEC Engineering Building, Dhurva, Ranchi-834002 (FAX : 0651 2400799 / 2490486).
- 4) Addl. Chief Engineer (SLDC/EHV), Deptt. of Power, Govt. of Sikkim, Kazi Road, Gangtok-737101 (FAX:03592 202927/209199)
- 5) Chief Engineer (PTR), West Bengal State Electricity Distribution Company Limited, Bidyut Bhavan, 8th Floor, Bidhannagar, Kolkata-700091 (FAX : 033 2334 5862)
- 6) General Manager (Commercial), NTPC Ltd., Loknayak Jaiprakash Bhawan, Dakbunglow Chowk, Patna-800001(FAX: 0612 2230035 / 2224287)
- 7) Regional Executive Director (East-II), 3rd Floor, OCHC Building (New), 24, Janpath, Bhubaneswar – 751001
- 8) CEO, Bhartiya Rail Bijlee Company Ltd., 1st Floor , Vidyut Bhavan, Bailey Road, Patna-800001(Fax 0612- 2504007)
- 9) Addl. General Manager (Commercial), ERTS-I, POWERGRID, Boring Road, Alankar Place, Patna-800001.
- 10) Addl. General Manager (Commercial), ERTS-II, POWERGRID, CF-17, Action Area-1C, New Town, Rajarhat, Kolkata -700156
- 11) Chief Engineer (Commercial), NHPC Ltd., NHPC Office Complex, Sector-33, Faridabad, Haryana - 121003, (TELEFAX : 0129 2278358)
- 12) Executive Director, ERLDC, 14 Golf Club Road, Kolkata-700033 (FAX: 033 2423 3648)
- 13) Sr. General Manager (PP), GRIDCO, 4th Floor, Vidyut Bhavan, Saheed Nagar, Bhubaneswar-751007
- 14) Member Secretary, WRPC, MIDC Area, Marol, Andheri(E), Mumbai-400093 (FAX : 022 2837 0193).
- 15) Member Secretary, NRPC, Katwaria Sarai, 18A SJSS Marg, New Delhi-16 (FAX 01126865206).
- 16) Member Secretary, SRPC, 29, Race Course Road, Bangalore-560009 (FAX : 080 2259343).
- 17) Member Secretary, NERPC, NERPC Complex, Dong Parmaw, Lapalang, Shillong-793006, Meghalaya
- 18) Chief Engineer (Commercial), M.P. Power Management Co. Ltd., Shakti Bhawan, Vidyut Nagar, Rampur, Jabalpur-482008 (Fax No. 0761-2661884)
- 19) Chief Engineer(PP), MSEDCL, Prakashgarh, 4th Floor, Bandra(East), Mumbai- 400051.
- 20) Chief Engineer.(Commercial), CSEB, Dandania, Post Sunder Nagar, Raipur-492013.
- 21) Executive Engineer, Electricity Department, Administration of Dadra and Nager Haveli, SILVASSA, Via. VAPI, PIN : 396 230.
- 22) Executive Engineer, Electricity Department, Administration of Daman & Diu, Power House Building, Nani Daman – 396 210.
- 23) Executive Engineer Division-III, Electricity Department, Government of Goa, Curti, Ponda- Goa (FAX-0832-2222354)
- 24) General Manager, Energy Accounts Dept., UPPCL, Shakti Bhawan Extn., 14Ashok Marg, Lucknow-226001.
- 25) Chief Engineer(Comm & Survey Wing), Power Dev.Deptt., Govt. of J&K, GLADNI, Narval Bala, Jammu-180006.
- 26) Chief Engineer , Rajasthan Power Procurement Centre, Bidyut Bhavan, Janpath, Jaipur.
- 27) General Manager (SLDC), SLDC building,, Minto Road, New Delhi-110002.(FAX-011-2322-1012)
- 28) Director (Interstate Billing), PSEB, 220 Kv Grid S/s, The Mall, Patiala-147001.
- 29) Chief Engineer (SO&Commercial), HVPNL ., Shakti Bhawan, Sector-6, Panch kula-134109.
- 30) GM (Commercial-Tariff), ASEB, Bijulee Bhawan, Paltan Bazar, Guwahati- 781001.
- 31) Chief Engineer (Power), Deptt. of Power, Govt. of Nagaland, Kohima –797 001.
- 32) Member (Technical) MeSEB, Lumjingshai, Short Round Road, Shillong.
- 33) Chief General Manager (RT & C), OPTCL, Janpath, Bhubaneswar-751022.(Tel FAX-0674 2542 120)
- 34) Vice President (CS-CB), PTC India Limited, 2nd Floor, NBCC Tower, 15, Bikaji Cama Place, New Delhi –110065 (FAX : 011 41659142)
- 35) Executive Director(Finance), Gujarat Urja Vikas Nigam Ltd., Sardar Patel Vidyut Bhavan, Race Course, Vadodara – 390007.
- 36) Chief G. M., Uttrakhand Power Corp. Ltd., Urja Bhawan, Kanwali Road, Dehradun - 248006.
- 37) Superintending Engineer(E), UT of Chandigarh, 5th Floor, New Addl. Office Bldg., Sector-9D, Chandigarh-160 009.
- 38) Chief Engineer (System Operation), Himachal Pradesh State Electricity Board, Vidyut Bhawan, Kumar House Complex , Block-II, Shimla-171004.
- 39) S.E.-I, Electricity Department, N0.137, NSC Bose Salai, Puducherry-605001.
- 40) AGM(BD / P&S), NVVNL, NTPC BHAWAN, Core-7, Scope Complex, 7, Institutional Area, Lodhi Road, New Delhi – 110 003 (FAX 011 24367201)
- 41) AVP (Power Sales), STERLITE Energy Limited., 1st Floor, City Mart, Commercial Complex, Baramunda, Bhubaneswar ORISSA, PIN-751003 (FAX : 0674-2354221-6610342)
- 42) AGM (Commercial), KBUNL, Kanti , Muzaffarpur Dist –Bihar 843130 (Fax: +91- 06223-267310).

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

Revision of DC for FSTPP-III due to allocation of 95% Capacity

S.No	NTPC POWER STATIONS	FSTPS STAGE-III (1 X 500 MW)					
		Oct,19	Nov,19	Dec,19	Jan,20	Feb,20	March,20
1	Installed Capacity (MW) :	500	500	500	500	500	500
2	Normative AUX as per CERC Tariff Order 2019-24(%) :	6.25000	6.25000	6.25000	6.25000	6.25000	6.25000
3	Ex-Bus Normative Capacity at 100% availability (MW) :	468.75	468.75	468.75	468.75	468.75	468.75
4	Average DC for the month (ex-bus) in MW:	448.52	456.41	468.87	419.95	459.11	469.30
5	Plant Availability Factor for Month - PAFM (%):	98.545	97.367	105.290	89.590	103.100	105.387
6	Cumulative DC (FY:2019-20) up to the preceeding month (%):	55.913	62.089	66.150	70.562	72.490	75.056
7	Cumulative DC (FY:2019-20) including the current month –PAFY (%):	62.089	66.150	70.562	72.490	75.056	77.431



Member Secretary