



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति
Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/591

Date: 12.08.2021

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comm & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comm), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comm), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 26.07.2021-01.08.2021

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 06.08.2021.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This is issued with the approval of Member Secretary.

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)
SUPERINTENDING ENGINEER

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 26/07/21 to 01/08/21**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)	AMOUNT RECEIVABLE(Rs.)	AMOUNT RECEIVABLE(Final After Adjustment)(Rs.)
BSPHCL	POOL	0	2907893	2907893
JUVNL	POOL	628603	0	0
DVC	POOL	0	404907	404907
GRIDCO	POOL	6032538	0	0
SIKKIM	POOL	0	9099	9099
WBSETCL	POOL	509454	0	0
Total		7170595	3321898	3321898

Note:

a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC

**b) Final Receivables Amount After Adjustment from the Reactive Pool are done as per Methodology
Approved in the 43rd ERPC meeting held on 26.03.2021 at Kolkata.**

SUPERINTENDING ENGINEER

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 26/07/21 to 01/08/21

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVA/H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVA/H (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-2832.9	439100	0	0	439100
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-3116.4	483042	0	0	483042
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-4018.1	622806	0	0	622806
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-25.1	3891	-289.4	-44857	-40967
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-83	12865	-165.4	-25637	-12772
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	-30	4650	-234	-36270	-31620
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-2303.8	357089	0	0	357089
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-150.6	23343	0	0	23343
	9	220 KV side of 220/132 Arah ICT-2	ER1882A	-159.2	24676	0	0	24676
	10	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-I	NP8641A	-164	25420	0	0	25420
	11	220 KV KHAGAUL(BSPHCL) - ARAH (PG)-II	NP6060A	-949.3	147142	0	0	147142
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	-33.8	5239	-387.1	-60000.5	-54762
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	166.1	-25746	0	0	-25746
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	70.9	-10990	0	0	-10990
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	-204.5	31698	0	0	31698
	16	220 KV NADHOKHAR(BSPHCL)- PUSAULI (PG)-2	NP8665A	-1306.9	202570	0	0	202570
	17	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	ER1872A	-94.1	14586	0	0	14586
	18	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	ER1873A	-99.1	15361	0	0	15361
	19	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1357.3	-210382	0	0	-210382
	20	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1281.6	-198648	0	0	-198648
	21	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1470.5	-227928	0	0	-227928
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1418.6	-219883	0	0	-219883
	23	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	95.3	-14772	294.9	45709.5	30938
	24	HV side of 400/220 Patna ICT-1	ER1877A	-1926	298530	0	0	298530
	25	HV side of 400/220 Patna ICT-2	ER1407A	-2330.6	361243	0	0	361243
	26	HV side of 400/220 Patna ICT-3	ER1231A	-2439	378045	0	0	378045
	27	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	43.1	-6681	0	0	-6681
	28	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	43.4	-6727	0	0	-6727
	29	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-2683.7	415974	0	0	415974
	30	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-2473.6	383408	0	0	383408
	31	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1275.9	-197765	0	0	-197765
	32	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1281.3	-198602	0	0	-198602
	33	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	238.3	-36937	-6.4	-992	-37929
	34	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	251.7	-39014	-7.9	-1224.5	-40238
	35	220 KV NEW PURNEA(PG)-BEGUSARAI(BSPTCL)-I	ER1348A	2637.9	-408875	0	0	-408875
	36	220 KV NEW PURNEA(PG)-KHAGARIA(BSPTCL)	ER1376A	2204.6	-341713	0	0	-341713
	37	220 KV DUMRAON NEW(BSPHCL)- ARA(PG) LINE-1	ER1305A	645.6	-100068	0	0	-100068
	38	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	-1957.9	303475	0	0	303475
	39	HV side of 400/220 KV Biharshariff(PG) ICT-4	ER1386A	-5445.9	844115	0	0	844115
	40	400 KV SIDE OF 400/220 500 MVA GAYA(PG) ICT-3	ER1442A	123.9	-19205	0	0	-19205
	41	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-1	ER1247A	-597.3	92582	0	0	92582
	42	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-2	ER1243A	-573.4	88877	0	0	88877
	43	220 KV DUMRAON NEW(BSPHCL)- ARA (PG)-2	ER1866A	643.5	-99743	0	0	-99743
	44	400 KV SIDE OF LAKHISARAI(PG) 315 MVA 400/132 ICT-3	ER1309A	-125.7	19484	0	0	19484
	45	400 KV SIDE BANKA(PG) 400/132 KV 315 MVA ICT-3	ER1362A	125.9	-19515	0	0	-19515
	46	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-1	ER1395A	-37.1	5751	0	0	5751
	47	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-2	ER1933A	-32.8	5084	0	0	5084
	48	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-3	ER1934A	-32.8	5084	0	0	5084
	49	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-2	ER1875A	650.9	-100890	2.1	325.5	-100564
	50	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-1	ER1816A	649.7	-100704	3.2	496	-100208
	51	400 KV HV SIDE OF 315 MVA MOTIHARI(DMTCL) ICT-3	ER1819A	0	0	0	0	0
		TOTAL			3030343		-122450	2907893
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-3347.4	518847	0	0	518847
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-2329	360995	0	0	360995
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-2146.7	332739	0	0	332739
	4	400 KV SIDE OF RANCHI ICT(PG)-2	NP5873A	2465.4	-382137	0	0	-382137
	5	400 KV SIDE OF RANCHI ICT(PG)-1	NP5878A	2921.2	-452786	0	0	-452786
	6	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	0	0	0	0	0
	7	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	3060.4	-474362	0	0	-474362
	8	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	3032.8	-470084	0	0	-470084
	9	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-2	NP8637A	0	0	0	0	0
	10	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-1	NP8678A	300.3	-46547	0	0	-46547
	11	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	52.6	-8153	0	0	-8153
	12	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	45.9	-7115	0	0	-7115
		TOTAL			-628603		0	-628603
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-831	128805	0	0	128805
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	ER1668A	185	-28675	0	0	-28675
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	256.8	-39804	0	0	-39804
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	ER1711A	472.8	-73284	0	0	-73284
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	ER1717A	510	-79050	0	0	-79050
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIKADA(PG)	ER1808A	0	0	0	0	0
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	ER1802A	0	0	0	0	0
	9	400 KV MEJIA(DVC)-MAITHON(PG)	ER1659A	-4441.7	688464	0	0	688464
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1657A	-4117.5	638213	0	0	638213
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1658A	-4218.5	653868	0	0	653868
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-1274.5	197548	0	0	197548
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-1086.9	168470	0	0	168470
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-106.1	16446	0	0	16446
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-293.6	45508	0	0	45508
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-III(MAIN)	NP6524A	-2434.6	377363	0	0	377363
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6522A	-2421.5	375333	0	0	375333
	18	400 KV RTPS(DVC)-RANCHI(PG)	ER1653A	-4992.3	773807	0	0	773807
	19	400 KV RTPS(DVC)-MAITHON(PG)	ER1652A	8383	-1299365	0	0	-1299365
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	ER1656A	-502.5	77888	0	0	77888
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	7187.9	-1114125	0	0	-1114125
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	7112.9	-1102500	0	0	-1102500
		TOTAL			404907		0	404907

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-1 AND ICT-3	ER1563A	21.7	-3363.5	0	0	-3364
	2	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-2 AND ICT-4	ER1565A	-34.7	5378.5	0	0	5379
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	400 KV SIDE OF JEYPORE (PG) 400/220 KV ICT-1 AND ICT-3	ER1550A	4572.4	-708722	0	0	-708722
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	2106.2	-326461	0	0	-326461
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	ER1759A	18781.1	-2911070.5	0	0	-2911071
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	23.1	-3580.5	0	0	-3581
	9	HV side meter of 400/220 Baripada ICT-2	ER1746A	0.2	-31	0	0	-31
	10	HV side meter of 400/220 Baripada ICT-3	ER1747A	0	0	0	0	0
	11	220 KV BALIMELA (GRIDCO)-UPPER SILERU (SR)	NP7991A	0	0	0	0	0
	12	400 KV DUBURI (GRIDCO)- BARIPADA (PG)	ER1900A	-1533.6	237708	0	0	237708
	13	400 KV MERAMUNDALI (GRIDCO)-BOLANGIR (PG)	ER1054A	1856.3	-287726.5	0	0	-287727
	14	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)-2	ER1055A	11643	-1804665	0	0	-1804665
	15	400 KV MERAMUNDALI (GRIDCO)-TSTPP (NTPC)	ER1758A	6171.6	-956598	0	0	-956598
	16	400 KV MENDHASAL (GRIDCO)- PANDIABIL (PG)-I	NP5980A	0	0	0	0	0
	17	400 KV MENDHASAL (GRIDCO)- PANDIABIL (PG)-II	NP7498A	0	0	0	0	0
	18	400 KV DUBRI (GRIDCO)-PANDIABIL (PG)	ER1897A	-3670.6	568943	0	0	568943
	19	HV side meter of 400/220 Bolangir ICT-1	ER1575A	0	0	0	0	0
	20	HV side meter of 400/220 Bolangir ICT-2	ER1582A	0	0	0	0	0
	21	HV side of 400/220 Pandiabili ICT-1	ER1583A	1056.5	-163757.5	0	0	-163758
	22	HV side of 400/220 Pandiabili ICT-2	ER1776A	1037.6	-160828	0	0	-160828
	23	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-I	ER1059A	-494.4	76632	0	0	76632
	24	400KV SUNDERGARH (PG)-STERLITE (GRIDCO)-II	ER1058A	-508.2	78771	0	0	78771
	25	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	26	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	27	400 KV SUNDERGARH (PG)-OPGC-1	ER1117A	-1040.4	161262	0	0	161262
	28	400 KV SUNDERGARH (PG)-OPGC-2	ER1119A	-1068.2	165571	0	0	165571
		TOTAL			-6032538		0	-6032538
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-49.20	7626	0	0	7626
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-9.50	1473	0	0	1473
	3	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	ER1490A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	ER1489A	0.00	0	0	0	0
		TOTAL			9099		0	9099
WBSETCL	1	400 KV JEERAT (WBSETCL) - RAJARAHAT (PG)	ER1471A	0	0	-28.3	-4387	-4387
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	134.6	-20863	-0.2	-31	-20894
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	121.8	-18879	0	0	-18879
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-1107.9	171725	0	0	171725
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-1157.8	179459	0	0	179459
	6	132 KV SILIGURI (PG) - NJP (WBSETCL)	ER1080A	-119.2	18476	0	0	18476
	7	132 KV SILIGURI (PG) - NBU (WBSETCL)	ER1675A	-150.8	23374	0	0	23374
	8	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2111.4	327267	0	0	327267
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-6.7	1039	0	0	1039
	10	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	ER1739A	686.5	-106408	0	0	-106408
	11	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-II	NP5881A	965.3	-149622	0	0	-149622
	12	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	13	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-I	NP5831A	6183.6	-958458	0	0	-958458
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR (WBSETCL)-II	NP6459A	404.5	-62698	0	0	-62698
	15	400 KV SAGARDIGHI (WB) - FARAKKA (NTPC)-1 (MAIN)	NP6482A	-948.8	147064	0	0	147064
	16	400 KV JEERAT (PG) - SUBHASGRAM (PG)	ER1477A	-170	26350	0.7	109	26459
	17	132 KV KURSEONG (WBSETCL)-RANGIT (NHPC)	NP7541A	20.7	-3209	0	0	-3209
	18	132 KV KURSEONG (WBSETCL)-SILIGURI (NHPC)	NP7542A	-62.8	9734	0	0	9734
	19	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	739.4	-114607	0	0	-114607
	20	400 KV DURGAPUR (PG)- SAGARDIGHI (WBSETCL)-I	NP6548A	410.4	-63612	0	0	-63612
	21	400 KV DURGAPUR (PG)- SAGARDIGHI (WBSETCL)-II	ER1637A	901.2	-139686	0	0	-139686
	22	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-I	ER1071A	-1052.3	163107	0	0	163107
	23	220 KV DALKHOLA (PG)-DALKHOLA (WBSETCL) LINE-II	ER1072A	-308.4	47802	0	0	47802
	24	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	ER1486A	74.9	-11610	0	0	-11610
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	ER1537A	78.1	-12106	0	0	-12106
	26	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	ER1484A	180.5	-27978	0	0	-27978
	27	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-I	ER1141A	701.5	-108733	0.3	47	-108686
	28	400 KV SUBHASHGRAM (PG)-HALDIA CESC (WB) LINE-II	ER1679A	1196.5	-185458	0	0	-185458
	29	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-I	NP8723A	-530.7	82259	0	0	82259
	30	400 KV SAGARDIGHI (WB)-BERHAMPUR (PG) LINE-II	NP8724A	-375.7	58234	0	0	58234
	31	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-I	NP8731A	-796.7	123489	0	0	123489
	32	400 KV KHARAGPUR (WB)-CHAIBASA (PG)-II	NP8720A	-719.7	111554	0	0	111554
	33	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-I	ER1040A	2755.2	-427056	0	0	-427056
	34	400 KV PPSP NEW (WB)-RANCHI NEW (PG)-II	ER1130A	2535	-392925	0	0	-392925
	35	400 KV GOKARNA (WB)-RAJARHAT (PG)	ER1133A	-1493	231415	0	0	231415
	36	400 KV GOKARNA (WB)-PURNEA (PG)	ER1138A	-1534.7	237879	0	0	237879
	37	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-I	ER1044A	-11	1705	0	0	1705
	38	220 KV ALIPURDUAR (PG)-ALIPURDUAR (WB)-II	ER1047A	-1.4	217	0	0	217
	39	400 KV SAGARDIGHI (WB)-FARAKKA (NTPC)-II	ER1131A	-412.8	63984	0	0	63984
	40	HV side of 400/220 KV RAJARHAT (PG) ICT-1	ER1526A	127.9	-19825	0	0	-19825
	41	220 KV SIDE OF 50 MVA MALDA (PG) 220/132 ICT-4	ER1639A	-696.5	107958	0	0	107958
	42	400 KV SIDE OF RAJARHAT (PG) 400/220 500 MVA ICT-2	ER1650A	123.8	-19189	0	0	-19189
	43	220 KV GAZOLE (WB)-MALDA (PG)-1	ER1693A	-97.3	15082	0	0	15082
	44	220 KV GAZOLE (WB)-MALDA (PG)-2	ER1696A	-127.8	19809	0	0	19809
	45	220 KV GAZOLE (WB)-DALKHOLA (PG)-1	ER1698A	0	0	0	0	0
	46	220 KV GAZOLE (WB)-DALKHOLA (PG)-2	ER1699A	-1088.7	168749	0	0	168749
	47	765 KV SIDE OF MEDINIPUR (PG) 765/400KV 1500 MVA ICT-1	ER1683A	0	0	0	0	0
	48	765 KV SIDE OF MEDINIPUR (PG) 765/400KV 1500 MVA ICT-2	ER1685A	0	0	0	0	0
		TOTAL			-505192		-4263	-509454

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVArH,w.e.f. 01/04/2021

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting ,the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.