



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee
14, गोल्फ क्लब रोड, टालीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



आई एस ओ : 9001-2008
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/2021/754

Date: 23.09.2021

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 06.09.2021-12.09.2021

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 17.09.2021.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This is issued with the approval of Member Secretary.

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)
SUPERINTENDING ENGINEER

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 06/09/21 to 12/09/21**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)	AMOUNT RECEIVABLE(Rs.)	AMOUNT RECEIVABLE(Final After Adjustment)(Rs.)
BSPHCL	POOL	0	2150470	2150470
JUVNL	POOL	850739	0	0
DVC	POOL	1578350	0	0
GRIDCO	POOL	6300022	0	0
SIKKIM	POOL	0	9889	9889
WBSETCL	POOL	126108	0	0
Total		8855218	2160359	2160359

Note:

a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC

b) Final Receivables Amount After Adjustment from the Reactive Pool are done as per Methodology Approved in the 43rd ERPC meeting held on 26.03.2021 at Kolkata.

SUPERINTENDING ENGINEER

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA
DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 06/09/21 to 12/09/21

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVAH_HIGH	REACTIVE CHARGE_MVAh (Rs)	MVAH_LOW	REACTIVE CHARGE_MVAh (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-1354.3	209917	-0.1	-15.5	209901
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-469	72695	0	0	72695
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-3621	561255	0	0	561255
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	-9.9	1535	-318.1	-49305.5	-47771
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-26.4	4092	-137	-21235	-17143
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	-8	1240	-258.6	-40083	-38843
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-3449.8	534719	0	0	534719
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-19.1	2961	-0.5	-77.5	2883
	9	220 KV side of 220/132 Arah ICT-2	ER1882A	-21.6	3348	-0.5	-77.5	3271
	10	220 KV KHAGAULI(BSPHCL) - ARAH (PG)-I	NP8641A	-6.2	961	0	0	961
	11	220 KV KHAGAULI(BSPHCL) - ARAH (PG)-II	NP6060A	-350.1	54266	0	0	54266
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	0	0	-488.5	-75717.5	-75718
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	-29.7	4604	-0.6	-93	4511
	16	220 KV NADHOKHAR(BSPHCL)- PUSAULI (PG)-2	NP8665A	-2280.8	353524	0	0	353524
	17	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	ER1872A	-9.6	1488	0	0	1488
	18	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	ER1873A	-11.1	1721	0	0	1721
	19	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	1045.5	-162053	0	0	-162053
	20	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	1040.3	-161247	0	0	-161247
	21	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	1136.4	-176142	0	0	-176142
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	1091.6	-169198	0	0	-169198
	23	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	-5.8	899	330.3	51196.5	52096
	24	HV side of 400/220 Patna ICT-1	ER1877A	-1351.2	209436	0	0	209436
	25	HV side of 400/220 Patna ICT-2	ER1407A	-1776.1	275296	0	0	275296
	26	HV side of 400/220 Patna ICT-3	ER1231A	-1640.4	254262	0	0	254262
	27	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	0.2	-31	0	0	-31
	28	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	0.4	-62	0	0	-62
	29	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-3354.9	520010	0	0	520010
	30	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-3290	509950	0	0	509950
	31	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	1305.6	-202368	0	0	-202368
	32	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	1478.6	-229183	0	0	-229183
	33	HV side of 400/220 Darhanaga DMTCL ICT-1	ER1274A	659.6	-102238	0	0	-102238
	34	HV side of 400/220 Darhanaga DMTCL ICT-2	ER1275A	683.6	-105958	0	0	-105958
	35	220 KV NEW PURNEA(PG)-BEGUSARAI(BSPTCL)-I	ER1348A	1751.6	-271498	0	0	-271498
	36	220 KV NEW PURNEA(PG)-KHAGARIA(BSPTCL)	ER1376A	1124.3	-174267	0	0	-174267
	37	220 KV DUMRAON NEW (BSPHCL)- ARA(PG) LINE-1	ER1305A	197.3	-30582	0	0	-30582
	38	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	-3140	486700	0	0	486700
	39	HV side of 400/220 KV Biharsharif(PG) ICT-4	ER1386A	-395.9	61365	0	0	61365
	40	400 KV SIDE OF 400/220 500 MVA GAYA(PG) ICT-3	ER1442A	0	0	0	0	0
	41	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-1	ER1247A	-497.1	77051	0	0	77051
	42	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-2	ER1243A	-479.9	74385	0	0	74385
	43	220 KV DUMRAON NEW (BSPHCL)- ARA (PG)-2	ER1866A	193.9	-30055	0	0	-30055
	44	400 KV SIDE OF LAKHISARAI(PG) 315 MVA 400/132 ICT-3	ER1309A	-5.2	806	0	0	806
	45	400 KV SIDE BANKA(PG) 400/132 KV 315 MVA ICT-3	ER1362A	0.8	-124	0	0	-124
	46	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-1	ER1395A	7.6	-1178	0	0	-1178
	47	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-2	ER1933A	6.5	-1008	0	0	-1008
	48	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-3	ER1934A	7.6	-1178	0	0	-1178
	49	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-2	ER1875A	547.3	-84832	1	155	-84677
	50	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-1	ER1816A	577.8	-89559	0	0	-89559
	51	400 KV HV SIDE OF 315 MVA MOTIHARI(DMTCL) ICT-3	ER1819A	0	0	0	0	0
	52	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-1	ER1806A	0	0	0	0	0
	53	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-2	ER1823A	0	0	0	0	0
		TOTAL			2285723		-135253	2150470
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-2315.9	358965	0	0	358965
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-1442.2	223541	0	0	223541
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-1534.5	237848	0	0	237848
	4	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	0	0	0	0	0
	5	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	855.8	-132649	0	0	-132649
	6	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	905.4	-140337	0	0	-140337
	7	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-2	NP8637A	65.8	-10199	0	0	-10199
	8	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-1	NP8678A	67.7	-10494	0	0	-10494
	9	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	40.8	-6324	0	0	-6324
	10	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	32.1	-4976	-0.2	-31	-5007
	11	220 KV RANCHI(PG)-HATIA(JUVNL)-I	NP5879A	2503.54	-388049	0	0	-388049
	12	221 KV RANCHI(PG)-HATIA(JUVNL)-II	ER1252A	2227.3	-345232	0	0	-345232
	13	222 KV RANCHI(PG)-HATIA(JUVNL)-III	NP7880A	2248.9	-348580	0	0	-348580
	14	223 KV RANCHI(PG)-CHANDIL(JUVNL)	NP5874A	1833.7	-284224	0	0	-284224
		TOTAL			-850708		-31	-850739
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-1376	213280	0	0	213280
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	ER1668A	-99	15345	0	0	15345
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-180.8	28024	-0.2	-31	27993
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	ER1711A	86.6	-13423	0	0	-13423
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	ER1717A	174.4	-27032	0	0	-27032
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	ER1808A	-1864.8	289044	0	0	289044
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	ER1802A	2812.4	-435922	0	0	-435922
	9	400 KV MEJIA(DVC)-MAITHON(PG)	ER1659A	-1151.6	178498	0	0	178498
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1657A	-705.1	109291	0	0	109291
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1658A	-769.8	119319	0	0	119319
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	NP7831A	-1730.4	268212	0	0	268212
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	NP7830A	-1066.5	165308	0	0	165308
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	NP7891A	-1095	169725	0	0	169725
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	NP7890A	-1542.8	239134	0	0	239134
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	NP6524A	-1800.4	279062	0	0	279062
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-III(MAIN)	NP6522A	-1760.9	272940	0	0	272940
	18	400 KV RTPS(DVC)-RANCHI(PG)	ER1653A	-4083.4	632927	0	0	632927
	19	400 KV RTPS(DVC)-MAITHON(PG)	ER1652A	11399.6	-1766938	0	0	-1766938
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	ER1656A	-989.5	153373	0	0	153373
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	6832.4	-1059022	0	0	-1059022
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	6739.9	-1044685	0	0	-1044685
23	220 KV RANCHI(PG)-RAMGARH(DVC)	ER1798A	2353.4	-364777	0	0	-364777	
24	221 KV RANCHI(PG)-MTPS(DVC)	ER1796A	0	0	0	0	0	
		TOTAL			-1578319		0	-1578350

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-1 AND ICT-3	ER1563A	0	0	0	0	0
	2	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-2 AND ICT-4	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	400 KV SIDE OF JEYPORE (PG) 400/220 KV ICT-1 AND ICT-3	ER1550A	5842	-905510	0	0	-905510
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	1798.8	-278814	0	0	-278814
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	ER1759A	17613	-2730015	0	0	-2730015
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	0	0	0	0	0
	9	HV side meter of 400/220 Baripada ICT-2	ER1746A	0	0	0	0	0
	10	HV side meter of 400/220 Baripada ICT-3	ER1747A	0	0	0	0	0
	11	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	12	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	ER1900A	-2173.5	336892.5	0	0	336893
	13	400 KV MERAMUNDALI (GRIDCO)-BOLANGIR(PG)	ER1054A	-1608.5	249317.5	0	0	249318
	14	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)-2	ER1055A	15632.3	-2423006.5	0	0	-2423007
	15	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	ER1758A	7097.4	-1100097	0	0	-1100097
	16	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	NP5980A	0	0	0	0	0
	17	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	NP7498A	0	0	0	0	0
	18	400 KV DUBRI(GRIDCO)-PANDIABIL(PG)	ER1897A	-3505.8	543399	0	0	543399
	19	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	-74.3	11516.5	-16.7	-2588.5	8928
	20	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	-73.5	11392.5	-16.7	-2588.5	8804
	21	HV side of 400/220 Pandiabili ICT-1	ER1583A	585.1	-90690.5	0	0	-90691
	22	HV side of 400/220 Pandiabili ICT-2	ER1776A	583.8	-90489	0	0	-90489
	23	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	0	0	0	0	0
	24	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	-13.8	2139	0	0	2139
	25	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	26	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	27	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	-535	82925	0	0	82925
	28	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	-556.1	86195.5	0	0	86196
		TOTAL		-6294845		-5177	-6300022	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-55.50	8603	0	0	8603
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-8.30	1287	0	0	1287
	3	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	ER1490A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	ER1489A	0.00	0	0	0	0
		TOTAL		9889		0	9889	
WBSETCL	1	400 KV JEERAT (WBSETCL) - RAJARAHAT(PG)	ER1471A	0	0	-42.1	-6526	-6526
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	21.3	-3302	0	0	-3302
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	20.3	-3147	0	0	-3147
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-821.2	127286	0	0	127286
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-909	140895	0	0	140895
	6	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-10.6	1643	0	0	1643
	7	132 KV SILIGURI (PG) - NBU (WBSETCL)	ER1675A	-88	13640	0	0	13640
	8	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-1608.4	249302	0	0	249302
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	0	0	0	0	0
	10	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	ER1739A	-364.4	56482	0	0	56482
	11	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	NP5881A	689.5	-106873	0	0	-106873
	12	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	13	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	NP5831A	3233.8	-501239	0	0	-501239
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	NP6459A	0	0	0	0	0
	15	400 KV SAGARDIGHI(WB) - FARAKKA (NTPC)-1(MAIN)	NP6482A	-644.7	99929	0	0	99929
	16	400 KV JEERAT(PG) - SUBHASGRAM (PG)	ER1477A	-63.8	9889	0	0	9889
	17	132 KV KURSEONG(WBSETCL)-RANGIT (NHPC)	NP7541A	32.1	-4976	0	0	-4976
	18	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	-65.5	10153	0	0	10153
	19	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	465.1	-72091	0	0	-72091
	20	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	0	0	0	0	0
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	ER1637A	0.7	-109	0	0	-109
	22	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-664.6	103013	0	0	103013
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-180.6	27993	0	0	27993
	24	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	ER1486A	12.3	-1907	0	0	-1907
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	ER1537A	12.5	-1938	0	0	-1938
	26	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	ER1484A	17	-2635	0	0	-2635
	27	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	779.2	-120776	0	0	-120776
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	ER1679A	1471.7	-228114	0	0	-228114
	29	400 KV SAGARDIGHI(WB)-BERHAMPURE(PG) LINE-I	NP8723A	-87	13485	0	0	13485
	30	400 KV SAGARDIGHI(WB)-BERHAMPURE(PG) LINE-II	NP8724A	-50.7	7859	0	0	7859
	31	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-883.4	136927	0	0	136927
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-807.8	125209	0	0	125209
	33	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-I	ER1040A	1797.5	-278613	0	0	-278613
	34	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	ER1130A	1645.7	-255084	0	0	-255084
	35	400 KV GOKARNA(WB)-RAJARHAT(PG)	ER1133A	-532.2	82491	0	0	82491
	36	400 KV GOKARNA(WB)-PURNEA(PG)	ER1138A	-290	44950	0	0	44950
	37	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	0	0	0	0	0
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	0	0	0	0	0
	39	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	-139.3	21592	0	0	21592
	40	HV side of 400/220 KV RAJARHAT(PG) ICT-1	ER1526A	41.2	-6386	0	0	-6386
	41	220 KV SIDE OF 50 MVA MALDA(PG) 220/132 ICT-4	ER1639A	-561.5	87033	0	0	87033
	42	400 KV SIDE OF RAJARHAT(PG) 400/220 500 MVA ICT-2	ER1650A	32.5	-5038	0	0	-5038
	43	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	17.7	-2744	0	0	-2744
	44	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	8.2	-1271	0	0	-1271
	45	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER1698A	-319.8	49569	0	0	49569
	46	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER1699A	-434.3	67317	0	0	67317
	47	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-1	ER1683A	0	0	0	0	0
	48	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-2	ER1685A	0	0	0	0	0
		TOTAL		-119583		-6526	-126108	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVArH.w.e.f. 01/04/2021

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTD.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting ,the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.