



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
पूर्वी क्षेत्रीय विद्युत समिति



**Eastern Regional Power Committee**  
14, गोल्फ क्लब रोड, टालीगंज, कोलकाता-700033  
14 Golf Club Road, Tollygunj, Kolkata-700033

आई एस ओ : 9001-2008  
ISO : 9001-2008

Tel No.:033-24239651, 24239650 FAX No.:033-24239652, 24239653 Web: [www.erpc.gov.in](http://www.erpc.gov.in)

NO: ERPC/COM-II/VARH/1591

Date: 03.03.2022

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3<sup>rd</sup> Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486 )
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4<sup>th</sup> floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6<sup>th</sup> floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

**Sub: Provisional Reactive Energy (VARH) Charges for the period 14.02.2022-20.02.2022**

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 25.02.2022.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.  
यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

**This is issued with the approval of Member Secretary.**

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)  
SUPERINTENDING ENGINEER

**Eastern Regional Power Committee:: KOLKATA**

**Provisional Reactive Energy (VArH) Charge Statement  
for the period 14/02/22 to 20/02/22**

**REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL**

<b>FROM</b>	<b>TO</b>	<b>AMOUNT PAYABLE (Rs.)</b>	<b>AMOUNT RECEIVABLE(Rs.)</b>	<b>AMOUNT RECEIVABLE(Final After Adjustment)(Rs.)</b>
BSPHCL	POOL	3601565	0	0
JUVNL	POOL	1845508	0	0
DVC	POOL	2205805	0	0
GRIDCO	POOL	2912497	0	0
SIKKIM	POOL	0	116405	116405
WBSETCL	POOL	2054587	0	0
<b>Total</b>		<b>12619961</b>	<b>116405</b>	<b>116405</b>

Note:

a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC

**b) Final Receivables Amount After Adjustment from the Reactive Pool are done as per Methodology Approved in the 43rd ERPC meeting held on 26.03.2021 at Kolkata.**

**SUPERINTENDING ENGINEER**

**DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL**

for the period 14/02/22 to 20/02/22

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVAh (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVAh (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-2395.2	371256	0	0	371256
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-665.8	103199	0	0	103199
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-2932.4	454522	0	0	454522
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	32.7	-5069	0	0	-5069
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	12.8	-1984	0	0	-1984
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	77.8	-12059	0	0	-12059
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-262	40610	0	0	40610
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-365	56575	0	0	56575
	9	220 KV side of 220/132 Arah ICT-2	ER1882A	-375.9	58265	0	0	58265
	10	220 KV KHAGAULI(BSPHCL) - ARAH (PG)-I	NP8641A	-311.1	48221	0	0	48221
	11	220 KV KHAGAULI(BSPHCL) - ARAH (PG)-II	NP6060A	-7	1085	0	0	1085
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	0	0	19.9	3084.5	3085
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	-478	74090	0	0	74090
	16	220 KV NADHOKHAR(BSPHCL)- PUSAULI (PG)-2	NP8665A	-792.9	122900	0	0	122900
	17	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	ER1872A	39.3	-6092	0	0	-6092
	18	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	ER1873A	41.9	-6495	0	0	-6495
	19	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1293A	2434.2	-377301	0	0	-377301
	20	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	2422.4	-375472	0	0	-375472
	21	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	2625.6	-406968	0	0	-406968
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	2575.8	-399249	0	0	-399249
	23	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	13.3	-2062	4.3	666.5	-1395
	24	HV side of 400/220 Patna ICT-1	ER1877A	1716.3	-266027	0	0	-266027
	25	HV side of 400/220 Patna ICT-2	ER1407A	1134.5	-175848	0	0	-175848
	26	HV side of 400/220 Patna ICT-3	ER1231A	1079.2	-167276	0	0	-167276
	27	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	114.5	-17748	0	0	-17748
	28	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	114.6	-17763	0	0	-17763
	29	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1458.7	226099	0	0	226099
	30	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1542.8	239134	0	0	239134
	31	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2465.6	-382168	0	0	-382168
	32	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2473.8	-383439	0	0	-383439
	33	HV side of 400/220 Darbhanaga DMTCL ICT-1	ER1274A	1291.2	-200136	0	0	-200136
	34	HV side of 400/220 Darbhanaga DMTCL ICT-2	ER1275A	1445.1	-223991	0	0	-223991
	35	220 KV NEW PURNEA(PG)-BEGUSARAI(BSPTCL)-I	ER1348A	2846.9	-441270	0	0	-441270
	36	220 KV NEW PURNEA(PG)-KHAGARIA(BSPTCL)	ER1376A	1709.2	-264926	0	0	-264926
	37	220 KV DUMRAON NEW (BSPHCL)- ARA(PG) LINE-1	ER1305A	124.5	-19298	0	0	-19298
	38	220 KV NADHOKHAR(BSPHCL)- PUSAULI(PG) LINE-1	ER1310A	-910.1	141066	0	0	141066
	39	HV side of 400/220 KV Biharshariff(PG) ICT-4	ER1386A	-948.7	147049	0	0	147049
	40	400 KV SIDE OF 400/220 500 MVA GAYA(PG) ICT-3	ER1442A	0	0	0	0	0
	41	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-1	ER1247A	159.4	-24707	0	0	-24707
	42	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-2	ER1243A	171.3	-26552	0	0	-26552
	43	220 KV DUMRAON NEW (BSPHCL)- ARA (PG)-2	ER1866A	124.8	-19344	0	0	-19344
	44	400 KV SIDE OF LAKHISARAI(PG) 315 MVA 400/132 ICT-3	ER1309A	90.1	-13966	0	0	-13966
	45	400 KV SIDE BANKA(PG) 400/132 KV 315 MVA ICT-3	ER1362A	216.4	-33542	0	0	-33542
	46	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-1	ER1395A	8.7	-1349	0	0	-1349
	47	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-2	ER1933A	9.8	-1519	0	0	-1519
	48	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-3	ER1934A	8.7	-1349	0	0	-1349
	49	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-2	ER1875A	1668	-258540	0	0	-258540
	50	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-1	ER1816A	1688.8	-261764	0	0	-261764
	51	400 KV HV SIDE OF 315 MVA MOTIHARI(DMTCL) ICT-3	ER1819A	0	0	0	0	0
	52	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-1	ER1806A	1742.2	-270041	0	0	-270041
	53	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-2	ER1823A	1792.3	-277807	0	0	-277807
	54	220 KV PUSAULI(PG)-KARAMNUSA NEW(BSPHCL)	NP6092A	2234	-346270	0	0	-346270
		<b>TOTAL</b>			<b>-3605316</b>		<b>3751</b>	<b>-3601565</b>
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-826	128030	0	0	128030
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-4641.6	719448	0	0	719448
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-3968.8	615164	0	0	615164
	4	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	0	0	0	0	0
	5	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	3246.8	-503254	0	0	-503254
	6	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	3647.4	-565347	0	0	-565347
	7	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-2	NP8637A	0.2	-31	0	0	-31
	8	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-1	NP8678A	0	0	0	0	0
	9	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	0	0	0
	10	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	0	0	0
	11	220 KV RANCHI(PG)-HATIA(JUVNL)-I	NP5879A	4695.8	-727849	0	0	-727849
	12	221 KV RANCHI(PG)-HATIA(JUVNL)-II	ER1252A	4145.9	-642615	0	0	-642615
	13	222 KV RANCHI(PG)-HATIA(JUVNL)-III	NP7880A	4222	-654410	0	0	-654410
	14	223 KV RANCHI(PG)-CHANDIL(JUVNL)	NP5874A	590	-91450	0	0	-91450
	15	400 KV RANCHI NEW (PG)-PATRATU NEW(JUVNL) LINE-1	ER1221A	415.2	-64356	0	0	-64356
	16	400 KV RANCHI NEW (PG)-PATRATU NEW(JUVNL) LINE-2	ER1230A	379.6	-58838	0	0	-58838
		<b>TOTAL</b>			<b>-1845508</b>		<b>0</b>	<b>-1845508</b>
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-3233	501115	0	0	501115
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	ER1668A	-63.8	9889	0	0	9889
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-46.6	7223	0	0	7223
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	ER1711A	-1631	252805	0	0	252805
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	ER1717A	-1872.4	290222	0	0	290222
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIKADA(PG)	ER1808A	-2690.9	417090	0	0	417090
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	ER1802A	3914.8	-606794	0	0	-606794
	9	400 KV MEJIA(DVC)-MAITHON(PG)	ER1659A	-2189.9	339435	0	0	339435
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1657A	-1055.4	163587	0	0	163587
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1658A	-1139.6	176638	0	0	176638
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	ER2042A	1291.6	-200198	0	0	-200198
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	ER2128A	1617.6	-250728	0	0	-250728
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	ER2129A	1896.7	-293989	0	0	-293989
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	ER2130A	1474.1	-228486	0	0	-228486
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-I(MAIN)	ER2046A	1733	-268615	0	0	-268615
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	ER2044A	0	0	0	0	0
	18	400 KV RTPS(DVC)-RANCHI(PG)	ER1653A	-1622.6	251503	0	0	251503
	19	400 KV RTPS(DVC)-MAITHON(PG)	ER1652A	12101.9	-1875795	0	0	-1875795
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	ER1656A	-1212.4	187922	0	0	187922
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	4535.3	-702972	0	0	-702972
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	4416.8	-684604	0	0	-684604
23	220 KV RANCHI(PG)-RAMGARH(DVC)	ER1798A	-1993.2	308946	0	0	308946	
24	221 KV RANCHI(PG)-MTPS(DVC)	ER1796A	0	0	0	0	0	
		<b>TOTAL</b>			<b>-2205805</b>		<b>0</b>	<b>-2205805</b>

**EASTERN REGIONAL POWER COMMITTEE :: KOLKATA**

GRIDCO	1	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-1 AND ICT-3	ER1563A	0	0	0	0	0
	2	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-2 AND ICT-4	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	400 KV SIDE OF JEYPORE (PG) 400/220 KV ICT-1 AND ICT-3	ER1550A	0	0	0	0	0
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	0	0	0	0	0
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	ER1759A	497.6	-77128	0	0	-77128
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	0	0	0	0	0
	9	HV side meter of 400/220 Baripada ICT-2	ER1746A	0	0	0	0	0
	10	HV side meter of 400/220 Baripada ICT-3	ER1747A	0	0	0	0	0
	11	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	12	400 KV DUBURI (GRIDCO) - BARIPADA(PG)	ER1900A	2202.8	-341434	0	0	-341434
	13	400 KV MERAMUNDALI (GRIDCO)-BOLANGIR(PG)	ER1054A	1452.4	-225122	0	0	-225122
	14	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)-2	ER1055A	8059.4	-1249207	0	0	-1249207
	15	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	ER1758A	3923.9	-608204.5	0	0	-608205
	16	400 KV MENDHASAL (GRIDCO) - PANDIABIL(PG)-I	ER2072A	0	0	0	0	0
	17	400 KV MENDHASAL (GRIDCO) - PANDIABIL(PG)-II	ER2071A	1216.8	-188604	0	0	-188604
	18	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	ER1897A	-4718.9	731429.5	0	0	731430
	19	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	20	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	21	HV side of 400/220 Pandiabil ICT-1	ER1583A	3609.3	-559441.5	0	0	-559442
	22	HV side of 400/220 Pandiabil ICT-2	ER1776A	3542.5	-549087.5	0	0	-549088
	23	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	0	0	0	0	0
	24	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	0	0	0	0	0
	25	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	26	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	27	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	-480.7	74508.5	0	0	74509
	28	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	-514.8	79794	0	0	79794
		<b>TOTAL</b>		<b>-2912497</b>		<b>0</b>	<b>-2912497</b>	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-112.00	17360	0	0	17360
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-141.50	21933	0	0	21933
	3	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	ER1490A	-250.10	38766	0	0	38766
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	ER1489A	-247.40	38347	0	0	38347
		<b>TOTAL</b>		<b>116405</b>		<b>0</b>	<b>116405</b>	
WBSETCL	1	400 KV JEERAT (WBSETCL) - RAJARHAT(PG)	ER1471A	0	0	0	0	0
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-1	ER1534A	7.9	-1225	0	0	-1225
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-2	ER1483A	0	0	0	0	0
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-2123.9	329205	0	0	329205
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-2235	346425	0	0	346425
	6	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-1766.7	273839	0	0	273839
	7	132 KV SILIGURI (PG) - NBU (WBSETCL)	ER1675A	-1192.4	184822	0	0	184822
	8	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2493.7	386524	0	0	386524
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-872.8	135284	0	0	135284
	10	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	ER1739A	9702.9	-1503950	0	0	-1503950
	11	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	ER2039A	8324.1	-1290236	0	0	-1290236
	12	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	13	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	ER2109A	-4423.4	685627	0	0	685627
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	ER2111A	0	0	0	0	0
	15	400 KV SAGARDIGHI(WB) - FARAKKA (NTPC)-1(MAIN)	NP6482A	-1048.7	162549	0	0	162549
	16	400 KV JEERAT(PG) - SUBHASHGRAM (PG)	ER1477A	0	0	0	0	0
	17	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	NP7541A	-110	17050	0	0	17050
	18	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	NP7542A	38.2	-5921	0	0	-5921
	19	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	-181.2	28086	0	0	28086
	20	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	0	0	0	0	0
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	ER1637A	1.8	-279	0	0	-279
	22	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-672.7	104269	0	0	104269
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-415.7	64434	0	0	64434
	24	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-3	ER1486A	0	0	0	0	0
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASHGRAM ICT-4	ER1537A	0	0	0	0	0
	26	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	ER1484A	38.9	-6030	0	0	-6030
	27	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	108.8	-16864	0	0	-16864
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	ER1679A	1221.1	-189271	0	0	-189271
	29	400 KV SAGARDIGHI(WB)-BERHAMPORE (PG) LINE-I	NP8723A	101.8	-15779	0	0	-15779
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE (PG) LINE-II	NP8724A	-5.1	791	0	0	791
	31	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-1226.1	190046	0	0	190046
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-1002.2	155341	0	0	155341
	33	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-I	ER1040A	5.4	-837	0	0	-837
	34	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	ER1130A	132	-20460	0	0	-20460
	35	400 KV GOKARNA(WB)-RAJARHAT(PG)	ER1133A	-659	102145	0	0	102145
	36	400 KV GOKARNA(WB)-PURNEA(PG)	ER1138A	-633.7	98224	0	0	98224
	37	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	836.9	-129720	0	0	-129720
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	899.7	-139454	0	0	-139454
	39	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	-16	2480	0	0	2480
	40	HV side of 400/220 KV RAJARHAT(PG) ICT-1	ER1526A	0	0	0	0	0
	41	220 KV SIDE OF 50 MVA MALDA(PG) 220/132 ICT-4	ER1639A	-1489.9	230935	0	0	230935
	42	400 KV SIDE OF RAJARHAT(PG) 400/220 500 MVA ICT-2	ER1650A	0	0	0	0	0
	43	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	3661.3	-567502	0	0	-567502
	44	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	3620	-561100	0	0	-561100
	45	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER2125A	3577.7	-554544	0	0	-554544
	46	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER2045A	3545.1	-549491	0	0	-549491
	47	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-1	ER1683A	0	0	0	0	0
	48	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-2	ER1685A	0	0	0	0	0
	49	400 KV JEERAT(WB)-NEW JEERAT(PMJTL) CKT-1	ER2101A	0	0	0	0	0
	50	401 KV JEERAT(WB)-NEW JEERAT(PMJTL) CKT-2	ER2103A	0	0	0	0	0
		<b>TOTAL</b>		<b>-2054587</b>		<b>0</b>	<b>-2054587</b>	

Note: 1) Rate of Reactive Energy Charge has been considered @ 15.5 paise/KVArH.w.e.f. 01/04/2021

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an ISGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting ,the methodology for compusion of Reactive Charges has been changed in conformity with other RPCs.