



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

75
Azadi Ka
Amrit Mahotsav



Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033

Tel. No.: 033-24239651, 24239658 FAX No.: 033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/887

Date: 12.10.2022

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 26.09.2022-02.10.2022

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 07.10.2022.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This issues with the approval of Member Secretary.

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)

SUPERINTENDING ENGINEER

14 गोल्फ क्लब रोड, टॉलीगंज, कोलकाता - 700 033 | 14 Golf Club Road, Tollygunge, Kolkata – 700 033.

Tele: 24239657, 24239651, 24239650. Fax: 24239652, 24239653. www.erpc.gov.in, Email: mserpc-power@nic.in

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 26/09/22 to 02/10/22**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)	AMOUNT RECEIVABLE(Rs.)	AMOUNT RECEIVABLE(Final After Adjustment)(Rs.)
BSPHCL	POOL	0	448544	448544
JUVNL	POOL	2968304	0	0
DVC	POOL	496672	0	0
GRIDCO	POOL	1947216	0	0
SIKKIM	POOL	0	15360	15360
WBSETCL	POOL	0	610256	610256
Total		5412192	1074160	1074160

Note:

a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC

b) Final Receivables Amount After Adjustment from the Reactive Pool are done as per Methodology Approved in the 43rd ERPC meeting held on 26.03.2021 at Kolkata.

SUPERINTENDING ENGINEER

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 26/09/22 to 02/10/22

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVA/H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVA/H (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-832	133120	0	0	133120
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6068A	-570.9	91344	0	0	91344
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-1181.5	189040	0	0	189040
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	0	0	-26	-4160	-4160
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	0	0	-1.3	-208	-208
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	0	0	-17.3	-2768	-2768
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-1061.5	169840	0	0	169840
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	0	0	-0.6	-96	-96
	9	220 KV side of 220/132 Arah ICT-2	ER1882A	0	0	-0.6	-96	-96
	10	220 KV NAUBATPUR(BGCL) - ARAH(PG) LINE-1	ER1829A	-2.1	336	0	0	336
	11	220 KV NAUBATPUR(BGCL) - ARAH(PG) LINE-2	ER1871A	-2.6	416	0	0	416
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	0	0	-58.4	-9344	-9344
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	0	0	-0.6	-96	-96
	16	220 KV NADHOKHAR(BSPHCL) - PUSAULI (PG)-2	NP8665A	-1696.5	271440	0	0	271440
	17	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	ER1872A	0	0	0	0	0
	18	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	ER1873A	0	0	0	0	0
	19	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1788A	805.4	-128864	0	0	-128864
	20	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	784	-125440	0	0	-125440
	21	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	898.8	-143808	0	0	-143808
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	804.9	-128784	0	0	-128784
	23	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	0	0	52.6	8416	8416
	24	HV side of 400/220 Patna ICT-1	ER1877A	0	0	0	0	0
	25	HV side of 400/220 Patna ICT-2	ER1407A	-17.8	2848	0	0	2848
	26	HV side of 400/220 Patna ICT-3	ER1231A	-17.5	2800	0	0	2800
	27	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	0	0	0	0	0
	28	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	0	0	0	0	0
	29	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-2416.8	386688	0	0	386688
	30	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-2202.3	352368	0	0	352368
	31	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	898.6	-143776	0	0	-143776
	32	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	872.4	-139584	0	0	-139584
	33	HV side of 400/220 Darthanaga DMTCL ICT-1	ER1274A	0	0	0	0	0
	34	HV side of 400/220 Darthanaga DMTCL ICT-2	ER1275A	0	0	0	0	0
	35	220 KV NEW PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	1826.1	-292176	0	0	-292176
	36	220 KV NEW PURNEA(PG)-KHAGARIA(BSPTCL)	ER1376A	748.5	-119760	0	0	-119760
	37	220 KV DUMRAON NEW(BSPHCL) - ARA(PG) LINE-1	ER1305A	7.9	-1264	0	0	-1264
	38	220 KV NADHOKHAR(BSPHCL) - PUSAULI(PG) LINE-1	ER1310A	-2058.7	329392	0	0	329392
	39	HV side of 400/220 KV Biharsharif(PG) ICT-4	ER1386A	0	0	0	0	0
	40	400 KV SIDE OF 400/220 500 MVA GAYA(PG) ICT-3	ER1442A	0	0	0	0	0
	41	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-1	ER1247A	-11.1	1776	0	0	1776
	42	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTCL) ICT-2	ER1243A	-9.6	1536	0	0	1536
	43	220 KV DUMRAON NEW(BSPHCL) - ARA (PG)-2	ER1866A	5.5	-880	0	0	-880
	44	400 KV SIDE OF LAKHISARAI(PG) 315 MVA 400/132 ICT-3	ER1309A	0	0	0	0	0
	45	400 KV SIDE BANKA(PG) 400/132 KV 315 MVA ICT-3	ER1362A	0	0	0	0	0
	46	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-1	ER1395A	0	0	0	0	0
	47	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-2	ER1933A	0	0	0	0	0
	48	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-3	ER1934A	0	0	0	0	0
	49	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-2	ER1875A	96	-15360	0	0	-15360
	50	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-1	ER1816A	103.6	-16576	0	0	-16576
	51	400 KV HV SIDE OF 315 MVA MOTIHARI(DMTCL) ICT-3	ER1819A	-13.1	2096	0	0	2096
	52	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-1	ER1806A	1133.4	-181344	0	0	-181344
	53	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-2	ER1823A	1089.8	-174368	0	0	-174368
	54	220 KV PUSAULI(PG)-KARAMNANA NEW(BSPHCL)	NP6092A	670.1	-107216	0	0	-107216
	55	400 KV NAUBATPUR(BGCL)-PATNA(PG)-1	ER1879A	314.8	-50368	0	0	-50368
	56	400 KV NAUBATPUR(BGCL)-PATNA(PG)-2	ER1848A	276.3	-44208	0	0	-44208
	57	400 KV JAKKANPUR(BGCL)-PATNA(PG)-1	ER1941A	-74.2	11872	0	0	11872
	58	400 KV JAKKANPUR(BGCL)-PATNA(PG)-2	ER1942A	-26.2	4192	0	0	4192
	59	220 KV MUZAFFARPUR(PG)-GORAUL(BSPHCL)-1	ER1945A	-1997.3	319568	0	0	319568
		TOTAL		456896		-8352	448544	
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-1164.5	186320	0	0	186320
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-606	96960	0	0	96960
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-792.5	126800	0	0	126800
	4	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	0	0	0	0	0
	5	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	2165	-346400	0	0	-346400
	6	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	4137.6	-662016	0	0	-662016
	7	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-2	NP8637A	0	0	0	0	0
	8	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-1	NP8678A	0	0	0	0	0
	9	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	0	0	0	0	0
	10	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	0	0	0	0	0
	11	220 KV RANCHI(PG)-HATIA(JUVNL)-I	NP5879A	28.2	-4512	0	0	-4512
	12	221 KV RANCHI(PG)-HATIA(JUVNL)-II	ER1252A	5907.5	-945200	0	0	-945200
	13	222 KV RANCHI(PG)-HATIA(JUVNL)-III	NP7880A	5982.6	-957216	0	0	-957216
	14	223 KV RANCHI(PG)-CHANDIL(JUVNL)	NP5874A	1554.3	-248688	0	0	-248688
	15	400 KV RANCHI NEW(PG)-PATRATU NEW(JUVNL) LINE-1	ER1221A	714.3	-114288	0	0	-114288
	16	400 KV RANCHI NEW(PG)-PATRATU NEW(JUVNL) LINE-2	ER1230A	625.4	-100064	0	0	-100064
		TOTAL		-2968304		0	-2968304	
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-609.6	97536	0	0	97536
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	ER1668A	2.8	-448	0	0	-448
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-1.4	224	0	0	224
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	ER1711A	-177.4	28384	0	0	28384
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	ER1717A	-270.8	43328	0	0	43328
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	ER1808A	-666.6	106656	0	0	106656
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	ER1802A	0	0	0	0	0
	9	400 KV MEJIA(DVC)-MAITHON(PG)	ER1659A	0	0	0	0	0
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1657A	-362.1	57936	0	0	57936
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1658A	-366.5	58640	0	0	58640
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	ER2042A	309.1	-49456	0	0	-49456
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	ER2128A	498.9	-79824	0	0	-79824
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	ER2129A	-331.6	53056	0	0	53056
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	ER2130A	-264	42240	0	0	42240
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-I(MAIN)	ER2046A	-1897.5	303600	0	0	303600
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	ER2044A	0	0	0	0	0
	18	400 KV RTPS(DVC)-RANCHI(PG)	ER1653A	-1136	181760	0	0	181760
	19	400 KV RTPS(DVC)-MAITHON(PG)	ER1652A	0	0	0	0	0
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	ER1656A	-280.7	44912	0	0	44912
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	4837	-773920	0	0	-773920
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	5799.1	-927856	0	0	-927856
	23	220 KV RANCHI(PG)-RAMGARH(DVC)	ER1798A	-3680.9	588944	0	0	588944
	24	221 KV RANCHI(PG)-MTPS(DVC)	ER1796A	1702.4	-272384	0	0	-272384
		TOTAL		-496872		0	-496872	

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-1 AND ICT-3	ER1563A	0	0	0	0	0
	2	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-2 AND ICT-4	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	400 KV SIDE OF JEYPORE (PG) 400/220 KV ICT-1 AND ICT-3	ER2062A	4825	-772000	0	0	-772000
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	3770.6	-603296	0	0	-603296
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	ER1759A	4932.4	-789184	0	0	-789184
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	0	0	0	0	0
	9	HV side meter of 400/220 Baripada ICT-2	ER1746A	0	0	0	0	0
	10	HV side meter of 400/220 Baripada ICT-3	ER1747A	0	0	0	0	0
	11	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	12	400 KV DUBURI (GRIDCO) - BARIPADA(PG)	ER1900A	-759.9	121584	0	0	121584
	13	400 KV MERAMUNDALI (GRIDCO)-BOLANGIR(PG)	ER1054A	0	0	0	0	0
	14	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)-2	ER1055A	29.1	-4656	0	0	-4656
	15	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	ER1758A	0.4	-64	0	0	-64
	16	400 KV MENDHASAL (GRIDCO) - PANDIABIL(PG)-I	ER2072A	0	0	0	0	0
	17	400 KV MENDHASAL (GRIDCO) - PANDIABIL(PG)-II	ER2071A	0	0	0	0	0
	18	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	ER1897A	-50.9	8144	0	0	8144
	19	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	0	0	0	0	0
	20	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	0	0	0	0	0
	21	HV side of 400/220 Pandiabil ICT-1	ER1583A	0	0	0	0	0
	22	HV side of 400/220 Pandiabil ICT-2	ER1776A	0	0	0	0	0
	23	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	0	0	0	0	0
	24	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	0	0	0	0	0
	25	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	26	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	27	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	-293.8	47008	0	0	47008
	28	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	-282.8	45248	0	0	45248
		TOTAL		-1947216	0	0	-1947216	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-81.10	12976	0	0	12976
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-14.90	2384	0	0	2384
	3	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	ER1490A	0.00	0	0	0	0
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	ER1489A	0.00	0	0	0	0
		TOTAL		15360	0	0	15360	
WBSETCL	1	400 KV JEERAT (WBSETCL) - RAJARAHAT(PG)	ER1471A	0	0	-5.8	-928	-928
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	-11.8	1888	0	0	1888
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	8.4	-1344	0	0	-1344
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	-650.4	104064	0	0	104064
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-703.7	112592	0	0	112592
	6	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	72.1	-11536	0	0	-11536
	7	132 KV SILIGURI (PG) - NBU (WBSETCL)	ER1675A	-142.5	22800	0	0	22800
	8	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-1597	255520	0	0	255520
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	0	0	0	0	0
	10	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	ER1739A	-4885.8	781728	0	0	781728
	11	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	ER2039A	-2121.1	339376	0	0	339376
	12	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	13	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	ER2109A	4927.3	-788368	0	0	-788368
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	ER2111A	0	0	0	0	0
	15	400 KV SAGARDIGHI(WB) - FARAKKA (NTPC)-1(MAIN)	NP6482A	0	0	0	0	0
	16	400 KV JEERAT(PG) - SUBHASGRAM (PG)	ER1477A	-48.8	7808	0	0	7808
	17	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	ER2122A	71	-11360	0	0	-11360
	18	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	ER2096A	-151.2	24192	0	0	24192
	19	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	362	-57920	0	0	-57920
	20	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	0.4	-64	0	0	-64
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	ER1637A	46.2	-7392	0	0	-7392
	22	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-599.7	95952	0	0	95952
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-52	8320	0	0	8320
	24	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	ER1486A	-18.4	2944	0	0	2944
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	ER1537A	-24.5	3920	0	0	3920
	26	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	ER1484A	-3	480	0	0	480
	27	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	133	-21280	0	0	-21280
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	ER1679A	-12	1920	0	0	1920
	29	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-I	NP8723A	0	0	0	0	0
	30	400 KV SAGARDIGHI(WB)-BERHAMPORE(PG) LINE-II	NP8724A	0	0	0	0	0
	31	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	-811.6	129856	0	0	129856
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	-749.1	119856	0	0	119856
	33	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-I	ER1040A	1234.9	-197584	0	0	-197584
	34	400 KV PPSP NEW(WB)-RANCHI NEW(PG)-II	ER1130A	1207.6	-193216	0	0	-193216
	35	400 KV GOKARNA(WB)-RAJARAHAT(PG)	ER1133A	-60	9600	0	0	9600
	36	400 KV GOKARNA(WB)-PURNEA(PG)	ER1138A	0	0	0	0	0
	37	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	0	0	0	0	0
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	0	0	0	0	0
	39	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	0	0	0	0	0
	40	HV side of 400/220 KV RAJARAHAT(PG) ICT-1	ER1526A	100.5	-16080	0	0	-16080
	41	220 KV SIDE OF 50 MVA MALDA(PG) 220/132 ICT-4	ER1639A	-428.3	68528	0	0	68528
	42	400 KV SIDE OF RAJARAHAT(PG) 400/220 500 MVA ICT-2	ER1650A	76.3	-12208	0	0	-12208
	43	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	-34.2	5472	0	0	5472
	44	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	-46.8	7488	0	0	7488
	45	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER2125A	601.2	-96192	0	0	-96192
	46	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER2045A	587	-93920	0	0	-93920
	47	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-1	ER1683A	0	0	0	0	0
	48	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-2	ER1685A	0	0	0	0	0
	49	400 KV JEERAT(WB)-NEW JEERAT(PM/JTL) CKT-1	ER2101A	-46.9	7504	0	0	7504
	50	401 KV JEERAT(WB)-NEW JEERAT(PM/JTL) CKT-2	ER2103A	-49	7840	0	0	7840
		TOTAL		611184	-928	0	610256	

Note: 1) Rate of Reactive Energy Charge has been considered @ 16 paise/KVARh.w.e.f. 01/04/2022

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an IGS have not been considered for computation of reactive exchange with ISTs.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.