



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
पूर्वी क्षेत्रीय विद्युत समिति

Eastern Regional Power Committee

14, गोल्फ क्लब रोड, टॉलीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033



वसुधैव कुटुम्बकम्
ONE EARTH • ONE FAMILY • ONE FUTURE



Tel. No.: 033-24239651, 24239658 FAX No.: 033-24239652, 24239653 Web: www.erpc.gov.in

NO: ERPC/COM-II/VARH/1455

Date: 14.02.2023

1. CE (Trans/O&M), BSPTCL, Vidyut Bhavan, Bailey Road, Patna-21. (Fax 0612-2504557)
2. ESE (Interstate), BSPHCL, Vidyut Bhavan, 3rd Floor, Bailey Road, Patna-800 021. (Fax 0612-2504557)
3. CE (Comml & Revenue), JSEB, Engineering Building, H.E.C. Township, Dhurva, Ranchi-834004, Jharkhand. (Fax : 0651- 2400799/2490486)
4. CE (Comml), DVC, DVC Towers, VIP Road, Kolkata-700 054. (Fax: 033-23552129)
5. Sr.GM(PP),GRIDCO,4th floor, Vidyut Bhawan, Janpath, Bhubaneswar-22. (Fax : 0674-2547180/2547261).
6. Sr. GM (PS), OPTCL, SLDC Bldg, PO Mancheswar Rly Colony, Bhubaneswar-17, (Fax: 0674-2542932)
7. CE (Trans.), Energy & Power Deptt, Govt. of Sikkim, Gangtok.-737 101 (Fax: 03592-201148/202284)
8. CE (Comml), WBSETCL, Vidyut Bhavan, Block-A, Sector-II, Salt Lake, Kolkata-91.(Fax : 033-23598398).
9. CE (SLDC), WBSTC, PO. Danesh Sheikh Lane, Howrah-9. (Fax: 033-26886232)
10. ED, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata-33 (Fax: 033-24235029)
11. CE (GM), CEA, Sewa Bhavan, (6th floor), R.K. Puram, New Delhi-110 066 (Fax: 011-26109750)

Sub: Provisional Reactive Energy (VARH) Charges for the period 23.01.2023-29.01.2023

The statement of provisional Reactive Energy (VARH) charges with payable / receivable particulars for the above mentioned period is enclosed. *The last installment of data for the subjected period has been received from ERLDC on 03.02.2023.*

The constituents are requested to make payments to the Reactive Pool account operated by ERLDC within 10 days of the billing date. In case of delayed payment against these bills beyond 12 days, the defaulting constituents shall have to pay simple interest @ 0.04 % for each day of delay.

Observations, if any, and the payment status of the bills may be intimated to ERPC Secretariat.

यदि कोई अवलोकन हो एवं बिलों के भुगतान की स्थिति को ERPC सचिवालय में सूचित किया जा सकता है।

This issues with the approval of Member Secretary.

भवदीय/Yours faithfully,

Encl: As above/ संलग्न यथोपरी

(S. KEJRIWAL)

SUPERINTENDING ENGINEER

Eastern Regional Power Committee:: KOLKATA

**Provisional Reactive Energy (VArH) Charge Statement
for the period 23/01/23 to 29/01/23**

REACTIVE ENERGY CHARGE PAYMENT WITH THE POOL

FROM	TO	AMOUNT PAYABLE (Rs.)	AMOUNT RECEIVABLE(Rs.)	AMOUNT RECEIVABLE(Final After Adjustment)(Rs.)
BSPHCL	POOL	4430384	0	0
JUVNL	POOL	3356848	0	0
DVC	POOL	0	1588880	1588880
GRIDCO	POOL	1124128	0	0
SIKKIM	POOL	0	145168	145168
WBSETCL	POOL	1505840	0	0
Total		10417200	1734048	1734048

Note:

a) Reactive Energy Charge calculation is done as per clause 1.7 and 6.6 of IEGC

b) Final Receivables Amount After Adjustment from the Reactive Pool are done as per Methodology Approved in the 43rd ERPC meeting held on 26.03.2021 at Kolkata.

SUPERINTENDING ENGINEER

DETAILED REACTIVE ENERGY EXCHANGES OF THE UTILITIES WITH THE POOL

for the period 23/01/23 to 29/01/23

BENEFICIARY	SL NO	NAME OF THE LINE	METER NO	MVA/H_HIGH	REACTIVE CHARGE_MVA/H (Rs)	MVA/H_LOW	REACTIVE CHARGE_MVA/H (Rs)	NET REACTIVE CHARGE (Rs)
BSPHCL	1	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-1	NP6063A	-653.7	104592	0	0	104592
	2	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-2	NP6069A	-903.8	144608	0	0	144608
	3	400 KV SIDE OF BIHARSARIF (PG) 400/220 KV ICT-3	NP6068A	-5363.9	858224	0	0	858224
	4	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-1	ER1355A	0	0	0	0	0
	5	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-2	ER1358A	-18.5	2960	0	0	2960
	6	220 KV SIDE OF 220/132 160 MVA NEW PURNEA ICT-3	ER1436A	63.1	-10096	0	0	-10096
	7	220 KV PUSAULI (PG) - DEHRI (BSPHCL)	NP6093A	-3240.8	518528	0	0	518528
	8	220 KV side of 220/132 Arah ICT-1	ER1312A	-133	21280	0	0	21280
	9	220 KV side of 220/132 Arah ICT-2	ER1882A	-142.3	22768	0	0	22768
	10	220 KV NAUBATPUR(BGCL) - ARAH(PG) LINE-1	ER1829A	-1400.5	224080	0	0	224080
	11	220 KV NAUBATPUR(BGCL) - ARAH(PG) LINE-2	ER1871A	-1411	225760	0	0	225760
	12	132 KV PUSAULI(PG)-MOHANIA(BSPHCL)	NP6094A	0.1	-16	-364.9	-58384	-58400
	13	400 KV SIDE GAYA 400/220 500 MVA ICT-1	ER1411A	0	0	0	0	0
	14	400 KV SIDE GAYA 400/220 500 MVA ICT-2	ER1419A	0	0	0	0	0
	15	220 KV SIDE OF 220/132 ARA 160 MVA ICT-3	ER1313A	-103	16480	0	0	16480
	16	220 KV NADHOKHAR(BSPHCL) - PUSAULI (PG)-2	NP8665A	-1141.8	182688	0	0	182688
	17	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-1	ER1872A	-10.9	1744	0	0	1744
	18	400 KV SIDE OF LAKHISARAI 200 MVA 400/132 ICT-2	ER1873A	-132.9	21264	0	0	21264
	19	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-I	ER1788A	2250	-360000	0	0	-360000
	20	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-II	ER1296A	2250.9	-360144	0	0	-360144
	21	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-III	ER1159A	2550.1	-408016	0	0	-408016
	22	220 KV KISHANGANJ(PG)-KISHANGANJ(BSPTCL)-IV	ER1154A	2520.3	-403248	0	0	-403248
	23	132 KV PUSAULI(PG)-KUDRA(BSPHCL)	NP6095A	23.1	-3696	312.9	50064	46368
	24	HV side of 400/220 Patna ICT-1	ER1877A	0	0	0	0	0
	25	HV side of 400/220 Patna ICT-2	ER1407A	1783.6	-285376	0	0	-285376
	26	HV side of 400/220 Patna ICT-3	ER1231A	1672.2	-267552	0	0	-267552
	27	400 KV SIDE BANKA 400/132 200 MVA ICT-1	ER1349A	164.9	-26384	0	0	-26384
	28	400 KV SIDE BANKA 400/132 200 MVA ICT-2	ER1347A	165.9	-26544	0	0	-26544
	29	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-I	ER1226A	-1519.4	243104	0	0	243104
	30	220 KV MUZAFFARPUR(PG)-HAJIPUR(BSPHCL) LINE-II	ER1228A	-1625.1	260016	0	0	260016
	31	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-I	ER1175A	2470.7	-395312	0	0	-395312
	32	220 KV PURNEA(PG)-MADHEPURA(BSPHCL) LINE-II	ER1176A	2476.4	-396224	0	0	-396224
	33	HV side of 400/220 Darthanaga DMTC ICT-1	ER1274A	1551.8	-248288	0	0	-248288
	34	HV side of 400/220 Darthanaga DMTC ICT-2	ER1275A	1619.2	-259072	0	0	-259072
	35	220 KV NEW PURNEA(PG)-BEGUSARA(BSPTCL)-I	ER1348A	2226.7	-356272	0	0	-356272
	36	220 KV NEW PURNEA(PG)-KHAGARIA(BSPTCL)	ER1376A	2223.4	-355744	0	0	-355744
	37	220 KV DUMRAON NEW(BSPHCL) - ARA(PG) LINE-1	ER1305A	623.5	-99760	0	0	-99760
	38	220 KV NADHOKHAR(BSPHCL) - PUSAULI(PG) LINE-1	ER1310A	-1450.9	232144	0	0	232144
	39	HV side of 400/220 KV Biharsharif(PG) ICT-4	ER1386A	-1715.6	274496	0	0	274496
	40	400 KV SIDE OF 400/220 500 MVA GAYA(PG) ICT-3	ER1442A	0	0	0	0	0
	41	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTC) ICT-1	ER1247A	8.5	-1360	0	0	-1360
	42	400 KV HV SIDE OF 200 MVA MOTIHARI(DMTC) ICT-2	ER1243A	14.9	-2384	0	0	-2384
	43	220 KV DUMRAON NEW(BSPHCL) - ARA (PG)-2	ER1866A	617.7	-98832	0	0	-98832
	44	400 KV SIDE OF LAKHISARAI(PG) 315 MVA 400/132 ICT-3	ER1309A	-132.8	21248	0	0	21248
	45	400 KV SIDE BANKA(PG) 400/132 KV 315 MVA ICT-3	ER1362A	316.6	-50656	0	0	-50656
	46	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-1	ER1395A	2.2	-352	0	0	-352
	47	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-2	ER1933A	0	0	0	0	0
	48	400 KV SIDE OF CHANDAUTI(PG) 500 MVA ICT-3	ER1934A	0	0	0	0	0
	49	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-2	ER1875A	2138.1	-342096	0	0	-342096
	50	400 KV SIDE OF SITAMARHI(PMTL) 500MVA 400/220/33KV ICT-1	ER1816A	2828.8	-452608	0	0	-452608
	51	400 KV HV SIDE OF 315 MVA MOTIHARI(DMTC) ICT-3	ER1819A	-3.3	528	0	0	528
	52	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-1	ER1806A	6360.1	-1017616	0	0	-1017616
	53	400KV SIDE OF SAHARSHA(PMTL) 400/220/33 KV 500 MVA ICT-2	ER1823A	6315.2	-1010432	0	0	-1010432
	54	220 KV PUSAULI(PG)-KARAMNANA NEW(BSPHCL)	NP6092A	1123.6	-179776	0	0	-179776
	55	400 KV NAUBATPUR(BGCL)-PATNA(PG)-1	ER1879A	3821.1	-611376	0	0	-611376
	56	400 KV NAUBATPUR(BGCL)-PATNA(PG)-2	ER1848A	3841.5	-614640	0	0	-614640
	57	400 KV JAKKANPUR(BGCL)-PATNA(PG)-1	ER1941A	-2704.7	432752	0	0	432752
	58	400 KV JAKKANPUR(BGCL)-PATNA(PG)-2	ER1942A	-2389.7	382352	0	0	382352
	59	220 KV MUZAFFARPUR(PG)-GORAUL(BSPHCL)-1	ER1945A	-188.7	30192	0	0	30192
		TOTAL			-4422064		-8320	-4430384
JUVNL	1	HV side meter of 400/220 Jamshedpur ICT-1	NP6106A	-1696.1	271376	0	0	271376
	2	HV side meter of 400/220 Jamshedpur ICT-2	NP6105A	-1014.8	162368	0	0	162368
	3	HV side meter of 400/220 Jamshedpur ICT- 3	ER1297A	-1109.7	177552	0	0	177552
	4	220 KV FARAKKA (NTPC)-LALMATIA (JUVNL)	NP5211A	0	0	0	0	0
	5	220 KV MAITHON(PG) - DUMKA(JUVNL) - I	NP8727A	3556.4	-569024	0	0	-569024
	6	220 KV MAITHON(PG) - DUMKA(JUVNL) - II	NP8739A	5180.4	-828864	0	0	-828864
	7	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-2	NP8637A	0	0	0	0	0
	8	400 KV SIDE OF CHAIBASA(PG) 315 MVA 400/220 ICT-1	NP8678A	0	0	0	0	0
	9	HV side meter of 400/220 Daltonganj ICT-1	ER1197A	442.2	-70752	0	0	-70752
	10	HV side meter of 400/220 Daltonganj ICT-2	ER1317A	404.2	-64672	0	0	-64672
	11	220 KV RANCHI(PG)-HATIA(JUVNL)-I	NP5879A	4350.4	-696064	0	0	-696064
	12	221 KV RANCHI(PG)-HATIA(JUVNL)-II	ER1252A	3880.9	-620944	0	0	-620944
	13	222 KV RANCHI(PG)-HATIA(JUVNL)-III	NP7880A	4143.2	-662912	0	0	-662912
	14	223 KV RANCHI(PG)-CHANDIL(JUVNL)	NP5874A	809.1	-129456	0	0	-129456
	15	400 KV RANCHI NEW(PG)-PATRATU NEW(JUVNL) LINE-1	ER1221A	1101.1	-176176	0	0	-176176
	16	400 KV RANCHI NEW(PG)-PATRATU NEW(JUVNL) LINE-2	ER1230A	933	-149280	0	0	-149280
		TOTAL			-3356848		0	-3356848
DVC	1	220 KV DURGAPUR (PG) - PARULIA (DVC) -I	NP6456A	0	0	0	0	0
	2	220 KV DURGAPUR (PG) - PARULIA (DVC) -II	NP6458A	-1399.6	223936	0	0	223936
	3	220 KV MAITHON (PG) - DHANBAD (DVC) -I	ER1668A	-74.2	11872	0	0	11872
	4	220 KV MAITHON (PG) - DHANBAD (DVC) -II	ER1147A	-233	37280	0	0	37280
	5	220 KV MAITHON (PG) - KALYANESWARI (DVC) -I	ER1711A	-614.2	98272	0	0	98272
	6	220 KV MAITHON (PG) - KALYANESWARI (DVC) -II	ER1717A	-1204	192640	0	0	192640
	7	400 KV TATA JAMSHEDPUR (DVC)- BARIPADA(PG)	ER1808A	-1441.1	230576	0	0	230576
	8	400 KV TATA JAMSHEDPUR (DVC)- JAMSHEDPUR (PG)	ER1802A	0	0	0	0	0
	9	400 KV MEJIA(DVC)-MAITHON(PG)	ER1659A	0	0	0	0	0
	10	400 KV MEJIA(DVC)-MAITHON(PG) LINE-I	ER1657A	-1485.8	237728	0	0	237728
	11	400 KV MEJIA(DVC)-MAITHON(PG) LINE-II	ER1658A	-1545.5	247280	0	0	247280
	12	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-I	ER2042A	-990.4	158464	0	0	158464
	13	400 KV KODERMA(DVC) - BIHARSHARIFF(PG)-LINE-II	ER2128A	-1306.2	208992	0	0	208992
	14	400 KV KODERMA(DVC) - Gaya(PG)-I	ER2129A	-3424.1	547856	0	0	547856
	15	400 KV KODERMA(DVC) - Gaya(PG)-II	ER2130A	-2357.9	377264	0	0	377264
	16	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-I(MAIN)	ER2046A	-1325	212000	0	0	212000
	17	400 KV DSTPS(DVC)-JAMSHEDPUR(PG)-II(MAIN)	ER2044A	-1565.8	250528	0	0	250528
	18	400 KV RTPS(DVC)-RANCHI(PG)	ER1653A	0	0	0	0	0
	19	400 KV RTPS(DVC)-MAITHON(PG)	ER2682A	4660.3	-745648	0	0	-745648
	20	400KV MEJIA(DVC) - JAMSHEDPUR(PG)	ER1656A	-1097.5	175600	0	0	175600
	21	400 KV RANCHI(PG)-RTPS(DVC)-II	NP7871A	3751.3	-600208	0	0	-600208
	22	400 KV RANCHI(PG)-RTPS(DVC)-III	NP7853A	3917	-626720	0	0	-626720
	23	220 KV RANCHI(PG)-RAMGARH(DVC)	ER1798A	-2991.6	478656	0	0	478656
	24	221 KV RANCHI(PG)-MTPS(DVC)	ER1796A	796.8	-127488	0	0	-127488
		TOTAL			1588880		0	1588880

EASTERN REGIONAL POWER COMMITTEE :: KOLKATA

GRIDCO	1	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-1 AND ICT-3	ER1563A	0	0	0	0	0
	2	400 KV SIDE OF ROURKELA (PG) 400/220 KV ICT-2 AND ICT-4	ER1565A	0	0	0	0	0
	3	HV side meter of 400/220 Rengali ICT-1	ER1598A	0	0	0	0	0
	4	HV side meter of 400/220 Rengali ICT-2	ER1595A	0	0	0	0	0
	5	400 KV SIDE OF JEYPORE (PG) 400/220 KV ICT-1 AND ICT-3	ER2062A	3984	-637440	0	0	-637440
	6	HV side meter of 400/220 Jeypore ICT-2	ER1571A	3227.3	-516368	0	0	-516368
	7	400 KV INDRAVATI (PG) - INDRAVATI P/H	ER1759A	3918.9	-627024	0	0	-627024
	8	HV side meter of 400/220 Baripada ICT-1	ER1553A	-1.5	240	0	0	240
	9	HV side meter of 400/220 Baripada ICT-2	ER1746A	0	0	0	0	0
	10	HV side meter of 400/220 Baripada ICT-3	ER1747A	0	0	0	0	0
	11	220 KV BALIMELA(GRIDCO)-UPPER SILERU(SR)	NP7991A	0	0	0	0	0
	12	400 KV DUBURI (GRIDCO)- BARIPADA(PG)	ER1900A	-1658.5	265360	0	0	265360
	13	400 KV MERAMUNDALI (GRIDCO)-BOLANGIR(PG)	ER1054A	0	0	0	0	0
	14	400 KV MERAMUNDALI (GRIDCO)-TSTPP(NTPC)-2	ER1055A	3.3	-528	0	0	-528
	15	400 KV MERAMUNDALI(GRIDCO)-TSTPP(NTPC)	ER1758A	0	0	0	0	0
	16	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-I	ER2072A	-25.1	4016	0	0	4016
	17	400 KV MENDHASAL (GRIDCO)- PANDIABIL(PG)-II	ER2071A	-144.7	23152	0	0	23152
	18	400 KV DUBURI(GRIDCO)-PANDIABIL(PG)	ER1897A	-1980.7	316912	0	0	316912
	19	HV side meter of 400/220 Bolangir-ICT-1	ER1575A	-152.4	24384	-3.7	-592	23792
	20	HV side meter of 400/220 Bolangir-ICT-2	ER1582A	-114.7	18352	-6.1	-976	17376
	21	HV side of 400/220 Pandiabil ICT-1	ER1583A	69.8	-11168	0	0	-11168
	22	HV side of 400/220 Pandiabil ICT-2	ER1776A	42.3	-6768	0	0	-6768
	23	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-I	ER1059A	0	0	0	0	0
	24	400KV SUNDERGARH(PG)-STERLITE(GRIDCO)-II	ER1058A	0	0	0	0	0
	25	HV side meter of 400/220 KV Keonjhar ICT-1	ER1589A	0	0	0	0	0
	26	HV side meter of 400/220 KV Keonjhar ICT-2	ER1587A	0	0	0	0	0
	27	400 KV SUNDERGARH(PG)-OPGC-1	ER1117A	-69.8	11168	0	0	11168
	28	400 KV SUNDERGARH(PG)-OPGC-2	ER1119A	-82.2	13152	0	0	13152
		TOTAL		-1122560		-1568	-1124128	
SIKKIM	1	132 KV MELLI (SIKKIM) - SILIGURI (PG)	NP8771A	-95.40	15264	0	0	15264
	2	132 KV MELLI (SIKKIM) - RANGPO (PG)	NP8770A	-192.50	30800	-100.4	-16064	14736
	3	132 KV SIDE OF GANGTOK 132/66 KV ICT-I	ER1490A	-360.40	57664	0	0	57664
	4	132 KV SIDE OF GANGTOK 132/66 KV ICT-II	ER1489A	-359.40	57504	0	0	57504
		TOTAL		161232		-16064	145168	
WBSETCL	1	400 KV JEERAT (WBSETCL) - RAJARAHAT(PG)	ER1471A	0	0	-876.4	-140224	-140224
	2	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-1	ER1534A	586.2	-93792	0	0	-93792
	3	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-2	ER1483A	487.3	-77968	0	0	-77968
	4	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-1	ER1466A	0	0	0	0	0
	5	220 KV SIDE OF 220/132 MALDA 160 MVA ICT-2	ER1512A	-2812.3	449968	0	0	449968
	6	132 KV SILIGURI (PG) - NJP(WBSETCL)	ER1080A	-2094.5	335120	0	0	335120
	7	132 KV SILIGURI (PG) - NBU (WBSETCL)	ER1675A	-1444.6	231136	0	0	231136
	8	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-1	ER1482A	-2039.3	326288	0	0	326288
	9	220 KV SIDE OF BIRPARA 220/132 160 MVA ICT-2	ER1485A	-521.3	83408	0	0	83408
	10	220 KV BINAGURI (PG) - JALPAIGURI (WBSETCL)-I	ER1739A	6553.1	-1048496	0	0	-1048496
	11	220 KV BINAGURI (PG) - JALPAIGURI(WBSETCL)-II	ER2039A	7825.3	-1252048	0	0	-1252048
	12	132 KV RAMMAM (WBSETCL) - RANGIT (NHPC)	NP5917A	0	0	0	0	0
	13	400 KV DURGAPUR(PG) - BIDHANNAGAR(WBSETCL)-I	ER2109A	1365.8	-218528	0	0	-218528
	14	400 KV DURGAPUR (PG) - BIDHANNAGAR(WBSETCL)-II	ER2111A	0	0	0	0	0
	15	400 KV SAGARDIGHI(WB) - FARAKKA (NTPC)-1(MAIN)	NP6482A	0	0	0	0	0
	16	400 KV JEERAT(PG) - SUBHASGRAM (PG)	ER1477A	-261.8	41888	0	0	41888
	17	132 KV KURSEONG(WBSETCL)-RANGIT(NHPC)	ER2122A	-198.9	31824	0	0	31824
	18	132 KV KURSEONG(WBSETCL)-SILIGURI(NHPC)	ER2096A	146.2	-23392	0	0	-23392
	19	400 KV KHARAGPUR (WBSETCL)-BARIPADA (PG)	ER1043A	0	0	0	0	0
	20	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-I	NP6548A	0	0	0	0	0
	21	400 KV DURGAPUR(PG)- SAGARDIGHI(WBSETCL)-II	ER1637A	0	0	0	0	0
	22	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-I	ER1071A	-1284.2	205472	0	0	205472
	23	220 KV DALKHOLA(PG)-DALKHOLA(WBSETCL)LINE-II	ER1072A	-730.9	116944	0	0	116944
	24	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-3	ER1486A	462.9	-74064	0	0	-74064
	25	400 KV SIDE OF 400/220 KV 315 MVA SUBHASGRAM ICT-4	ER1537A	475.3	-76048	0	0	-76048
	26	400 KV SIDE OF 400/220 KV 500 MVA SUBHASHGRAM ICT-5	ER1484A	721.5	-115440	0	0	-115440
	27	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-I	ER1141A	720.3	-115248	0	0	-115248
	28	400 KV SUBHASHGRAM(PG)-HALDIA CESC(WB) LINE-II	ER1679A	152.6	-24416	0	0	-24416
	29	400 KV SAGARDIGHI(WB)-BERHAMPUR(PG) LINE-I	NP8723A	0	0	0	0	0
	30	400 KV SAGARDIGHI(WB)-BERHAMPUR(PG) LINE-II	NP8724A	0	0	0	0	0
	31	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-I	NP8731A	0	0	0	0	0
	32	400 KV KHARAGPUR(WB)-CHAIBASA(PG)-II	NP8720A	0	0	0	0	0
	33	400 KV PPS NEW(WB)-RANCHI NEW(PG)-I	ER1040A	-274.9	43984	0	0	43984
	34	400 KV PPS NEW(WB)-RANCHI NEW(PG)-II	ER1130A	-55.6	8896	0	0	8896
	35	400 KV GOKARNA(WB)-RAJARAHAT(PG)	ER1133A	-1411.7	225872	0	0	225872
	36	400 KV GOKARNA(WB)-PURNEA(PG)	ER1138A	-1.1	176	0	0	176
	37	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-I	ER1044A	0	0	0	0	0
	38	220 KV ALIPURDUAR(PG)-ALIPURDUAR(WB)-II	ER1047A	828.4	-132544	0	0	-132544
	39	400 KV SAGARDIGHI(WB)-FARAKKA(NTPC)-II	ER1131A	-68.3	10928	0	0	10928
	40	HV side of 400/220 KV RAJARAHAT(PG) ICT-1	ER1526A	364.7	-58352	0	0	-58352
	41	220 KV SIDE OF 50 MVA MALDA(PG) 220/132 ICT-4	ER1639A	-2090.5	334480	0	0	334480
	42	400 KV SIDE OF RAJARAHAT(PG) 400/220 500 MVA ICT-2	ER1650A	349.4	-55904	0	0	-55904
	43	220 KV GAZOLE(WB)-MALDA(PG)-1	ER1693A	1572	-251520	0	0	-251520
	44	220 KV GAZOLE(WB)-MALDA(PG)-2	ER1696A	0	0	0	0	0
	45	220 KV GAZOLE(WB)-DALKHOLA(PG)-1	ER2125A	861.6	-137856	0	0	-137856
	46	220 KV GAZOLE(WB)-DALKHOLA(PG)-2	ER2045A	0	0	0	0	0
	47	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-1	ER1683A	0	0	0	0	0
	48	765 KV SIDE OF MEDINIPUR(PG) 765/400KV 1500 MVA ICT-2	ER1685A	0	0	0	0	0
	49	400 KV JEERAT(WB)-NEW JEERAT(PM/JTL) CKT-1	ER2101A	171.3	-27408	0	0	-27408
	50	401 KV JEERAT(WB)-NEW JEERAT(PM/JTL) CKT-2	ER2103A	181.1	-28976	0	0	-28976
		TOTAL		-1365616		-140224	-1505840	

Note: 1) Rate of Reactive Energy Charge has been considered @ 16 paise/KVARH, w.e.f. 01/04/2022

2) For reactive energy, (+) means injection and (-) means drawal with respect to utility

3) For reactive energy charge, (+) means receivable by the utility and (-) means payable by the utility.

4) In line with clause 6.6.1 of revised IEGC, beneficiary's own lines emanating from an IGS have not been considered for computation of reactive exchange with ISTS.

5) "NA" means meter reading not available.

6) As per the decision taken in 147th OCC meeting, the methodology for computation of Reactive Charges has been changed in conformity with other RPCs.